

Appendix to
ENVIRONMENTAL CONTROL SYSTEMS FOR THE CAPSTONE BUILDING, NOBLE CENTER,
OKLAHOMA STATE UNIVERSITY, STILLWATER, OKLAHOMA
Cooling and Heating Loads


of Michael P. Boerger
for Professional Project
in partial fulfillment of the requirements
for the degree of Master of Architectural Engineering
Fall, 1985

Appendix to
ENVIRONMENTAL CONTROL SYSTEMS FOR THE CAPSTONE BUILDING, NOBLE CENTER,
OKLAHOMA STATE UNIVERSITY, STILLWATER, OKLAHOMA
Cooling and Heating Loads


of Michael P. Boerger
for Professional Project
in partial fulfillment of the requirements
for the degree of Master of Architectural Engineering
Fall, 1985


ARCHITECTURE LIBRARY


Key to Zones and Rooms



LOWER LEVEL








THIRD

AL



FOURTH

Variable Names and Definitions

ACLONG	Local longitude, deg
AD	Area of doors, ft ²
AMP	Ground temperature amplitude, deg F
APPL	Residential room sensible heat gain, Btu/hr
AREA	Residential room floor area, ft ²
AW	Area of windows, ft ²
CFMD	Infiltration rate for first shift, ft ³ /min
CFMM	Minimum amount of outdoor air, ft ³ /min
CFMN	Infiltration rate for second shift, ft ³ /min
CFMT	Maximum outdoor air per ASHRAE Standard 62-81 for smoking, ft ³ /min
DPOR	Return air fan total pressure, in. wat.
DPOS	Supply air fan total pressure, in. wat.
ENCRE	Increment between standard air handler capacities, Btu/hr
EPSILN	Inclination of a surface measured from horizontal, deg
ERMAX	Maximum capacity of an air handler, Btu/hr
ERMIN	Minimum capacity of an air handler, Btu/hr
ETAF	Air filter efficiency, dec. fraction
ETAFR	Returns air fan total efficiency, dec. fraction
ETAFS	Supply fan total efficiency, dec. fraction
ETAFT	Return air fan total efficiency, fraction
FLL	Basement floor length, ft
FLW	Basement floor width, ft
FNAME	Output file name
HGT	Basement wall height, ft
IA	Infiltration parameter; light, medium, or loose

IAIR	Air temperature zone classification
IB	Specific building type, 1, 2, 3
ICNDT	Conduction zone classification.
IHDT	Specifies heating ducts below floor or slab
IHEAT	Load type, heating or cooling
ILGHT	Lighting zone classification
INS	Basement wall insulation type
INSUL	Specifies insulation for a floor slab
INWRIT	Parameter to write out input data
IOCEQ	Occupant/equipment zone classification
ISOLAR	Solar zone classification
ISOLAR	Solar zone classification.
MC	Construction weight, residential; light, medium or heavy
MEX	Exhaust air location parameter
NCOIL	Parameter to select air quantity and coil load option
NDOM	Number of the day of the month
NHTX	Parameter to select heat extraction rate calculation
NM	Number of the month of the year
NPD	Number of occupants during first shift
NPN	Number of occupants during second shift
NPRT	Specifies type of output
NRMS	Number of rooms in the zone
NSF	Supply air fan location, draw-thru or flow-thru
OFCT	Hour that the unoccupied time begins, hours (1-24)
OFST	Hour that the occupied time begins, hour (1-24)
ORIENT	Text description of the surface (wall, roof, north, floor, etc.)
PSI	Angle between the normal to a surface and south measured counterclockwise in deg

QFLD Flourescent light wattage for the first shift, kW
QFLN Flourescent light wattage for the second shift, kW
QOTLD Internal latent heat gain for the first shift, Btu/hr
QOTLN Internal latent heat gain for the second shift, Btu/hr
QOTSD Internal sensible heat gain from equipment during 1st shift, Btu/hr
QOTSN Internal sensible heat gain from equipment during 2nd shift, Btu/hr
QTLD Incandescent light wattage for the first shift, kW
QTLN Incondescent light wattage for the second shift, kW
RV Basement wall thermal resistance, Hr-F-ft²/Btu
SCG Shading coefficient for the glass and inside shade assembly
STLONG Longitude for the local time zone, deg
THRANG Thermostat throttling range, deg F
THSETD Thermostat set point for 1st shift, deg F
THSETN Thermostat set point for 2nd shift, deg F
THTIMD Thermostat set time for 1st shift, hour
THTIMN Thermostat set time for 2nd shift, hour
TIH Indoor design temperature for residential heating, deg F
TITLE2 Text data to identify the output
TITLE3 Text data to identify the output
TM Average Winter temperature, deg F
TMAXIM Outdoor Design temperature, deg F
TOH Outdoor design temperature for residential heating, deg F
TRANGE Daily range of temperature, deg F
TROOM Room design temperature, deg F
TWBI Room design wet bulb temperature, deg F
TWBO Outdoor design wet bulb temperature, deg F
UD Overall heat transfer coefficient for the door assembly, Btu/hr-ft²-F

UWRA Overall heat transfer coefficient for the surface assembly, Btu/hr-
ft²F

WDT Basement wall width, ft

WO Outdoor design humidity ratio for cooling case, lbw/lba

WRL Wall height or roof length, feet

WRW Wall width or roof width, feet

XLAT Local latitude, deg

noble center
cooling load, atrium.

***** GENERAL INPUT DATA *****

B= 3, MC= 2, NRMS= 1, WD= .0136, IA= 0, NPRT= 0, INWRT= 1, XLAT= 36.0
ICLONG= 97.0, STLONG= 90.0, TROOM= 80.0, TMAXIM= 96.0 TRANGE= 24.0
IH= 72.0 TDH= 13.0

NM= 8, NHTX= 0, TWBD= 74.00, IHEAT= 0
IDDM= 21, NITR= 10, TWBI= 65.00, WD= .0136, PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 1 *****

north entry

WRL= 50.60 WRW= 57.30 AD= 87.00 AW= ***** PSI= 180.00
EPSILN= 90.00 SCB= .71 UWRA= .0840 UW= .3800 UD= .3400 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 1 *****

north roof

WRL= 26.00 WRW= 20.70 AD= .00 AW= 537.00 PSI= 180.00
EPSILN= 45.00 SCB= .46 UWRA= .0840 UW= .3700 UD= .3400 ISHAD= 0

***** INPUT DATA FOR SURFACE # 3 OF ROOM # 1 *****

south roof

WRL= 73.30 WRW= 127.00 AD= .00 AW= ***** PSI= .00
EPSILN= 35.00 SCB= .15 UWRA= .0840 UW= .5300 UD= .3400 ISHAD= 0

***** INPUT DATA FOR SURFACE # 4 OF ROOM # 1 *****

south wall

WRL= 32.00 WRW= 180.00 AD= 174.00 AW= ***** PSI= .00
EPSILN= 90.00 SCB= .71 UWRA= .0840 UW= .3800 UD= .3400 ISHAD= 1
SHADE TYPE= 0 GLASS WIDTH= 180.0
GLASS HEIGHT= 32.0 OVERHANG DEPTH= 24.0
OVERHANG RISE= .0 OVERHANG EXT, LEFT= 20.0
OVERHANG EXT, RIGHT= 20.0 OVERHANG END PROJ= 18.0

1	.0000	4	.0000	7	.0000	10	.0029	13	.0000	16	.0319	19	.0000	22	.0000
2	.0000	5	.0000	8	.0922	11	.0000	14	.0000	17	.0984	20	.0000	23	.0000
3	.0000	6	.0000	9	.0292	12	.0000	15	.0038	18	.0000	21	.0000	24	.0000

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 1, NPD= 40, CFMN= 920.00, CFMD= 3400.00
QOTSM= .0, QOTSD= .0, QOTLN= .0
QOTLD= .0, QFLN= 1.4, QFLD= .0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISGLAR= 6,ICNDT= 3,ILGHT= 3,IOCEQ= 3,IAIR= 18

noble center
cooling load, atrium.

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1719E+06	.1454E+05	.1864E+06	.9220E+00
2	73.9	.1520E+06	.1454E+05	.1665E+06	.9127E+00
3	73.0	.1335E+06	.1454E+05	.1480E+06	.9017E+00
4	72.2	.1165E+06	.1454E+05	.1310E+06	.8890E+00
5	72.0	.1017E+06	.1454E+05	.1162E+06	.8748E+00
6	72.5	.8995E+05	.1454E+05	.1045E+06	.8608E+00
7	73.7	.1038E+06	.1454E+05	.1183E+06	.8771E+00
8	75.8	.1195E+06	.6101E+05	.1805E+06	.8619E+00
9	79.0	.1767E+06	.6101E+05	.2377E+06	.7433E+00
10	82.6	.2424E+06	.6101E+05	.3034E+06	.7989E+00
11	86.6	.3122E+06	.6101E+05	.3732E+06	.8365E+00
12	90.5	.3772E+06	.6101E+05	.4382E+06	.8608E+00
13	93.4	.4297E+06	.6101E+05	.4908E+06	.8757E+00
14	95.3	.4659E+06	.6101E+05	.5269E+06	.8842E+00
15	96.0	.4813E+06	.6101E+05	.5423E+06	.8875E+00
16	95.3	.4735E+06	.6101E+05	.5345E+06	.8858E+00
17	93.6	.4428E+06	.6101E+05	.5039E+06	.8789E+00
18	91.0	.3952E+06	.6101E+05	.4562E+06	.8663E+00
19	87.8	.3405E+06	.6101E+05	.4016E+06	.8481E+00
20	84.7	.2994E+06	.6101E+05	.3604E+06	.8307E+00
21	82.1	.2635E+06	.6101E+05	.3246E+06	.8120E+00
22	79.7	.2387E+06	.1454E+05	.2532E+06	.9426E+00
23	77.8	.2151E+06	.1454E+05	.2296E+06	.9367E+00
24	76.3	.1929E+06	.1454E+05	.2075E+06	.9299E+00

noble center
cooling load, atrium.

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1719E+06	.1454E+05	.1864E+06	.9220E+00
2	73.9	.1520E+06	.1454E+05	.1665E+06	.9127E+00
3	73.0	.1335E+06	.1454E+05	.1480E+06	.9017E+00
4	72.2	.1165E+06	.1454E+05	.1310E+06	.8890E+00
5	72.0	.1017E+06	.1454E+05	.1162E+06	.8748E+00
6	72.5	.8995E+05	.1454E+05	.1045E+06	.8608E+00
7	73.7	.1038E+06	.1454E+05	.1183E+06	.8771E+00
8	75.8	.1195E+06	.6101E+05	.1805E+06	.8619E+00
9	79.0	.1767E+06	.6101E+05	.2377E+06	.7433E+00
10	82.6	.2424E+06	.6101E+05	.3034E+06	.7989E+00
11	86.6	.3122E+06	.6101E+05	.3732E+06	.8365E+00
12	90.5	.3772E+06	.6101E+05	.4382E+06	.8608E+00
13	93.4	.4297E+06	.6101E+05	.4908E+06	.8757E+00
14	95.3	.4659E+06	.6101E+05	.5269E+06	.8842E+00
15	96.0	.4813E+06	.6101E+05	.5423E+06	.8875E+00
16	95.3	.4735E+06	.6101E+05	.5345E+06	.8858E+00
17	93.6	.4428E+06	.6101E+05	.5039E+06	.8789E+00
18	91.0	.3952E+06	.6101E+05	.4562E+06	.8663E+00
19	87.8	.3405E+06	.6101E+05	.4016E+06	.8481E+00
20	84.7	.2994E+06	.6101E+05	.3604E+06	.8307E+00
21	82.1	.2635E+06	.6101E+05	.3246E+06	.8120E+00
22	79.7	.2387E+06	.1454E+05	.2532E+06	.9426E+00
23	77.8	.2151E+06	.1454E+05	.2296E+06	.9367E+00
24	76.3	.1929E+06	.1454E+05	.2075E+06	.9299E+00

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone a

***** GENERAL INPUT DATA *****

B= 3,MC= 2,NRMS= 6,WD= .0136,IA= 0,NPRT= 0,INWRIT= 1,XLAT= 36.0
CLONG= 97.0,STLONG= 90.0,TROOM= 78.0,TMAXIM= 96.0 TRANGE= 24.0
IH= 72.0 TOH= 13.0

NM= 8,NHTX= 1,TWBO= 74.00,IHEAT= 0
IDOM= 21,NITR= 10,TWBI= 62.00,WD= .0136,PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** GENERAL INPUT DATA FOR ROOM # 1 *****

QPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 6000.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .4
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IGCEQ= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone a

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4059E+03	.0000E+00	.4059E+03	.1000E+01
2	73.9	.3629E+03	.0000E+00	.3629E+03	.1000E+01
3	73.0	.3245E+03	.0000E+00	.3245E+03	.1000E+01
4	72.2	.2901E+03	.0000E+00	.2901E+03	.1000E+01
5	72.0	.2594E+03	.0000E+00	.2594E+03	.1000E+01
6	72.5	.2319E+03	.0000E+00	.2319E+03	.1000E+01
7	73.7	.2073E+03	.0000E+00	.2073E+03	.1000E+01
8	75.8	.6286E+04	.2000E+03	.6486E+04	.9692E+00
9	79.0	.6671E+04	.2000E+03	.6871E+04	.9709E+00
10	82.6	.6866E+04	.2000E+03	.7066E+04	.9717E+00
11	86.6	.6997E+04	.2000E+03	.7197E+04	.9722E+00
12	90.5	.7100E+04	.2000E+03	.7300E+04	.9726E+00
13	93.4	.7189E+04	.2000E+03	.7389E+04	.9729E+00
14	95.3	.7267E+04	.2000E+03	.7467E+04	.9732E+00
15	96.0	.7337E+04	.2000E+03	.7537E+04	.9735E+00
16	95.3	.7399E+04	.2000E+03	.7599E+04	.9737E+00
17	93.6	.1353E+04	.0000E+00	.1353E+04	.1000E+01
18	91.0	.9986E+03	.0000E+00	.9986E+03	.1000E+01
19	87.8	.8298E+03	.0000E+00	.8298E+03	.1000E+01
20	84.7	.7231E+03	.0000E+00	.7231E+03	.1000E+01
21	82.1	.6408E+03	.0000E+00	.6408E+03	.1000E+01
22	79.7	.5713E+03	.0000E+00	.5713E+03	.1000E+01
23	77.8	.5102E+03	.0000E+00	.5102E+03	.1000E+01
24	76.3	.4560E+03	.0000E+00	.4560E+03	.1000E+01

**** GENERAL INPUT DATA FOR ROOM # 2 ****

= 0,NPD= 4,CFMN= .00,CFMD= .00
SN= .0,QOTSD= 1450.0,QOTLN= .0
LD= .0,QFLN= .1,QFLD= 1.4
N= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

**** DATA FOR TRANSFER FUNCTION COEFFICIENTS ****

ILAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IATR= 5

noble center
cooling loads, zone a

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1103E+04	.0000E+00	.1103E+04	.1000E+01
2	73.9	.1046E+04	.0000E+00	.1046E+04	.1000E+01
3	73.0	.9955E+03	.0000E+00	.9955E+03	.1000E+01
4	72.2	.9502E+03	.0000E+00	.9502E+03	.1000E+01
5	72.0	.9098E+03	.0000E+00	.9098E+03	.1000E+01
6	72.5	.8737E+03	.0000E+00	.8737E+03	.1000E+01
7	73.7	.8415E+03	.0000E+00	.8415E+03	.1000E+01
8	75.8	.5904E+04	.8000E+03	.6704E+04	.8807E+00
9	79.0	.6378E+04	.8000E+03	.7178E+04	.8886E+00
10	82.6	.6630E+04	.8000E+03	.7430E+04	.8923E+00
11	86.6	.6802E+04	.8000E+03	.7602E+04	.8948E+00
12	90.5	.6940E+04	.8000E+03	.7740E+04	.8966E+00
13	93.4	.7058E+04	.8000E+03	.7858E+04	.8982E+00
14	95.3	.7162E+04	.8000E+03	.7962E+04	.8995E+00
15	96.0	.7254E+04	.8000E+03	.8054E+04	.9007E+00
16	95.3	.7337E+04	.8000E+03	.8137E+04	.9017E+00
17	93.6	.2319E+04	.0000E+00	.2319E+04	.1000E+01
18	91.0	.1884E+04	.0000E+00	.1884E+04	.1000E+01
19	87.8	.1668E+04	.0000E+00	.1668E+04	.1000E+01
20	84.7	.1527E+04	.0000E+00	.1527E+04	.1000E+01
21	82.1	.1418E+04	.0000E+00	.1418E+04	.1000E+01
22	79.7	.1325E+04	.0000E+00	.1325E+04	.1000E+01
23	77.8	.1244E+04	.0000E+00	.1244E+04	.1000E+01
24	76.3	.1172E+04	.0000E+00	.1172E+04	.1000E+01

: INPUT DATA FOR SURFACE # 1 OF ROOM # 3 *****

9.00 WRW= 10.00 AD= .00 AW= 58.50 PSI= 180.00
N= 90.00 SCG= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

* INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

h

3.00 WRW= 10.00 AD= .00 AW= .00 PSI= 180.00
N= 90.00 SCG= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

*** GENERAL INPUT DATA FOR ROOM # 3 *****

0,NPD= 1,CFMN= .00,CFMD= .00
N= .0,QOTSD= .0,QOTLN= .0
D= .0,QFLN= .0,QFLD= .2
= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

AR= 2,ICNDT= 2,ILGHT= 2,IOCEO= 2,IAIR= 1

center
 ig loads, zone a

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2709E+03	.0000E+00	.2709E+03	.1000E+01
2	73.9	.2164E+03	.0000E+00	.2164E+03	.1000E+01
3	73.0	.1670E+03	.0000E+00	.1670E+03	.1000E+01
4	72.2	.1235E+03	.0000E+00	.1235E+03	.1000E+01
5	72.0	.9001E+02	.0000E+00	.9001E+02	.1000E+01
6	72.5	.7180E+02	.0000E+00	.7180E+02	.1000E+01
7	73.7	.3140E+03	.0000E+00	.3140E+03	.1000E+01
8	75.8	.1131E+04	.2000E+03	.1331E+04	.8497E+00
9	79.0	.1374E+04	.2000E+03	.1574E+04	.8729E+00
10	82.6	.1581E+04	.2000E+03	.1781E+04	.8877E+00
11	86.6	.1777E+04	.2000E+03	.1977E+04	.8988E+00
12	90.5	.1942E+04	.2000E+03	.2142E+04	.9066E+00
13	93.4	.2061E+04	.2000E+03	.2261E+04	.9115E+00
14	95.3	.2128E+04	.2000E+03	.2328E+04	.9141E+00
15	96.0	.2136E+04	.2000E+03	.2336E+04	.9144E+00
16	95.3	.2090E+04	.2000E+03	.2290E+04	.9127E+00
17	93.6	.1343E+04	.0000E+00	.1343E+04	.1000E+01
18	91.0	.1143E+04	.0000E+00	.1143E+04	.1000E+01
19	87.8	.7984E+03	.0000E+00	.7984E+03	.1000E+01
20	84.7	.6509E+03	.0000E+00	.6509E+03	.1000E+01
21	82.1	.5511E+03	.0000E+00	.5511E+03	.1000E+01
22	79.7	.4662E+03	.0000E+00	.4662E+03	.1000E+01
23	77.8	.3922E+03	.0000E+00	.3922E+03	.1000E+01
24	76.3	.3285E+03	.0000E+00	.3285E+03	.1000E+01

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 4 *****

north

WRL= 7.00 WRW= 20.00 AD= .00 AW= 130.00 PSI= 180.00
PSILN= 90.00 SCG= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 4 *****

north

WRL= 3.00 WRW= 20.00 AD= .00 AW= .00 PSI= 180.00
PSILN= 90.00 SCG= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 4 *****

PN= 0,NPD= 1,CFMN= .00,CFMD= .00
JTSN= .0,QOTSD= 50.0,QOTLN= .0
JTLN= .0,QFLN= .0,QFLD= .2
FLN= .0,QTLN= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

SOLAR= 2,ICNDT= 2,ILSHT= 2,IOCEQ= 2,IAIR= 1

oble center
ooling loads, zone a

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4857E+03	.0000E+00	.4857E+03	.1000E+01
2	73.9	.3763E+03	.0000E+00	.3763E+03	.1000E+01
3	73.0	.2775E+03	.0000E+00	.2775E+03	.1000E+01
4	72.2	.1908E+03	.0000E+00	.1908E+03	.1000E+01
5	72.0	.1255E+03	.0000E+00	.1255E+03	.1000E+01
6	72.5	.9345E+02	.0000E+00	.9345E+02	.1000E+01
7	73.7	.6389E+03	.0000E+00	.6389E+03	.1000E+01
8	75.8	.1710E+04	.2000E+03	.1910E+04	.8953E+00
9	79.0	.2176E+04	.2000E+03	.2376E+04	.9158E+00
10	82.6	.2595E+04	.2000E+03	.2795E+04	.9285E+00
11	86.6	.3000E+04	.2000E+03	.3200E+04	.9375E+00
12	90.5	.3343E+04	.2000E+03	.3543E+04	.9436E+00
13	93.4	.3585E+04	.2000E+03	.3785E+04	.9472E+00
14	95.3	.3713E+04	.2000E+03	.3913E+04	.9489E+00
15	96.0	.3712E+04	.2000E+03	.3912E+04	.9489E+00
16	95.3	.3595E+04	.2000E+03	.3795E+04	.9473E+00
17	93.6	.2668E+04	.0000E+00	.2668E+04	.1000E+01
18	91.0	.2291E+04	.0000E+00	.2291E+04	.1000E+01
19	87.8	.1559E+04	.0000E+00	.1559E+04	.1000E+01
20	84.7	.1254E+04	.0000E+00	.1254E+04	.1000E+01
21	82.1	.1050E+04	.0000E+00	.1050E+04	.1000E+01
22	79.7	.8779E+03	.0000E+00	.8779E+03	.1000E+01
23	77.8	.7283E+03	.0000E+00	.7283E+03	.1000E+01
24	76.3	.6005E+03	.0000E+00	.6005E+03	.1000E+01

* INPUT DATA FOR SURFACE # 1 OF ROOM # 5 *****

h

= 12.00 WRW= 10.00 AD= .00 AW= .00 PSI= 180.00
LN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

** INPUT DATA FOR SURFACE # 2 OF ROOM # 5 *****

t

= 12.00 WRW= 9.00 AD= .00 AW= .00 PSI= 90.00
LN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 5 *****

= 0,NPD= 0,CFMN= .00,CFMD= .00
SN= .0,QOTSD= .0,QOTLN= .0
LD= .0,QFLN= .0,QFLD= .1
N= .0,QTLD= .0,DFST= 7.0,QFCT= 21.0

DATA FOR TRANSFER FUNCTION COEFFICIENTS***

ILAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

oble center
ooling loads, zone a

TOTAL COOLING LOAD FOR ROOM 5 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4676E+03	.0000E+00	.4676E+03	.1000E+01
2	73.9	.4544E+03	.0000E+00	.4544E+03	.1000E+01
3	73.0	.4414E+03	.0000E+00	.4414E+03	.1000E+01
4	72.2	.4281E+03	.0000E+00	.4281E+03	.1000E+01
5	72.0	.4143E+03	.0000E+00	.4143E+03	.1000E+01
6	72.5	.4000E+03	.0000E+00	.4000E+03	.1000E+01
7	73.7	.3854E+03	.0000E+00	.3854E+03	.1000E+01
8	75.8	.7609E+03	.0000E+00	.7609E+03	.1000E+01
9	79.0	.7953E+03	.0000E+00	.7953E+03	.1000E+01
10	82.6	.8087E+03	.0000E+00	.8087E+03	.1000E+01
11	86.6	.8162E+03	.0000E+00	.8162E+03	.1000E+01
12	90.5	.8230E+03	.0000E+00	.8230E+03	.1000E+01
13	93.4	.8311E+03	.0000E+00	.8311E+03	.1000E+01
14	95.3	.8408E+03	.0000E+00	.8408E+03	.1000E+01
15	96.0	.8521E+03	.0000E+00	.8521E+03	.1000E+01
16	95.3	.8642E+03	.0000E+00	.8642E+03	.1000E+01
17	93.6	.8770E+03	.0000E+00	.8770E+03	.1000E+01
18	91.0	.8899E+03	.0000E+00	.8899E+03	.1000E+01
19	87.8	.9027E+03	.0000E+00	.9027E+03	.1000E+01
20	84.7	.9152E+03	.0000E+00	.9152E+03	.1000E+01
21	82.1	.9269E+03	.0000E+00	.9269E+03	.1000E+01
22	79.7	.5468E+03	.0000E+00	.5468E+03	.1000E+01
23	77.8	.5062E+03	.0000E+00	.5062E+03	.1000E+01
24	76.3	.4853E+03	.0000E+00	.4853E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 6 *****

NPN= 0,NPD= 0,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
QTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 21.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling loads, zone a

TOTAL COOLING LOAD FOR ROOM 6 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.8854E+02	.0000E+00	.8854E+02	.1000E+01
2	73.9	.7846E+02	.0000E+00	.7846E+02	.1000E+01
3	73.0	.6984E+02	.0000E+00	.6984E+02	.1000E+01
4	72.2	.6225E+02	.0000E+00	.6225E+02	.1000E+01
5	72.0	.5552E+02	.0000E+00	.5552E+02	.1000E+01
6	72.5	.4953E+02	.0000E+00	.4953E+02	.1000E+01
7	73.7	.4418E+02	.0000E+00	.4418E+02	.1000E+01
8	75.8	.3281E+03	.0000E+00	.3281E+03	.1000E+01
9	79.0	.3603E+03	.0000E+00	.3603E+03	.1000E+01
10	82.6	.3770E+03	.0000E+00	.3770E+03	.1000E+01
11	86.6	.3881E+03	.0000E+00	.3881E+03	.1000E+01
12	90.5	.3968E+03	.0000E+00	.3968E+03	.1000E+01
13	93.4	.4042E+03	.0000E+00	.4042E+03	.1000E+01
14	95.3	.4107E+03	.0000E+00	.4107E+03	.1000E+01
15	96.0	.4165E+03	.0000E+00	.4165E+03	.1000E+01
16	95.3	.4217E+03	.0000E+00	.4217E+03	.1000E+01
17	93.6	.4263E+03	.0000E+00	.4263E+03	.1000E+01
18	91.0	.4303E+03	.0000E+00	.4303E+03	.1000E+01
19	87.8	.4340E+03	.0000E+00	.4340E+03	.1000E+01
20	84.7	.4372E+03	.0000E+00	.4372E+03	.1000E+01
21	82.1	.4402E+03	.0000E+00	.4402E+03	.1000E+01
22	79.7	.4541E+03	.0000E+00	.4541E+03	.1000E+01
23	77.8	.4199E+03	.0000E+00	.4199E+03	.1000E+01
24	76.3	.4015E+03	.0000E+00	.4015E+03	.1000E+01

ble center
 sling loads, zone a

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2822E+04	.0000E+00	.2822E+04	.1000E+01
2	73.9	.2535E+04	.0000E+00	.2535E+04	.1000E+01
3	73.0	.2276E+04	.0000E+00	.2276E+04	.1000E+01
4	72.2	.2045E+04	.0000E+00	.2045E+04	.1000E+01
5	72.0	.1855E+04	.0000E+00	.1855E+04	.1000E+01
6	72.5	.1720E+04	.0000E+00	.1720E+04	.1000E+01
7	73.7	.2431E+04	.0000E+00	.2431E+04	.1000E+01
8	75.8	.1612E+05	.1400E+04	.1752E+05	.9201E+00
9	79.0	.1775E+05	.1400E+04	.1915E+05	.9269E+00
10	82.6	.1886E+05	.1400E+04	.2026E+05	.9309E+00
11	86.6	.1978E+05	.1400E+04	.2118E+05	.9339E+00
12	90.5	.2055E+05	.1400E+04	.2195E+05	.9362E+00
13	93.4	.2113E+05	.1400E+04	.2253E+05	.9379E+00
14	95.3	.2152E+05	.1400E+04	.2292E+05	.9389E+00
15	96.0	.2171E+05	.1400E+04	.2311E+05	.9394E+00
16	95.3	.2171E+05	.1400E+04	.2311E+05	.9394E+00
17	93.6	.8987E+04	.0000E+00	.8987E+04	.1000E+01
18	91.0	.7637E+04	.0000E+00	.7637E+04	.1000E+01
19	87.8	.6191E+04	.0000E+00	.6191E+04	.1000E+01
20	84.7	.5508E+04	.0000E+00	.5508E+04	.1000E+01
21	82.1	.5027E+04	.0000E+00	.5027E+04	.1000E+01
22	79.7	.3941E+04	.0000E+00	.3941E+04	.1000E+01
23	77.8	.3501E+04	.0000E+00	.3501E+04	.1000E+01
24	76.3	.3144E+04	.0000E+00	.3144E+04	.1000E+01

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTMD= 5.0 THTMN= 25.0 NCOIL = 1

noble center
cooling loads, zone a

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

UNCONVERGED FOR THE GIVEN ERROR&NUMBER OF ITERATIONS, THE LAST ITERATION VALUES OF HEAT EXTRACTION IN HEATX ARE THE MAXIMUM CAPICITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THRMOSTAT SETTING

ROOM AIR TEMPS 1-24HRS		THERMOSTAT SETTING		78.0 F AT 5.HRS		78.0 F AT 25.HRS									
1	77.2	4	77.2	7	77.2	10	78.7	13	78.9	16	78.9	19	77.5	22	77.3
2	77.2	5	77.1	8	78.5	11	78.8	14	78.9	17	77.7	20	77.4	23	77.3
3	77.2	6	77.1	9	78.6	12	78.9	15	78.9	18	77.6	21	77.4	24	77.2

HEAT EXTRACTION RATES 1-24 HRS		ERMIN=		.000000		ERMAX=		24000.		ENCRE=		1000.		BTU/HOUR	
1	2677.	4	1933.	7	2378.	10	20580.	13	22805.	16	23312.	19	6000.	22	3762.
2	2401.	5	1754.	8	17897.	11	21487.	14	23177.	17	8774.	20	5327.	23	3333.
3	2153.	6	1633.	9	19496.	12	22238.	15	23339.	18	7450.	21	4857.	24	2987.

CFMT =	.0	CFMM =	35.0	ETAF =	.500
PB =	14.6960	MEX =	0	DPOR =	.000
ETAFR=	.5000	NSF =	0	DPDS =	2.000
ETAFS=	.5000				

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone a

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 23339. AT 15 HOURS WITH A SENSIBLE HEAT FACTOR OF .940

OUTDOOR AIR= 35. CFM AT 14.696 PSIA AND 96.0 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 32. CFM AT 14.696 PSIA AND
55.0 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 846. CFM AT 55.0 DEG F DRY BULB --- 52.7 DEG F WET BULB AND 14.696 PSIA

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 80.2 DEG F
ENTERING WET BULB TEMP= 63.1 DEG F
LEAVING DRY BULB TEMP= 55.0 DEG F
LEAVING WET BULB TEMP= 52.7 DEG F
ENTERING AIR QUANTITY= 887. CFM *846 LEAVING*
COIL SENSIBLE HEAT FACTOR= .926
TOTAL COIL CAPACITY= 26263. BTUH

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

***** GENERAL INPUT DATA *****

B= 3, MC= 2, NRMS= 7, WD= .0136, IA= 0, NPRT= 0, INWRIT= 1, XLAT= 36.0
ICLONG= 97.0, STLONG= 90.0, TROOM= 78.0, TMAXIM= 96.0 TRANGE= 24.0
IH= 72.0 TOH= 13.0

NM= 8, NHTX= 1, TWBO= 74.00, IHEAT= 0
JDDM= 21, NITR= 10, TWBI= 62.00, WD= .0136, PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 1 *****

west

WRL= 13.00 WRW= 9.00 AD= .00 AW= .00 PSI= 270.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 1 *****

north

WRL= 13.00 WRW= 6.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0, NPD= 0, CFMN= .00, CFND= .00
BOTSN= .0, BOTSD= .0, BOTLN= .0
BOTLD= .0, BFLN= .0, BFLD= .1
BTLN= .0, BTLD= .0, OFST= 7.0, OFCT= 21.0

***** DATA FOR TRANSFER FUNCTION COEFFICIENTS *****

ISOLAR= 2, ICNDT= 2, ILGHT= 2, IGCEQ= 2, IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

able center
ooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4147E+03	.0000E+00	.4147E+03	.1000E+01
2	73.9	.4096E+03	.0000E+00	.4096E+03	.1000E+01
3	73.0	.4036E+03	.0000E+00	.4036E+03	.1000E+01
4	72.2	.3963E+03	.0000E+00	.3963E+03	.1000E+01
5	72.0	.3878E+03	.0000E+00	.3878E+03	.1000E+01
6	72.5	.3781E+03	.0000E+00	.3781E+03	.1000E+01
7	73.7	.3674E+03	.0000E+00	.3674E+03	.1000E+01
8	75.8	.6446E+03	.0000E+00	.6446E+03	.1000E+01
9	79.0	.6690E+03	.0000E+00	.6690E+03	.1000E+01
10	82.6	.6771E+03	.0000E+00	.6771E+03	.1000E+01
11	86.6	.6794E+03	.0000E+00	.6794E+03	.1000E+01
12	90.5	.6796E+03	.0000E+00	.6796E+03	.1000E+01
13	93.4	.6791E+03	.0000E+00	.6791E+03	.1000E+01
14	95.3	.6789E+03	.0000E+00	.6789E+03	.1000E+01
15	96.0	.6795E+03	.0000E+00	.6795E+03	.1000E+01
16	95.3	.6814E+03	.0000E+00	.6814E+03	.1000E+01
17	93.6	.6852E+03	.0000E+00	.6852E+03	.1000E+01
18	91.0	.6917E+03	.0000E+00	.6917E+03	.1000E+01
19	87.8	.7011E+03	.0000E+00	.7011E+03	.1000E+01
20	84.7	.7133E+03	.0000E+00	.7133E+03	.1000E+01
21	82.1	.7277E+03	.0000E+00	.7277E+03	.1000E+01
22	79.7	.4539E+03	.0000E+00	.4539E+03	.1000E+01
23	77.8	.4312E+03	.0000E+00	.4312E+03	.1000E+01
24	76.3	.4226E+03	.0000E+00	.4226E+03	.1000E+01

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 2 *****

north wall

WRL= 13.00 WRN= 10.00 AB= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCB= 1.00 UWRA= .1170 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 2 *****

NPN= 0,NPD= 0,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 21.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEE= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2799E+03	.0000E+00	.2799E+03	.1000E+01
2	73.9	.2575E+03	.0000E+00	.2575E+03	.1000E+01
3	73.0	.2355E+03	.0000E+00	.2355E+03	.1000E+01
4	72.2	.2138E+03	.0000E+00	.2138E+03	.1000E+01
5	72.0	.1925E+03	.0000E+00	.1925E+03	.1000E+01
6	72.5	.1717E+03	.0000E+00	.1717E+03	.1000E+01
7	73.7	.1517E+03	.0000E+00	.1517E+03	.1000E+01
8	75.8	.4222E+03	.0000E+00	.4222E+03	.1000E+01
9	79.0	.4447E+03	.0000E+00	.4447E+03	.1000E+01
10	82.6	.4563E+03	.0000E+00	.4563E+03	.1000E+01
11	86.6	.4670E+03	.0000E+00	.4670E+03	.1000E+01
12	90.5	.4802E+03	.0000E+00	.4802E+03	.1000E+01
13	93.4	.4971E+03	.0000E+00	.4971E+03	.1000E+01
14	95.3	.5176E+03	.0000E+00	.5176E+03	.1000E+01
15	96.0	.5410E+03	.0000E+00	.5410E+03	.1000E+01
16	95.3	.5657E+03	.0000E+00	.5657E+03	.1000E+01
17	93.6	.5903E+03	.0000E+00	.5903E+03	.1000E+01
18	91.0	.6131E+03	.0000E+00	.6131E+03	.1000E+01
19	87.8	.6325E+03	.0000E+00	.6325E+03	.1000E+01
20	84.7	.6478E+03	.0000E+00	.6478E+03	.1000E+01
21	82.1	.6568E+03	.0000E+00	.6568E+03	.1000E+01
22	79.7	.3707E+03	.0000E+00	.3707E+03	.1000E+01
23	77.8	.3317E+03	.0000E+00	.3317E+03	.1000E+01
24	76.3	.3051E+03	.0000E+00	.3051E+03	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 3 *****

north wall

WRL= 9.00 WRW= 20.00 AD= .00 AW= 130.00 PSI= 180.00
EPSILN= 90.00 SCG= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

north wall

WRL= 3.00 WRW= 20.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 1,NPD= 4,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 1320.0,QOTLN= .0
QOTLD= .0,QFLN= .2,QFLD= .5
QTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 1

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1512E+04	.2000E+03	.1712E+04	.8832E+00
2	73.9	.1390E+04	.2000E+03	.1590E+04	.8742E+00
3	73.0	.1280E+04	.2000E+03	.1480E+04	.8648E+00
4	72.2	.1183E+04	.2000E+03	.1383E+04	.8553E+00
5	72.0	.1108E+04	.2000E+03	.1308E+04	.8471E+00
6	72.5	.1068E+04	.2000E+03	.1268E+04	.8423E+00
7	73.7	.1606E+04	.2000E+03	.1806E+04	.8893E+00
8	75.8	.4466E+04	.8000E+03	.5266E+04	.8481E+00
9	79.0	.5049E+04	.8000E+03	.5849E+04	.8632E+00
10	82.6	.5528E+04	.8000E+03	.6328E+04	.8736E+00
11	86.6	.5973E+04	.8000E+03	.6773E+04	.8819E+00
12	90.5	.6348E+04	.8000E+03	.7148E+04	.8881E+00
13	93.4	.6617E+04	.8000E+03	.7417E+04	.8921E+00
14	95.3	.6769E+04	.8000E+03	.7569E+04	.8943E+00
15	96.0	.6790E+04	.8000E+03	.7590E+04	.8946E+00
16	95.3	.6692E+04	.8000E+03	.7492E+04	.8932E+00
17	93.6	.3987E+04	.2000E+03	.4187E+04	.9522E+00
18	91.0	.3501E+04	.2000E+03	.3701E+04	.9460E+00
19	87.8	.2718E+04	.2000E+03	.2918E+04	.9315E+00
20	84.7	.2380E+04	.2000E+03	.2580E+04	.9225E+00
21	82.1	.2152E+04	.2000E+03	.2352E+04	.9150E+00
22	79.7	.1958E+04	.2000E+03	.2158E+04	.9073E+00
23	77.8	.1790E+04	.2000E+03	.1990E+04	.8995E+00
24	76.3	.1645E+04	.2000E+03	.1845E+04	.8916E+00

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 4 *****

north wall

WRL= 9.00 WRW= 20.00 AD= .00 AW= 130.00 PSI= 180.00
PSILN= 90.00 SCG= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 4 *****

north wall

WRL= 3.00 WRW= 20.00 AD= .00 AW= .00 PSI= 180.00
PSILN= 90.00 SCG= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 4 *****

IPN= 0,NPD= 2,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 50.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .2
ITLN= .0,QTLN= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

SOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEB= 2,IAIR= 1

* FAYE MCGUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4962E+03	.0000E+00	.4962E+03	.1000E+01
2	73.9	.3857E+03	.0000E+00	.3857E+03	.1000E+01
3	73.0	.2859E+03	.0000E+00	.2859E+03	.1000E+01
4	72.2	.1983E+03	.0000E+00	.1983E+03	.1000E+01
5	72.0	.1323E+03	.0000E+00	.1323E+03	.1000E+01
6	72.5	.9948E+02	.0000E+00	.9948E+02	.1000E+01
7	73.7	.6443E+03	.0000E+00	.6443E+03	.1000E+01
8	75.8	.1917E+04	.4000E+03	.2317E+04	.8274E+00
9	79.0	.2394E+04	.4000E+03	.2794E+04	.8568E+00
10	82.6	.2818E+04	.4000E+03	.3218E+04	.8757E+00
11	86.6	.3226E+04	.4000E+03	.3626E+04	.8897E+00
12	90.5	.3572E+04	.4000E+03	.3972E+04	.8993E+00
13	93.4	.3817E+04	.4000E+03	.4217E+04	.9051E+00
14	95.3	.3946E+04	.4000E+03	.4346E+04	.9080E+00
15	96.0	.3947E+04	.4000E+03	.4347E+04	.9080E+00
16	95.3	.3832E+04	.4000E+03	.4232E+04	.9055E+00
17	93.6	.2704E+04	.0000E+00	.2704E+04	.1000E+01
18	91.0	.2316E+04	.0000E+00	.2316E+04	.1000E+01
19	87.8	.1580E+04	.0000E+00	.1580E+04	.1000E+01
20	84.7	.1272E+04	.0000E+00	.1272E+04	.1000E+01
21	82.1	.1067E+04	.0000E+00	.1067E+04	.1000E+01
22	79.7	.8927E+03	.0000E+00	.8927E+03	.1000E+01
23	77.8	.7415E+03	.0000E+00	.7415E+03	.1000E+01
24	76.3	.6123E+03	.0000E+00	.6123E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 5 *****

NPN= 0,NPD= 0,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .2
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

****DATA FOR TRANSFER FUNCTION COEFFICIENTS****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

* FAYE MCGUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 5 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.7176E+02	.0000E+00	.7176E+02	.1000E+01
2	73.9	.6401E+02	.0000E+00	.6401E+02	.1000E+01
3	73.0	.5711E+02	.0000E+00	.5711E+02	.1000E+01
4	72.2	.5094E+02	.0000E+00	.5094E+02	.1000E+01
5	72.0	.4545E+02	.0000E+00	.4545E+02	.1000E+01
6	72.5	.4055E+02	.0000E+00	.4055E+02	.1000E+01
7	73.7	.3617E+02	.0000E+00	.3617E+02	.1000E+01
8	75.8	.5518E+03	.0000E+00	.5518E+03	.1000E+01
9	79.0	.6141E+03	.0000E+00	.6141E+03	.1000E+01
10	82.6	.6478E+03	.0000E+00	.6478E+03	.1000E+01
11	86.6	.6710E+03	.0000E+00	.6710E+03	.1000E+01
12	90.5	.6897E+03	.0000E+00	.6897E+03	.1000E+01
13	93.4	.7057E+03	.0000E+00	.7057E+03	.1000E+01
14	95.3	.7198E+03	.0000E+00	.7198E+03	.1000E+01
15	96.0	.7323E+03	.0000E+00	.7323E+03	.1000E+01
16	95.3	.7435E+03	.0000E+00	.7435E+03	.1000E+01
17	93.6	.7338E+03	.0000E+00	.7338E+03	.1000E+01
18	91.0	.7170E+03	.0000E+00	.7170E+03	.1000E+01
19	87.8	.7148E+03	.0000E+00	.7148E+03	.1000E+01
20	84.7	.7291E+03	.0000E+00	.7291E+03	.1000E+01
21	82.1	.7142E+03	.0000E+00	.7142E+03	.1000E+01
22	79.7	.7101E+03	.0000E+00	.7101E+03	.1000E+01
23	77.8	.7055E+02	.0000E+00	.7055E+02	.1000E+01
24	76.3	.8076E+02	.0000E+00	.8076E+02	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** GENERAL INPUT DATA FOR ROOM # 6 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

file center
cooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 6 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.5833E+02	.0000E+00	.5833E+02	.1000E+01
2	73.9	.5207E+02	.0000E+00	.5207E+02	.1000E+01
3	73.0	.4648E+02	.0000E+00	.4648E+02	.1000E+01
4	72.2	.4149E+02	.0000E+00	.4149E+02	.1000E+01
5	72.0	.3704E+02	.0000E+00	.3704E+02	.1000E+01
6	72.5	.3306E+02	.0000E+00	.3306E+02	.1000E+01
7	73.7	.2951E+02	.0000E+00	.2951E+02	.1000E+01
8	75.8	.5752E+03	.2000E+03	.7752E+03	.7420E+00
9	79.0	.6271E+03	.2000E+03	.8271E+03	.7582E+00
10	82.6	.6547E+03	.2000E+03	.8547E+03	.7660E+00
11	86.6	.6735E+03	.2000E+03	.8735E+03	.7710E+00
12	90.5	.6887E+03	.2000E+03	.8887E+03	.7749E+00
13	93.4	.7016E+03	.2000E+03	.9016E+03	.7782E+00
14	95.3	.7130E+03	.2000E+03	.9130E+03	.7809E+00
15	96.0	.7231E+03	.2000E+03	.9231E+03	.7833E+00
16	95.3	.7321E+03	.2000E+03	.9321E+03	.7854E+00
17	93.6	.1913E+03	.0000E+00	.1913E+03	.1000E+01
18	91.0	.1438E+03	.0000E+00	.1438E+03	.1000E+01
19	87.8	.1201E+03	.0000E+00	.1201E+03	.1000E+01
20	84.7	.1046E+03	.0000E+00	.1046E+03	.1000E+01
21	82.1	.9264E+02	.0000E+00	.9264E+02	.1000E+01
22	79.7	.8246E+02	.0000E+00	.8246E+02	.1000E+01
23	77.8	.7353E+02	.0000E+00	.7353E+02	.1000E+01
24	76.3	.6562E+02	.0000E+00	.6562E+02	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 7 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 175.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .4
QTLN= .0,QTLD= .0,OFST= 7.0,OFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNOT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

TOTAL COOLING LOAD FOR ROOM 7 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1614E+03	.0000E+00	.1614E+03	.1000E+01
2	73.9	.1440E+03	.0000E+00	.1440E+03	.1000E+01
3	73.0	.1285E+03	.0000E+00	.1285E+03	.1000E+01
4	72.2	.1147E+03	.0000E+00	.1147E+03	.1000E+01
5	72.0	.1024E+03	.0000E+00	.1024E+03	.1000E+01
6	72.5	.9135E+02	.0000E+00	.9135E+02	.1000E+01
7	73.7	.8152E+02	.0000E+00	.8152E+02	.1000E+01
8	75.8	.1456E+04	.2000E+03	.1656E+04	.8792E+00
9	79.0	.1598E+04	.2000E+03	.1798E+04	.8888E+00
10	82.6	.1674E+04	.2000E+03	.1874E+04	.8933E+00
11	86.6	.1727E+04	.2000E+03	.1927E+04	.8962E+00
12	90.5	.1768E+04	.2000E+03	.1968E+04	.8984E+00
13	93.4	.1804E+04	.2000E+03	.2004E+04	.9002E+00
14	95.3	.1836E+04	.2000E+03	.2036E+04	.9018E+00
15	96.0	.1864E+04	.2000E+03	.2064E+04	.9031E+00
16	95.3	.1889E+04	.2000E+03	.2089E+04	.9043E+00
17	93.6	.5279E+03	.0000E+00	.5279E+03	.1000E+01
18	91.0	.3978E+03	.0000E+00	.3978E+03	.1000E+01
19	87.8	.3325E+03	.0000E+00	.3325E+03	.1000E+01
20	84.7	.2898E+03	.0000E+00	.2898E+03	.1000E+01
21	82.1	.2565E+03	.0000E+00	.2565E+03	.1000E+01
22	79.7	.2282E+03	.0000E+00	.2282E+03	.1000E+01
23	77.8	.2035E+03	.0000E+00	.2035E+03	.1000E+01
24	76.3	.1815E+03	.0000E+00	.1815E+03	.1000E+01

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2994E+04	.2000E+03	.3194E+04	.9374E+00
2	73.9	.2703E+04	.2000E+03	.2903E+04	.9311E+00
3	73.0	.2437E+04	.2000E+03	.2637E+04	.9241E+00
4	72.2	.2198E+04	.2000E+03	.2398E+04	.9166E+00
5	72.0	.2006E+04	.2000E+03	.2206E+04	.9093E+00
6	72.5	.1882E+04	.2000E+03	.2082E+04	.9039E+00
7	73.7	.2917E+04	.2000E+03	.3117E+04	.9358E+00
8	75.8	.1003E+05	.1600E+04	.1163E+05	.8625E+00
9	79.0	.1140E+05	.1600E+04	.1300E+05	.8769E+00
10	82.6	.1246E+05	.1600E+04	.1406E+05	.8862E+00
11	86.6	.1342E+05	.1600E+04	.1502E+05	.8934E+00
12	90.5	.1423E+05	.1600E+04	.1583E+05	.8989E+00
13	93.4	.1482E+05	.1600E+04	.1642E+05	.9026E+00
14	95.3	.1518E+05	.1600E+04	.1678E+05	.9047E+00
15	96.0	.1528E+05	.1600E+04	.1688E+05	.9052E+00
16	95.3	.1514E+05	.1600E+04	.1674E+05	.9044E+00
17	93.6	.8919E+04	.2000E+03	.9119E+04	.9781E+00
18	91.0	.7841E+04	.2000E+03	.8041E+04	.9751E+00
19	87.8	.6232E+04	.2000E+03	.6432E+04	.9689E+00
20	84.7	.5537E+04	.2000E+03	.5737E+04	.9651E+00
21	82.1	.5066E+04	.2000E+03	.5266E+04	.9620E+00
22	79.7	.4087E+04	.2000E+03	.4287E+04	.9534E+00
23	77.8	.3661E+04	.2000E+03	.3861E+04	.9482E+00
24	76.3	.3313E+04	.2000E+03	.3513E+04	.9431E+00

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THIND= 5.0 THTIMN= 20.0 NCOIL = 1

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

able center
ooling loads, zone b

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THERMOSTAT SETTING
IF THE ROOM TEMPERATURE IS HIGH DURING THE OFFICE TIME CHOOSE A ERMAX BIGGER THAN THE PRESENT ONE

ROOM AIR TEMPS 1-24HRS THERMOSTAT SETTING 78.0 F AT 5.HRS 78.0 F AT 20.HRS

1	77.3	4	77.3	7	77.4	10	78.7	13	79.0	16	79.0	19	77.7	22	77.5
2	77.3	5	77.2	8	78.4	11	78.8	14	79.0	17	78.0	20	77.6	23	77.4
3	77.3	6	77.2	9	78.6	12	78.9	15	79.0	18	77.9	21	77.6	24	77.4

HEAT EXTRACTION RATES 1-24 HRS ERMIN= .000000 ERMAX= 17000. ENCRE= 1000. BTU/HOUR

1	2967.	4	2210.	7	3041.	10	14433.	13	16778.	16	16984.	19	6188.	22	4027.
2	2688.	5	2032.	8	12032.	11	15392.	14	17111.	17	8919.	20	5495.	23	3612.
3	2434.	6	1927.	9	13376.	12	16198.	15	17170.	18	7846.	21	5031.	24	3276.

CFMT = 140.0 CFMM = 49.0 ETAF = .500
PB = 14.6960 MEX = 0 DPOR = 2.000
ETAFR= .5000 NSF = 0 DPOS = 2.000
ETAFS= .5000

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone b

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 17170. AT 15 HOURS WITH A SENSIBLE HEAT FACTOR OF .907

OUTDOOR AIR= 49. CFM AT 14.696 PSIA AND 96.0 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 214. CFM AT 14.696 PSIA AND
54.8 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 594. CFM AT 54.8 DEG F DRY BULB --- 52.2 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 621. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 82.4 DEG F

ENTERING WET BULB TEMP= 64.2 DEG F

LEAVING DRY BULB TEMP= 54.8 DEG F

LEAVING WET BULB TEMP= 52.2 DEG F

ENTERING AIR QUANTITY= 626. CFM

COIL SENSIBLE HEAT FACTOR= .873

TOTAL COIL CAPACITY= 21278. BTUH

noble center
cooling loads, zone 0

***** GENERAL INPUT DATA *****

IE= 3, MC= 2, NRMS= 4, WD= .0136, IA= 0, NPRT= 0, INWRIT= 1, XLAT= 36.0
ACLONS= 97.0, STLONG= 90.0, TROOM= 78.0, TMAXIM= 96.0, TRANGE= 24.0
TIR= 72.0, TGR= 13.0

NH= 8, NHTX= 1, TWBO= 74.00, IHEAT= 0
NDOO= 21, NITR= 10, TWBI= 67.00, WD= .0136, PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	97.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 1 *****

west wall

WRL= 13.00, WRW= 25.00, AD= .00, AW= .00, PSI= 270.00
EPSILN= 90.00, SCG= 1.00, UWRA= .0510, UW= 1.0800, UD= .5500, ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0, NPD= 1, CFMN= .00, CFMD= .00
QOTSN= .0, QOTSD= .0, QOTLN= .0
QOTLD= .0, QFLN= .0, QFLD= .1
QTLN= .0, QTLD= .0, QFST= 7.0, QFCT= 16.0

***** DATA FOR TRANSFER FUNCTION COEFFICIENTS *****

ISOLAR= 2, ICNDT= 2, ILGHT= 2, IDCEQ= 2, IAIR= 5

noble center
cooling loads, zone c

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TCOUTDOOR	SENSIBLE	LATENT	TOTAL	EHF
1	75.1	.1582E+03	.0000E+00	.1582E+03	.1000E+01
2	75.9	.1584E+03	.0000E+00	.1584E+03	.1000E+01
3	73.0	.1586E+03	.0000E+00	.1586E+03	.1000E+01
4	72.2	.1584E+03	.0000E+00	.1584E+03	.1000E+01
5	72.0	.1575E+03	.0000E+00	.1575E+03	.1000E+01
6	72.5	.1559E+03	.0000E+00	.1559E+03	.1000E+01
7	73.7	.1534E+03	.0000E+00	.1534E+03	.1000E+01
8	75.8	.6990E+03	.2000E+03	.8990E+03	.7775E+00
9	79.0	.7496E+03	.2000E+03	.9496E+03	.7894E+00
10	82.6	.7749E+03	.2000E+03	.9749E+03	.7949E+00
11	86.6	.7905E+03	.2000E+03	.9905E+03	.7981E+00
12	90.5	.8015E+03	.2000E+03	.1001E+04	.8003E+00
13	93.4	.8097E+03	.2000E+03	.1010E+04	.8019E+00
14	95.3	.8159E+03	.2000E+03	.1016E+04	.8031E+00
15	96.0	.8208E+03	.2000E+03	.1021E+04	.8041E+00
16	95.3	.8246E+03	.2000E+03	.1025E+04	.8048E+00
17	93.6	.2790E+03	.0000E+00	.2790E+03	.1000E+01
18	91.0	.2274E+03	.0000E+00	.2274E+03	.1000E+01
19	87.8	.2008E+03	.0000E+00	.2008E+03	.1000E+01
20	84.7	.1841E+03	.0000E+00	.1841E+03	.1000E+01
21	82.1	.1728E+03	.0000E+00	.1728E+03	.1000E+01
22	79.7	.1655E+03	.0000E+00	.1655E+03	.1000E+01
23	77.8	.1614E+03	.0000E+00	.1614E+03	.1000E+01
24	76.3	.1596E+03	.0000E+00	.1596E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 2 *****

QPN= 0, QPD= 8, QPMN= .00, QPKD= .00
QOTSN= .0, QOTSD= 1710.0, QOTLN= .0
QOTLD= .0, QFLN= .2, QFLD= .8
QTLN= .0, QTLD= .0, QFST= 7.0, QFCT= 21.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2, ICNDT= 2, ILGHT= 2, IDCEQ= -2, IAIR= 5

noble center
cooling loads, zone c

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHP
1	75.1	.1639E+04	.0000E+00	.1639E+04	.1000E+01
2	73.9	.1547E+04	.0000E+00	.1547E+04	.1000E+01
3	73.0	.1468E+04	.0000E+00	.1468E+04	.1000E+01
4	72.2	.1398E+04	.0000E+00	.1398E+04	.1000E+01
5	72.0	.1336E+04	.0000E+00	.1336E+04	.1000E+01
6	72.5	.1281E+04	.0000E+00	.1281E+04	.1000E+01
7	73.7	.1232E+04	.0000E+00	.1232E+04	.1000E+01
8	75.8	.5761E+04	.1600E+04	.7361E+04	.7826E+00
9	79.0	.6082E+04	.1600E+04	.7682E+04	.7917E+00
10	82.6	.6241E+04	.1600E+04	.7841E+04	.7959E+00
11	86.6	.6344E+04	.1600E+04	.7944E+04	.7986E+00
12	90.5	.6425E+04	.1600E+04	.8025E+04	.8006E+00
13	93.4	.6493E+04	.1600E+04	.8093E+04	.8023E+00
14	95.3	.6553E+04	.1600E+04	.8153E+04	.8038E+00
15	96.0	.6607E+04	.1600E+04	.8207E+04	.8050E+00
16	95.3	.6654E+04	.1600E+04	.8254E+04	.8062E+00
17	93.6	.6697E+04	.1600E+04	.8297E+04	.8072E+00
18	91.0	.6735E+04	.1600E+04	.8335E+04	.8080E+00
19	87.8	.6768E+04	.1600E+04	.8368E+04	.8088E+00
20	84.7	.6799E+04	.1600E+04	.8399E+04	.8095E+00
21	82.1	.6826E+04	.1600E+04	.8426E+04	.8101E+00
22	79.7	.2277E+04	.0000E+00	.2277E+04	.1000E+01
23	77.8	.1938E+04	.0000E+00	.1938E+04	.1000E+01
24	76.3	.1763E+04	.0000E+00	.1763E+04	.1000E+01

THE INSIDE DESIGN TEMPR. = 78.0 MONTH= 8 DAY= 21

APN= 0,NPD= 39,CFMN= .00,CFMD= .00
BOTSN= .0,BOTSD= .0,BOTLN= .0
BOTLD= .0,BFLN= .0,BFLD= 1.0
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISCLAR= 1,ICNDT= 1,ILGHT= 1,IOCEQ= 1,IAIR= 1

noble center
cooling loads, zone c

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3209E+03	.0000E+00	.3209E+03	.1000E+01
2	73.9	.2854E+03	.0000E+00	.2854E+03	.1000E+01
3	73.0	.2544E+03	.0000E+00	.2544E+03	.1000E+01
4	72.2	.2270E+03	.0000E+00	.2270E+03	.1000E+01
5	72.0	.2027E+03	.0000E+00	.2027E+03	.1000E+01
6	72.5	.1811E+03	.0000E+00	.1811E+03	.1000E+01
7	73.7	.1619E+03	.0000E+00	.1619E+03	.1000E+01
8	75.8	.1081E+05	.7800E+04	.1861E+05	.5808E+00
9	79.0	.1197E+05	.7800E+04	.1977E+05	.6054E+00
10	82.6	.1251E+05	.7800E+04	.2031E+05	.6159E+00
11	86.6	.1278E+05	.7800E+04	.2058E+05	.6211E+00
12	90.5	.1294E+05	.7800E+04	.2074E+05	.6240E+00
13	93.4	.1305E+05	.7800E+04	.2085E+05	.6258E+00
14	95.3	.1312E+05	.7800E+04	.2092E+05	.6272E+00
15	96.0f	.1318E+05	.7800E+04	.2098E+05	.6283E+00
16	95.3	.1324E+05	.7800E+04	<u>.2104E+05</u>	.6292E+00
17	93.6	.2619E+04	.0000E+00	.2619E+04	.1000E+01
18	91.0	.1485E+04	.0000E+00	.1485E+04	.1000E+01
19	87.8	.9638E+03	.0000E+00	.9638E+03	.1000E+01
20	84.7	.7070E+03	.0000E+00	.7070E+03	.1000E+01
21	82.1	.5657E+03	.0000E+00	.5657E+03	.1000E+01
22	79.7	.4770E+03	.0000E+00	.4770E+03	.1000E+01
23	77.8	.4137E+03	.0000E+00	.4137E+03	.1000E+01
24	76.3	.3640E+03	.0000E+00	.3640E+03	.1000E+01

THE INSIDE DESIGN TEMPR. = 78.0 MONTH = 8 DAY = 21

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 4 *****

west wall

WRL= 13.00 WRH= 22.00 AD= .00 AH= .00 PSI= 270.00
EPSILN= 50.00 SCG= 1.00 UNRA= .0510 UH= 1.0800 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 4 *****

south wall

WRL= 13.00 WRH= 20.00 AD= .00 AH= .00 PSI= .00
EPSILN= 50.00 SCG= 1.00 UNRA= .1170 UH= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 4 *****

NPN= 1,NPD= 125,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .2,QFLD= 2.2
QTLN= .0,QTLD= .3,QFST= 7.0,QFCT= 16.0

****DATA FOR TRANSFER FUNCTION COEFFICIENTS****

SOLAR= 1,ICNDT= 1,ILGHT= 1,IOCEO= 1,IAIR= 1

apple center
cooling loads, zone c

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2853E+04	.2000E+03	.3038E+04	.9342E+00
2	73.9	.2697E+04	.2000E+03	.2897E+04	.9307E+00
3	73.0	.2548E+04	.2000E+03	.2746E+04	.9272E+00
4	72.2	.2419E+04	.2000E+03	.2619E+04	.9236E+00
5	72.0	.2298E+04	.2000E+03	.2498E+04	.9199E+00
6	72.5	.2184E+04	.2000E+03	.2384E+04	.9161E+00
7	73.7	.2078E+04	.2000E+03	.2278E+04	.9122E+00
8	75.8	.3352E+05	.2500E+05	.5852E+05	.5728E+00
9	79.0	.3674E+05	.2500E+05	.6174E+05	.5951E+00
10	82.6	.3825E+05	.2500E+05	.6325E+05	.6047E+00
11	86.6	.3902E+05	.2500E+05	.6402E+05	.6095E+00
12	90.5	.3950E+05	.2500E+05	.6450E+05	.6124E+00
13	93.4	.3986E+05	.2500E+05	.6486E+05	.6146E+00
14	95.3	.4017E+05	.2500E+05	.6517E+05	.6164E+00
15	96.0	.4044E+05	.2500E+05	.6544E+05	.6180E+00
16	95.3	.4070E+05	.2500E+05	.6570E+05	.6195E+00
17	93.6	.9384E+04	.2000E+03	.9584E+04	.9791E+00
18	91.0	.6256E+04	.2000E+03	.6456E+04	.9690E+00
19	87.8	.4829E+04	.2000E+03	.5029E+04	.9602E+00
20	84.7	.4114E+04	.2000E+03	.4314E+04	.9536E+00
21	82.1	.3701E+04	.2000E+03	.3901E+04	.9487E+00
22	79.7	.3419E+04	.2000E+03	.3619E+04	.9447E+00
23	77.8	.3200E+04	.2000E+03	.3400E+04	.9412E+00
24	76.3	.3014E+04	.2000E+03	.3214E+04	.9378E+00

THE INSIDE DESIGN TEMPR. = 78.0

MONTH = 8 DAY = 21

noble center
cooling loads, zone c

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4956E+04	.2000E+03	.5156E+04	.9612E+00
2	73.9	.4678E+04	.2000E+03	.4878E+04	.9590E+00
3	73.0	.4429E+04	.2000E+03	.4629E+04	.9568E+00
4	72.2	.4202E+04	.2000E+03	.4402E+04	.9546E+00
5	72.0	.3994E+04	.2000E+03	.4194E+04	.9523E+00
6	72.5	.3802E+04	.2000E+03	.4002E+04	.9500E+00
7	73.7	.3625E+04	.2000E+03	.3825E+04	.9477E+00
8	75.8	.5078E+05	.3460E+05	.8538E+05	.5948E+00
9	79.0	.5554E+05	.3460E+05	.9014E+05	.6162E+00
10	82.6	.5777E+05	.3460E+05	.9237E+05	.6254E+00
11	86.6	.5894E+05	.3460E+05	.9354E+05	.6301E+00
12	90.5	.5967E+05	.3460E+05	.9427E+05	.6330E+00
13	93.4	.6021E+05	.3460E+05	.9481E+05	.6351E+00
14	95.3	.6066E+05	.3460E+05	.9526E+05	.6368E+00
15	96.0	.6106E+05	.3460E+05	.9566E+05	.6383E+00
16	95.3	.6141E+05	.3460E+05	.9601E+05	.6396E+00
17	93.6	.1898E+05	.1800E+04	.2078E+05	.9134E+00
18	91.0	.1470E+05	.1800E+04	.1650E+05	.8909E+00
19	87.8	.1276E+05	.1800E+04	.1456E+05	.8764E+00
20	84.7	.1180E+05	.1800E+04	.1360E+05	.8677E+00
21	82.1	.1126E+05	.1800E+04	.1306E+05	.8622E+00
22	79.7	.6338E+04	.2000E+03	.6538E+04	.9694E+00
23	77.8	.5713E+04	.2000E+03	.5913E+04	.9662E+00
24	76.3	.5301E+04	.2000E+03	.5501E+04	.9636E+00

ERMAX =	.0	ERMIN =	.0	ENCRE =	1000.0
THRANS =	2.0	THSETD =	79.0	THSETN =	78.0
THTIMD =	5.0	THTIMN =	20.0	NCGIL =	1

noble center
cooling loads, zone c

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THERMOSTAT SETTING

ROOM AIR TEMPS 1-24HRS		THERMOSTAT SETTING		78.0 F AT 5.HRS		78.0 F AT 20.HRS									
1	77.1	4	77.1	7	77.1	10	78.9	13	79.0	16	79.0	19	77.3	22	77.1
2	77.1	5	77.1	8	78.8	11	78.9	14	79.0	17	77.4	20	77.3	23	77.1
3	77.1	6	77.1	9	78.9	12	79.0	15	79.0	18	77.3	21	77.3	24	77.1

HEAT EXTRACTION RATES 1-24 HRS		ERMIN=		.000000		ERMAX=		97000.		ENCRE=		1000.		BTU/HOUR	
1	4895.	4	4210.	7	3686.	10	92971.	13	95254.	16	96348.	19	14168.	22	6180.
2	4642.	5	4021.	8	86227.	11	94082.	14	95663.	17	20190.	20	13254.	23	5594.
3	4410.	6	3847.	9	90828.	12	94760.	15	96025.	18	16043.	21	12750.	24	5214.

CFMT =	3440.0	CFNM =	860.0	ETAF =	.500
FB =	14.6960	HEX =	0	DPOR =	2.000
ETAFF =	.5000	NSF =	0	DPOS =	2.000
ETAFB =	.5000				

noble center
cooling loads, zone c

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 96346. BTU/H AT 15 HOURS WITH A SENSIBLE HEAT FACTOR OF .641

OUTDOOR AIR= 860. CFM AT 14.696 PSIA AND 95.3 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 5725. CFM AT 14.696 PSIA AND
68.0 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 5725. CFM AT 68.0 DEG F DRY BULB --- 62.0 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 5833. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 83.6 DEG F

ENTERING WET BULB TEMP= 68.6 DEG F

LEAVING DRY BULB TEMP= 68.0 DEG F

LEAVING WET BULB TEMP= 62.0 DEG F

ENTERING AIR QUANTITY= 5893. CFM

COIL SENSIBLE HEAT FACTOR= .725

TOTAL COIL CAPACITY= 139693. BTUH

noobie center
cooling load, zone 0

***** GENERAL INPUT DATA *****

IB= 3.HC= 2.NRMS= 5.WD= .0136,IA= 0.NPRT= 0.INWRIT= 1,ALAT= 36.0
ACLONG= 97.0,STLONG= 90.0,TROOM= 78.0,TMAXIM= 98.0 TRANGE= 24.0
TIH= 72.0 TGH= 13.0

NH= 8.NHTA= 1. TWBO= 74.00. IHEAT= 0
NDDM= 21.NITR= 10.TWBI= 62.00.WD= .0136. PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0.NPD= 6.CFMN= .00.CFMD= .00
QOTSN= .0.QOTSD= 1200.0.QOTLN= .0
QOTLD= .0.QFLN= .0.QFLD= .6
QTLN= .0.QTLD= .0.QFST= 7.0.QFCI= 21.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2.ICNDT= 2.ILGHT= 2.IDCEQ= 2.IAIR= 5

node center
cooling load, zone d

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.7271E+03	.0000E+00	.7271E+03	.1000E+01
2	73.9	.6450E+03	.0000E+00	.6450E+03	.1000E+01
3	73.0	.5747E+03	.0000E+00	.5747E+03	.1000E+01
4	72.2	.5129E+03	.0000E+00	.5129E+03	.1000E+01
5	72.0	.4580E+03	.0000E+00	.4580E+03	.1000E+01
6	72.5	.4090E+03	.0000E+00	.4090E+03	.1000E+01
7	73.7	.3653E+03	.0000E+00	.3653E+03	.1000E+01
8	75.8	.4071E+04	.1200E+04	.5271E+04	.7724E+00
9	79.0	.4352E+04	.1200E+04	.5552E+04	.7838E+00
10	82.6	.4491E+04	.1200E+04	.5691E+04	.7891E+00
11	86.6	.4582E+04	.1200E+04	.5782E+04	.7925E+00
12	90.5	.4653E+04	.1200E+04	.5853E+04	.7950E+00
13	93.4	.4714E+04	.1200E+04	.5914E+04	.7971E+00
14	95.3	.4767E+04	.1200E+04	.5967E+04	.7989E+00
15	96.0	.4814E+04	.1200E+04	.6014E+04	.8005E+00
16	95.3	.4856E+04	.1200E+04	.6056E+04	.8019E+00
17	93.6	.4894E+04	.1200E+04	.6094E+04	.8031E+00
18	91.0	.4927E+04	.1200E+04	.6127E+04	.8041E+00
19	87.8	.4957E+04	.1200E+04	.6157E+04	.8051E+00
20	84.7	.4984E+04	.1200E+04	.6184E+04	.8059E+00
21	82.1	.5007E+04	.1200E+04	<u>.6207E+04</u>	.8067E+00
22	79.7	.1283E+04	.0000E+00	.1283E+04	.1000E+01
23	77.8	.9874E+03	.0000E+00	.9874E+03	.1000E+01
24	76.3	.8338E+03	.0000E+00	.8338E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 2 *****

HPN= 0.NPD= 4.CFMN= .00.CFMD= .00
QOTSN= .0.QOTSU= .0.QOTLN= .0
QOTLD= .0.QFLN= .0.QFLD= .2
QTLN= .0.QLD= .0.QFST= 7.0.QFCI= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2.ICNDT= 2.ILGHT= 2.IOCED= 2.IAIR= 5

node center
cooling load, zone d

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1137E+03	.0000E+00	.1137E+03	.1000E+01
2	73.9	.1016E+03	.0000E+00	.1016E+03	.1000E+01
3	73.0	.9075E+02	.0000E+00	.9075E+02	.1000E+01
4	72.2	.8106E+02	.0000E+00	.8106E+02	.1000E+01
5	72.0	.7240E+02	.0000E+00	.7240E+02	.1000E+01
6	72.5	.6467E+02	.0000E+00	.6467E+02	.1000E+01
7	73.7	.5777E+02	.0000E+00	.5777E+02	.1000E+01
8	75.8	.1381E+04	.8000E+03	.2181E+04	.6332E+00
9	79.0	.1485E+04	.8000E+03	.2285E+04	.6499E+00
10	82.6	.1539E+04	.8000E+03	.2339E+04	.6580E+00
11	86.6	.1576E+04	.8000E+03	.2376E+04	.6633E+00
12	90.5	.1605E+04	.8000E+03	.2405E+04	.6674E+00
13	93.4	.1630E+04	.8000E+03	.2430E+04	.6708E+00
14	95.3	.1652E+04	.8000E+03	.2452E+04	.6738E+00
15	96.0	.1672E+04	.8000E+03	.2472E+04	.6764E+00
16	95.3	.1689E+04	.8000E+03	.2489E+04	.6786E+00
17	93.6	.3756E+03	.0000E+00	.3756E+03	.1000E+01
18	91.0	.2801E+03	.0000E+00	.2801E+03	.1000E+01
19	87.8	.2335E+03	.0000E+00	.2335E+03	.1000E+01
20	84.7	.2035E+03	.0000E+00	.2035E+03	.1000E+01
21	82.1	.1802E+03	.0000E+00	.1802E+03	.1000E+01
22	79.7	.1605E+03	.0000E+00	.1605E+03	.1000E+01
23	77.8	.1432E+03	.0000E+00	.1432E+03	.1000E+01
24	76.3	.1279E+03	.0000E+00	.1279E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 0.NPD= 2.CFMN= .00.CFMD= .00
QOTSN= .0.QOTSD= .0.QOTLN= .0
QOTLD= .0.QFLN= .2.QFLD= .6
QTLN= .0.QTLD= 1.1.QFST= 7.0.QFCI= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2.ICNDT= 2.ILGHT= 2.IOCEQ= 2.IAIR= 5

node center
cooling load, zone d

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1143E+04	.0000E+00	.1143E+04	.1000E+01
2	73.9	.1090E+04	.0000E+00	.1090E+04	.1000E+01
3	73.0	.1043E+04	.0000E+00	.1043E+04	.1000E+01
4	72.2	.1001E+04	.0000E+00	.1001E+04	.1000E+01
5	72.0	.9642E+03	.0000E+00	.9642E+03	.1000E+01
6	72.5	.9309E+03	.0000E+00	.9309E+03	.1000E+01
7	73.7	.9012E+03	.0000E+00	.9012E+03	.1000E+01
8	75.8	.4676E+04	.4000E+03	.5076E+04	.9212E+00
9	79.0	.5103E+04	.4000E+03	.5503E+04	.9273E+00
10	82.6	.5334E+04	.4000E+03	.5734E+04	.9302E+00
11	86.6	.5493E+04	.4000E+03	.5893E+04	.9321E+00
12	90.5	.5620E+04	.4000E+03	.6020E+04	.9336E+00
13	93.4	.5730E+04	.4000E+03	.6130E+04	.9347E+00
14	95.3	.5826E+04	.4000E+03	.6226E+04	.9357E+00
15	96.0	.5911E+04	.4000E+03	.6311E+04	.9366E+00
16	95.3	.5987E+04	.4000E+03	.6387E+04	.9374E+00
17	93.6	.2254E+04	.0000E+00	.2254E+04	.1000E+01
18	91.0	.1863E+04	.0000E+00	.1863E+04	.1000E+01
19	87.8	.1666E+04	.0000E+00	.1666E+04	.1000E+01
20	84.7	.1536E+04	.0000E+00	.1536E+04	.1000E+01
21	82.1	.1435E+04	.0000E+00	.1435E+04	.1000E+01
22	79.7	.1349E+04	.0000E+00	.1349E+04	.1000E+01
23	77.8	.1273E+04	.0000E+00	.1273E+04	.1000E+01
24	76.3	.1206E+04	.0000E+00	.1206E+04	.1000E+01

***** INPUT DATA FOR ROOM # 4 *****

east wall

WRL= 13.00 WRW= 50.00 AD= .00 HW= 130.00 PSI= 90.00
EPSILN= 90.00 SCG= .51 UWRH= .0510 UW= .5200 UD= .3500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 4 *****

WPN= 0.0 NPD= 5.0 CFMN= .00 CFMD= .00
QOTSN= .0 QOTSD= 100.0 QOTLN= .0
QOTLD= .0 QFLN= .0 QFLD= .9
WILN= .0 QTLN= .0 QFST= 7.0 QFCT= 16.0

***** DATA FOR TRANSFER FUNCTION COEFFICIENTS *****

ISOLAR= 2.0 ICNDT= 2.0 ILGHT= 2.0 ICEQ= 2.0 IAIR= 5

noble center
cooling load, zone 0

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1352E+04	.0000E+00	.1352E+04	.1000E+01
2	73.9	.1189E+04	.0000E+00	.1189E+04	.1000E+01
3	73.0	.1042E+04	.0000E+00	.1042E+04	.1000E+01
4	72.2	.9102E+03	.0000E+00	.9102E+03	.1000E+01
5	72.0	.8030E+03	.0000E+00	.8030E+03	.1000E+01
6	72.5	.7323E+03	.0000E+00	.7323E+03	.1000E+01
7	73.7	.5818E+04	.0000E+00	.5818E+04	.1000E+01
8	75.8	.1250E+05	.1000E+04	.1350E+05	.9259E+00
9	79.0	.1387E+05	.1000E+04	<u>.1487E+05</u>	.9327E+00
10	82.6	.1342E+05	.1000E+04	.1442E+05	.9307E+00
11	86.6	.1165E+05	.1000E+04	.1265E+05	.9209E+00
12	90.5	.9346E+04	.1000E+04	.1035E+05	.9033E+00
13	93.4	.8570E+04	.1000E+04	.9570E+04	.8955E+00
14	95.3	.8395E+04	.1000E+04	.9395E+04	.8936E+00
15	96.0	.8286E+04	.1000E+04	.9286E+04	.8923E+00
16	95.3	.8084E+04	.1000E+04	.9084E+04	.8899E+00
17	93.6	.4454E+04	.0000E+00	.4454E+04	.1000E+01
18	91.0	.3640E+04	.0000E+00	.3640E+04	.1000E+01
19	87.8	.2885E+04	.0000E+00	.2885E+04	.1000E+01
20	84.7	.2495E+04	.0000E+00	.2495E+04	.1000E+01
21	82.1	.2202E+04	.0000E+00	.2202E+04	.1000E+01
22	79.7	.1947E+04	.0000E+00	.1947E+04	.1000E+01
23	77.8	.1724E+04	.0000E+00	.1724E+04	.1000E+01
24	76.3	.1530E+04	.0000E+00	.1530E+04	.1000E+01

east wall

WRL= 13.00 WRW= 10.00 AD= .00 HW= 26.00 FSI= 90.00
EPSILN= 90.00 SC6= .51 UWRW= .0510 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 5 *****

south wall

WRL= 13.00 WRW= 20.00 AD= .00 HW= .00 FSI= .00
EPSILN= 90.00 SC6= .51 UWRW= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 5 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .2
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILBHT= 2,IOCEQ= 2,IAIR= 5

noobie center
cooling load, zone 0

TOTAL COOLING LOAD FOR ROOM 5 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.9661E+03	.0000E+00	.9661E+03	.1000E+01
2	73.9	.8864E+03	.0000E+00	.8864E+03	.1000E+01
3	73.0	.8090E+03	.0000E+00	.8090E+03	.1000E+01
4	72.2	.7347E+03	.0000E+00	.7347E+03	.1000E+01
5	72.0	.6655E+03	.0000E+00	.6655E+03	.1000E+01
6	72.5	.6044E+03	.0000E+00	.6044E+03	.1000E+01
7	73.7	.1576E+04	.0000E+00	.1576E+04	.1000E+01
8	75.8	.2930E+04	.2000E+03	.3130E+04	.9361E+00
9	79.0	.3177E+04	.2000E+03	<u>.3377E+04</u>	.9408E+00
10	82.6	.3072E+04	.2000E+03	.3272E+04	.9389E+00
11	86.6	.2721E+04	.2000E+03	.2921E+04	.9315E+00
12	90.5	.2291E+04	.2000E+03	.2491E+04	.9197E+00
13	93.4	.2193E+04	.2000E+03	.2393E+04	.9164E+00
14	95.3	.2236E+04	.2000E+03	.2436E+04	.9179E+00
15	96.0	.2305E+04	.2000E+03	.2505E+04	.9202E+00
16	95.3	.2357E+04	.2000E+03	.2557E+04	.9218E+00
17	93.6	.1654E+04	.0000E+00	.1654E+04	.1000E+01
18	91.0	.1547E+04	.0000E+00	.1547E+04	.1000E+01
19	87.8	.1430E+04	.0000E+00	.1430E+04	.1000E+01
20	84.7	.1361E+04	.0000E+00	.1361E+04	.1000E+01
21	82.1	.1290E+04	.0000E+00	.1290E+04	.1000E+01
22	79.7	.1213E+04	.0000E+00	.1213E+04	.1000E+01
23	77.8	.1133E+04	.0000E+00	.1133E+04	.1000E+01
24	76.3	.1052E+04	.0000E+00	.1052E+04	.1000E+01

noble center
cooling load, zone d

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4302E+04	.0000E+00	.4302E+04	.1000E+01
2	73.9	.3913E+04	.0000E+00	.3913E+04	.1000E+01
3	73.0	.3560E+04	.0000E+00	.3560E+04	.1000E+01
4	72.2	.3240E+04	.0000E+00	.3240E+04	.1000E+01
5	72.0	.2963E+04	.0000E+00	.2963E+04	.1000E+01
6	72.5	.2741E+04	.0000E+00	.2741E+04	.1000E+01
7	73.7	.8718E+04	.0000E+00	.8718E+04	.1000E+01
8	75.8	.2556E+05	.3600E+04	.2916E+05	.8765E+00
9	79.0	.2798E+05	.3600E+04	.3158E+05	.8860E+00
10	82.6	.2786E+05	.3600E+04	.3146E+05	.8856E+00
11	86.6	.2602E+05	.3600E+04	.2962E+05	.8785E+00
12	90.5	.2352E+05	.3600E+04	.2712E+05	.8672E+00
13	93.4	.2284E+05	.3600E+04	.2644E+05	.8638E+00
14	95.3	.2288E+05	.3600E+04	.2648E+05	.8640E+00
15	96.0	.2299E+05	.3600E+04	.2659E+05	.8646E+00
16	95.3	.2297E+05	.3600E+04	.2657E+05	.8645E+00
17	93.6	.1363E+05	.1200E+04	.1483E+05	.9191E+00
18	91.0	.1226E+05	.1200E+04	.1346E+05	.9108E+00
19	87.8	.1117E+05	.1200E+04	.1237E+05	.9030E+00
20	84.7	.1058E+05	.1200E+04	.1178E+05	.8981E+00
21	82.1	.1011E+05	.1200E+04	.1131E+05	.8939E+00
22	79.7	.5953E+04	.0000E+00	.5953E+04	.1000E+01
23	77.8	.5260E+04	.0000E+00	.5260E+04	.1000E+01
24	76.3	.4751E+04	.0000E+00	.4751E+04	.1000E+01

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTIMD= 5.0 THTIMN= 20.0 NCOIL = 1

noble center
cooling load, zone d

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THERMOSTAT SETTING
IF THE ROOM TEMPERATURE IS HIGH DURING THE OFFICE TIME CHOOSE A ERMAX BIGGER THAN THE PRESENT ONE

ROOM AIR TEMPS 1-24HRS THERMOSTAT SETTING 78.0 F AT 5.HRS 78.0 F AT 20.HRS

1	77.2	4	77.2	7	77.5	10	79.0	13	78.7	16	78.7	19	77.8	22	77.3
2	77.2	5	77.2	8	78.9	11	78.9	14	78.7	17	77.9	20	77.7	23	77.3
3	77.2	6	77.2	9	79.0	12	78.7	15	78.7	18	77.8	21	77.7	24	77.3

HEAT EXTRACTION RATES 1-24 HRS ERMIN= .000000 ERMAX= 32000. ENCRE= 1000. BTU/HOUR

1	3925.	4	2926.	7	8737.	10	32166.	13	26782.	16	26844.	19	12110.	22	5497.
2	3557.	5	2669.	8	30050.	11	30173.	14	26799.	17	14563.	20	11525.	23	4839.
3	3224.	6	2469.	9	32408.	12	27514.	15	26888.	18	13201.	21	11069.	24	4355.

CFMT =	380.0	CFMM =	90.0	ETAF =	.500
FB =	14.6960	HEX =	0	DPDR =	2.000
ETAFR =	.5000	NSF =	0	DPDS =	2.000
ETAFS =	.5000				

mobile center
cooling load, zone d

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 32408. AT 9 HOURS WITH A SENSIBLE HEAT FACTOR OF .889

OUTDOOR AIR= 90. CFM AT 14.696 PSIA AND 79.0 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 601. CFM AT 14.696 PSIA AND
54.3 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 1077. CFM AT 54.3 DEG F DRY BULB --- 51.7 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 1127. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 80.9 DEG F
ENTERING WET BULB TEMP= 63.7 DEG F
LEAVING DRY BULB TEMP= 54.3 DEG F
LEAVING WET BULB TEMP= 51.7 DEG F
ENTERING AIR QUANTITY= 1133. CFM
COIL SENSIBLE HEAT FACTOR= .849
TOTAL COIL CAPACITY= 38232. BTUH

noble center
cooling loads, zone e

***** GENERAL INPUT DATA *****

IB= 3,MC= 2,NRMS= 7,WD= .0136,IA= 0,NPRT= 0,INWRIT= 1,XLAT= 36.0
ACLONG= 97.0,STLONG= 90.0,TROOM= 78.0,TMAXIM= 96.0 TRANGE= 24.0
TIH= 72.0 TDH= 13.0

NM= 8,NHTX= 1,TWBO= 74.00,IHEAT= 0
NDDM= 21,NITR= 10,TWBI= 62.00,WD= .0136,PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0,NPD= 3,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .9
QTLN= .0,QTLD= .0,OFST= 7.0,OFCT= 16.0

****-DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3586E+03	.0000E+00	.3586E+03	.1000E+01
2	73.9	.3200E+03	.0000E+00	.3200E+03	.1000E+01
3	73.0	.2856E+03	.0000E+00	.2856E+03	.1000E+01
4	72.2	.2548E+03	.0000E+00	.2548E+03	.1000E+01
5	72.0	.2274E+03	.0000E+00	.2274E+03	.1000E+01
6	72.5	.2029E+03	.0000E+00	.2029E+03	.1000E+01
7	73.7	.1811E+03	.0000E+00	.1811E+03	.1000E+01
8	75.8	.3138E+04	.6000E+03	.3738E+04	.8395E+00
9	79.0	.3453E+04	.6000E+03	.4053E+04	.8519E+00
10	82.6	.3621E+04	.6000E+03	.4221E+04	.8579E+00
11	86.6	.3738E+04	.6000E+03	.4338E+04	.8617E+00
12	90.5	.3831E+04	.6000E+03	.4431E+04	.8646E+00
13	93.4	.3911E+04	.6000E+03	.4511E+04	.8670E+00
14	95.3	.3981E+04	.6000E+03	.4581E+04	.8690E+00
15	96.0	.4043E+04	.6000E+03	.4643E+04	.8708E+00
16	95.3	.4099E+04	.6000E+03	.4699E+04	.8723E+00
17	93.6	.1172E+04	.0000E+00	.1172E+04	.1000E+01
18	91.0	.8842E+03	.0000E+00	.8842E+03	.1000E+01
19	87.8	.7391E+03	.0000E+00	.7391E+03	.1000E+01
20	84.7	.6442E+03	.0000E+00	.6442E+03	.1000E+01
21	82.1	.5702E+03	.0000E+00	.5702E+03	.1000E+01
22	79.7	.5074E+03	.0000E+00	.5074E+03	.1000E+01
23	77.8	.4523E+03	.0000E+00	.4523E+03	.1000E+01
24	76.3	.4035E+03	.0000E+00	.4035E+03	.1000E+01

north wall

WRL= 10.00 WRW= 20.00 AD= .00 AW= 130.00 PSI= 180.00
EPSILN= 90.00 SCB= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 2 *****

north wall

WRL= 3.00 WRW= 20.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCB= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 2 *****

NPN= 0,NPD= 2,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .3
QTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILSHT= 2,IOCEQ= 2,IAIR= 1

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.5847E+03	.0000E+00	.5847E+03	.1000E+01
2	73.9	.4660E+03	.0000E+00	.4660E+03	.1000E+01
3	73.0	.3584E+03	.0000E+00	.3584E+03	.1000E+01
4	72.2	.2636E+03	.0000E+00	.2636E+03	.1000E+01
5	72.0	.1908E+03	.0000E+00	.1908E+03	.1000E+01
6	72.5	.1517E+03	.0000E+00	.1517E+03	.1000E+01
7	73.7	.6906E+03	.0000E+00	.6906E+03	.1000E+01
8	75.8	.2361E+04	.4000E+03	.2761E+04	.8551E+00
9	79.0	.2887E+04	.4000E+03	.3287E+04	.8783E+00
10	82.6	.3338E+04	.4000E+03	.3738E+04	.8930E+00
11	86.6	.3765E+04	.4000E+03	.4165E+04	.9040E+00
12	90.5	.4127E+04	.4000E+03	.4527E+04	.9116E+00
13	93.4	.4387E+04	.4000E+03	.4787E+04	.9164E+00
14	95.3	.4530E+04	.4000E+03	.4930E+04	.9189E+00
15	96.0	.4544E+04	.4000E+03	<u>.4944E+04</u>	.9191E+00
16	95.3	.4441E+04	.4000E+03	.4841E+04	.9174E+00
17	93.6	.2921E+04	.0000E+00	.2921E+04	.1000E+01
18	91.0	.2490E+04	.0000E+00	.2490E+04	.1000E+01
19	87.8	.1732E+04	.0000E+00	.1732E+04	.1000E+01
20	84.7	.1411E+04	.0000E+00	.1411E+04	.1000E+01
21	82.1	.1194E+04	.0000E+00	.1194E+04	.1000E+01
22	79.7	.1010E+04	.0000E+00	.1010E+04	.1000E+01
23	77.8	.8486E+03	.0000E+00	.8486E+03	.1000E+01
24	76.3	.7101E+03	.0000E+00	.7101E+03	.1000E+01

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 3 *****

north wall

WRL= 10.00 WRW= 10.00 AD= .00 AW= 65.00 PSI= 180.00
EPSILN= 90.00 SCG= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

north wall

WRL= 3.00 WRW= 10.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 50.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .3
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEB= 2,IAIR= 1

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3557E+03	.0000E+00	.3557E+03	.1000E+01
2	73.9	.2895E+03	.0000E+00	.2895E+03	.1000E+01
3	73.0	.2296E+03	.0000E+00	.2296E+03	.1000E+01
4	72.2	.1767E+03	.0000E+00	.1767E+03	.1000E+01
5	72.0	.1355E+03	.0000E+00	.1355E+03	.1000E+01
6	72.5	.1116E+03	.0000E+00	.1116E+03	.1000E+01
7	73.7	.3772E+03	.0000E+00	.3772E+03	.1000E+01
8	75.8	.1693E+04	.2000E+03	.1893E+04	.8943E+00
9	79.0	.2011E+04	.2000E+03	.2211E+04	.9095E+00
10	82.6	.2266E+04	.2000E+03	.2466E+04	.9189E+00
11	86.6	.2500E+04	.2000E+03	.2700E+04	.9259E+00
12	90.5	.2698E+04	.2000E+03	.2898E+04	.9310E+00
13	93.4	.2841E+04	.2000E+03	.3041E+04	.9342E+00
14	95.3	.2926E+04	.2000E+03	.3126E+04	.9360E+00
15	96.0	.2944E+04	.2000E+03	.3144E+04	.9364E+00
16	95.3	.2902E+04	.2000E+03	.3102E+04	.9355E+00
17	93.6	.1667E+04	.0000E+00	.1667E+04	.1000E+01
18	91.0	.1401E+04	.0000E+00	.1401E+04	.1000E+01
19	87.8	.9968E+03	.0000E+00	.9968E+03	.1000E+01
20	84.7	.8194E+03	.0000E+00	.8194E+03	.1000E+01
21	82.1	.6979E+03	.0000E+00	.6979E+03	.1000E+01
22	79.7	.5945E+03	.0000E+00	.5945E+03	.1000E+01
23	77.8	.5042E+03	.0000E+00	.5042E+03	.1000E+01
24	76.3	.4263E+03	.0000E+00	.4263E+03	.1000E+01

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 4 *****

north wall

WRL= 13.00 WRW= 10.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SC6= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 4 *****

east

WRL= 13.00 WRW= 9.00 AD= .00 AW= .00 PSI= 90.00
EPSILN= 90.00 SC6= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 4 *****

NPN= 0, NPD= .0, CFM1= .00, CFM2= .00
QOTSN= .0, QOTSD= .0, QOTLN= .0
QOTLD= .0, QFLN= .0, QFLD= .1
QTLN= .0, QTLD= .0, QFST= 7.0, QFCT= 16.0

***** DATA FOR TRANSFER FUNCTION COEFFICIENTS *****

ISOLAR= 2, ICNDT= 2, ILCHT= 2, IOCEQ= 2, IAIR= 5

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4308E+03	.0000E+00	.4308E+03	.1000E+01
2	73.9	.4254E+03	.0000E+00	.4254E+03	.1000E+01
3	73.0	.4187E+03	.0000E+00	.4187E+03	.1000E+01
4	72.2	.4108E+03	.0000E+00	.4108E+03	.1000E+01
5	72.0	.4016E+03	.0000E+00	.4016E+03	.1000E+01
6	72.5	.3913E+03	.0000E+00	.3913E+03	.1000E+01
7	73.7	.3799E+03	.0000E+00	.3799E+03	.1000E+01
8	75.8	.7583E+03	.0000E+00	.7583E+03	.1000E+01
9	79.0	.7950E+03	.0000E+00	.7950E+03	.1000E+01
10	82.6	.8105E+03	.0000E+00	.8105E+03	.1000E+01
11	86.6	.8198E+03	.0000E+00	.8198E+03	.1000E+01
12	90.5	.8284E+03	.0000E+00	.8284E+03	.1000E+01
13	93.4	.8383E+03	.0000E+00	.8383E+03	.1000E+01
14	95.3	.8500E+03	.0000E+00	.8500E+03	.1000E+01
15	96.0	.8630E+03	.0000E+00	.8630E+03	.1000E+01
16	95.3	.8771E+03	.0000E+00	<u>.8771E+03</u>	.1000E+01
17	93.6	.5010E+03	.0000E+00	.5010E+03	.1000E+01
18	91.0	.4663E+03	.0000E+00	.4663E+03	.1000E+01
19	87.8	.4532E+03	.0000E+00	.4532E+03	.1000E+01
20	84.7	.4476E+03	.0000E+00	.4476E+03	.1000E+01
21	82.1	.4448E+03	.0000E+00	.4448E+03	.1000E+01
22	79.7	.4429E+03	.0000E+00	.4429E+03	.1000E+01
23	77.8	.4407E+03	.0000E+00	.4407E+03	.1000E+01
24	76.3	.4377E+03	.0000E+00	.4377E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 5 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
BOTSN= .0,BOTSD= 175.0,BOTLN= .0
BOTLD= .0,BFLN= .0,BFLD= .4
BTLN= .0,BTLD= .0,OFST= 7.0,OFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= -2,IAIR= 5

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 5 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1596E+03	.0000E+00	.1596E+03	.1000E+01
2	73.9	.1424E+03	.0000E+00	.1424E+03	.1000E+01
3	73.0	.1271E+03	.0000E+00	.1271E+03	.1000E+01
4	72.2	.1134E+03	.0000E+00	.1134E+03	.1000E+01
5	72.0	.1012E+03	.0000E+00	.1012E+03	.1000E+01
6	72.5	.9035E+02	.0000E+00	.9035E+02	.1000E+01
7	73.7	.8064E+02	.0000E+00	.8064E+02	.1000E+01
8	75.8	.1443E+04	.2000E+03	.1643E+04	.8782E+00
9	79.0	.1583E+04	.2000E+03	.1783E+04	.8878E+00
10	82.6	.1658E+04	.2000E+03	.1858E+04	.8924E+00
11	86.6	.1710E+04	.2000E+03	.1910E+04	.8953E+00
12	90.5	.1752E+04	.2000E+03	.1952E+04	.8975E+00
13	93.4	.1787E+04	.2000E+03	.1987E+04	.8993E+00
14	95.3	.1818E+04	.2000E+03	.2018E+04	.9009E+00
15	96.0	.1846E+04	.2000E+03	.2046E+04	.9022E+00
16	95.3	.1871E+04	.2000E+03	<u>.2071E+04</u>	.9034E+00
17	93.6	.5222E+03	.0000E+00	.5222E+03	.1000E+01
18	91.0	.3934E+03	.0000E+00	.3934E+03	.1000E+01
19	87.8	.3288E+03	.0000E+00	.3288E+03	.1000E+01
20	84.7	.2866E+03	.0000E+00	.2866E+03	.1000E+01
21	82.1	.2537E+03	.0000E+00	.2537E+03	.1000E+01
22	79.7	.2257E+03	.0000E+00	.2257E+03	.1000E+01
23	77.8	.2013E+03	.0000E+00	.2013E+03	.1000E+01
24	76.3	.1796E+03	.0000E+00	.1796E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 6 *****

NPN= 0,NPD= 0,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
QTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 6 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4784E+02	.0000E+00	.4784E+02	.1000E+01
2	73.9	.4267E+02	.0000E+00	.4267E+02	.1000E+01
3	73.0	.3807E+02	.0000E+00	.3807E+02	.1000E+01
4	72.2	.3396E+02	.0000E+00	.3396E+02	.1000E+01
5	72.0	.3030E+02	.0000E+00	.3030E+02	.1000E+01
6	72.5	.2703E+02	.0000E+00	.2703E+02	.1000E+01
7	73.7	.2411E+02	.0000E+00	.2411E+02	.1000E+01
8	75.8	.3679E+03	.0000E+00	.3679E+03	.1000E+01
9	79.0	.4094E+03	.0000E+00	.4094E+03	.1000E+01
10	82.6	.4318E+03	.0000E+00	.4318E+03	.1000E+01
11	86.6	.4474E+03	.0000E+00	.4474E+03	.1000E+01
12	90.5	.4598E+03	.0000E+00	.4598E+03	.1000E+01
13	93.4	.4705E+03	.0000E+00	.4705E+03	.1000E+01
14	95.3	.4799E+03	.0000E+00	.4799E+03	.1000E+01
15	96.0	.4882E+03	.0000E+00	.4882E+03	.1000E+01
16	95.3	.4956E+03	.0000E+00	<u>.4956E+03</u>	.1000E+01
17	93.6	.1559E+03	.0000E+00	.1559E+03	.1000E+01
18	91.0	.1180E+03	.0000E+00	.1180E+03	.1000E+01
19	87.8	.9873E+02	.0000E+00	.9873E+02	.1000E+01
20	84.7	.8605E+02	.0000E+00	.8605E+02	.1000E+01
21	82.1	.7614E+02	.0000E+00	.7614E+02	.1000E+01
22	79.7	.6774E+02	.0000E+00	.6774E+02	.1000E+01
23	77.8	.6037E+02	.0000E+00	.6037E+02	.1000E+01
24	76.3	.5384E+02	.0000E+00	.5384E+02	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 7 *****

NPN= 0,NPD= 3,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 750.0,QOTLN= .0
QOTLD= .0,QFLN= .2,QFLD= .7
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

****DATA FOR TRANSFER FUNCTION COEFFICIENTS****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR ROOM 7 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.8986E+03	.0000E+00	.8986E+03	.1000E+01
2	73.9	.8725E+03	.0000E+00	.8725E+03	.1000E+01
3	73.0	.8493E+03	.0000E+00	.8493E+03	.1000E+01
4	72.2	.8285E+03	.0000E+00	.8285E+03	.1000E+01
5	72.0	.8099E+03	.0000E+00	.8099E+03	.1000E+01
6	72.5	.7934E+03	.0000E+00	.7934E+03	.1000E+01
7	73.7	.7786E+03	.0000E+00	.7786E+03	.1000E+01
8	75.8	.3305E+04	.6000E+03	.3905E+04	.8463E+00
9	79.0	.3526E+04	.6000E+03	.4126E+04	.8546E+00
10	82.6	.3642E+04	.6000E+03	.4242E+04	.8586E+00
11	86.6	.3722E+04	.6000E+03	.4322E+04	.8612E+00
12	90.5	.3786E+04	.6000E+03	.4386E+04	.8632E+00
13	93.4	.3840E+04	.6000E+03	.4440E+04	.8649E+00
14	95.3	.3888E+04	.6000E+03	.4488E+04	.8663E+00
15	96.0	.3931E+04	.6000E+03	.4531E+04	.8676E+00
16	95.3	.3969E+04	.6000E+03	<u>.4569E+04</u>	.8687E+00
17	93.6	.1464E+04	.0000E+00	.1464E+04	.1000E+01
18	91.0	.1261E+04	.0000E+00	.1261E+04	.1000E+01
19	87.8	.1161E+04	.0000E+00	.1161E+04	.1000E+01
20	84.7	.1096E+04	.0000E+00	.1096E+04	.1000E+01
21	82.1	.1045E+04	.0000E+00	.1045E+04	.1000E+01
22	79.7	.1002E+04	.0000E+00	.1002E+04	.1000E+01
23	77.8	.9649E+03	.0000E+00	.9649E+03	.1000E+01
24	76.3	.9316E+03	.0000E+00	.9316E+03	.1000E+01

noble center
cooling loads, zone e

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2836E+04	.0000E+00	.2836E+04	.1000E+01
2	73.9	.2559E+04	.0000E+00	.2559E+04	.1000E+01
3	73.0	.2307E+04	.0000E+00	.2307E+04	.1000E+01
4	72.2	.2082E+04	.0000E+00	.2082E+04	.1000E+01
5	72.0	.1897E+04	.0000E+00	.1897E+04	.1000E+01
6	72.5	.1768E+04	.0000E+00	.1768E+04	.1000E+01
7	73.7	.2512E+04	.0000E+00	.2512E+04	.1000E+01
8	75.8	.1306E+05	.2000E+04	.1506E+05	.8672E+00
9	79.0	.1466E+05	.2000E+04	.1666E+05	.8800E+00
10	82.6	.1577E+05	.2000E+04	.1777E+05	.8874E+00
11	86.6	.1670E+05	.2000E+04	.1870E+05	.8931E+00
12	90.5	.1748E+05	.2000E+04	.1948E+05	.8973E+00
13	93.4	.1807E+05	.2000E+04	.2007E+05	.9004E+00
14	95.3	.1847E+05	.2000E+04	.2047E+05	.9023E+00
15	96.0	.1866E+05	.2000E+04	.2066E+05	.9032E+00
16	95.3	.1865E+05	.2000E+04	.2065E+05	.9032E+00
17	93.6	.8403E+04	.0000E+00	.8403E+04	.1000E+01
18	91.0	.7014E+04	.0000E+00	.7014E+04	.1000E+01
19	87.8	.5510E+04	.0000E+00	.5510E+04	.1000E+01
20	84.7	.4791E+04	.0000E+00	.4791E+04	.1000E+01
21	82.1	.4282E+04	.0000E+00	.4282E+04	.1000E+01
22	79.7	.3850E+04	.0000E+00	.3850E+04	.1000E+01
23	77.8	.3472E+04	.0000E+00	.3472E+04	.1000E+01
24	76.3	.3143E+04	.0000E+00	.3143E+04	.1000E+01

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTIMD= 5.0 THTIMN= 20.0 NCOIL = 1

noble center
cooling loads, zone e

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THRMOSTAT SETTING

ROOM AIR TEMPS 1-24HRS THERMOSTAT SETTING 78.0 F AT 5.HRS 78.0 F AT 20.HRS

1	77.3	4	77.2	7	77.2	10	78.7	13	78.9	16	79.0	19	77.5	22	77.3
2	77.2	5	77.2	8	78.5	11	78.8	14	79.0	17	77.8	20	77.4	23	77.3
3	77.2	6	77.2	9	78.6	12	78.9	15	79.0	18	77.6	21	77.4	24	77.3

HEAT EXTRACTION RATES 1-24 HRS ERMIN= .000000 ERMAX= 21000. ENCRE= 1000. BTU/HOUR

1	2672.	4	1952.	7	2451.	10	18113.	13	20379.	16	20880.	19	5287.	22	3657.
2	2406.	5	1779.	8	15453.	11	19035.	14	20756.	17	8174.	20	4577.	23	3289.
3	2165.	6	1664.	9	17024.	12	19802.	15	20915.	18	6804.	21	4079.	24	2970.

CFMT =	200.0	CFMM =	70.0	ETAF =	.500
PB =	14.6960	MEX =	0	DPOR =	2.000
ETAFR =	.5000	NSF =	0	DPQS =	2.000
ETAFS =	.5000				

* FAYE MCBUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone e

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 20915. AT 15 HOURS WITH A SENSIBLE HEAT FACTOR OF .904

OUTDOOR AIR= 70. CFM AT 14.696 PSIA AND 96.0 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 305. CFM AT 14.696 PSIA AND
54.7 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 720. CFM AT 54.7 DEG F DRY BULB --- 52.1 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 752. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 82.6 DEG F

ENTERING WET BULB TEMP= 64.4 DEG F

LEAVING DRY BULB TEMP= 54.7 DEG F

LEAVING WET BULB TEMP= 52.1 DEG F

ENTERING AIR QUANTITY= 759. CFM

COIL SENSIBLE HEAT FACTOR= .862

TOTAL COIL CAPACITY= 26396. BTUH

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone f

***** GENERAL INPUT DATA *****

IB= 3,MC= 2,NRMS= 3,WO= .0136,IA= 0,NPRT= 0,INWRIT= 1,XLAT= 36.0
ACLONG= 97.0,STLONG= 90.0,TROOM= 78.0,TMAXIM= 96.0 TRANGE= 24.0
TIH= 72.0 TOH= 13.0

NM= 8,NHTX= 1,TWBO= 74.00,IHEAT= 0
NDDM= 21,NITR= 10,TWBI= 62.00,WO= .0136,PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS

IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 1 *****

west

WRL= 13.00 WRW= 9.00 AD= .00 AW= .00 PSI= 270.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 1 *****

north

WRL= 13.00 WRW= 10.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0,NPD= 0,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
WTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone f

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4323E+03	.0000E+00	.4323E+03	.1000E+01
2	73.9	.4321E+03	.0000E+00	.4321E+03	.1000E+01
3	73.0	.4297E+03	.0000E+00	.4297E+03	.1000E+01
4	72.2	.4253E+03	.0000E+00	.4253E+03	.1000E+01
5	72.0	.4190E+03	.0000E+00	.4190E+03	.1000E+01
6	72.5	.4109E+03	.0000E+00	.4109E+03	.1000E+01
7	73.7	.4013E+03	.0000E+00	.4013E+03	.1000E+01
8	75.8	.7810E+03	.0000E+00	.7810E+03	.1000E+01
9	79.0	.8185E+03	.0000E+00	.8185E+03	.1000E+01
10	82.6	.8337E+03	.0000E+00	.8337E+03	.1000E+01
11	86.6	.8409E+03	.0000E+00	.8409E+03	.1000E+01
12	90.5	.8450E+03	.0000E+00	.8450E+03	.1000E+01
13	93.4	.8480E+03	.0000E+00	.8480E+03	.1000E+01
14	95.3	.8510E+03	.0000E+00	.8510E+03	.1000E+01
15	96.0	.8547E+03	.0000E+00	.8547E+03	.1000E+01
16	95.3	.8598E+03	.0000E+00	<u>.8598E+03</u>	.1000E+01
17	93.6	.4764E+03	.0000E+00	.4764E+03	.1000E+01
18	91.0	.4369E+03	.0000E+00	.4369E+03	.1000E+01
19	87.8	.4222E+03	.0000E+00	.4222E+03	.1000E+01
20	84.7	.4185E+03	.0000E+00	.4185E+03	.1000E+01
21	82.1	.4204E+03	.0000E+00	.4204E+03	.1000E+01
22	79.7	.4248E+03	.0000E+00	.4248E+03	.1000E+01
23	77.8	.4296E+03	.0000E+00	.4296E+03	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 2 *****

north wall

WRL= 10.00 WRW= 20.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= 1.00 UWRA= .1170 UW= 1.0800 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 2 *****

north wall

WRL= 3.00 WRW= 20.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0690 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 2 *****

NPN= 0,NPD= 2,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .8
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCED= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone f

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.6140E+03	.0000E+00	.6140E+03	.1000E+01
2	73.9	.5563E+03	.0000E+00	.5563E+03	.1000E+01
3	73.0	.5010E+03	.0000E+00	.5010E+03	.1000E+01
4	72.2	.4482E+03	.0000E+00	.4482E+03	.1000E+01
5	72.0	.3983E+03	.0000E+00	.3983E+03	.1000E+01
6	72.5	.3520E+03	.0000E+00	.3520E+03	.1000E+01
7	73.7	.3136E+03	.0000E+00	.3136E+03	.1000E+01
8	75.8	.2774E+04	.4000E+03	.3174E+04	.8740E+00
9	79.0	.3040E+04	.4000E+03	.3440E+04	.8837E+00
10	82.6	.3190E+04	.4000E+03	.3590E+04	.8886E+00
11	86.6	.3304E+04	.4000E+03	.3704E+04	.8920E+00
12	90.5	.3407E+04	.4000E+03	.3807E+04	.8949E+00
13	93.4	.3505E+04	.4000E+03	.3905E+04	.8976E+00
14	95.3	.3599E+04	.4000E+03	.3999E+04	.9000E+00
15	96.0	.3687E+04	.4000E+03	.4087E+04	.9021E+00
16	95.3	.3767E+04	.4000E+03	.4167E+04	.9040E+00
17	93.6	.1355E+04	.0000E+00	.1355E+04	.1000E+01
18	91.0	.1130E+04	.0000E+00	.1130E+04	.1000E+01
19	87.8	.1021E+04	.0000E+00	.1021E+04	.1000E+01
20	84.7	.9372E+03	.0000E+00	.9372E+03	.1000E+01
21	82.1	.8683E+03	.0000E+00	.8683E+03	.1000E+01
22	79.7	.8037E+03	.0000E+00	.8037E+03	.1000E+01
23	77.8	.7401E+03	.0000E+00	.7401E+03	.1000E+01
24	76.3	.6778E+03	.0000E+00	.6778E+03	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 3 *****

north wall

WRL= 10.00 WRW= 40.00 AD= .00 AW= 260.00 PSI= 180.00
EPSILN= 90.00 SCG= .51 UWRH= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

north wall

WRL= 3.00 WRW= 40.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= .51 UWRH= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 0,NPD= 6,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= 3.3
QTLN= .0,QTLD= .0,OFST= 7.0,OFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 1

noble center
cooling loads, zone f

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2094E+04	.0000E+00	.2094E+04	.1000E+01
2	73.9	.1757E+04	.0000E+00	.1757E+04	.1000E+01
3	73.0	.1452E+04	.0000E+00	.1452E+04	.1000E+01
4	72.2	.1183E+04	.0000E+00	.1183E+04	.1000E+01
5	72.0	.9671E+03	.0000E+00	.9671E+03	.1000E+01
6	72.5	.8258E+03	.0000E+00	.8258E+03	.1000E+01
7	73.7	.1847E+04	.0000E+00	.1847E+04	.1000E+01
8	75.8	.1208E+05	.1200E+04	.1328E+05	.9097E+00
9	79.0	.1394E+05	.1200E+04	.1514E+05	.9207E+00
10	82.6	.1528E+05	.1200E+04	.1648E+05	.9272E+00
11	86.6	.1643E+05	.1200E+04	.1763E+05	.9319E+00
12	90.5	.1739E+05	.1200E+04	.1859E+05	.9355E+00
13	93.4	.1812E+05	.1200E+04	.1932E+05	.9379E+00
14	95.3	.1859E+05	.1200E+04	.1979E+05	.9394E+00
15	96.0	.1878E+05	.1200E+04	<u>.1998E+05</u>	.9399E+00
16	95.3	.1871E+05	.1200E+04	.1991E+05	.9397E+00
17	93.6	.8857E+04	.0000E+00	.8857E+04	.1000E+01
18	91.0	.7260E+04	.0000E+00	.7260E+04	.1000E+01
19	87.8	.5372E+04	.0000E+00	.5372E+04	.1000E+01
20	84.7	.4485E+04	.0000E+00	.4485E+04	.1000E+01
21	82.1	.3859E+04	.0000E+00	.3859E+04	.1000E+01
22	79.7	.3328E+04	.0000E+00	.3328E+04	.1000E+01
23	77.8	.2864E+04	.0000E+00	.2864E+04	.1000E+01
24	76.3	.2460E+04	.0000E+00	.2460E+04	.1000E+01

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone f

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3140E+04	.0000E+00	.3140E+04	.1000E+01
2	73.9	.2745E+04	.0000E+00	.2745E+04	.1000E+01
3	73.0	.2383E+04	.0000E+00	.2383E+04	.1000E+01
4	72.2	.2057E+04	.0000E+00	.2057E+04	.1000E+01
5	72.0	.1784E+04	.0000E+00	.1784E+04	.1000E+01
6	72.5	.1589E+04	.0000E+00	.1589E+04	.1000E+01
7	73.7	.2562E+04	.0000E+00	.2562E+04	.1000E+01
8	75.8	.1564E+05	.1600E+04	.1724E+05	.9072E+00
9	79.0	.1780E+05	.1600E+04	.1940E+05	.9175E+00
10	82.6	.1930E+05	.1600E+04	.2090E+05	.9234E+00
11	86.6	.2058E+05	.1600E+04	.2218E+05	.9278E+00
12	90.5	.2165E+05	.1600E+04	.2325E+05	.9312E+00
13	93.4	.2247E+05	.1600E+04	.2407E+05	.9335E+00
14	95.3	.2304E+05	.1600E+04	.2464E+05	.9351E+00
15	96.0	.2332E+05	.1600E+04	.2492E+05	.9358E+00
16	95.3	.2334E+05	.1600E+04	.2494E+05	.9358E+00
17	93.6	.1069E+05	.0000E+00	.1069E+05	.1000E+01
18	91.0	.8827E+04	.0000E+00	.8827E+04	.1000E+01
19	87.8	.6815E+04	.0000E+00	.6815E+04	.1000E+01
20	84.7	.5840E+04	.0000E+00	.5840E+04	.1000E+01
21	82.1	.5148E+04	.0000E+00	.5148E+04	.1000E+01
22	79.7	.4556E+04	.0000E+00	.4556E+04	.1000E+01
23	77.8	.4033E+04	.0000E+00	.4033E+04	.1000E+01
24	76.3	.3571E+04	.0000E+00	.3571E+04	.1000E+01

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTIND= 5.0 THTIMN= 20.0 NCOIL = 1

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone f

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THERMOSTAT SETTING

ROOM AIR TEMPS 1-24HRS	THERMOSTAT SETTING	78.0 F AT 5.HRS	78.0 F AT 20.HRS
1 77.2 4 77.2	7 77.2	10 78.6 13 78.9	16 78.9 19 77.5 22 77.3
2 77.2 5 77.1	8 78.4	11 78.7 14 78.9	17 77.8 20 77.4 23 77.3
3 77.2 6 77.1	9 78.5	12 78.8 15 78.9	18 77.7 21 77.4 24 77.3

HEAT EXTRACTION RATES 1-24 HRS	ERMIN=	.000000	ERMAX=	26000.	ENCRE=	1000.	BTU/HOUR
1 2992. 4 1959. 7 2557. 10 21303. 13 24399. 16 25154. 19 6553. 22 4358.							
2 2614. 5 1704. 8 17758. 11 22553. 14 24930. 17 10365. 20 5603. 23 3852.							
3 2269. 6 1526. 9 19841. 12 23601. 15 25173. 18 8566. 21 4932. 24 3408.							

CFHT =	160.0	CFHM =	40.0	ETAF =	.500
PB =	14.6960	MEI =	0	DPOR =	2.000
ETAFR =	.5000	NSF =	0	DPDS =	2.000
ETAFS =	.5000				

noble center
cooling loads, zone f

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 25173. AT 15 HOURS WITH A SENSIBLE HEAT FACTOR OF .936

OUTDOOR AIR= 40. CFM AT 14.696 PSIA AND 96.0 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 259. CFM AT 14.696 PSIA AND
55.0 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 909. CFM AT 55.0 DEG F DRY BULB --- 52.6 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 950. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 81.7 DEG F
ENTERING WET BULB TEMP= 63.7 DEG F
LEAVING DRY BULB TEMP= 55.0 DEG F
LEAVING WET BULB TEMP= 52.6 DEG F
ENTERING AIR QUANTITY= 956. CFM
COIL SENSIBLE HEAT FACTOR= .919
TOTAL COIL CAPACITY= 29883. BTUH

noble center
cooling load, zone q

***** GENERAL INPUT DATA *****

IB= 3,MC= 2,NRMS= 3,WO= .0136,IA= 0,NPRT= 0,INWRIT= 1,XLAT= 36.0
ACLONG= 97.0,STLONG= 90.0,TROOM= 78.0,TMAXIM= 96.0 TRANGE= 24.0
TIH= 72.0 TOH= 13.0

NM= 8,NHTX= 1, TWBD= 74.00, IHEAT= 0
NDDM= 21,NITR= 10,TWBI= 65.00,WO= .0136, PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
75.1	73.9	73.0	72.2	72.0	72.5	73.7	75.8	79.0	82.6	86.6	90.5	93.4	95.3	96.0	95.3	93.6	91.0	87.8	84.7	82.1	79.7	77.8	76.3

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 1 *****

west wall

WRL= 13.00 WRW= 40.00 AD= .00 AW= 104.00 PSI= 270.00
EPSILN= 90.00 SCG= .51 UWRA= .0610 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 1,NPD= 125,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= 2.2
QTLN= .0,QTLD= .4,OFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 1,ICNDT= 1,ILGHT= 1,IDCEQ= 1,IAIR= 1

noble center
cooling load, zone q

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	73.1	.2238E+04	.2000E+03	.2438E+04	.9180E+00
2	73.9	.2002E+04	.2000E+03	.2202E+04	.9092E+00
3	73.0	.1795E+04	.2000E+03	.1995E+04	.8997E+00
4	72.2	.1614E+04	.2000E+03	.1814E+04	.8897E+00
5	72.0	.1465E+04	.2000E+03	.1665E+04	.8799E+00
6	72.5	.1356E+04	.2000E+03	.1556E+04	.8714E+00
7	73.7	.1623E+04	.2000E+03	.1823E+04	.8903E+00
8	75.8	.3443E+05	.2500E+05	.5943E+05	.5794E+00
9	79.0	.3824E+05	.2500E+05	.6324E+05	.6047E+00
10	82.6	.4019E+05	.2500E+05	.6519E+05	.6165E+00
11	86.6	.4133E+05	.2500E+05	.6633E+05	.6231E+00
12	90.5	.4210E+05	.2500E+05	.6710E+05	.6274E+00
13	93.4	.4311E+05	.2500E+05	.6811E+05	.6329E+00
14	95.3	.4566E+05	.2500E+05	.7066E+05	.6462E+00
15	96.0	.4829E+05	.2500E+05	.7329E+05	.6589E+00
16	95.3	.5012E+05	.2500E+05	<u>.7512E+05</u>	.6672E+00
17	93.6	.1817E+05	.2000E+03	.1837E+05	.9891E+00
18	91.0	.1285E+05	.2000E+03	.1305E+05	.9847E+00
19	87.8	.6513E+04	.2000E+03	.6713E+04	.9702E+00
20	84.7	.4641E+04	.2000E+03	.4841E+04	.9587E+00
21	82.1	.3765E+04	.2000E+03	.3965E+04	.9496E+00
22	79.7	.3225E+04	.2000E+03	.3425E+04	.9416E+00
23	77.8	.2830E+04	.2000E+03	.3030E+04	.9340E+00
24	76.3	.2514E+04	.2000E+03	.2714E+04	.9263E+00

***** GENERAL INPUT DATA FOR ROOM # 2 *****

NPN= 0,NPD= 8,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 300.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .0
QTLN= .0,QTLD= .0,OFST= 7.0,OFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling load, zone q

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.9657E+02	.0000E+00	.9657E+02	.1000E+01
2	73.9	.8644E+02	.0000E+00	.8644E+02	.1000E+01
3	73.0	.7737E+02	.0000E+00	.7737E+02	.1000E+01
4	72.2	.6926E+02	.0000E+00	.6926E+02	.1000E+01
5	72.0	.6200E+02	.0000E+00	.6200E+02	.1000E+01
6	72.5	.5550E+02	.0000E+00	.5550E+02	.1000E+01
7	73.7	.4968E+02	.0000E+00	.4968E+02	.1000E+01
8	75.8	.1907E+04	.1600E+04	.3507E+04	.5438E+00
9	79.0	.2003E+04	.1600E+04	.3603E+04	.5559E+00
10	82.6	.2050E+04	.1600E+04	.3650E+04	.5616E+00
11	86.6	.2081E+04	.1600E+04	.3681E+04	.5653E+00
12	90.5	.2105E+04	.1600E+04	.3705E+04	.5682E+00
13	93.4	.2126E+04	.1600E+04	.3726E+04	.5706E+00
14	95.3	.2144E+04	.1600E+04	.3744E+04	.5727E+00
15	96.0	.2161E+04	.1600E+04	.3761E+04	.5746E+00
16	95.3	.2175E+04	.1600E+04	.3775E+04	.5762E+00
17	93.6	.3260E+03	.0000E+00	.3260E+03	.1000E+01
18	91.0	.2372E+03	.0000E+00	.2372E+03	.1000E+01
19	87.8	.1964E+03	.0000E+00	.1964E+03	.1000E+01
20	84.7	.1711E+03	.0000E+00	.1711E+03	.1000E+01
21	82.1	.1518E+03	.0000E+00	.1518E+03	.1000E+01
22	79.7	.1354E+03	.0000E+00	.1354E+03	.1000E+01
23	77.8	.1211E+03	.0000E+00	.1211E+03	.1000E+01
24	76.3	.1084E+03	.0000E+00	.1084E+03	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

west wall

WRL= 25.00 WRW= 20.00 AD= .00 AW= 52.00 PSI= 270.00
EPSILN= 90.00 SCG= .51 UWRW= .0610 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

south wall

WRL= 18.00 WRW= 20.00 AD= .00 AW= 360.00 PSI= .00
EPSILN= 90.00 SCG= .51 UWRW= .0610 UW= .5200 UD= .5500 ISHAD= 1
SHADE TYPE= 1 GLASS WIDTH= 10.0

GLASS HEIGHT= 18.0 OVERHANG DEPTH= 24.0
OVERHANG RISE= .0 OVERHANG EXT, LEFT= .0
OVERHANG EXT, RIGHT= 1000.0 OVERHANG END PROJ= 18.0
LEFT FIN DEPTH= .0 LEFT FIN EXT, TOP= .0
LEFT FIN OFFSET= .0 LEFT FIN EXT, BOTM= .0
GHT FIN DEPTH= 24.0 RGHT FIN EXT, TOP= .0
RGHT FIN OFFSET= .0 RGHT FIN EXT, BOTM= .0

1	.0000	4	.0000	7	.0000	10	.6456	13	.0000	16	.0000	19	.0000	22	.0000
2	.0000	5	.0000	8	.8678	11	.8659	14	.0000	17	.0000	20	.0000	23	.0000
3	.0000	6	.0000	9	.7815	12	.8510	15	.0000	18	.0000	21	.0000	24	.0000

***** INPUT DATA FOR SURFACE # 3 OF ROOM # 3 *****

south roof

WRL= 24.40 WRW= 30.00 AD= .00 AW= .00 PSI= .00
EPSILN= 35.00 SCG= .51 UWRW= .0840 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QDTSN= 300.0,QDTS= 300.0,QDTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .0
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 7,ICNDT= 2,ILGHT= 3,IOCEQ= 3,IAIR= 5

noble center
cooling load, zone q

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3348E+04	.0000E+00	.3348E+04	.1000E+01
2	73.9	.2817E+04	.0000E+00	.2817E+04	.1000E+01
3	73.0	.2335E+04	.0000E+00	.2335E+04	.1000E+01
4	72.2	.1908E+04	.0000E+00	.1908E+04	.1000E+01
5	72.0	.1565E+04	.0000E+00	.1565E+04	.1000E+01
6	72.5	.1346E+04	.0000E+00	.1346E+04	.1000E+01
7	73.7	.2535E+04	.0000E+00	.2535E+04	.1000E+01
8	75.8	.4906E+04	.2000E+03	.5106E+04	.9608E+00
9	79.0	.8570E+04	.2000E+03	.8770E+04	.9772E+00
10	82.6	.1255E+05	.2000E+03	.1275E+05	.9843E+00
11	86.6	.1776E+05	.2000E+03	.1796E+05	.9889E+00
12	90.5	.2134E+05	.2000E+03	.2154E+05	.9907E+00
13	93.4	.1778E+05	.2000E+03	.1798E+05	.9889E+00
14	95.3	.1789E+05	.2000E+03	.1809E+05	.9889E+00
15	96.0	.1817E+05	.2000E+03	<u>.1837E+05</u>	.9891E+00
16	95.3	.1768E+05	.2000E+03	.1788E+05	.9888E+00
17	93.6	.1597E+05	.0000E+00	.1597E+05	.1000E+01
18	91.0	.1301E+05	.0000E+00	.1301E+05	.1000E+01
19	87.8	.8942E+04	.0000E+00	.8942E+04	.1000E+01
20	84.7	.7205E+04	.0000E+00	.7205E+04	.1000E+01
21	82.1	.6153E+04	.0000E+00	.6153E+04	.1000E+01
22	79.7	.5297E+04	.0000E+00	.5297E+04	.1000E+01
23	77.8	.4557E+04	.0000E+00	.4557E+04	.1000E+01
24	76.3	.3919E+04	.0000E+00	.3919E+04	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

noble center
cooling load, zone q

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.5683E+04	.2000E+03	.5883E+04	.9660E+00
2	73.9	.4905E+04	.2000E+03	.5105E+04	.9608E+00
3	73.0	.4207E+04	.2000E+03	.4407E+04	.9546E+00
4	72.2	.3591E+04	.2000E+03	.3791E+04	.9472E+00
5	72.0	.3092E+04	.2000E+03	.3292E+04	.9393E+00
6	72.5	.2757E+04	.2000E+03	.2957E+04	.9324E+00
7	73.7	.4208E+04	.2000E+03	.4408E+04	.9546E+00
8	75.8	.4125E+05	.2680E+05	.6805E+05	.6062E+00
9	79.0	.4881E+05	.2680E+05	.7561E+05	.6456E+00
10	82.6	.5479E+05	.2680E+05	.8159E+05	.6715E+00
11	86.6	.6116E+05	.2680E+05	.8796E+05	.6953E+00
12	90.5	.6555E+05	.2680E+05	.9235E+05	.7098E+00
13	93.4	.6301E+05	.2680E+05	.8981E+05	.7016E+00
14	95.3	.6569E+05	.2680E+05	.9249E+05	.7102E+00
15	96.0	.6862E+05	.2680E+05	.9542E+05	.7191E+00
16	95.3	.6997E+05	.2680E+05	.9677E+05	.7231E+00
17	93.6	.3447E+05	.2000E+03	.3467E+05	.9942E+00
18	91.0	.2610E+05	.2000E+03	.2630E+05	.9924E+00
19	87.8	.1565E+05	.2000E+03	.1585E+05	.9874E+00
20	84.7	.1202E+05	.2000E+03	.1222E+05	.9836E+00
21	82.1	.1007E+05	.2000E+03	.1027E+05	.9805E+00
22	79.7	.8657E+04	.2000E+03	.8857E+04	.9774E+00
23	77.8	.7507E+04	.2000E+03	.7707E+04	.9741E+00
24	76.3	.6541E+04	.2000E+03	.6741E+04	.9703E+00

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTIND= 5.0 THTIMN= 20.0 NCDIL = 1

noble center
cooling load, zone a

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THERMOSTAT SETTING
IF THE ROOM TEMPERATURE IS HIGH DURING THE OFFICE TIME CHOOSE A ERMAX BIGGER THAN THE PRESENT ONE

ROOM AIR TEMPS 1-24HRS THERMOSTAT SETTING 78.0 F AT 5.HRS 78.0 F AT 20.HRS

1	77.1	4	77.1	7	77.1	10	78.7	13	78.9	16	79.0	19	77.3	22	77.2
2	77.1	5	77.1	8	78.4	11	78.8	14	78.9	17	77.7	20	77.2	23	77.1
3	77.1	6	77.0	9	78.6	12	78.9	15	79.0	18	77.5	21	77.2	24	77.1

HEAT EXTRACTION RATES 1-24 HRS ERMIN= .000000 ERMAX= 98000. ENCRE= 1000. BTU/HOUR

1	4904.	4	2999.	7	3869.	10	83568.	13	91499.	16	98307.	19	14485.	22	7678.
2	4190.	5	2561.	8	70153.	11	89980.	14	94151.	17	33533.	20	10894.	23	6597.
3	3554.	6	2288.	9	77613.	12	94337.	15	97045.	18	25153.	21	9021.	24	5699.

CFMT =	2680.0	CFMM =	670.0	ETAF =	.500
FB =	14.6960	MEX =	0	DPOR =	2.000
ETAFR =	.5000	NSF =	0	DPOS =	2.000
ETAFS =	.5000				

noble center
cooling load, zone q

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 98307. AT 16 HOURS WITH A SENSIBLE HEAT FACTOR OF .727

OUTDOOR AIR= 670. CFM AT 14.696 PSIA AND 95.3 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 4419. CFM AT 14.696 PSIA AND
63.2 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 4419. CFM AT 63.2 DEG F DRY BULB --- 57.9 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 4544. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 83.6 DEG F

ENTERING WET BULB TEMP= 67.5 DEG F

LEAVING DRY BULB TEMP= 63.2 DEG F

LEAVING WET BULB TEMP= 57.9 DEG F

ENTERING AIR QUANTITY= 4592. CFM

COIL SENSIBLE HEAT FACTOR= .737

TOTAL COIL CAPACITY= 137310. BTUH

noble center
cooling load, zone h

***** GENERAL INPUT DATA *****

IB= 3,HC= 2,HRMS= 5,WD= .0136,IA= 0,NPRT= 0,INWRIT= 1,XLAT= 36.0
ACLONG= 97.0,BTLONG= 90.0,TRDOM= 78.0,TMAXIM= 96.0 TRANGE= 24.0
TIR= 72.0 TDH= 13.0

NM= 6,NHTX= 1,TWBD= 74.00,IHEAT= 0
NDOM= 21,NITR= 10,TWBI= 65.00,WD= .0136,PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.5	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.8	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .6
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling load, zone h

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2258E+03	.0000E+00	.2258E+03	.1000E+01
2	73.9	.2014E+03	.0000E+00	.2014E+03	.1000E+01
3	73.0	.1797E+03	.0000E+00	.1797E+03	.1000E+01
4	72.2	.1604E+03	.0000E+00	.1604E+03	.1000E+01
5	72.0	.1431E+03	.0000E+00	.1431E+03	.1000E+01
6	72.5	.1277E+03	.0000E+00	.1277E+03	.1000E+01
7	73.7	.1139E+03	.0000E+00	.1139E+03	.1000E+01
8	75.8	.1863E+04	.2000E+03	.2063E+04	.9030E+00
9	79.0	.2060E+04	.2000E+03	.2260E+04	.9115E+00
10	82.6	.2166E+04	.2000E+03	.2366E+04	.9155E+00
11	86.6	.2239E+04	.2000E+03	.2439E+04	.9180E+00
12	90.5	.2298E+04	.2000E+03	.2498E+04	.9199E+00
13	93.4	.2348E+04	.2000E+03	.2548E+04	.9215E+00
14	95.3	.2393E+04	.2000E+03	.2593E+04	.9229E+00
15	96.0	.2432E+04	.2000E+03	.2632E+04	.9240E+00
16	95.3	.2467E+04	.2000E+03	.2667E+04	.9250E+00
17	93.6	.7369E+03	.0000E+00	.7369E+03	.1000E+01
18	91.0	.5567E+03	.0000E+00	.5567E+03	.1000E+01
19	87.8	.4656E+03	.0000E+00	.4656E+03	.1000E+01
20	84.7	.4058E+03	.0000E+00	.4058E+03	.1000E+01
21	82.1	.3591E+03	.0000E+00	.3591E+03	.1000E+01
22	79.7	.3195E+03	.0000E+00	.3195E+03	.1000E+01
23	77.8	.2848E+03	.0000E+00	.2848E+03	.1000E+01
24	76.3	.2541E+03	.0000E+00	.2541E+03	.1000E+01

***** GENERAL INPUT DATA FOR CASE 1 *****

NPN= 0,NPD= 2,CFMN= .00,CFMD= .00
QOTGN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .8
QTLN= .0,QTLD= .0,QFST= 7.0,QFDT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCED= 2,IAIR= 5

noble center
cooling load, zone h

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2869E+03	.0000E+00	.2869E+03	.1000E+01
2	73.9	.2560E+03	.0000E+00	.2560E+03	.1000E+01
3	73.0	.2284E+03	.0000E+00	.2284E+03	.1000E+01
4	72.2	.2039E+03	.0000E+00	.2039E+03	.1000E+01
5	72.0	.1819E+03	.0000E+00	.1819E+03	.1000E+01
6	72.5	.1623E+03	.0000E+00	.1623E+03	.1000E+01
7	73.7	.1448E+03	.0000E+00	.1448E+03	.1000E+01
8	75.8	.2460E+04	.4000E+03	.2860E+04	.8601E+00
9	79.0	.2711E+04	.4000E+03	.3111E+04	.8714E+00
10	82.6	.2846E+04	.4000E+03	.3246E+04	.8768E+00
11	86.6	.2939E+04	.4000E+03	.3339E+04	.8802E+00
12	90.5	.3014E+04	.4000E+03	.3414E+04	.8828E+00
13	93.4	.3078E+04	.4000E+03	.3478E+04	.8850E+00
14	95.3	.3134E+04	.4000E+03	.3534E+04	.8868E+00
15	96.0	.3184E+04	.4000E+03	.3584E+04	.8884E+00
16	95.3	.3228E+04	.4000E+03	<u>.3628E+04</u>	.8898E+00
17	93.6	.9374E+03	.0000E+00	.9374E+03	.1000E+01
18	91.0	.7074E+03	.0000E+00	.7074E+03	.1000E+01
19	87.8	.5915E+03	.0000E+00	.5915E+03	.1000E+01
20	84.7	.5155E+03	.0000E+00	.5155E+03	.1000E+01
21	82.1	.4563E+03	.0000E+00	.4563E+03	.1000E+01
22	79.7	.4060E+03	.0000E+00	.4060E+03	.1000E+01
23	77.8	.3619E+03	.0000E+00	.3619E+03	.1000E+01
24	76.3	.3228E+03	.0000E+00	.3228E+03	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** INPUT DATA FOR SURFACE 4.4 OF ROOM # 7 *****

east wall

WRL= 15.00 WRW= 20.00 AD= .00 AW= 104.00 PSI= 90.00
EPSILN= 90.00 SCG= .51 UWRA= .0610 LW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 0,NPD= 4,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 50.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .7
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEB= 2,IAIR= 5

noble center
cooling load, zone h

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1280E+04	.0000E+00	.1280E+04	.1000E+01
2	73.9	.1149E+04	.0000E+00	.1149E+04	.1000E+01
3	73.0	.1032E+04	.0000E+00	.1032E+04	.1000E+01
4	72.2	.9272E+03	.0000E+00	.9272E+03	.1000E+01
5	72.0	.8421E+03	.0000E+00	.8421E+03	.1000E+01
6	72.5	.7865E+03	.0000E+00	.7865E+03	.1000E+01
7	73.7	.4856E+04	.0000E+00	.4856E+04	.1000E+01
8	75.8	.1018E+05	.8000E+03	.1098E+05	.9271E+00
9	79.0	.1127E+05	.8000E+03	<u>.1207E+05</u>	.9337E+00
10	82.6	.1092E+05	.8000E+03	.1172E+05	.9317E+00
11	86.6	.9498E+04	.8000E+03	.1030E+05	.9223E+00
12	90.5	.7657E+04	.8000E+03	.8457E+04	.9054E+00
13	93.4	.7036E+04	.8000E+03	.7836E+04	.8979E+00
14	95.3	.6896E+04	.8000E+03	.7696E+04	.8961E+00
15	96.0	.6809E+04	.8000E+03	.7609E+04	.8949E+00
16	95.3	.6646E+04	.8000E+03	<u>.7446E+04</u>	.8926E+00
17	93.6	.3766E+04	.0000E+00	.3766E+04	.1000E+01
18	91.0	.3114E+04	.0000E+00	.3114E+04	.1000E+01
19	87.8	.2509E+04	.0000E+00	.2509E+04	.1000E+01
20	84.7	.2196E+04	.0000E+00	.2196E+04	.1000E+01
21	82.1	.1961E+04	.0000E+00	.1961E+04	.1000E+01
22	79.7	.1757E+04	.0000E+00	.1757E+04	.1000E+01
23	77.8	.1578E+04	.0000E+00	.1578E+04	.1000E+01
24	76.3	.1423E+04	.0000E+00	.1423E+04	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** GENERAL INPUT DATA FOR ROOM # 4 *****

NPH= 0,NPD= 2,CPMH= .00,CPMD= .00
QOTSH= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .0
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IQCEG= .2,IAIR= 5

noble center
cooling load, zone h

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2099E+02	.0000E+00	.2099E+02	.1000E+01
2	73.9	.1879E+02	.0000E+00	.1879E+02	.1000E+01
3	73.0	.1682E+02	.0000E+00	.1682E+02	.1000E+01
4	72.2	.1506E+02	.0000E+00	.1506E+02	.1000E+01
5	72.0	.1348E+02	.0000E+00	.1348E+02	.1000E+01
6	72.5	.1206E+02	.0000E+00	.1206E+02	.1000E+01
7	73.7	.1080E+02	.0000E+00	.1080E+02	.1000E+01
8	75.8	.4146E+03	.4000E+03	.8146E+03	.5089E+00
9	79.0	.4354E+03	.4000E+03	.8354E+03	.5212E+00
10	82.6	.4457E+03	.4000E+03	.8457E+03	.5270E+00
11	86.6	.4524E+03	.4000E+03	.8524E+03	.5307E+00
12	90.5	.4577E+03	.4000E+03	.8577E+03	.5336E+00
13	93.4	.4622E+03	.4000E+03	.8622E+03	.5361E+00
14	95.3	.4662E+03	.4000E+03	.8662E+03	.5382E+00
15	96.0	.4698E+03	.4000E+03	.8698E+03	.5401E+00
16	95.3	.4729E+03	.4000E+03	<u>.8729E+03</u>	.5418E+00
17	93.5	.7087E+02	.0000E+00	.7087E+02	.1000E+01
18	91.0	.5158E+02	.0000E+00	.5158E+02	.1000E+01
19	87.9	.4269E+02	.0000E+00	.4269E+02	.1000E+01
20	84.7	.3719E+02	.0000E+00	.3719E+02	.1000E+01
21	82.1	.3299E+02	.0000E+00	.3299E+02	.1000E+01
22	79.7	.2944E+02	.0000E+00	.2944E+02	.1000E+01
23	77.8	.2633E+02	.0000E+00	.2633E+02	.1000E+01
24	76.3	.2356E+02	.0000E+00	.2356E+02	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 5 *****

east wall

WRL= 25.00 WRW= 20.00 AD= .00 AW= 25.00 PSI= 90.00
EPSILN= 90.00 SCG= .51 UWRA= .0610 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 5 *****

south wall

WRL= 18.00 WRW= 20.00 AD= .00 AW= 360.00 PSI= .00
EPSILN= 90.00 SCG= .51 UWRA= .0610 UW= .5200 UD= .5500 ISHAD= 1

SHADE TYPE= 1 GLASS WIDTH= 10.0
GLASS HEIGHT= 18.0 OVERHANG DEPTH= 24.0
OVERHANG RISE= .0 OVERHANG EXT, LEFT= .0
OVERHANG EXT, RIGHT= .0 OVERHANG END PROJ= 18.0
LEFT FIN DEPTH= 24.0 LEFT FIN EXT, TOP= .0
LEFT FIN OFFSET= .0 LEFT FIN EXT, BOTM= .0
RHT FIN DEPTH= .0 RIGHT FIN EXT, TOP= .0
RIGHT FIN OFFSET= .0 RIGHT FIN EXT, BOTM= .0

1	.0000	4	.0000	7	.0000	10	.0000	13	.8520	16	.7680	19	.0000	22	.0000
2	.0000	5	.0000	8	.0000	11	.4790	14	.8670	17	.8725	20	.0000	23	.0000
3	.0000	6	.0000	9	.0000	12	.7322	15	.8570	18	.0000	21	.0000	24	.0000

***** INPUT DATA FOR SURFACE # 3 OF ROOM # 5 *****

south roof

WRL= 24.40 WRW= 30.00 AD= .00 AW= .00 PSI= .00
EPSILN= 35.00 SCG= .51 UWRA= .0840 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 5 *****

NPN= 0,NPD= 2,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
QTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 7,ICNDT= 2,ILGHT= 3,IGCEQ= 3,IAIR= 5

noble center
cooling load, zone h

TOTAL COOLING LOAD FOR ROOM 5 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3148E+04	.0000E+00	.3148E+04	.1000E+01
2	73.9	.2621E+04	.0000E+00	.2621E+04	.1000E+01
3	73.0	.2141E+04	.0000E+00	.2141E+04	.1000E+01
4	72.2	.1715E+04	.0000E+00	.1715E+04	.1000E+01
5	72.0	.1370E+04	.0000E+00	.1370E+04	.1000E+01
6	72.5	.1144E+04	.0000E+00	.1144E+04	.1000E+01
7	73.7	.3038E+04	.0000E+00	.3038E+04	.1000E+01
8	75.8	.6175E+04	.4000E+03	.6575E+04	.9392E+00
9	79.0	.8704E+04	.4000E+03	.9104E+04	.9561E+00
10	82.6	.1093E+05	.4000E+03	.1133E+05	.9647E+00
11	86.6	.1551E+05	.4000E+03	.1591E+05	.9749E+00
12	90.5	.1982E+05	.4000E+03	.2022E+05	.9802E+00
13	93.4	.2260E+05	.4000E+03	.2300E+05	.9826E+00
14	95.3	.2299E+05	.4000E+03	<u>.2339E+05</u>	.9829E+00
15	96.0	.2055E+05	.4000E+03	.2095E+05	.9809E+00
16	95.3	.1783E+05	.4000E+03	.1823E+05	.9781E+00
17	93.6	.1387E+05	.0000E+00	.1387E+05	.1000E+01
18	91.0	.1091E+05	.0000E+00	.1091E+05	.1000E+01
19	87.8	.8246E+04	.0000E+00	.8246E+04	.1000E+01
20	84.7	.6840E+04	.0000E+00	.6840E+04	.1000E+01
21	82.1	.5887E+04	.0000E+00	.5887E+04	.1000E+01
22	79.7	.5067E+04	.0000E+00	.5067E+04	.1000E+01
23	77.8	.4343E+04	.0000E+00	.4343E+04	.1000E+01
24	76.3	.3714E+04	.0000E+00	.3714E+04	.1000E+01

noble center
cooling load, zone h

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4961E+04	.0000E+00	.4961E+04	.1000E+01
2	73.9	.4246E+04	.0000E+00	.4246E+04	.1000E+01
3	73.0	.3597E+04	.0000E+00	.3597E+04	.1000E+01
4	72.2	.3021E+04	.0000E+00	.3021E+04	.1000E+01
5	72.0	.2550E+04	.0000E+00	.2550E+04	.1000E+01
6	72.5	.2232E+04	.0000E+00	.2232E+04	.1000E+01
7	73.7	.8163E+04	.0000E+00	.8163E+04	.1000E+01
8	75.8	.2109E+05	.2200E+04	.2329E+05	.9055E+00
9	79.0	.2518E+05	.2200E+04	.2738E+05	.9197E+00
10	82.6	.2731E+05	.2200E+04	.2951E+05	.9254E+00
11	86.6	.3064E+05	.2200E+04	.3284E+05	.9330E+00
12	90.5	.3325E+05	.2200E+04	.3545E+05	.9379E+00
13	93.4	.3552E+05	.2200E+04	.3772E+05	.9417E+00
14	95.3	.3588E+05	.2200E+04	.3808E+05	.9422E+00
15	96.0	.3344E+05	.2200E+04	.3564E+05	.9383E+00
16	95.3	.3065E+05	.2200E+04	.3285E+05	.9330E+00
17	93.6	.1939E+05	.0000E+00	.1939E+05	.1000E+01
18	91.0	.1534E+05	.0000E+00	.1534E+05	.1000E+01
19	87.8	.1186E+05	.0000E+00	.1186E+05	.1000E+01
20	84.7	.9995E+04	.0000E+00	.9995E+04	.1000E+01
21	82.1	.8697E+04	.0000E+00	.8697E+04	.1000E+01
22	79.7	.7579E+04	.0000E+00	.7579E+04	.1000E+01
23	77.8	.6595E+04	.0000E+00	.6595E+04	.1000E+01
24	76.3	.5737E+04	.0000E+00	.5737E+04	.1000E+01

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTIMD= 5.0 THTIMN= 20.0 NCOIL = 1

noble center
cooling load, zone h

ZONE AIR TEMPERATURES AND HEAT EXTRACTION RATES

THE MAXIMUM CAPACITY IS CHOSEN ON THE BASIS OF MAXIMUM LOAD OCCURING DUE TO THE THERMOSTAT SETTING
IF THE ROOM TEMPERATURE IS HIGH DURING THE OFFICE TIME CHOOSE A ERMAX BIGGER THAN THE PRESENT ONE

ROOM AIR TEMPS 1-24HRS THERMOSTAT SETTING 78.0 F AT 5.HRS 78.0 F AT 20.HRS

1	77.2	4	77.1	7	77.4	10	78.6	13	79.0	16	78.7	19	77.6	22	77.3
2	77.2	5	77.1	8	78.3	11	78.8	14	79.0	17	78.0	20	77.5	23	77.3
3	77.1	6	77.1	9	78.5	12	78.9	15	78.9	18	77.7	21	77.4	24	77.2

HEAT EXTRACTION RATES 1-24 HRS ERMIN= .000000 ERMAX= 39000. ENCRE= 1000. BTU/HOUR

1	3938.	4	2103.	7	8086.	10	31153.	13	39645.	16	33761.	19	10817.	22	6497.
2	3253.	5	1680.	8	24814.	11	34650.	14	39837.	17	18790.	20	8914.	23	5524.
3	2639.	6	1421.	9	29037.	12	37329.	15	36956.	18	14518.	21	7613.	24	4688.

CFMT =	220.0	CFMM =	55.0	ETAF =	.500
PB =	14.6760	MEX =	0	DPOR =	2.000
ETAFR=	.5000	NSF =	0	DPOS =	2.000
ETAFB=	.5000				

noble center
cooling load, zone h

SUMMARY OF AIR QUANTITY AND COIL CALCULATIONS

TOTAL ZONE LOAD= 39637. AT 14 HOURS WITH A SENSIBLE HEAT FACTOR OF .945

OUTDOOR AIR= 55. CFM AT 14.696 PSIA AND 95.3 DEG F-- ASHRAE STD 62-81 SUPPLY AIR= 362. CFM AT 14.696 PSIA AND
61.5 DEG F WITH FILTER EFF= .50

SUPPLY AIR= 2051. CFM AT 61.5 DEG F DRY BULB --- 59.0 DEG F WET BULB AND 14.696 PSIA

THE RETURN AIR FAN TOTAL PRESSURE IS 2.00 IN. WAT. WITH TOTAL EFFICIENCY OF .50 AND 2116. CFM

THE SUPPLY AIR FAN IS BLOW-THRU WITH TOTAL PRESSURE OF 2.00 IN. WAT. AND TOTAL EFFICIENCY OF .50

THE COIL HAS THE FOLLOWING CHARACTERISTICS: ENTERING DRY BULB TEMP= 81.4 DEG F
ENTERING WET BULB TEMP= 66.3 DEG F
LEAVING DRY BULB TEMP= 61.5 DEG F
LEAVING WET BULB TEMP= 59.0 DEG F
ENTERING AIR QUANTITY= 2130. CFM
COIL SENSIBLE HEAT FACTOR= .959
TOTAL COIL CAPACITY= 48306. BTUH

noble center
cooling loads, zone i

***** GENERAL INPUT DATA *****

IE= 3,MC= 2,NRMS= 6,WO= .0136,IA= 0,NPRT= 0,INWRIT= 1,XLAT= 36.0
ACLONG= 97.0,STLONG= 90.0,TROOM= 78.0,TMAXIM= 96.0 TRANGE= 24.0
TIH= 72.0 TDH= 13.0

NM= 8,NHTX= 1,TWBO= 74.00,IHEAT= 0
NDDM= 21,NITR= 10,TWBI= 62.00,WO= .0136,PB= 14.696

OUT DOOR TEMPERATURES 1-24HRS IN F

1	75.1	4	72.2	7	73.7	10	82.6	13	93.4	16	95.3	19	87.8	22	79.7
2	73.9	5	72.0	8	75.8	11	86.6	14	95.3	17	93.6	20	84.7	23	77.8
3	73.0	6	72.5	9	79.0	12	90.5	15	96.0	18	91.0	21	82.1	24	76.3

***** GENERAL INPUT DATA FOR ROOM # 1 *****

NPN= 0,NPD= 3,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .9
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling loads, zone i

TOTAL COOLING LOAD FOR ROOM 1 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.3586E+03	.0000E+00	.3586E+03	.1000E+01
2	73.9	.3200E+03	.0000E+00	.3200E+03	.1000E+01
3	73.0	.2856E+03	.0000E+00	.2856E+03	.1000E+01
4	72.2	.2548E+03	.0000E+00	.2548E+03	.1000E+01
5	72.0	.2274E+03	.0000E+00	.2274E+03	.1000E+01
6	72.5	.2029E+03	.0000E+00	.2029E+03	.1000E+01
7	73.7	.1811E+03	.0000E+00	.1811E+03	.1000E+01
8	75.8	.3138E+04	.6000E+03	.3738E+04	.8395E+00
9	79.0	.3453E+04	.6000E+03	.4053E+04	.8519E+00
10	82.6	.3621E+04	.6000E+03	.4221E+04	.8579E+00
11	86.6	.3738E+04	.6000E+03	.4338E+04	.8617E+00
12	90.5	.3831E+04	.6000E+03	.4431E+04	.8646E+00
13	93.4	.3911E+04	.6000E+03	.4511E+04	.8670E+00
14	95.3	.3981E+04	.6000E+03	.4581E+04	.8690E+00
15	96.0	.4043E+04	.6000E+03	.4643E+04	.8708E+00
16	95.3	.4099E+04	.6000E+03	<u>.4699E+04</u>	.8723E+00
17	93.6	.1172E+04	.0000E+00	.1172E+04	.1000E+01
18	91.0	.8842E+03	.0000E+00	.8842E+03	.1000E+01
19	87.8	.7391E+03	.0000E+00	.7391E+03	.1000E+01
20	84.7	.6442E+03	.0000E+00	.6442E+03	.1000E+01
21	82.1	.5702E+03	.0000E+00	.5702E+03	.1000E+01
22	79.7	.5074E+03	.0000E+00	.5074E+03	.1000E+01
23	77.8	.4523E+03	.0000E+00	.4523E+03	.1000E+01
24	76.3	.4035E+03	.0000E+00	.4035E+03	.1000E+01

***** INPUT DATA FOR SURFACE # 1 OF ROOM # 2 *****

north wall

WRL= 10.00 WRW= 30.00 AD= .00 AW= 195.00 PSI= 180.00
EPSILN= 90.00 SC6= .51 UWRA= .1170 UW= .5200 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 2 *****

north wall

WRL= 3.00 WRW= 30.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SC6= .51 UWRA= .0690 UW= .5200 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 2 *****

NPN= 0,NPD= 3,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .5
QTLN= .0,QTLD= .0,DFST= 7.0,DFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 1

noble center
cooling loads, zone i

TOTAL COOLING LOAD FOR ROOM 2 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.8771E+03	.0000E+00	.8771E+03	.1000E+01
2	73.9	.6990E+03	.0000E+00	.6990E+03	.1000E+01
3	73.0	.5376E+03	.0000E+00	.5376E+03	.1000E+01
4	72.2	.3953E+03	.0000E+00	.3953E+03	.1000E+01
5	72.0	.2861E+03	.0000E+00	.2861E+03	.1000E+01
6	72.5	.2275E+03	.0000E+00	.2275E+03	.1000E+01
7	73.7	.1036E+04	.0000E+00	.1036E+04	.1000E+01
8	75.8	.3542E+04	.6000E+03	.4142E+04	.8551E+00
9	79.0	.4330E+04	.6000E+03	.4930E+04	.8783E+00
10	82.6	.5008E+04	.6000E+03	.5608E+04	.8930E+00
11	86.6	.5648E+04	.6000E+03	.6248E+04	.9040E+00
12	90.5	.6191E+04	.6000E+03	.6791E+04	.9116E+00
13	93.4	.6580E+04	.6000E+03	.7180E+04	.9164E+00
14	95.3	.6795E+04	.6000E+03	.7395E+04	.9189E+00
15	96.0	.6816E+04	.6000E+03	<u>.7416E+04</u>	.9191E+00
16	95.3	.6661E+04	.6000E+03	.7261E+04	.9174E+00
17	93.6	.4382E+04	.0000E+00	.4382E+04	.1000E+01
18	91.0	.3736E+04	.0000E+00	.3736E+04	.1000E+01
19	87.8	.2599E+04	.0000E+00	.2599E+04	.1000E+01
20	84.7	.2117E+04	.0000E+00	.2117E+04	.1000E+01
21	82.1	.1792E+04	.0000E+00	.1792E+04	.1000E+01
22	79.7	.1515E+04	.0000E+00	.1515E+04	.1000E+01
23	77.8	.1273E+04	.0000E+00	.1273E+04	.1000E+01
24	76.3	.1065E+04	.0000E+00	.1065E+04	.1000E+01

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

north

WRL= 13.00 WRW= 10.00 AD= .00 AW= .00 PSI= 180.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** INPUT DATA FOR SURFACE # 2 OF ROOM # 3 *****

north

WRL= 13.00 WRW= 9.00 AD= .00 AW= .00 PSI= 90.00
EPSILN= 90.00 SCG= 1.00 UWRA= .0930 UW= 1.0800 UD= .5500 ISHAD= 0

***** GENERAL INPUT DATA FOR ROOM # 3 *****

NPN= 0,NPD= 0,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .1
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

noble center
cooling loads, zone i

TOTAL COOLING LOAD FOR ROOM 3 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.4308E+03	.0000E+00	.4308E+03	.1000E+01
2	73.9	.4254E+03	.0000E+00	.4254E+03	.1000E+01
3	73.0	.4187E+03	.0000E+00	.4187E+03	.1000E+01
4	72.2	.4108E+03	.0000E+00	.4108E+03	.1000E+01
5	72.0	.4016E+03	.0000E+00	.4016E+03	.1000E+01
6	72.5	.3913E+03	.0000E+00	.3913E+03	.1000E+01
7	73.7	.3799E+03	.0000E+00	.3799E+03	.1000E+01
8	75.8	.7583E+03	.0000E+00	.7583E+03	.1000E+01
9	79.0	.7950E+03	.0000E+00	.7950E+03	.1000E+01
10	82.6	.8105E+03	.0000E+00	.8105E+03	.1000E+01
11	86.6	.8198E+03	.0000E+00	.8198E+03	.1000E+01
12	90.5	.8284E+03	.0000E+00	.8284E+03	.1000E+01
13	93.4	.8383E+03	.0000E+00	.8383E+03	.1000E+01
14	95.3	.8500E+03	.0000E+00	.8500E+03	.1000E+01
15	96.0	.8630E+03	.0000E+00	.8630E+03	.1000E+01
16	95.3	.8771E+03	.0000E+00	<u>.8771E+03</u>	.1000E+01
17	93.6	.5010E+03	.0000E+00	.5010E+03	.1000E+01
18	91.0	.4663E+03	.0000E+00	.4663E+03	.1000E+01
19	87.8	.4532E+03	.0000E+00	.4532E+03	.1000E+01
20	84.7	.4476E+03	.0000E+00	.4476E+03	.1000E+01
21	82.1	.4448E+03	.0000E+00	.4448E+03	.1000E+01
22	79.7	.4429E+03	.0000E+00	.4429E+03	.1000E+01
23	77.8	.4407E+03	.0000E+00	.4407E+03	.1000E+01
24	76.3	.4377E+03	.0000E+00	.4377E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 4 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 175.0,QOTLN= .0
QOTLD= .0,QFLN= .2,QFLD= .4
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= -2,IAIR= 5

noble center
cooling loads, zone 1

TOTAL COOLING LOAD FOR ROOM 4 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.7578E+03	.0000E+00	.7578E+03	.1000E+01
2	73.9	.7468E+03	.0000E+00	.7468E+03	.1000E+01
3	73.0	.7370E+03	.0000E+00	.7370E+03	.1000E+01
4	72.2	.7282E+03	.0000E+00	.7282E+03	.1000E+01
5	72.0	.7204E+03	.0000E+00	.7204E+03	.1000E+01
6	72.5	.7134E+03	.0000E+00	.7134E+03	.1000E+01
7	73.7	.7071E+03	.0000E+00	.7071E+03	.1000E+01
8	75.8	.1677E+04	.2000E+03	.1877E+04	.8935E+00
9	79.0	.1771E+04	.2000E+03	.1971E+04	.8985E+00
10	82.6	.1821E+04	.2000E+03	.2021E+04	.9010E+00
11	86.6	.1855E+04	.2000E+03	.2055E+04	.9027E+00
12	90.5	.1882E+04	.2000E+03	.2082E+04	.9039E+00
13	93.4	.1905E+04	.2000E+03	.2105E+04	.9050E+00
14	95.3	.1926E+04	.2000E+03	.2126E+04	.9059E+00
15	96.0	.1944E+04	.2000E+03	.2144E+04	.9067E+00
16	95.3	.1961E+04	.2000E+03	<u>.2161E+04</u>	.9074E+00
17	93.6	.9994E+03	.0000E+00	.9994E+03	.1000E+01
18	91.0	.9139E+03	.0000E+00	.9139E+03	.1000E+01
19	87.8	.8713E+03	.0000E+00	.8713E+03	.1000E+01
20	84.7	.8435E+03	.0000E+00	.8435E+03	.1000E+01
21	82.1	.8219E+03	.0000E+00	.8219E+03	.1000E+01
22	79.7	.8036E+03	.0000E+00	.8036E+03	.1000E+01
23	77.8	.7876E+03	.0000E+00	.7876E+03	.1000E+01
24	76.3	.7733E+03	.0000E+00	.7733E+03	.1000E+01

***** GENERAL INPUT DATA FOR ROOM # 5 *****

NPN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= .0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .3
QTLN= .0,QTLD= .0,QFST= 7.0,QFCT= 16.0

*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****

ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone 1

TOTAL COOLING LOAD FOR ROOM 5 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1301E+03	.0000E+00	.1301E+03	.1000E+01
2	73.9	.1161E+03	.0000E+00	.1161E+03	.1000E+01
3	73.0	.1036E+03	.0000E+00	.1036E+03	.1000E+01
4	72.2	.9244E+02	.0000E+00	.9244E+02	.1000E+01
5	72.0	.8249E+02	.0000E+00	.8249E+02	.1000E+01
6	72.5	.7361E+02	.0000E+00	.7361E+02	.1000E+01
7	73.7	.6569E+02	.0000E+00	.6569E+02	.1000E+01
8	75.8	.1127E+04	.2000E+03	.1327E+04	.8493E+00
9	79.0	.1241E+04	.2000E+03	.1441E+04	.8612E+00
10	82.6	.1302E+04	.2000E+03	.1502E+04	.8669E+00
11	86.6	.1345E+04	.2000E+03	.1545E+04	.8705E+00
12	90.5	.1378E+04	.2000E+03	.1578E+04	.8733E+00
13	93.4	.1407E+04	.2000E+03	.1607E+04	.8756E+00
14	95.3	.1433E+04	.2000E+03	.1633E+04	.8775E+00
15	96.0	.1455E+04	.2000E+03	.1655E+04	.8792E+00
16	95.3	.1476E+04	.2000E+03	<u>.1676E+04</u>	.8806E+00
17	93.6	.4252E+03	.0000E+00	.4252E+03	.1000E+01
18	91.0	.3207E+03	.0000E+00	.3207E+03	.1000E+01
19	87.8	.2682E+03	.0000E+00	.2682E+03	.1000E+01
20	84.7	.2337E+03	.0000E+00	.2337E+03	.1000E+01
21	82.1	.2069E+03	.0000E+00	.2069E+03	.1000E+01
22	79.7	.1841E+03	.0000E+00	.1841E+03	.1000E+01
23	77.0	.1621E+03	.0000E+00	.1621E+03	.1000E+01

24 76.3 .1464E+03 .0000E+00 .1464E+03 .1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

***** GENERAL INPUT DATA FOR ROOM # 6 *****

NFN= 0,NPD= 1,CFMN= .00,CFMD= .00
QOTSN= .0,QOTSD= 175.0,QOTLN= .0
QOTLD= .0,QFLN= .0,QFLD= .4
QTLN= 0,QILD= 0,QEST= 7.0,QEQT= 16.0
*****DATA FOR TRANSFER FUNCTION COEFFICIENTS*****
ISOLAR= 2,ICNDT= 2,ILGHT= 2,IOCEQ= 2,IAIR= 5

* FAYE McQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone 1

TOTAL COOLING LOAD FOR ROOM 6 (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.1614E+03	.0000E+00	.1614E+03	.1000E+01
2	73.9	.1440E+03	.0000E+00	.1440E+03	.1000E+01
3	73.0	.1285E+03	.0000E+00	.1285E+03	.1000E+01
4	72.2	.1147E+03	.0000E+00	.1147E+03	.1000E+01
5	72.0	.1024E+03	.0000E+00	.1024E+03	.1000E+01
6	72.5	.9135E+02	.0000E+00	.9135E+02	.1000E+01
7	73.7	.8152E+02	.0000E+00	.8152E+02	.1000E+01
8	75.8	.1456E+04	.2000E+03	.1656E+04	.8792E+00
9	79.0	.1598E+04	.2000E+03	.1798E+04	.8888E+00
10	82.6	.1674E+04	.2000E+03	.1874E+04	.8933E+00
11	86.6	.1727E+04	.2000E+03	.1927E+04	.8962E+00
12	90.5	.1768E+04	.2000E+03	.1968E+04	.8984E+00
13	93.4	.1804E+04	.2000E+03	.2004E+04	.9002E+00
14	95.3	.1836E+04	.2000E+03	.2036E+04	.9018E+00
15	96.0	.1864E+04	.2000E+03	.2064E+04	.9031E+00
16	95.3	.1889E+04	.2000E+03	<u>.2089E+04</u>	.9043E+00
17	93.6	.5279E+03	.0000E+00	.5279E+03	.1000E+01
18	91.0	.3978E+03	.0000E+00	.3978E+03	.1000E+01
19	87.8	.3325E+03	.0000E+00	.3325E+03	.1000E+01
20	84.7	.2898E+03	.0000E+00	.2898E+03	.1000E+01
21	82.1	.2565E+03	.0000E+00	.2565E+03	.1000E+01
22	79.7	.2282E+03	.0000E+00	.2282E+03	.1000E+01
23	77.8	.2035E+03	.0000E+00	.2035E+03	.1000E+01

THE INSIDE DESIGN TEMPR.= 78.0 MONTH= 8 DAY= 21

* FAYE MCQUISTON, P.E., OKLAHOMA STATE UNIVERSITY *

noble center
cooling loads, zone i

TOTAL COOLING LOAD FOR THE ZONE (BTU/HR)

TIME	TOUTDOOR	SENSIBLE	LATENT	TOTAL	SHF
1	75.1	.2716E+04	.0000E+00	.2716E+04	.1000E+01
2	73.9	.2451E+04	.0000E+00	.2451E+04	.1000E+01
3	73.0	.2211E+04	.0000E+00	.2211E+04	.1000E+01
4	72.2	.1996E+04	.0000E+00	.1996E+04	.1000E+01
5	72.0	.1820E+04	.0000E+00	.1820E+04	.1000E+01
6	72.5	.1700E+04	.0000E+00	.1700E+04	.1000E+01
7	73.7	.2451E+04	.0000E+00	.2451E+04	.1000E+01
8	75.8	.1170E+05	.1800E+04	.1350E+05	.8666E+00
9	79.0	.1319E+05	.1800E+04	.1499E+05	.8799E+00
10	82.6	.1424E+05	.1800E+04	.1604E+05	.8878E+00
11	86.6	.1513E+05	.1800E+04	.1693E+05	.8937E+00
12	90.5	.1588E+05	.1800E+04	.1768E+05	.8982E+00
13	93.4	.1645E+05	.1800E+04	.1825E+05	.9013E+00
14	95.3	.1682E+05	.1800E+04	.1862E+05	.9033E+00
15	96.0	.1699E+05	.1800E+04	.1879E+05	.9042E+00
16	95.3	.1696E+05	.1800E+04	.1876E+05	.9041E+00
17	93.6	.8008E+04	.0000E+00	.8008E+04	.1000E+01
18	91.0	.6718E+04	.0000E+00	.6718E+04	.1000E+01
19	87.8	.5263E+04	.0000E+00	.5263E+04	.1000E+01
20	84.7	.4576E+04	.0000E+00	.4576E+04	.1000E+01
21	82.1	.4092E+04	.0000E+00	.4092E+04	.1000E+01
22	79.7	.3681E+04	.0000E+00	.3681E+04	.1000E+01
23	77.8	.3321E+04	.0000E+00	.3321E+04	.1000E+01

ERMAX = .0 ERMIN = .0 ENCRE = 1000.0
THRANG= 2.0 THSETD= 78.0 THSETN= 78.0
THTIND= 5.0 THTIMN= 20.0 NCDIL = 1