

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION

By

ANDREW JAMES WILSON

Bachelor of Science
University of Missouri - Rolla
Rolla, Missouri
1974

Master of Science
University of Missouri - Columbia
Columbia, Missouri
1979


Submitted to the Faculty of the Graduate College
of the Oklahoma State University
in partial fulfillment of the requirements
for the Degree of
DOCTOR OF PHILOSOPHY
December, 1983

Thesis
1983D
W746d
Cop. 2




DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION


Thesis Approved:




Thesis Adviser




Gary L. Fentch



Robert Heiderberg



J. B. Chandler



Dean of the Graduate College

© Copyright

by

Andrew James Wilson

December, 1983

PREFACE

This study was performed to meet a need in the field of ion exchange demineralization. The development of a demineralization system simulation should aid system operators and designers in achieving optimum results or designs. The study also serves as a basis for further work by adding other design options or incorporating theoretical based models of resin performance.

I would like to express my appreciation to Dr. Jan Wagner, my major adviser, for his assistance and guidance. I am also grateful to my other committee members, Dr. G. L. Foutch, Dr. Robert H. Heidersbach, Jr., and Dr. John P. Chandler for their contributions. I would also acknowledge my appreciation for the guidance of the late Dr. John Harold Erber who also served as my major adviser. The financial assistance of the Water Research Institute of Oklahoma State University in the form of the Presidential Fellowship in Water Resources is gratefully acknowledged. I would like to express my thanks to Mrs. Sharon Phillips for her professional work in typing the manuscript and final copy.

I reserve special thanks for my wife, Priscilla, whose sacrifices, labor, and encouragement allowed my undertaking and completing this work.

TABLE OF CONTENTS

Chapter	Page
I. INTRODUCTION.	1
II. LITERATURE REVIEW	4
General Process Description.	4
Ion Exchange Process.	4
Ion Exchange Resin Types.	6
System Configurations	7
Resin Properties and Behavior.	10
General Resin Behavior.	10
Strong Acid Cation Resin.	11
Strong Base Anion Resin	18
Weak Base Anion Resin	24
System Design Considerations	26
Overall System Design	26
Vessel Design	27
Other Design Options.	30
III. PERFORMANCE SIMULATION PROGRAM.	32
General Features	32
Overall Program Logic.	33
Subroutine Descriptions.	34
WATCON.	34
DECON	36
CRESIN.	36
DHCRS	36
ARESIN.	39
DSBRP	39
DWGR2	42
CREGN	43
AREGN	44
MASBAL.	45
Interpolation Functions	45
Program Options.	45
IV. PROGRAM VERIFICATION AND RESULTS.	47
Comparison of Calculated Resin Ratings With Literature Estimates	47
Comparison of Design Performances.	51

LIST OF TABLES

Table	Page
I. Some Physical and Chemical Properties of Dowex HCR-S . . .	12
II. Recommended Operating Conditions for Dowex HCR-S	12
III. Some Representative Capacities and Average Sodium Leakages for Dowex HCR-S	13
IV. Bed Depth Capacity Correction Factors.	14
V. Capacity Correction Factors for Service Flow Rates on a 30 Inch Bed.	15
VI. Expansion Characteristics of Dowex HCR-S	16
VII. Recommended Concentrations of Sulfuric Acid.	17
VIII. Recommended Regenerant Flow Rates.	17
IX. Some Physical and Chemical Properties of Dowex SBR-P . . .	19
X. Recommended Operating Conditions for Dowex SBR-P	19
XI. Some Representative Capacities and Average Silica Leak- ages for Dowex SBR-P	20
XII. Silica Leakage Correction Factors for Various Operating Temperatures	21
XIII. Silica Leakage Correction Factors for Sodium Leakage . . .	22
XIV. Capacity Correction Factor for Chlorides	22
XV. Capacity Correction Factor for Silica Rise to End Point.	23
XVI. Expansion Characteristics of Dowex SBR-P	23
XVII. Some Physical and Chemical Properties of Dowex WGR-2 . . .	24
XVIII. Recommended Operating Conditions for Dowex WGR-2	25
XIX. Capacity of Dowex WGR-2.	25

Table	Page
XX. Expansion Characteristics of Dowex WGR-2	26
XXI. Comparison of Calculated and Literature Resin Ratings for Dowex HCR-S or Equivalent.	48
XXII. Comparison of Calculated and Literature Resin Ratings for Dowex SBR-P or Equivalent.	49
XXIII. Comparison of Calculated and Literature Resin Ratings for Dowex WGR-2 or Equivalent.	50
XXIV. Comparison With Six Bed Demineralizer Performance Re- ported by Webb and Carr.	52
XXV. Comparison With Three Bed Demineralizer Performance Reported by Webb and Carr.	52
XXVI. Comparison With Case 1 Demineralizer Design Proposed by Applebaum	53
XXVII. Dowex HCR-S Sodium Leakage Rating Data	68
XXVIII. Dowex HCR-S Capacity Rating Data	69
XXIX. Dowex SBR-P Silica Leakage Rating Data	72
XXX. Dowex SBR-P Capacity Rating Data	73
XXXI. Dowex HCR-S Sodium Leakage Correlation Coefficients. . .	78
XXXII. Dowex HCR-S Capacity Correlation Coefficients.	79

LIST OF FIGURES

Figure	Page
1. Demineralizer Arrangement With Degasifier Following Primary Cation Exchanger	8
2. Demineralizer Arrangement With Degasifier Following Primary Exchangers	9
3. Typical Demineralization System Process Diagram	28
4. Typical Exchanger Vessel Design	29
5. Program Organization	35

CHAPTER I

INTRODUCTION

Demineralization of water by means of synthetic ion exchange resins is a widely used industrial process (15). The process gained acceptance in the late nineteen forties and early nineteen fifties as resin manufacturers were able to produce ion exchange resins having high capacity and stability characteristics (1). Demineralization of water involves the removal of objectionable dissolved solids such as silica and salts of calcium, magnesium, and sodium by hydrogen or hydroxide exchange. Cation resins exchange hydrogen ions for calcium, magnesium, sodium, and other cations. Anion resins exchange hydroxide ions for sulfates, chlorides, and other anions as well as carbon dioxide and silica. These ion exchange processes are reversible. Exhausted resin exchange capacity is restored by regeneration. Regeneration is accomplished by an acid solution for cation resins or an alkali solution for anion resins. Systems employing a series of vessels containing fixed beds of either a single resin type or a mixture of cation and anion resins are the most common method of accomplishing demineralization. Water is demineralized until the exchange capacity of one or more of the beds is exhausted. The exhausted bed is removed from service, regenerated, and returned to service. Other systems using continuous regeneration, moving beds, or stirred tanks are also utilized.

The design of fixed bed ion exchange demineralization systems for industrial use is not, in practice, a precise science. The complex behavior of the ion exchange resins, the variations in operating conditions from site to site, and the variety of design options available to the design engineer make comprehensive evaluation and rigorous design development impractical. To simplify the design process, resin manufacturers have provided tables and charts which allow the designer to estimate resin behavior in his specific application. The use of these charts bypasses determination of behavior by a more rigorous approach based upon chemical equilibria and kinetic theory. Applebaum (1) has documented the general approach taken in design of industrial demineralization systems. Although this approach greatly simplifies design, complete evaluation of the design options is not always possible because of the time consuming nature of the computations.

Ideally, the design of ion exchange demineralization systems should be based upon chemical equilibria and kinetic theory and the optimum choice of design options. If this is to be accomplished in a practical manner, computer calculation of the system performance is required. Modeling of the resin equilibria and kinetic behavior has been accomplished by a number of investigators (2, 13, 24, 28). However, computer modeling of ion exchange demineralization systems compatible with industrial practice has not been effectively accomplished.

The purpose of this study was to develop a computer program patterned after industrial practice for ion exchange demineralizer design. This program is designed to facilitate the evaluation of the various options available to the system designer. The scope of this work was to develop a computer program which will simulate system

performance given the design conditions. The program will form a basis for further work to incorporate the theoretical models of chemical equilibria and behavior.

The program is limited to considering systems having up to nine vessels in series (including forced draft or vacuum degasifiers) and nine vessels in parallel. Resin selection is limited to the strong acid cation resin Dowex HCR-S, the strong base anion resin Dowex SBR-P, and the weak base resin Dowex WGR-2. Fixed beds of only a single resin type are considered. Only sulfuric acid and sodium hydroxide are considered as regenerant chemicals and only downflow regeneration are considered. Future work will allow the incorporation of other resin types, consideration of mixed beds of cation and anion resins, other regenerant chemicals, and upflow regeneration. However, the program in its initial form will facilitate evaluation of a large percentage of the most common demineralization system designs.

CHAPTER II




LITERATURE REVIEW

General Process Description

Ion Exchange Process

The history of the development of ion exchange as an industrial process is discussed by a number of authors, including Kunin (18) and Applebaum (1). The terms "demineralization" and "deionization" have come into common useage to distinguish the removal of dissolved solids from water by means of ion exchange from the removal by means of distillation or evaporation (23).






The process of cation exchange may be illustrated by the following reactions (25):



where R refers to an exchange site on a resin particle. These reactions are reversible, and the exhausted cation exchange resin is converted back to the hydrogen form by means of acids such as sulfuric or hydrochloric acid. The cation exchange process also neutralizes any

alkalinity present in the water, converting hydroxide into water and carbonate and bicarbonate into carbon dioxide.

Similarly, the anion exchange process may be described by the following reactions (25):



where R refers to an exchange site on a resin particle. The exhausted resin may be converted back to hydroxide form by means of an alkali such as sodium hydroxide.

The conversion of exhausted resin back to hydrogen or hydroxide forms is called "regeneration," and the general steps to regenerate exhausted resin capacity are as follows. The resin bed is first backwashed to remove debris and broken resin beads or fines. The regenerant chemical is applied to the resin in sufficient quantity and contact time to achieve the desired resin operating performance. The regenerant is displaced from the resin by water. This step is termed the "displacement" or "slow rinse." This takes place at the same flow rate as the regenerant was applied. The resin is then rinsed at the service flow rate until acceptable water purity is obtained. This step is termed the "final" or "fast rinse." Following this step, the bed is placed back in service.

Ion Exchange Resin Types

The ion exchange resins most commonly employed in demineralization consist of beads of polystyrene of varying degrees of crosslinkage. Crosslinking is controlled by the amount of divinyl/benzene added to the polymer. Depending upon the type of resin, ionic groups are substituted on the resulting polymer matrix to form the active sites for ion exchange to take place. The functionality of the substituted ionic group determines the resin type. The capacity and kinetics of the resin are controlled by the bead size, degree of crosslinkage, and the number of exchange sites. For some applications, acrylic polymer resins are being utilized, particularly where organic removal is required.

In general, there are four basic resin types: strong acid cation resins having a sulfonic acid functionality, weak acid cation resins having a carboxylic acid functionality, strong base anion resins having a quaternary amine functionality, and weak base anion resins having generally a mixture of primary, secondary, and tertiary amine functionalities (3, 17). There are other types of resins and functional groups; however, the four described are the most common.

Lists of available resins from domestic and foreign manufacturers can be found in a variety of sources (1, 16, 17, 18). Product descriptions and performance information for specific resins are available from the resin manufacturer. In this study, weak acid resins will not be considered, as they have very limited use in water treatment (3). In general, the resins of a given type exhibit relatively the same performance characteristics regardless of the manufacturer. Therefore,

in this study, the resins of one manufacturer will be used to represent the three relevant resin types. The strong acid cation resin will be Dowex HCR-S. The strong base anion resin will be Dowex SBR-P. The weak base anion resin will be Dowex WGR-2. These resins are manufactured by the Dow Chemical Company.

System Configurations

There are a variety of ways to configure a demineralization system. Marks (20) identifies 10 major system configurations. These 10 configurations do not represent all of the current designs utilized. The simplest demineralization systems consist of a single mixed bed exchanger vessel or a cation exchanger vessel followed by an anion exchanger vessel. The more complex configurations may use as many as six vessels in series, three pairs of cation and anion exchange vessels, and also include either a forced draft or vacuum degasifier (29). In addition, vessel size considerations may dictate the use of parallel vessels. No single arrangement of cation and anion vessels can be used universally.

Two typical demineralizer configurations are shown in Figures 1 and 2. In Figure 1, the system has a primary anion exchanger using strong base type resin, following a degasifier. This design is appropriate for a raw water having a relatively low percentage of strong base or mineral ions (i.e., sulfates, chlorides, and nitrates) compared to weak base ions (i.e., alkalinity, carbon dioxide, and silica). The degasifier reduces the carbon dioxide load to the strong base exchange resin allowing the use of a smaller vessel, less resin, and less regenerant chemical consumption. In Figure 2, the primary anion




Figure 1. Demineralizer Arrangement With Degasifier Following Primary Cation Exchanger




Figure 2. Demineralizer Arrangement With Degasifier Following Primary Exchangers

exchanger uses a weak base type resin. This design is most effective for a raw water containing a relatively high percentage of strong base ions. As carbon dioxide is not removed by the weak base resins being displaced from the exchange sites by the strong base ions, the degasifier may be located downstream. This location of the degasifier is preferred for corrosion considerations. In both systems, polishing cation and anion vessels are provided to reduce ion leakage to the purity levels required by the application. This comparison illustrates the considerations required to determine the optimum vessel configuration for a given application and the need for the numerous variations of system designs which are employed.

Resin Properties and Behavior

General Resin Behavior

Resin behavior is influenced by a great number of variables. The significant behavior characteristics for demineralization are the resin operating capacity, meaning the relative number of sites available for ion exchange, and the resin ion leakage, meaning the amount of impurities passing through or released by the resin. As mentioned previously, the resin particle size, crosslinkage, and ultimate capacity influence the operating capacity and leakage. Other factors which are significant include: operating characteristics such as system flow rate and dissolved solids composition, and regeneration characteristics such as the amount and flow rate of regenerant, and the method of regenerant application. Operating and regeneration temperature may also affect performance.

In order to minimize the number of variables which the system designer must optimize, the resin manufacturer has established specific operating conditions or ranges. This also insures the validity of the manufacturer's performance data for a given resin. Examples of manufacturer specified parameters include minimum and maximum system and regeneration flow rates, rinse rates and volumes, and regenerant application times.

Strong Acid Cation Resin

To illustrate strong acid cation resin behavior, Dowex HCR-S was selected. A summary of the physical and chemical properties of the resin is given in Table I. Table II provides a summary of the suggested operating conditions. A summary of capacity and leakage performance is provided in Table III. A more complete tabulation of capacity and leakage data is included as part of Appendix A. The order of selectivity for Dowex HCR-S is as follows: calcium, magnesium, potassium, sodium, and hydrogen in order of highest preference to lowest (6). When operating in the hydrogen cycle, sodium will be the first cation to be eluted. The service cycle is then normally terminated at or before sodium breakthrough.

Given the suggested operating conditions, the variation in capacity and leakage is negligible over the range of normal operating temperatures, 32 to 95°F (27). The capacities will vary with magnesium concentration, and should be corrected accordingly. A magnesium correction correlation developed from the data of Dow (4) is as

TABLE I
SOME PHYSICAL AND CHEMICAL PROPERTIES
OF DOWEX HCR-S (5)

	Na ⁺ Form	H ⁺ Form
Water retention capacity	44-48%	50-56%
Density, lbs/cu ft	53	50
Minimum total capacity (Kgr CaCO ₃ /cu ft)	43.5	39.0
Original sphericity	93% minimum	
Wet screen mesh	Typical %	
+16	4.1	
+20	39.8	
+30	39.8	
+35	8.6	
+40	5.2	
+50	2.3	
-50	0.2	

TABLE II
RECOMMENDED OPERATING CONDITIONS FOR
DOWEX HCR-S (5, 10)

Operating Conditions for Hydrogen Cycle	
Minimum bed depth	30 inches
Service flow rate	2-4 gpm/cu ft
Backwash bed expansion	50%
Regenerant level	Dependent upon leakage and capacity required (see Table III)
Regenerant concentration	4-10% hydrochloric acid 2-8% sulfuric acid
Regenerant flow rate	0.5-2.0 gpm/cu ft
Rinse water volume	40-100 gal/cu ft
Displacement rinse rate	Same as regenerant rate
Final rinse rate	Same as service rate

TABLE III
 SOME REPRESENTATIVE CAPACITIES AND AVERAGE SODIUM
 LEAKAGES FOR DOWEX HCR-S (4)

Regenerant Level (66°BE H ₂ SO ₄ Basis)		5.0 lb H ₂ SO ₄ /cu ft resin		10.0 lb H ₂ SO ₄ /cu ft resin	
Alkalinity %	Sodium %	Capacity* Kgr/cu ft	Na Leakage %	Capacity* Kgr/cu ft	Na Leakage %
0	20	17.7	2.15	23.9	0.5
	100	20.0	38.7	27.9	18.5
100	20	18.7	0	24.8	0
	100	24.0	0	31.0	0

*Basis 25% magnesium of non-sodium cations.

follows:

$$C_{Mg} = (m_m P_{mg} + b_m) P_{Na} + m_b P_{Mg} + b_b$$

where: C_{Mg} - capacity correction, Kgr as $CaCO_3$ /cu ft

P_{Mg} - percent magnesium of non-sodium cations

P_{Na} - percent sodium of total cations

$$m_m = -0.0003$$

$$b_m = 0.03$$

$$m_b = 0.0075$$

$$b_b = -0.75$$

Capacity corrections must also be made for bed depths other than 30 inches and for service flow rates in excess of five gallons per minute per square foot of resin. Bed depth correction factors are shown in Table IV. Correction factors for service flow rate are shown in Table V.

TABLE IV
BED DEPTH CAPACITY CORRECTION FACTORS (4)

Bed Depth inches	Correction Factor %
18	71
24	88
30	100
36	107
42	111
48	114
54	117
60	119

TABLE V
CAPACITY CORRECTION FACTORS FOR SERVICE
FLOW RATES ON A 30 INCH BED (4)

Flow Rate gpm/sq ft	Correction Factor %
5	100
20	65
50	25
100	0

After determination of the corrected capacity, the operating or throughput capacity may be determined by multiplying the corrected capacity by a throughput correction factor, F_{th} , where:

$$F_{th} = 100/(100 - \% \text{ Sodium Leakage}).$$

The backwash flow rate required varies with the required bed expansion and the water temperature. The relationship between backwash flow rate and bed expansion is given in Table VI.

Sulfuric acid is most commonly used as the regenerant chemical for cation resins because its cost is generally lower than hydrochloric acid. This study will consider only sulfuric acid as a regenerant. The use of sulfuric acid is complicated by the potential for fouling the resin with calcium sulfate where a significant percentage of the cation loading is calcium. The precipitation of calcium sulfate is minimized by gradually increasing the regenerant

concentration and increasing the regenerant flow rate. The lower concentrations of acid at the start of regeneration prevent immediate elution of calcium from the resin. Since there is a certain time delay to form precipitates in a supersaturated solution, the higher flow rates cause the solution to leave the exchanger before precipitation occurs. The recommendations of Dow regarding acid concentrations and flow rates are given in Tables VII and VIII.

TABLE VI
EXPANSION CHARACTERISTICS OF DOWEX HCR-S (5)

Backwash Flow Rate* gpm/sq ft	Bed Expansion %
0.0	0.0
2.0	10.0
4.0	21.2
6.0	34.7
8.0	49.5
10.0	64.0
12.0	79.0
14.0	93.9
14.72	100.0

*Basis 77°F, to determine flow at temperature, t;

$$F_t = F_{77} (1 + 0.008 (t - 77))$$

where: F_t , F_{77} - Flow rate at temperature t and 77°F, respectively.

TABLE VII
RECOMMENDED CONCENTRATIONS OF SULFURIC
ACID (11)

Sulfuric Acid lb/cu ft	lb/cu ft @2%	lb/cu ft @4%	lb/cu ft @6%	lb/cu ft @8%
4	2	2	-	-
6	2	2	2	-
8	2	2	2	2
10	2	2	3	3
12	2	2	4	4

TABLE VIII
RECOMMENDED REGENERANT FLOW RATES (11)

% Calcium of Total Cations as CaCO ₃	Regeneration Flow Rate gpm/cu ft
0	0.5
25	0.5
50	1.0
75	1.5
100*	2.25

*When % calcium is high, the first 2 lb/cu ft of H₂SO₄ should be at 0.5% H₂SO₄ concentration. The remainder of the acid is applied as described in Table V.

If the water being treated is sufficiently low in calcium such that calcium sulfate precipitation does not pose a problem, the regeneration flow rate can be at 0.5 gallons per minute per cubic foot of resin and the acid concentration may be eight percent. However, higher operating capacities will be achieved if acid concentrations are held below six percent.

Strong Base Anion Resin

Strong base anion resin behavior was chosen to be demonstrated by Dowex SBR-P. A summary of the physical and chemical properties of the resin are given in Table IX. Table X provides a summary of the recommended operating conditions. A summary of capacity and leakage performance is given in Table XI. A more complete tabulation of capacity and leakage data is included as part of Appendix A. The order of selectivity for Dowex SBR-P is as follows: nitrate, bisulfate, chloride, carbonic, hydroxide, in order of strongest to weakest preference (6). The weak acids of carbon dioxide and silica are eluted before any mineral acids. Silica leakage occurs first. The service cycle is normally terminated at or before silica breakthrough.

As was the case with the strong acid cation resin, the recommended operating conditions are such that temperature has a negligible effect upon capacity and leakage in the normal operating temperature range, silica excepted. Silica leakage is affected by operating temperature. Correction factors for silica leakage as a function of operating temperatures are given in Table XII. Silica leakage is also affected by the amount of sodium leakage from the upstream strong acid

TABLE IX
SOME PHYSICAL AND CHEMICAL PROPERTIES OF
DOWEX SBR-P (7)

	Cl ⁻ Form
Water retention capacity	53-60%
Density, lbs/cu ft	43
Typical total capacity Kgr CaCO ₃ /cu ft	27.3
Sphericity	90% minimum
Wet screen mesh	Typical %
+16	1.1
+20	37.4
+30	47.4
+35	10.5
+40	2.6
+50	1.0
-50	0.0

TABLE X
RECOMMENDED OPERATING CONDITIONS FOR
DOWEX SBR-P (7)

Minimum bed depth	30 inches
Service flow rate	2-4 gpm/cu ft
Backwash bed expansion	50%
Regenerant level	Dependent upon leakage and capacity required (see Table XI)
Regenerant concentration	4% sodium hydroxide
Regenerant flow rate	0.25 to 1.0 gpm/cu ft (60 to 90 minute appli- cation time recommended (1))
Regenerant temperature	Ambient to 120°F
Rinse water volume	Approx. 50 gal/cu ft
Displacement rinse rate	Same as regenerant rate
Final rinse rate	Approx 1 gpm/cu ft

TABLE XI
SOME REPRESENTATIVE CAPACITIES AND AVERAGE SILICA
LEAKAGES FOR DOWEX SBR-P (8)

Regenerant Temperature F	Regeneration Level* lb/cu ft	Capacity, Kgr CaCO ₃ /cu ft % Weak Acid of TEA**			Silica Leakage, ppm % Silica of TEA		
		20	50	80	20	50	80
75	5	13.6	14.5	15.5	0.06	0.21	0.378
	10	16.3	17.0	17.9	0.02	0.068	0.125
120	5	13.7	14.9	16.3	0.018	0.07	0.135
	10	16.6	17.5	18.5	0	0.018	0.043

*Basis 16 100% NaOH/cu ft

**TEA - Total Exchangeable Anions

cation exchanger. Silica leakage correction factors as a function of sodium leakage are given in Table XIII.

TABLE XII
SILICA LEAKAGE CORRECTION FACTORS FOR
VARIOUS OPERATING TEMPERATURES (8)

Temperature °F	Correction Factor %
50	53.6
55	58.8
60	66.4
65	77.2
70	87.6
75	100.0
80	114.4
85	129.2
90	146.4

The capacity of the resin varies as a function of the chloride concentration and the rise in silica to the service run end point. Table XIV shows the capacity correction factors for chlorides. The capacity correction factor for silica rise to end point is given in Table XV.

The backwash flow rate required to produce a desired bed expansion varies with the water temperature. The relationship between water temperature, backwash flow rate, and bed expansion is given in Table XVI.

TABLE XIII
SILICA LEAKAGE CORRECTION FACTORS FOR
SODIUM LEAKAGE (8)

Sodium Leakage ppm as CaCO ₃	Correction Factor %
0	83.2
0.4	95.2
0.6	100.0
0.8	105.6
1.2	114.8
1.6	123.6
2.0	132.0
2.4	138.0
2.8	143.2
3.2	148.0

TABLE XIV
CAPACITY CORRECTION FACTOR FOR CHLORIDES (8)

% Chloride of Total Anions	Capacity Correction Factor %
0	100.0
10	95.5
20	92.5
30	89.5
40	87.0
50	85.5
60	83.0
70	81.5
80	80.5
90	79.0
100	78.0

TABLE XV
CAPACITY CORRECTION FACTOR FOR SILICA
RISE TO END POINT (8)

Silica Rise to End Point mg/l as SiO ₂	Capacity Correction Factor %
0.0	0
0.1	91.0
0.2	94.0
0.3	95.0
0.4	96.0
0.5	97.0
0.6	98.0
0.7	98.75
0.8	99.0
0.9	99.5
1.0	100.0

TABLE XVI
EXPANSION CHARACTERISTICS OF DOWEX SBR-P (7)

Backwash Flow Rate* gpm/sq ft	Bed Expansion %
0	0
1	23.33
2	46.67
3	70.00
4	93.33

*Basis 77°F, to determine flow at temperature, t:

$$F_t = F_{77}(1 + 0.008 (t - 77))$$

where: F_t , F_{77} - Flow rate at temperature t and 77°F,
respectively.

Weak Base Anion Resin

Weak base anion resin behavior was chosen to be demonstrated by Dowex WGR-2. This resin has approximately 90 percent tertiary amine functional groups and 10 percent quaternary amine groups. A summary of the physical and chemical properties of the resin are given in Table XVII. Table XVIII provides a summary of the recommended operating conditions. A weak base resin is used primarily to remove the mineral acids found in the effluent of a cation exchanger. Weak acid anions such as those formed by the presence of dissolved carbon dioxide and silica are not generally removed by a weak base resin. The capacity of Dowex WGR-2 for sulfuric and hydrochloric acids is shown in Table XIX.

TABLE XVII
SOME PHYSICAL AND CHEMICAL PROPERTIES OF
DOWEX WGR-2 (9)

	Free Base Form
Water retention capacity	Approx. 50%
Density	43
Operating capacity at 5 lb NaOH/cu ft	
- HCl	25.0 Kgr CaCO ₃ /cu ft
- H ₂ SO ₄	30.0 Kgr CaCO ₃ /cu ft
Wet screen mesh	Typical %
+20	8
+30	65
+35	20
+40	5
+50	2
-50	0

TABLE XVIII
RECOMMENDED OPERATING CONDITIONS FOR
DOWEX WGR-2 (9)

Bed depth	30-72 inches
Service flow rate	2 gpm/cu ft
Backwash bed expansion	50%
Regenerant level	Dependent upon capacity required (see Table XIX)
Regenerant concentration	4% sodium hydroxide or ammonium hydroxide
Regenerant flow rate	0.5 gpm/cu ft
Rinse water volume	25-100 gal/cu ft ³
Displacement rinse rate	same as regenerant rate
Final rinse rate	1 gpm/cu ft

TABLE XIX
CAPACITY OF DOWEX WGR-2 (9)

Regenerant Level lb NaOH/cu ft	Capacity, Kgr CaCO ₃ /cu ft	
	H ₂ SO ₄	HCl
2	23.75	20.0
3	28.0	24.0
4	30.0	25.0
5	30.25	25.25

The service cycle is terminated at or prior to breakthrough of free mineral acidity. At the recommended operating conditions, temperature effects are minimal on capacity.

The backwash flow rate required to produce a desired bed expansion varies with the water temperature. The relationship between water temperature, backwash flow rate, and bed expansion is given in Table XX.

TABLE XX
EXPANSION CHARACTERISTICS OF DOWEX WGR-2 (9)

Backwash Flow Rate* gpm/sq ft	Bed Expansion %
0	0
1	8.7
2	18.7
3	28.7
4	38.7
5	48.7

*Basis 77°F, to determine flow at temperature, t:

$$F_t = F_{77} (1 + 0.008 (t - 77))$$

where: F_t , F_{77} - Flow rate at temperature t and 77°F, respectively.

System Design Considerations

Overall System Design

The results of any process design must be developed within the

constraints of the structural and mechanical requirements (22). A complete demineralization system, in addition to a series of vessels containing beds of ion exchange resin, will require the necessary pretreatment equipment; supply pumps; regenerant storage, pumping and dilution equipment; control valves and control system; and waste collection and disposal facilities. Structural constraints may dictate equipment size and weight. A diagram, typical of a demineralization system, showing major equipment, is given in Figure 3.

The process information which is required for equipment design and economic evaluation is as follows. The system flow rate allows sizing of supply and transfer pumps, main flow and recycle piping, and control valves. The vessel size and resin volume allows design of the exchanger vessels and internal distributors and collectors. A typical exchanger vessel is shown in Figure 4. The regenerant flow rates and concentrations allow for sizing regenerant storage tanks, regenerant and dilution water pumps and piping, and waste collection and treatment facilities. The performance predictions allow for establishment of control setpoints and operating procedures. Capital costs may be determined from the overall design. Operating costs may be estimated from the consumption of water and regenerant chemicals, wastewater production, pump energy requirements, and labor and maintenance requirements. The overall design considerations given a process design are described by Applebaum (1). A method for determining relative economics of a demineralization system was described by Downing (12).

Vessel Design

Exchanger vessels used in demineralization are commonly of carbon




Figure 3. Typical Demineralization System Process Diagram




Figure 4. Typical Exchanger Vessel Design

steel construction with baked phenolic or vulcanized rubber linings. Stainless steel or Fiberglass Reinforced Plastic (FRP) vessels are used in some applications. The standard steel tank sizes range in outside diameter from 30 inches to 132 inches, increasing at 6 inch increments. The straight side ranges from 5 feet to 13 feet, increasing also in 6 inch increments. It is generally good engineering practice to hold exchanger vessels in series to the same straight side dimension to facilitate piping. The vessel straight side should be sufficient to allow for effective bed expansion during backwash.

The vessel distributors should be designed to provide uniform distribution. The regenerant distributor should be located above the resin bed in its most swollen state. The collector should be designed to minimize the amount of ineffective resin.

Some system designs require parallel vessels because of vessel size limitations or for operating flexibility. Parallel vessels are generally identical in design. Piping to parallel vessel should be such that uniform splitting of flow is obtained.

Other Design Options

Other design options not considered in this study include regenerant recovery, rinse water recycle, regeneration of vessels in series, upflow or counterflow regeneration, and mixed bed exchange vessels. These options should be given consideration in system design.

Regenerant recovery involves recovery, storage, and use of approximately the final third of the regenerant. The recovered regenerant is then applied during the first stage of the next regeneration. This

results in a reduction in chemical consumption. These savings are offset by the additional tankage, piping, pumps, and controls.

Rinse water recycle involves recycling the final rinse water of an exchanger to the system inlet when the conductivity of the rinse water has dropped below the inlet water conductivity. One-third to one-half of the required rinse water may be saved, minimizing wastewater production.

Series regeneration of exchangers involves simultaneous regeneration of a downstream cation or anion exchanger with a corresponding upstream cation or anion exchanger. The regenerant volume is based upon that required for the upstream exchanger. Regenerant chemical consumption is reduced by this technique.

Upflow or counterflow regeneration occurs when the regenerant is applied in the opposite direction of the service flow (1, 21). This technique requires blocking water to be fed at the top of the vessel to hold the bed in place. Increased capacities and lower leakages result from this type of regeneration where the ions are easily eluted from the resin.

Mixed bed ion exchangers employ a mixture of cation and anion resins in a single vessel (19). The major advantage is the lower leakage resulting from the intimately mixed resin. The regeneration process requires hydraulic classification of the resins prior to regenerant chemical application. Following regeneration, the resins must be mixed again. Leakage from mixed bed exchangers is commonly a result of incomplete resin separation. Inert resin having an intermediate density between the two resins may be used to facilitate resin separation.

CHAPTER III

PERFORMANCE SIMULATION PROGRAM

General Features

A demineralization system performance program was developed to calculate the system throughput, runtime, and effluent quality, as well as the regeneration chemical and water requirements. This program requires the specification of the system design. The present version is limited to fixed bed exchangers containing a single resin type. The program is written in FORTRAN and a listing is provided in Appendix C.

The required system design input parameters are as follows:

- Number of vessels in series,
- Number and position of parallel vessels,
- Type of vessel,
- System flow rate,
- Water analysis units,
- Influent water analysis, and
- Influent water temperature.

The required vessel design input parameters for each vessel are as follows:

- Vessel outside diameter,
- Vessel straight side,
- Effective resin depth,

Vessel wall thickness,
Resin type,
Regenerant temperature (anion exchanger only),
Regeneration level, and
Capacity effectiveness.

If a vessel is a degasifier, the effluent carbon dioxide concentration must be specified.

The program is capable of simulating systems having up to nine vessels in series, including a degasifier, and nine vessels in parallel. The regenerant chemicals used are 66 degree Baumé (93%) sulfuric acid for cation resins and 50 percent sodium hydroxide. The resin types available include Dowex HCR-S strong acid cation resin, Dowex SBR-P strong base anion resin, and Dowex WGR-2 weak base anion resin.

The program output may be specified to be only an overall system summary or a complete output, including individual exchanger operating performance and regeneration. Examples of the program input and output are shown in Appendix D.

Overall Program Logic

The program follows the following sequence of steps:

1. Variables are declared, dimensioned, and initialized.
2. Input data are read. Water analysis data are converted to calcium carbonate equivalents (WATCON). Default variables are modified as necessary.
3. Vessel resin ratings, effluent analysis, and regeneration conditions are determined as follows:

- a. Vessel type is determined. If vessel is a degasifier, water analysis is adjusted for carbon dioxide removed (DECON).
 - b. For cation and anion vessels, resin selection is made and rating parameters computed (CRESIN, ARESIN).
 - c. Resin capacities and leakages are determined. The water analysis is revised accordingly. Specific regeneration constraints are established for the resin selected (DHCRS, DSBRP, DWGR2).
 - d. Resin regeneration conditions are determined. Regenerant and regeneration flow rates, volumes, and application times are determined (CREGN, AREGN).
 - e. System and vessel throughputs and operating time are determined by water mass balance (MASBAL).
4. Output results are displayed in accordance with user preferences. Either a system performance summary or a complete summary, which includes vessel performances, may be selected.

The program subroutine organization is shown in Figure 5.

Subroutine Descriptions

WATCON

Subroutine WATCON performs two functions. The first is to convert the water analysis into units of milligram per liter as calcium carbonate from the units with which the analysis was entered. The second function is to check the electronegativity balance between the




Figure 5. Program Organization

cations and anions. The sodium concentration is adjusted in order to compensate for any imbalance.

DECON

Subroutine DECON converts the degasifier effluent carbon dioxide entered into units of milligrams per liter of calcium carbonate. This value is stored in the water analysis array location corresponding to the degasifier effluent.

CRESIN

Subroutine CRESIN computes the parameters commonly used for cation resin rating. This subroutine calls the cation resin rating subroutine for cation resin selected. Presently, Dowex HCR-S is the only cation resin available. The subroutine is structured to call other cation resins as they are added in the future.

DHCRS

Subroutine DHCRS computes the resin capacity and sodium leakage ratings of Dowex HCR-S based upon the vessel influent water analysis. The resin rating procedure follows the method outlined in the Dow literature (4, 5, 11). A tabulation of the sodium leakage and capacity data taken from the Dow information is contained in Appendix A. A series of straight line equations was obtained by least squares regression of the leakage and capacity data. The sodium leakage is determined by linear interpolation of the straight line coefficients using the arbitrary function subroutine of Franks (14). The capacity is determined by computing the four capacities bounding the point of

interest since there are two dependent variables. A bilinear interpolation in two variables is performed to determine the desired capacity. The subroutine used to compute the capacity is shown in Appendix C. The coefficients of the straight line equations for sodium leakage and capacity are given in Appendix B.

The alkalinity correction factors for sodium leakage were fitted by least squares regression to the polynomial of the form:

$$F_{ALK} = A_0 + A_1 P_{ALK} + A_2 P_{ALK}^2 + A_3 P_{ALK}^3$$

where: F_{ALK} - Alkalinity correction factor

P_{ALK} - Percent alkalinity of the total anions

$$A_0 = 1.00$$

$$A_1 = -6.109762 \times 10$$

$$A_2 = -8.64853 \times 10$$

$$A_3 = -3.016536 \times 10$$

This alkalinity factor is multiplied by the total anion concentration to yield a capacity correction factor.

The calculated capacity is corrected by the addition of the magnesium correction computed from the relationship described in Chapter II. The capacity is then corrected for flow rate and bed depth. The flow rate relationship developed from the information in Table V is given as:

$$F_{FR} = A_0 + A_1 q + A_2 q^2 + A_3 q^3$$

where: F_{FR} - Flow rate correction factor, percent, where $q > 5$ gpm/cu ft ($F_{FR} = 100\%$ where $q \leq 5$ gpm/cu ft)

q - Flow rate, gpm/cu ft

$$A_0 = 1.145102 \times 10^2$$

$$A_1 = -3.056652$$

$$A_2 = 3.15424 \times 10^{-2}$$

$$A_3 = -1.242690 \times 10^{-4}$$

The bed depth correction derived from the data in Table IV is given as:

for $h \geq 18$ inches,

$$F_{BD} = A_0 + A_1 h_{BD} + A_2 h_{BD}^2 + A_3 h_{BD}^3$$

where: F_{BD} - Bed depth correction factor, percent

h_{BD} - Bed depth, inches

$$A_0 = -2.466667 \times 10^1$$

$$A_1 = 7.591991$$

$$A_2 = -1.433682 \times 10^{-1}$$

$$A_3 = 9.469697 \times 10^{-4}$$

for $h < 18$ inches,

$$F_{BD} = A_1 h_{BD}$$

where: $A_1 = 3.9444444 \times 10^{-2}$

The capacity is corrected for sodium leakage by the throughput correction factor described in Chapter II. The backwash flow rate is computed by linear interpolation from the data in Table VI. The regenerant flow rate is interpolated from the data in Table VIII. The backwash time is set at 5 minutes, unless the vessel is first in the series, in which case the backwash time is set at 10 minutes. This default condition may be changed if desired. The final rinse volume is computed based upon a requirement of 25 gallons per cubic foot of resin. This default may also be changed.

The subroutine computes the effluent water analysis from the sodium leakage. This computation assumes the removal of all cations except sodium and the neutralization of all alkalinity.

ARESIN

Subroutine ARESIN computes the parameters commonly used for anion resin rating. This subroutine calls the anion resin rating subroutine for the anion resin selected. Presently, Dowex SBR-P and WGR-2 are the only resins available. The subroutine is structured to allow the addition of other anion resin subroutines in the future.

DSBRP

Subroutine DSBRP computes the resin capacity and silica leakage ratings of Dowex SBR-P based upon the vessel influent water analysis. The resin rating procedure follows the method outlined in the Dow literature (7, 8). A tabulation of the silica leakage and capacity data taken from the Dow information is contained in Appendix A. The silica leakage and sodium leakage are determined by a bilinear interpolation in two variables from these data. The subroutine used to perform this interpolation is shown in Appendix C. Ratings at intermediate resin temperatures are obtained by interpolation of the ratings at the reference temperatures.

Silica leakage must be corrected for sodium leakage and operating temperature. The silica leakage correction factors for sodium leakage in Table XIII were fit to the quadratic below:

$$\text{for } x_{NA} \leq 4.76 \text{ mg/l as CaCO}_3,$$

$$F_{NA} = A_0 + A_1 x_{NA} + A_2 x_{NA}^2$$

where: F_{NA} - Sodium leakage correction factor, percent

X_{NA} - Sodium leakage, mg/l as $CaCO_3$

$$A_0 = 83.7886$$

$$A_1 = 30.50159$$

$$A_2 = -3.203408$$

for $X_{NA} > 4.76$ mg/l as $CaCO_3$,

$$F_{NA} = 155.78489\%$$

The silica leakage correction factors for operating temperature in Table XII were fit to the polynomial below:

for $t \geq 50^\circ F$,

$$F_t = A_0 + A_1 t + A_2 t^2 + A_3 t^3 + A_4 t^4$$

where: F_t - Temperature correction factor, percent

t - Temperature, $^\circ F$

$$A_0 = 4.801963 \times 10^2$$

$$A_1 = -2.547444 \times 10^1$$

$$A_2 = 5.330862 \times 10^{-1}$$

$$A_3 = -4.696193 \times 10^{-3}$$

$$A_4 = 1.622378 \times 10^{-5}$$

for $t < 50^\circ F$,

$$F_t = 50.0\%$$

Exchange capacity must be corrected for the chloride concentration and the rise in silica to the endpoint. The capacity correction factors for chloride concentration in Table XIV were fitted to the polynomial expression:

$$F_{CL} = A_0 + A_1 P_{CL} + A_2 P_{CL}^2 + A_3 P_{CL}^3$$

where: F_{CL} - Chloride correction factor

P_{CL} - Chloride percent of total anions

$$A_0 = 9.981469 \times 10^{-1}$$

$$A_1 = -4.292541 \times 10^{-3}$$

$$A_2 = 3.210956 \times 10^{-5}$$

$$A_3 = -1.107226 \times 10^{-7}$$

The capacity correction factors for silica rise to the endpoint in Table XV were fitted to the expression:

for $0.1 \leq x \leq 1.0$ mg/l as SiO_2 ,

$$F_{SR} = A_0 + A_1 x_{SR} + A_2 x_{SR}^2 + A_3 x_{SR}^3$$

where: F_{SR} - Silica rise correction factor

x_{SR} - Silica rise to endpoint, mg/l as SiO_2

$$A_0 = 8.870000 \times 10^{-1}$$

$$A_1 = 2.895979 \times 10^{-1}$$

$$A_2 = -2.999709 \times 10^{-1}$$

$$A_3 = 1.238345 \times 10^{-1}$$

for $x_{SR} < 0.1$ mg/l as SiO_2 ,

$$F_{SR} = 9.1 x_{SR}$$

for $x_{SR} > 1.0$ mg/l as SiO_2 ,

$$F_{SR} = 1.0$$

The backwash rate is computed from the data in Table XVI by means of the linear expression:

$$q_{BW} = P_{BE} / 23.33333$$

where: q_{BW} - Backwash rate, gpm/sq ft

P_{BE} - Percent bed expansion

The regenerant application time is set at 60 minutes. The backwash time is set at five minutes. The final rinse volume is computed based upon a requirement of 100 gallons per cubic foot of resin. These default parameters may be changed, if desired.

The subroutine computes the effluent water analysis from the silica leakage. This computation assumes removal of all anions except silica and chloride, and neutralization of all acidity. The chloride concentration is assumed to be equivalent to the sodium concentration.

DWGR2

Subroutine DWGR2 computes the resin capacity rating for Dowex WGR-2 based upon the vessel influent water analysis. The resin rating procedure is based upon the Dow capacity data shown in Table XIX. The capacity rating of the resin is interpolated from this data.

The backwash rate is computed from the data in Table XX by means of the relation given as:

$$q_{BW} = (P_{BE} + 1.3)/10.0$$

where: q_{BW} - Backwash rate, gpm/sq ft

P_{BE} - Percent bed expansion

The backwash time is set at five minutes. The regenerant flow rate is computed based upon 0.5 gallons per minute per cubic foot of resin. The final rinse volume is computed based upon a requirement of 75 gallons per minute per cubic foot of resin. These default parameters may be changed, if desired.

The subroutine computes the effluent water analysis. This computation assumes removal of all sulfates and nitrates. No removal of

silica or carbon dioxide is assumed. Chloride concentration is assumed to be equivalent to the sodium concentration. All acidity is assumed to be neutralized.

CREGN

Subroutine CREGN calculates the volume, flow rate, and duration of each step of the regeneration process for vessels containing cation resins. Presently, 66 degree Baumé or 93 percent sulfuric acid is the only cation regenerant, although the subroutine is structured to allow the consideration of other regenerants in the future. If the influent water analysis indicates the presence of calcium, a stepwise regenerant application is followed as shown in Table VII. If no calcium is present, acid is assumed to be applied at a six percent concentration. The volumes of regenerant and dilution water, flow rate of regenerant, and the application time are determined from the dilution water flow rate provided by the resin rating subroutine and the regenerant level.

The backwash volume is calculated from the flow rate and duration. The displacement rinse volume is estimated by the following relationship:

$$V_{DR} = (V_R F_R + A_V h_D) F_V F_{DR}$$

where: V_{DR} - Displacement rinse volume, gallons

V_R - Resin volume, cubic feet

F_R - Resin void fraction (0.5)

A_V - Exchanger area, square feet

h_D - Height of distributor above resin, feet (0.75)

F_V - Volume conversion factor, cubic feet to gallons (7.48)

F_{DR} - Displacement rinse correction factor (1.5)

The values in parentheses are contained in the subroutine. The displacement rinse volume may be supplied directly, if known. The displacement rinse is assumed to be carried out at the regeneration water flow rate. The duration of the displacement rinse is determined from these quantities.

The final rinse is assumed to be performed at the service flow rate. The duration of the final rinse is determined from the flow rate and volume required.

AREGN

Subroutine AREGN calculates the volume, flow rate, and duration of each step of the regeneration process for vessels containing anion resins. Presently, 50 percent sodium hydroxide is the only anion regenerant, although the subroutine is structured to allow the consideration of other regenerants in the future.

The backwash volume is computed from the backwash flow rate and duration. The regenerant and regenerant dilution water volumes, flow rates, and durations are calculated from the dilution water flow rate or the duration supplied by the anion resin rating subroutine and the regenerant level.

The displacement rinse is assumed to be carried out at the regeneration water flow rate. The rinse volume is supplied directly or estimated by the method used in subroutine CREGN. These quantities allow the determination of the rinse duration.

The final rinse is assumed to be performed at the service flow rate. The duration of the final rinse is determined from the flow rate and volume required.

MASBAL

Subroutine MASBAL calculates the gross and net throughput, total regeneration chemical and dilution water volumes, and operating time between regenerations. Individual throughputs for each vessel are calculated.

Interpolation Functions

Linear interpolation function subroutines are called by several subroutines. Function F1 is a single dependent variable interpolation subroutine taken from Franks (14). Functions F2 and F3 are bilinear interpolation in two dependent variable subroutines.

Program Options

The program user is allowed to modify a number of the default parameters to more closely represent the application simulated. For any given vessel, the following defaults may be modified in the program edit mode:

- Backwash duration,
- Backwash bed expansion,
- Anion regenerant application time,
- Slow rinse volume, and
- Fast rinse volume.

The edit mode will also provide a listing of current input parameters and default conditions. Input parameters may also be revised in this mode.

CHAPTER IV

PROGRAM VERIFICATION AND RESULTS

The simulation program developed underwent verification in the following manner. Since the ratings of the resins are the most significant part of the overall calculations, a series of comparisons were made between the resin ratings generated by the program with those determined from the resin literature. These resin ratings were also compared with the ratings of other manufacturers' equivalent resins. A series of performance comparisons were made with some demineralizer designs appearing in the open literature. The results of these comparisons are as follows.

Comparison of Calculated Resin Ratings With Literature Estimates

A summary of the resin ratings calculated by the simulation program compared to those estimated from the resin manufacturer's literature is shown in Table XXI for Dowex HCR-S or its equivalent. The comparison of ratings for Dowex SBR-P is shown in Table XXII, and the comparison of ratings for Dowex WGR-2 is shown in Table XXIII.

From these comparisons, the following general observations can be made. First, the calculated resin ratings appear to be in reasonable agreement with the Dow literature. The deviations appear to be within the range of the accuracy of the charts. Second, the capacities and

TABLE XXI

COMPARISON OF CALCULATED AND LITERATURE RESIN RATINGS
FOR DOWEX HCR-S OR EQUIVALENT

Regen. Level lb/cu ft	Total Cations mg/l	Mg ⁺² %	Na ⁺ %	Alkalinity %	Sodium Leakage, mg/l as CaCO ₃			Capacity, Kgr CaCO ₃ /cu ft		
					Dowex Calc.	HCR-S Lit.	Amberlite IR-120 (26)	Dowex Calc.	HCR-S Lit.	Amberlite IR-120 (26)
6.0	170	68.8	10.0	91.2	0.21	0.17	0.18	20.6	20.7	19.3
6.0	0.21	0.0	100.0	0.0	0.070	0.070	0.066	22.6	22.1	20.8
6.0	85	44.7	20.0	77.6	0.49	0.46	0.26	20.7	20.8	18.0
6.0	0.49	0.0	100.0	0.0	0.16	0.17	0.16	22.1	22.1	20.8
9.0	0.16	0.0	100.0	0.0	0.035	0.035	0.029	26.7	26.5	24.0

TABLE XXII

COMPARISON OF CALCULATED AND LITERATURE RESIN RATINGS
FOR DOWEX SBR-P OR EQUIVALENT

Regen. Level lb/cu ft	Weak Acids %	SiO ₂ %	Cl ⁻ %	Sodium Leakage mg/l as CaCO ₃	Silica Leakage, mg/l as SiO ₃			Capacity, Kgr CaCO ₃ /cu ft		
					Dowex Calc.	SBR-P Lit.	Amberlite IRA-402 (26)	Dowex Calc.	SBR-P Lit.	Amberlite IRA-402 (26)
6.0	58.0	42.1	22.4	0.21	0.041	0.04	0.062	13.3	13.2	13.2
6.0	8.1	8.1	92.0	0.070	0.0052	0.005	0.02	16.8	16.7	15.1

TABLE XXIII
 COMPARISON OF CALCULATED AND LITERATURE RESIN RATINGS
 FOR DOWEX WGR-2 OR EQUIVALENT

Regen. Level lb/cu ft	HCl, Capacity, Kgr, CaCO ₃ /cu ft			H ₂ SO ₄ Capacity, Kgr CaCO ₃ /cu ft		
	Dowex WGR-2		Amberlite	Dowex WGR-2		Amberlite
	Calc.	Lit.	IRA-45 (26)	Calc.	Lit.	IRA-45 (26)
3.2	24.2	24.0	28.0	28.4	28.5	33.0

leakages appear to compare well with those of the equivalent resin performance. The exception to this appears to be with regard to the low silica leakage region for Dowex SBR-P and the capacity of Dowex WGR-2 with respect to IRA-45. The discrepancies in the low silica leakage region between Dowex SBR-P and IRA-402 could reflect a difference in resin properties; however, it is more likely that the difference lies in the manner in which the charts were drawn. The differences between Dowex WGR-2 and Amberlite IRA-45 are likely a result of the difference in properties of these two resins.

Comparison of Design Performances

Some of the demineralizer designs in the literature were evaluated. A six bed and a three bed demineralization system is described by Webb and Carr (29). These are operating demineralizers and the overall performance data was reported. The two systems are at the same site and their comparative performance was evaluated. The calculated performance estimate is compared with the reported performance in Table XXIV for the six bed system. The performance of the mixed bed in the three bed system was approximated by individual cation and anion exchanges. The performance comparison of the three bed system is shown in Table XXV. The six bed performance comparison shows reasonable agreement in throughput and leakage. The three bed performance comparison agrees reasonably in throughput. The comparison differs in leakage of sodium and silica. This reflects the improved leakage performance capability of the mixed bed exchanger. Copies of the performance calculations are shown in Appendix D.

TABLE XXIV
 COMPARISON WITH SIX BED DEMINERALIZER PERFORMANCE
 REPORTED BY WEBB AND CARR (29)

	Reported	Calculated
Throughput, gpd, net to storage	150,000	179,000*
Effluent conductivity, micromhos/cm	0.3	0.2**
Effluent silica, mg/l as SiO ₂	0.010	0.0021**

*Based upon original design water analysis and eight hours for regeneration.

**Based upon three bed design water analysis.

TABLE XXV
 COMPARISON WITH THREE BED DEMINERALIZER PERFORMANCE
 REPORTED BY WEBB AND CARR (29)

	Reported	Calculated
Throughput, gpd, net to storage	300,000	304,000*
Effluent conductivity, micromhos/cm	0.5	1.8
Effluent silica, mg/l as SiO ₂	0.020	0.033

*Based upon eight hours for regeneration.

Applebaum (1) includes several demineralizer designs as examples. The performance of Case 1 was calculated and the results are shown in Table XXVI. The design is for a two bed demineralizer. The overall comparison of the designs indicates relatively good agreement. The differences in throughput arise from the different assumptions in the required regeneration and rinse volumes. Modification of the default regeneration and rinse parameters would allow the design to be more closely approximated.

TABLE XXVI
COMPARISON WITH CASE 1 DEMINERALIZER DESIGN
PROPOSED BY APPLEBAUM (1)

	Design	Calculated
Net throughput, gpd	383,000	345,000
Effluent conductivity, micromhos/cm	10.0	20.0
Effluent silica, mg/l as SiO ₂	0.03	0.024
Capacity, Kgr CaCO ₃ /cu ft		
cation	13.6	13.6
anion	10.6	10.3
Cation regeneration volumes		
backwash, gal	2120	1487
sulfuric acid, gal 66 Be	19.3	20.0
dilution water, gal	1111	1286
displacement rinse, gal	265	527
final rinse, gal	2950	1469
Anion regeneration volumes		
backwash, gal	1070	197
sodium hydroxide, gal 50%	46	47
dilution water, gal	802	1139
displacement rinse, gal	265	527
final rinse, gal	2950	5877

CHAPTER V

PROGRAM APPLICATION AND DISCUSSION

Program Use

This simulation program will be useful in both modeling the performance of existing demineralizers and aiding in the design of new demineralizers. Since the program requires that a well defined design be provided, the present form is more readily useful in modeling existing designs to assess the effects of changes in water supply, operation, or design. In order to be used in system design, the designer must make some estimates concerning the configuration, loading, and operation of the system. Optimizing the design becomes a trial and error process. However, the program can still afford the system designer appreciable time savings in performance evaluation. Future modifications may allow some of the initial system design estimates to be performed by the program.

An example of the input dialogue is shown in Appendix D. The required system design input parameters are as follows:

- Number of vessels in series,
- Number and position of parallel vessels,
- Type of vessel,
- System flow rate,
- Water analysis units,

Influent water analysis, and

Influent water temperature.

The required vessel design input parameters for each vessel are as follows:

Vessel outside diameter,

Vessel straight side,

Effective resin depth,

Vessel wall thickness,

Resin type,

Regenerant temperature (anion exchanger only),

Regeneration level, and

Capacity effectiveness.

If a vessel is a degasifier, the effluent carbon dioxide concentration must be specified.

The program user is allowed to modify a number of the default parameters to more closely represent the application simulated. For any given vessel, the following defaults may be modified in the program edit mode:

Backwash duration,

Backwash bed expansion,

Anion regenerant application time,

Slow rinse volume, and

Fast rinse volume.

As resin ratings are the most significant parameters, the program user has the ability to adjust the resin capacity by means of an effectiveness factor. This factor is chosen based upon the actual operating capacity in the case of an existing design or upon experience in

a new design. This factor is widely variable and depends upon the resin age, characteristics, and operating practices.

Interpretation of Results

The program in its present form does not provide a total picture of the system performance, but does provide sufficient information to determine the complete system operating characteristics. The parameters which can be derived from the results include the system regeneration time, the vessel regeneration frequency, and the gross and net throughput per day.

The vessel regeneration frequency is determined by the program user from the vessel capacity utilization. A schedule of regeneration frequency may be established by comparing the percent capacity utilization for each vessel and by taking into consideration any vessels which may be regenerated in series.

The regeneration time may be determined by the individual vessel regeneration times and frequency, taking into account steps which can be performed simultaneously (i.e., regenerant application can take place for a cation exchanger and an anion exchanger simultaneously). A sequence of regeneration steps is established, and from this the system regeneration time may be determined.

The gross and net throughput per day of the system may be determined from the summation of the vessel regeneration water requirements, the service cycle and the system regeneration time, and the net throughput per regeneration. The total cycle time, service and regeneration, and the gross and net system throughput per regeneration are

determined. Throughput may be converted to a daily basis by means of the cycle time.

The mechanical design of the system is supported by the program results. From the flow rate information, pipe and valve sizes may be determined and pumps may be sized. Regenerant storage tanks and water heating sizing may be performed. Regenerant waste volumes and neutralization requirements may be estimated.

Program Features and Limitations

The program in its present form represents a significant improvement over manual computation. The program has the flexibility to allow a user to tailor the design to fit his application. The program also provides a faster, more reproducible, and possibly more accurate means of interpolating resin ratings from the manufacturer's data. This is supported by the comparative results shown in Chapter IV.

The program is limited in a number of ways. The program cannot be used in a straightforward manner in design. The designer must approximate the design and optimize by trial and error.

Resin selection is limited. Only resins from one manufacturer are represented. The ratings generated must also be corrected by the user by the use of the resin effectiveness to reflect operating conditions, resin age, and deterioration.

The regeneration of cation resins is limited to sulfuric acid. Hydrochloric acid is used as regenerant, although not as commonly as sulfuric.

Cocurrent or downflow regeneration is assumed. Current practice sometimes finds countercurrent or upflow regeneration being applied.

Improved capacity and leakage performance results from this technique where ions are easily eluted. Individual vessel regeneration is the only mode assumed. In many applications, regeneration of vessels in series results in substantial savings in regenerant consumption.

The program only considers fixed beds of a single resin type. Fixed beds of cation and anion mixtures called "mixed beds" have been widely used. Mixed bed exchangers exhibit superior leakage performance.

CHAPTER VI

SUMMARY AND CONCLUSIONS

The purpose of this study was to develop a computer program patterned after industrial practice to simulate ion exchange demineralizer operation. The program is designed to aid the program user in evaluation of a number of possible demineralization system options, and will estimate the system performance for a given design and set of operation conditions.

The program has the following constraints. The maximum system configuration size is nine vessels in series, inclusive of a forced draft or vacuum degasifier, and nine vessels in parallel. The minimum system configuration size is a two bed system of a cation exchanger followed by an anion exchanger. The available resins consist of Dowex HCR-S, strong acid cation resin; Dowex SBR-P, strong base anion resin; and Dowex WGR-2, weak base anion resin. Only fixed beds of a single type of exchange resin are considered. The regenerants are sulfuric acid for cation regeneration and sodium hydroxide for anion regeneration. Regenerant is assumed to be applied cocurrent to the service flow or downflow. Despite these constraints, evaluation of a large percentage of the most common system designs is possible with this program.

The program was developed and evaluated and the following conclusions can be made as a result of this study.

The comparison of the resin ratings determined from the manufacturer's literature with those estimated by the program shows reasonable agreement. The comparison of the performance estimates calculated by the program with operating performance results and other performance predictions appears to be reasonable, particularly in view of the inaccuracies and uncertainties inherent in an industrial operating environment.

The program has the advantage of generating resin ratings quicker and with more reproducible results than can be obtained by using the charts contained in the manufacturer's literature. Changes in system operation and design may easily be evaluated as a result. The program is a useful tool in the evaluation of existing systems and the design of new systems.

The following recommendations are made for further work as a result of this study. The program should be enhanced in the following ways:

1. Mixed bed exchanger simulation should be incorporated.
2. Hydrochloric acid should be included as a regenerant for cation regeneration.
3. Countercurrent and series regeneration options should be added.
4. Additional resin types should be incorporated into the data base.
5. Regeneration wastes should be characterized and the neutralization requirements determined.
6. To facilitate system design, the program should provide initial vessel size estimates.

Areas of further study which were identified as a result of this study are as follows:

1. A means should be developed in which the equilibria and kinetic theories may be used to predict resin performance for industrial ion exchange systems.
2. The range of the resin effectiveness factors should be determined for various resin types based upon operating experience.

A SELECTED BIBLIOGRAPHY

- (1) Applebaum, Samuel B. Demineralization by Ion Exchange. New York: Academic Press, 1968.
- (2) Clazie, Ronald N., Gerhard Klein, and Theodore Vermeulen. Multicomponent Diffusion: Generalized Theory With Ion Exchange Applications. Berkeley, California: Sea Water Conversion Laboratory Report No. 67-4, Water Resources Center Desalination Report No. 19, 1967.
- (3) The Dow Chemical Company. Dowex: Ion Exchange. Midland, Michigan, 1958.
- (4) Dow Chemical U.S.A. Dowex Cation Resin Hydrogen Cycle, T.D. Index 510.01. Midland, Michigan: Form No. 177-1279-77, n.d.
- (5) _____ . Dowex HCR-S Cation Exchange Resin, T.D. Index 110.01. Midland, Michigan: Form No. 177-1195-77R, 1977.
- (6) _____ . Dowex Ion Exchange Resins. Midland, Michigan: Form No. 176-1080-77, n.d.
- (7) _____ . Dowex SBR-P Anion Exchange Resin, T. D. Index 230.01. Midland Michigan: Form No. 177-1130-76, n.d.
- (8) _____ . Dowex SBR-P Anion Exchange Resin - Engineering Design Ratings, T.D. Index 534.01. Midland, Michigan: Form No. 177-1220-75, n.d.
- (9) _____ . Dowex WGR-2 Weakly Basic Anion Exchange Resin, T.D. Index 330.1. Midland, Michigan: Form No. 177-1326-78, n.d.
- (10) _____ . Engineering Data Dowex Cation Exchange Resins, T.D. Index 100.02. Midland, Michigan: Form No. 176-1227-74, n.d.
- (11) _____ . Strong Acid Cation Exchange Resins, T.D. Index 100.01. Midland, Michigan: Form No. 177-1117-77.

- (12) Downing, D. G. "Calculating the Minimum-Cost Ion-Exchange Units." Chemical Engineering, 72(25) (Dec. 6, 1965), pp. 170-176.
- (13) Dranoff, Joshua S. and Leon Lapidus. "Multicomponent Ion Exchange Column Calculations." Industrial and Engineering Chemistry, 50(11) (Nov., 1958), pp. 1648-1653.
- (14) Franks, Roger G. E. Modeling and Simulation in Chemical Engineering. New York: Wiley-Interscience, 1972.
- (15) Gold, Harris and Calvin Calmon. "Ion Exchange: Present Status, Needs, and Trends." Recent Advances in Separation Techniques - II. AICLE Symposium Series No. 192. New York: American Institute of Chemical Engineerings, 1980, pp. 60-67.
- (16) Inczedy, J. Analytical Application of Ion Exchangers. Oxford: Pergamon Press, 1966.
- (17) Kitchener, J. A. Ion-Exchange Resins. London: Methuen and Co., Ltd., 1957.
- (18) Kunin, Robert. Elements of Ion Exchange. New York: Reinhold Publishing Corp., 1960.
- (19) Kunin, Robert and Francix X. McGarvey. "Monobed Deionization With Ion Exchange Resins." Industrial and Engineering Chemistry, 43(3) (March, 1951), pp. 734-739,.
- (20) Marks, R. H. "Water Treatment." Power (Dec., 1958), pp. 73-104.
- (21) Michalson, A. W. "Ion Exchange." Chemical Engineering, 70(6) (March 18, 1963), pp. 163-182.
- (22) Michener, J. W. and H. E. Lundberg. "Equipment and Process Design." Ion Exchange Technology. Eds.: F. C. Dachod and Jack Schubert. New York: Academic Press, 1956, pp. 27-51.
- (23) Nordell, Eskel. Water Treatment. New York: Reinhold Publishing, 1961.
- (24) Opler, Ascher. "Application of Computing Machines to Ion Exchange Column Calculations." Industrial and Engineering Chemistry, 45(12) (Dec., 1953), pp. 2621-2629.
- (25) The Permutit Company, Inc. Data Book. Paramus, New Jersey, 1961.
- (26) Rohm and Haas Company. Engineering Manual for the Amberlite Ion Exchange Resins. Philadelphia, Pennsylvania, 1976.

- (27) Sanks, Robert L. Water Treatment Plant Design. Ann Arbor, Michigan: Ann Arbor Science, 1978.
- (28) Tan, K. S. and I. H. Spinner. "Cyclic Operation of a Fixed Bed Ion Exchange Process: Experimental and Computer Simulation Studies." The Canadian Journal of Chemical Engineering, 49 (Apr., 1971), pp. 252-259.
- (29) Webb, Lester C. and Roy E. Carr. "Comparison of Six-Bed and Three-Bed Demineralization Systems." American Power Conference Proceedings, 42 (1980), pp. 1109-1112.

APPENDIXES

APPENDIX A
RESIN RATING DATA

RESIN RATING DATA

The resin rating data used by the simulation program, either by means of linear correlations or by interpolating functions, are provided herein. The Dowex HCR-S sodium leakage data are given in Table XXVII. The leakage data are based upon a water containing no alkalinity. The Dowex HCR-S capacity data are given in Table XXVIII. The capacity data are based upon a calcium to magnesium concentration ratio of 3:1. The Dowex SBR-P silica leakage data are given in Table XXIX. The leakage data are based upon a water at 75°F and specific conductance of three micromhos per centimeter. The Dowex SBR-P capacity data are given in Table XXX. The capacity data are based upon a water containing no chlorides and operation to a silica rise of one part per million.

TABLE XXVII
DOWEX HCR-S SODIUM LEAKAGE RATING DATA (4)

Regeneration Level 1b 66°Be H ₂ SO ₄ /cu ft	Sodium Leakage, Percent of Corrected Total Mineral Anions							
	Percent Sodium of Total Cations							
	20	40	50	60	70	80	90	100
3	3.4	6.2	9.3	13.9	19.5	28.0	--	--
4	2.7	5.0	7.6	11.4	16.0	23.25	--	--
5	2.15	4.2	6.3	9.5	13.45	19.6	--	--
6	1.7	3.5	5.3	7.9	11.3	16.5	24.2	--
7	1.35	3.0	4.3	6.6	9.4	13.9	20.7	--
8	1.0	2.5	3.7	5.4	7.9	11.75	17.6	25.1
9	0.75	2.0	3.0	4.4	6.45	9.8	14.7	21.7
10	0.5	1.5	2.4	3.5	5.25	8.0	12.3	18.5
12	--	0.9	1.3	1.9	3.05	5.0	7.9	13.2
14	--	--	--	0.6	1.2	2.5	4.4	8.9

TABLE XXVIII
DOWEX HCR-S CAPACITY RATING DATA (4)

Regeneration Level lb 66° Be H ₂ SO ₄ /cu ft	Percent Alkalinity	Capacity, Kgr CaCO ₃ /cu ft					
		Percent Sodium of Total Cations					
		0	20	40	60	80	100
2	0	--	--	--	--	--	--
	50	--	--	--	--	--	12.9
	100	--	--	--	--	13.4	14.7
3	0	12.9	13.0	13.3	12.8	11.3	14.2
	50	12.9	13.7	13.9	14.4	13.8	17.1
	100	12.9	14.2	14.7	16.4	17.4	18.9
4	0	15.1	15.7	16.1	15.9	15.1	17.4
	50	15.1	16.2	16.8	17.3	17.2	20.1
	100	15.1	16.8	17.6	19.1	20.1	21.8
5	0	16.9	17.7	18.3	18.3	18.0	20.0
	50	16.9	18.1	18.9	19.8	19.9	22.3
	100	16.9	18.7	19.8	21.4	22.3	24.0
6	0	18.5	19.4	20.1	20.2	20.5	22.1
	50	18.5	19.9	20.9	21.6	22.0	24.2
	100	18.5	20.3	21.6	22.9	24.1	25.9

TABLE XXVIII (Continued)

Regeneration Level lb 66° Be H ₂ SO ₄ /cu ft	Percent Alkalinity	Capacity, Kgr CaCO ₃ /cu ft					
		Percent Sodium of Total Cations					
		0	20	40	60	80	100
7	0	19.8	20.7	21.6	21.9	22.5	23.9
	50	19.8	21.2	22.2	23.0	23.9	25.9
	100	19.8	21.7	23.0	24.5	25.7	27.5
8	0	20.8	21.9	22.9	23.4	24.3	25.4
	50	20.8	22.3	23.7	24.4	25.6	27.3
	100	20.8	22.8	24.2	25.8	27.0	28.8
9	0	21.8	22.9	24.0	24.6	25.9	26.6
	50	21.8	23.5	24.8	25.8	26.9	28.4
	100	21.8	23.9	25.5	26.9	28.1	30.0
10	0	22.6	23.9	25.2	25.9	27.3	27.9
	50	22.6	24.4	25.9	26.8	28.1	29.6
	100	22.6	24.8	26.5	27.9	29.2	31.0
12	0	24.1	25.5	26.8	27.8	29.7	29.9
	50	24.1	26.0	27.7	28.5	30.3	31.4
	100	24.1	26.3	28.1	29.6	31.0	33.0

TABLE XXVIII (Continued)

Regeneration Level lb 66° Be H ₂ SO ₄ /cu ft	Percent Alkalinity	Capacity, Kgr CaCO ₃ /cu ft					
		Percent Sodium of Total Cations					
		0	20	40	60	80	100
14	0	25.3	--	28.4	29.5	--	31.6
	50	25.3	--	29.1	30.2	--	32.6
	100	25.3	--	29.8	31.0	--	34.5

TABLE XXIX
DOWEX SBR-P SILICA LEAKAGE RATING DATA (8)

Regen. Temp °F	Regen. Level lb NaOH/cu ft	Silica Leakage, Parts per Million SiO ₂										
		Percent Silica of Total Anions										
		0	10	20	30	40	50	60	70	80	90	100
75	3.5	0	0.060	0.145	0.270	0.445	--	--	--	--	--	--
	5.0	0	0.025	0.060	0.105	0.145	0.210	0.270	0.3275	0.3775	0.4225	0.4575
	7.5	0	0.020	0.0375	0.0575	0.075	0.105	0.130	0.155	0.170	0.1875	0.200
	10	0	0.0075	0.020	0.0325	0.045	0.0675	0.0850	0.1075	0.125	0.140	0.150
95	3.5	0	0.060	0.12	0.18	0.24	0.30	0.36	0.42	0.48	0.54	0.60
	5.0	0	0.020	0.040	0.060	0.085	0.11	0.14	0.16	0.21	-.25	0.30
	7.5	0	0.015	0.025	0.000	0.055	0.070	0.085	0.10	0.12	0.135	0.15
	10	0	0.010	0.020	0.025	0.0325	0.045	0.060	0.075	0.090	0.11	0.125
120	3.5	0	0.025	0.06	0.10	0.15	0.195	0.24	0.28	--	--	--
	5.0	0	0.0075	0.0175	0.030	0.045	0.070	0.0975	0.12	0.135	0.145	0.15
	7.5	0	0.005	0.010	0.015	0.025	0.035	0.045	0.060	0.0725	0.0875	0.10
	10	0	0	0	0.005	0.010	0.0175	0.025	0.035	0.0425	0.0525	0.0625

TABLE XXX
DOWEX SBR-P CAPACITY RATING DATA (8)

Regeneration Level lb NaOH/cu ft	Capacity, Kgr CaCO ₃ /cu ft							
	Percent Weak Acids	Mixed Anions Temperature, °F			Percent Silica	Weak Acid Anions Temperature, °F		
		75	95	120		75	95	120
3.5	0	11.13	--	--	0	16.5	16.57	16.53
	10	11.53	--	--	10	16.2	16.5	16.47
	20	11.90	--	12.1	20	15.83	16.33	16.33
	30	12.23	12.23	12.5	30	15.33	16.13	16.3
	40	12.53	12.77	12.9	40	14.73	15.8	16.2
	50	12.86	13.2	13.3	50	14.1	15.2	16.07
	60	13.23	13.6	13.7	60	13.5	14.67	15.83
	70	13.53	14.0	14.1	70	12.87	14.2	15.6
	80	13.93	14.47	14.6	80	12.2	13.8	15.3
	90	14.47	14.87	15.1	90	11.6	13.4	15.07
	100	15.0	15.33	15.7	100	11.0	13.0	14.8
7.5	0	14.67	14.3	14.5	0	18.72	18.8	18.7
	10	14.96	14.77	14.93	10	18.67	18.67	18.7
	20	15.23	15.13	15.4	20	18.50	18.63	18.7
	30	15.50	15.5	15.8	30	18.23	18.57	18.7

TABLE XXX (Continued)

Regeneration Level lb NaOH/cu ft	Capacity, Kgr CaCO ₃ /cu ft							
	Percent Weak Acids	Mixed Anions			Percent Silica	Weak Acid Anions		
		75	Temperature, °F			75	Temperature, °F	
			95	120		75	95	120
	40	15.80	15.83	16.13	40	17.90	18.47	18.7
	50	16.00	16.17	16.53	50	17.50	18.3	18.7
	60	16.30	16.5	16.9	60	17.07	18.07	18.7
	70	16.67	16.83	17.3	70	16.67	17.73	18.7
	80	17.00	17.27	17.67	80	16.20	17.3	18.7
	90	17.50	17.67	18.1	90	15.80	17.0	18.7
	100	18.03	13.13	18.6	100	15.33	16.83	18.7
5.0	0	12.87	12.77	12.9	0	17.83	17.84	18.27
	10	13.23	13.27	13.27	10	17.67	17.84	18.2
	20	13.60	13.77	13.67	20	17.47	17.83	18.17
	30	13.90	14.1	14.07	30	17.07	17.73	18.13
	40	14.17	14.43	14.5	40	16.67	17.53	18.1
	50	14.50	14.77	14.9	50	16.1	17.2	18.0
	60	14.80	15.07	15.3	60	15.47	16.87	17.9
	70	15.10	15.4	15.8	70	14.8	16.5	17.8
	80	15.47	15.77	16.3	80	14.1	16.1	17.6

TABLE XXX (Continued)

Regeneration Level lb NaOH/cu ft	Capacity, Kgr CaCO ₃ /cu ft							
	Percent Weak Acids	Mixed Anions Temperature, °F			Percent Silica	Weak Acid Anions Temperature, °F		
		75	95	120		75	95	120
10.0	90	15.90	16.13	16.9	90	13.5	15.8	17.4
	100	16.37	16.6	17.67	100	12.87	15.5	17.2
	0	15.87	15.57	15.9	0	--	19.3	19.2
	10	16.07	15.9	16.3	10	--	19.2	19.2
	20	16.33	16.23	16.6	20	--	19.1	19.2
	30	16.56	16.5	16.9	30	18.84	19.07	19.2
	40	16.83	16.8	17.2	40	18.59	19.0	19.2
	50	17.00	17.07	17.53	50	18.28	18.9	19.2
	60	17.27	17.33	17.87	60	17.90	18.73	19.2
	70	17.57	17.6	18.2	70	17.53	18.4	19.2
	80	17.93	17.97	18.5	80	17.13	17.93	19.2
90	18.43	18.4	18.8	90	16.83	17.6	19.2	
100	18.97	18.9	19.1	100	16.43	17.3	19.2	

APPENDIX B

DOWEX HCR-S LINEAR CORRELATION COEFFICIENTS

DOWEX HCR-S LINEAR CORRELATION COEFFICIENTS

The Dowex HCR-S sodium leakage rating data were fit to the following model:

$$P_{\text{NAL}} = (\text{Ln } R - b)/m$$

where: P_{NAL} - Percent sodium leakage of corrected total anions
R - Regeneration level, lb 66° Be H₂SO₄/cu ft
m, b - Coefficients interpolated from Table XXXI

The Dowex HCR-S capacity rating data were fit to the following model:

$$\text{Cap} = (\text{Ln } R - b)/m$$

where: Cap - Capacity, Kgr CaCO₃/cu ft
R - Regeneration level, lb 66° BeH₂SO₄/cu ft
m, b - Coefficients interpolated from Table XXXII

TABLE XXXI
DOWEX HCR-S SODIUM LEAKAGE CORRELATION
COEFFICIENTS

Percent Sodium of Total Cations	m	b
0	-1.243*	2.503*
20	-0.4142	2.503
40	-0.2629	2.719
50	-0.1745	2.715
60	-0.1157	2.707
70	-0.08441	2.743
80	-0.06028	2.787
90	-0.04237	2.825
100	-0.03445	2.943

*Estimated

TABLE XXXII
DOWEX HCR-S CAPACITY CORRELATION COEFFICIENTS

Percent Sodium of Total Cations	m			b		
	Percent Alkalinity			Percent Alkalinity		
	0	50	100	0	50	100
0	0.1232	0.1231	0.1231	-0.4836	-0.4836	-0.4836
20	0.1113	0.1122	0.1143	-0.3579	-0.4332	-0.5296
40	0.1021	0.1009	0.1030	-0.2589	-0.3055	-0.4232
60	0.09210	0.09773	0.1051	-0.07632	-0.3120	-0.6274
80	0.07521	0.08387	0.1018	-0.2512	-0.05823	-0.6672
100	0.08824	0.09712	0.09893	-0.1556	-0.5628	-0.7571

APPENDIX C
PROGRAM LISTING

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      37      562 FORMAT(/5X,'ENTER USER NAME (25 CHARACTERS MAXIMUM)',
1          /5X,1H?)
ISN      38          READ(NI,520)(UNAME(I),I=1,6)
ISN      39          IF(ECHO)WRITE(NO,5520)(UNAME(I),I=1,6)
ISN      41          WRITE(NO,563)
ISN      42      563 FORMAT(/5X,'ENTER DATE (20 CHARACTERS MAXIMUM)',
1          /5X,1H?)
ISN      43          READ(NI,520)(DATE(I),I=1,5)
ISN      44          IF(ECHO)WRITE(NO,5520)(DATE(I),I=1,5)
ISN      46          WRITE(NO,601)
ISN      47      601 FORMAT(/1X,'***ENTER SYSTEM DESIGN DATA***',/)
ISN      48      100 WRITE(NO,1602)
ISN      49      1602 FORMAT(5X,'ENTER NUMBER OF VESSELS IN SERIES ',
1          '(9 MAXIMUM)',/5X,1H?)
ISN      50          READ(NI,500)NV
ISN      51      500 FORMAT(11)
ISN      52          IF(ECHO)WRITE(NO,5500)NV
ISN      54      5500 FORMAT(1X,11)
ISN      55          IF(NV.LE.0) GO TO 100
ISN      56          WRITE(NO,602)
ISN      57      602 FORMAT(/5X,'ENTER NUMBER OF VESSELS IN SERIES WITH ',
1          'PARALLEL VESSELS',/5X,1H?)
ISN      58          READ(NI,500)LL
ISN      59          IF(ECHO)WRITE(NO,5500)LL
ISN      61          IF(LL.LE.0) GO TO 109
ISN      62      101 WRITE(NO,603)
ISN      63      603 FORMAT(/5X,'ENTER POSITIONS OF PARALLEL VESSELS',/
1          10X,'(EXAMPLE: 1,2,3, )',/
2          10X,'( -FIRST THREE POSITIONS HAVE ',
3          'PARALLEL VESSELS)',/5X,1H?)
ISN      64          READ(NI,500)(LLP(I),I=1,LL)
ISN      65          IF(ECHO)WRITE(NO,5500)(LLP(I),I=1,LL)
ISN      67          DD 103 I=1,LL
ISN      68          IF(LLP(I).LE.NV) GO TO 102
ISN      69          WRITE(NO,604)
ISN      70      604 FORMAT(1X,'***INVALID VESSEL POSITION***',/)
ISN      71          GO TO 101
ISN      72      102 LLPI=LLP(I)
ISN      73          WRITE(NO,605)LLPI
ISN      74      605 FORMAT(/5X,'ENTER NUMBER OF PARALLEL VESSELS IN ',
1          'POSITION ',11,' (9 MAXIMUM)',/5X,1H?)
ISN      75          READ(NI,500)IVES(LLPI,2)
ISN      76          IF(ECHO)WRITE(NO,5500)IVES(LLPI,2)
ISN      78      103 CONTINUE
ISN      79      109 WRITE(NO,606)
ISN      80      606 FORMAT(5X,'ENTER VESSEL TYPE',/10X,'CX-CATION EXCHANGER',
1          /10X,'AX-ANION EXCHANGER'/10X,
2          'FG-FORCED DRAFT DEGASIFIER',
3          /10X,'VG-VACUUM DEGASIFIER',/)
ISN      81          DD 115 I=1,NV
ISN      82      110 WRITE(NO,607)I
ISN      83      607 FORMAT(5X,'POSITION ',11,2H ?)
ISN      84          READ(NI,502)CMD
ISN      85          IF(ECHO)WRITE(NO,5502)CMD
ISN      87      5502 FORMAT(1X,A2)
ISN      88      502 FORMAT(A2)

```

```

*.....1.....2.....3.....4.....5.....6.....7.*.....8
ISN      89      DD 111 J=1,6                      00001080
ISN      90      IF(CMD.EQ.VT(J)) GO TO 112          00001090
ISN      91      111 CONTINUE                          00001100
ISN      92      WRITE(ND,608)                        00001110
ISN      93      608 FORMAT(1X,'****INVALID VESSEL TYPE****',/1X,
                1 'ENTER VT FOR LIST OF VESSEL TYPES',/) 00001120
ISN      94      GO TO 110                             00001130
ISN      95      112 IF(J.NE.1) GO TO 113              00001140
ISN      96      WRITE(ND,606)                          00001150
ISN      97      GO TO 110                             00001160
ISN      98      113 IF(J.GE.5) GO TO 114              00001170
ISN      99      IF(J.EQ.2) IVES(1,1)=1                00001180
ISN      101     IF(J.EQ.3) IVES(1,1)=2                00001190
ISN      103     IF(J.NE.4) GO TO 115                  00001200
ISN      104     IVES(1,1)=3                            00001210
ISN      105     IMB=IMB+1                              00001220
ISN      106     IVES(1,7)=IMB                          00001230
ISN      107     GO TO 115                              00001240
ISN      108     114 IF(J.EQ.5) IVES(1,1)=-1           00001250
ISN      110     IF(J.EQ.6) IVES(1,1)=-2               00001260
ISN      112     115 CONTINUE                          00001270
ISN      113     WRITE(ND,609)                          00001280
ISN      114     C 609 FORMAT(/5X,'ENTER REGENERATION MODES',/10X,
                1 'INDICATE IF INDIVIDUAL OR SERIES ' 00001290
ISN      115     C 2 'REGENERATION IS PERFORMED',/10X, 00001300
ISN      116     C 3 'O-INDIVIDUAL',/10X,'N-SERIES WHERE N IS ', 00001310
ISN      117     C 4 'POSITION OF VESSEL WITH WHICH SERIES ',/12X, 00001320
ISN      118     C 5 'REGENERATION IS PERFORMED',/) 00001330
ISN      119     C DO 125 I=1,NV                       00001340
ISN      120     C IF(IVES(1,I).LE.0) GO TO 125        00001350
ISN      121     C IF(IVES(1,5).GT.0) GO TO 125        00001360
ISN      122     C WRITE(ND,610)I                      00001370
ISN      123     C 610 FORMAT(5X,'VESSEL ',11,2H ?) 00001380
ISN      124     C READ(N1,500) IVES(1,5)              00001390
ISN      125     C IF(ECHO)WRITE(ND,5500) IVES(1,5)   00001400
ISN      126     C J=IVES(1,5)                        00001410
ISN      127     C IVES(J,5)=1                         00001420
ISN      128     C 125 CONTINUE                        00001430
ISN      129     C WRITE(ND,611)                      00001440
ISN      130     C 611 FORMAT(/5X,'ENTER SYSTEM FLOW RATE(GPM)',
                1 '/5X,1H?)                          00001450
ISN      131     C READ(N1,510) QSYS                    00001460
ISN      132     C 510 FORMAT(F10.0)                  00001470
ISN      133     C IF(ECHO)WRITE(ND,5510) QSYS         00001480
ISN      134     C 5510 FORMAT(1X,E12.5)              00001490
ISN      135     C 130 WRITE(ND,612)                  00001500
ISN      136     C 612 FORMAT(/5X,'ENTER WATER ANALYSIS UNITS',/10X,
                1 '1-MG/L AS SUCH',/10X,'2-MG/L AS CaCO3',
                2 '/10X,'3-MEQ/L',/5X,1H?)           00001510
ISN      137     C READ(N1,500) IWAU                   00001520
ISN      138     C IF(ECHO)WRITE(ND,5500) IWAU        00001530
ISN      139     C IF(IWAU.LT.1.OR.IWAU.GT.3) GO TO 130 00001540
ISN      140     C WRITE(ND,613)                      00001550
ISN      141     C 613 FORMAT(/5X,'ENTER INFLUENT WATER ANALYSIS')
ISN      142     C DD 140 I=2,14                      00001560
ISN      143     C WRITE(ND,614) IONS(I-1)            00001570
ISN      144     C                                     00001580
ISN      145     C                                     00001590
ISN      146     C                                     00001600
ISN      147     C                                     00001610
ISN      148     C                                     00001620
ISN      149     C                                     00001630

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      130      614 FORMAT(5X,A4,2H ?) 00001640
ISN      131      READ(NI,510)WAN(1,1) 00001650
ISN      132      IF(ECHO)WRITE(NO,5510)WAN(1,1) 00001660
ISN      134      140 CONTINUE 00001670
ISN      135      IF(SUB1)WRITE(NO,6650) 00001680
ISN      137      6650 FORMAT(1X,'WATCON') 00001690
ISN      138      CALL WATCON(IWAW,WAN,CNA) 00001700
ISN      139      IF(SUB1)WRITE(NO,6650) 00001710
ISN      141      IF(CNA.LE.0) GO TO 141 00001720
ISN      142      WRITE(NO,615)CNA 00001730
ISN      143      615 FORMAT(/5X,'SODIUM ADJUSTED TO',F10.2,'TO BALANCE') 00001740
ISN      144      141 WRITE(NO,616) 00001750
ISN      145      616 FORMAT(/5X,'ENTER INFLUENT TEMPERATURE(F)', 00001760
ISN      146      1 /5X,1H?) 00001770
ISN      147      READ(NI,510)WAN(1,15) 00001780
ISN      148      IF(ECHO)WRITE(NO,5510)WAN(1,15) 00001790
ISN      149      ICR=1 00001800
C        WRITE(NO,617) 00001810
C 617    FORMAT(/5X,'ENTER CATION RESIN REGENERANT', 00001820
C 1      /10X,'1-SULFURIC ACID',/10X, 00001830
C 2      '2-HYDROCHLORIC ACID',/5X,1H?) 00001840
C        READ(NI,500)ICR 00001850
C        IF(ECHO)WRITE(NO,5500)ICR 00001860
ISN      150      IAR=-1 00001870
ISN      151      WRITE(NO,625) 00001880
ISN      152      625 FORMAT(/1X,'****ENTER VESSEL DESIGN DATA****',/) 00001890
ISN      153      IBW=0 00001900
ISN      154      DO 200 J=1,NV 00001910
ISN      155      IF(IVES(J,1).LE.0) GO TO 190 00001920
ISN      156      IND=IVES(J,1)-2 00001930
ISN      157      VES(J,25)=5.0 00001940
ISN      158      IF(IBW.EQ.0)VES(J,25)=10.0 00001950
ISN      160      IBW=1 00001960
ISN      161      WRITE(NO,626)J 00001970
ISN      162      626 FORMAT(/1X,'*** VESSEL ',11,' ***') 00001980
ISN      163      WRITE(NO,627) 00001990
ISN      164      627 FORMAT(/5X,'ENTER VESSEL DIAMETER (INCHES)', 00002000
ISN      165      1 /5X,1H?) 00002010
ISN      166      READ(NI,510)VES(J,1) 00002020
ISN      168      IF(ECHO)WRITE(NO,5510)VES(J,1) 00002030
ISN      169      WRITE(NO,628) 00002040
ISN      170      628 FORMAT(/5X,'ENTER VESSEL SIDE SHEET (INCHES)', 00002050
ISN      171      1 /5X,1H?) 00002060
ISN      172      READ(NI,510)VES(J,2) 00002070
ISN      173      IF(ECHO)WRITE(NO,5510)VES(J,2) 00002080
ISN      174      WRITE(NO,629) 00002090
ISN      175      629 FORMAT(/5X,'ENTER EFFECTIVE RESIN DEPTH (INCHES)', 00002100
ISN      176      1 /5X,1H?) 00002110
ISN      177      READ(NI,510)VES(J,5) 00002120
ISN      178      IF(ECHO)WRITE(NO,5510)VES(J,5) 00002130
ISN      179      WRITE(NO,630) 00002140
ISN      180      630 FORMAT(/5X,'ENTER INEFFECTIVE RESIN DEPTH (INCHES)', 00002150
ISN      181      1 /5X,1H?) 00002160
ISN      182      READ(NI,510)VES(J,4) 00002170
ISN      183      IF(ECHO)WRITE(NO,5510)VES(J,4) 00002180
ISN      184      WRITE(NO,631) 00002190

```

```

* ..... 1 ..... 2 ..... 3 ..... 4 ..... 5 ..... 6 ..... 7 ..... 8
ISN 184 631 FORMAT(/5X,'ENTER VESSEL WALL THICKNESS (INCHES)', 00002200
      1 /5X,1H?) 00002210
ISN 185 143 READ(NI,510)VES(J,7) 00002220
ISN 186 IF(ECHO)WRITE(NO,5510)VES(J,7) 00002230
      C IF(IND.NE.1) GO TO 44 00002240
      C IMB=IVES(J,7) 00002250
      C WRITE(NO,632) 00002260
      C 632 FORMAT(/5X,'ENTER CATION/ANION RESIN RATIO', 00002270
      1 /5X,1H?) 00002280
      C READ(NI,510)MBV(IMB,1) 00002290
      C IF(ECHO)WRITE(NO,5510)MBV(IMB,1) 00002300
ISN 188 44 IF(IND)144,147,144 00002310
ISN 189 144 WRITE(NO,633)(CAT(L),L=1,2) 00002320
ISN 190 633 FORMAT(/5X,'ENTER ',A4,A2,' RESIN TYPE',/10X, 00002330
      C 1 '100-LIST OF GENERIC RESIN TYPE CODES',/10X, 00002340
      2 '200-LIST OF DOWEX RESIN TYPE CODES',/5X,1H?) 00002350
      C 3 '300-LIST OF AMBERLITE RESIN TYPE CODES',/10X, 00002360
      C 4 '400-LIST OF IDNAC RESIN TYPE CODES',/10X, 00002370
      C 5 '500-LIST OF DUOLITE RESIN TYPE CODES',/5X,1H?) 00002380
ISN 191 1144 READ(NI,503)IVES(J,3) 00002390
ISN 192 IF(ECHO)WRITE(NO,5503)IVES(J,3) 00002400
ISN 194 5503 FORMAT(1X,13) 00002410
ISN 195 503 FORMAT(13) 00002420
ISN 196 IRES=IVES(J,3) 00002430
ISN 197 145 IRES=IRES-100 00002440
ISN 198 IF(DIAG)WRITE(NO,6600)IRES 00002450
ISN 200 6600 FORMAT(1X,'IRES = ',13) 00002460
ISN 201 IF(IRES.GT.100) GO TO 145 00002470
ISN 202 IF(IRES.GE.0) GO TO 1145 00002480
ISN 203 WRITE(NO,6633) 00002490
ISN 204 6633 FORMAT(/5X,'DOWEX RESIN TYPE CODES', 00002500
      1 /10X,'201 - DOWEX HCR-S', 00002510
      2 /10X,'221 - DOWEX SBR-P', 00002520
      3 /10X,'241 - DOWEX WGR-2', 00002530
      4 /5X,1H?) 00002540
ISN 205 GO TO 1144 00002550
ISN 206 1145 IF(IRES.LT.20) GO TO 146 00002560
ISN 207 GO TO 144 00002570
ISN 208 146 IVES(J,6)=ICR 00002580
ISN 209 GO TO 150 00002590
ISN 210 147 WRITE(NO,633)(ANI(L),L=1,2) 00002600
ISN 211 READ(NI,503)IVES(J,3) 00002610
ISN 212 IF(ECHO)WRITE(NO,5503)IVES(J,3) 00002620
ISN 214 IRES=IVES(J,3) 00002630
ISN 215 148 IRES=IRES-100 00002640
ISN 216 IF(DIAG)WRITE(NO,6600)IRES 00002650
ISN 218 IF(IRES.GT.100) GO TO 148 00002660
ISN 219 IF(IRES.GE.20) GO TO 149 00002670
ISN 220 GO TO 147 00002680
ISN 221 149 IVES(J,6)=IAR 00002690
ISN 222 WRITE(NO,634) 00002700
ISN 223 634 FORMAT(/5X,'ENTER REGENERANT TEMPERATURE(F)', 00002710
      1 /5X,1H?) 00002720
ISN 224 READ(NI,510)VES(J,31) 00002730
ISN 225 IF(ECHO)WRITE(NO,5510)VES(J,31) 00002740
ISN 227 150 IF(IND.NE.0)WRITE(NO,635)(CAT(L),L=1,2) 00002750

```

```

      * ..... 1 ..... 2 ..... 3 ..... 4 ..... 5 ..... 6 ..... 7 ..... 8
ISN   229      IF(IND.EQ.0)WRITE(NO,635)(ANI(L),L=1,2)          00002760
ISN   231      635 FORMAT(/SX,'ENTER ',A4,A2,' RESIN REGENERANT LEVEL', 00002770
            1      '(LB/CU FT)',/SX,1H?)          00002780
ISN   232      READ(NI,510)VES(J,10)          00002790
ISN   233      IF(ECHO)WRITE(NO,5510)VES(J,10)          00002800
ISN   235      IF(IND.NE.0)WRITE(NO,636)(CAT(L),L=1,2)          00002810
ISN   237      IF(IND.EQ.0)WRITE(NO,636)(ANI(L),L=1,2)          00002820
ISN   239      636 FORMAT(/SX,'ENTER ',A4,A2,' RESIN CAPACITY EFFECTIVENESS', 00002830
            1      '(PERCENT)',/SX,1H?)          00002840
ISN   240      READ(NI,510)VES(J,12)          00002850
ISN   241      IF(ECHO)WRITE(NO,5510)VES(J,12)          00002860
ISN   243      VES(J,6)=PI*(VES(J,1)/2.0-VES(J,7))*2/144.0 00002870
ISN   244      VES(J,3)=VES(J,6)+VES(J,5)/12.0          00002880
            C      IF(IND.NE.1) GO TO 200          00002890
            C 154 WRITE(NO,633)(ANI(L),L=1,2)          00002900
            C      READ(NI,503)IMBV(IMB,1)          00002910
            C      IF(ECHO)WRITE(NO,5503)IMBV(IMB,1)          00002920
            C      IRES=IMBV(IMB,1)          00002930
            C 155 IRES=IRES-100          00002940
            C      IF(DIAG)WRITE(NO,6600)IRES          00002950
            C      IF(IRES.GT.100) GO TO 155          00002960
            C      IF(IRES.GE.20) GO TO 156          00002970
            C      GO TO 154          00002980
            C 156 IMBV(IMB,2)=IAR          00002990
            C      WRITE(NO,634)          00003000
            C      READ(NI,510)VES(J,31)          00003010
            C      IF(ECHO)WRITE(NO,5510)VES(J,31)          00003020
            C      WRITE(NO,635)ANI          00003030
            C      READ(NI,510)MBV(IMB,4)          00003040
            C      IF(ECHO)WRITE(NO,5510)MBV(IMB,4)          00003050
            C      WRITE(NO,636)ANI          00003060
            C      READ(NI,510)MBV(IMB,6)          00003070
            C      IF(ECHO)WRITE(NO,5510)MBV(IMB,6)          00003080
            C      MBV(IMB,3)=VES(J,3)/(MBV(IMB,1)+1.0) 00003090
            C      MBV(IMB,2)=VES(J,3)-MBV(IMB,3)          00003100
            C      GO TO 200          00003110
ISN   245      190 WRITE(NO,638)          00003120
ISN   246      638 FORMAT(/SX,'ENTER DEGASIFIER EFFLUENT CO2', 00003130
            1      'CONCENTRATION',/SX,1H?)          00003140
ISN   248      READ(NI,510)WAN(J+1,14)          00003150
ISN   249      IF(ECHO)WRITE(NO,5510)WAN(J+1,14)          00003160
ISN   251      IF(SUBI)WRITE(NO,6660)          00003170
ISN   253      6660 FORMAT(1X,'DECON')          00003180
ISN   254      CALL DECON(IWAU,WAN,J)          00003190
ISN   255      IF(SUBI)WRITE(NO,6660)          00003200
ISN   257      200 CONTINUE          00003210
ISN   258      WRITE(NO,641)          00003220
ISN   259      641 FORMAT(1X,'RUN CURRENT CASE OR EDIT',/SX, 00003230
            1      '1-RUN',/SX,'2-EDIT',/1X,1H?)          00003240
ISN   260      READ(NI,500)IOP          00003250
ISN   261      IF(ECHO)WRITE(NO,5500)IOP          00003260
ISN   263      IF(IOP.NE.1) GO TO 4000          00003270
ISN   264      1000 DO 1200 J=1,NV          00003280
ISN   265      IF(IVES(J,2))1015,1015,1010          00003290
ISN   266      1010 VP=IVES(J,2)          00003300
ISN   267      VES(J,29)=QSYS/VP          00003310

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      268          GO TO 1020                      00003320
ISN      269      1015 IVES(J,2)=1                    00003330
ISN      270          VES(J,29)=OSYS                  00003340
ISN      271      1020 IF(IVES(J,1))1100,1100,1025    00003350
ISN      272      1025 IND=IVES(J,1)-2                00003360
ISN      273          IF(IND)1030,1040,1050          00003370
ISN      274      1030 IF(SUBI)WRITE(NO,6670)         00003380
ISN      275      6670 FORMAT(1X,'CRESIN')            00003390
ISN      276          CALL CRESIN(J)                 00003400
ISN      277          IF(SUBI)WRITE(NO,6680)          00003410
ISN      278      6680 FORMAT(1X,'CRESIN',/1X,'CREGN') 00003420
ISN      279          CALL CREGN(J)                 00003430
ISN      280          IF(SUBI)WRITE(NO,6690)         00003440
ISN      281      6690 FORMAT(1X,'CREGN')            00003450
ISN      282          GO TO 1200                     00003460
ISN      283      1040 IF(SUBI)WRITE(NO,6700)         00003470
ISN      284      6700 FORMAT(1X,'ARESIN')            00003480
ISN      285          CALL ARESIN(J)                 00003490
ISN      286          IF(SUBI)WRITE(NO,6710)         00003500
ISN      287      6710 FORMAT(1X,'ARESIN',/1X,'AREGN') 00003510
ISN      288          CALL AREGN(J)                 00003520
ISN      289          IF(SUBI)WRITE(NO,6720)         00003530
ISN      290      6720 FORMAT(1X,'AREGN')            00003540
ISN      291          GO TO 1200                     00003550
ISN      292      1050 CONTINUE                      00003560
ISN      293          GO TO 1200                     00003570
ISN      294      1100 JP=J+1                        00003580
ISN      295          CO2=WAN(JP,14)                  00003590
ISN      296          DO 1105 I=1,15                  00003600
ISN      297          WAN(JP,I)=WAN(J,I)              00003610
ISN      298          CONTINUE                        00003620
ISN      299          WAN(JP,14)=CO2                  00003630
ISN      300          IND=IVES(JP,I)-2                00003640
ISN      301          IF(IND)1200,1110,1200          00003650
ISN      302      1110 DO 1111 K=7,12                00003660
ISN      303          TDS=TDS+WAN(JP,K)              00003670
ISN      304          CONTINUE                        00003680
ISN      305          WAN(JP,I)=TDS                  00003690
ISN      306          GO TO 1200                     00003700
ISN      307      1200 CONTINUE                      00003710
ISN      308          IF(SUBI)WRITE(NO,6730)         00003720
ISN      309      6730 FORMAT(1X,'MASBAL')            00003730
ISN      310          CALL MASBAL(NV, TOP, OG, ON, TA, TC) 00003740
ISN      311          IF(SUBI)WRITE(NO,6730)         00003750
ISN      312          IF(.NOT.DIAG) GO TO 3000        00003760
ISN      313          WRITE(NO,2600)                 00003770
ISN      314          FORMAT(/5X,'WAN',/)            00003780
ISN      315          DO 2010 I=1,15                  00003790
ISN      316          WRITE(NO,2601)I,WAN(1,I)        00003800
ISN      317      2601 FORMAT(5X,12,5X,E12.6)        00003810
ISN      318          CONTINUE                        00003820
ISN      319          DO 2100 J=1,NV                  00003830
ISN      320          K=J+1                          00003840
ISN      321          WRITE(NO,2602)J                 00003850
ISN      322      2602 FORMAT(/5X,'VESSEL ',11,/)    00003860
ISN      323          WRITE(NO,2603)                 00003870

```



```

      1.....2.....3.....4.....5.....6.....7.....8
ISN   332   2603  FORMAT(5X,'IVES',/)                00003880
ISN   333           DD 2605 I=1,8                    00003890
ISN   334           WRITE(NO,2604)I,IVES(J,1)        00003900
ISN   335   2604  FORMAT(5X,I1,5X,I3)                00003910
ISN   336           2605  CONTINUE                    00003920
ISN   337           WRITE(NO,2606)                   00003930
ISN   338   2606  FORMAT(/5X,'VES',/)                00003940
ISN   339           DD 2608 I=1,32                   00003950
ISN   340           WRITE(NO,2607)I,VES(J,1)         00003960
ISN   341   2607  FORMAT(5X,I2,5X,E12.6)             00003970
ISN   342           2608  CONTINUE                    00003980
ISN   343           WRITE(NO,2600)                   00003990
ISN   344           DD 2609 I=1,15                    00004000
ISN   345           WRITE(NO,2601)I,WAN(K,1)         00004010
ISN   346           2609  CONTINUE                    00004020
ISN   347           2100  CONTINUE                    00004030
ISN   348           WRITE(NO,2620)TDP                 00004040
ISN   349   2620  FORMAT(/5X,'TOP=',F10.2)          00004050
ISN   350           C      GO TO 4000                 00004060
ISN   351           NV1=NV+1                          00004070
ISN   352   3000  DD 3001 I=1,NV1                     00004080
ISN   353           CALL CONWAT(IWAW,WAN,I)           00004090
ISN   354           3001  CONTINUE                    00004100
ISN   355           3002  IPG=IPG+1                    00004110
ISN   356           CALL HEADG(IPG)                   00004120
ISN   357           WRITE(NO,3600)                    00004130
ISN   358   3600  FORMAT(5X,'*** OUTPUT SELECTION ***',/5X,
ISN   359           1      'ENTER OUTPUT TYPE',/10X,'0 - COMPLETE',
ISN   360           2      '/10X,'1 - SYSTEM DESIGN',/10X,'2 - SYSTEM
ISN   361           3      'PERFORMANCE',/10X,'3 - VESSEL DESIGN',/10X,
ISN   362           4      '4 - VESSEL PERFORMANCE',/10X,'5 - EDIT INPUT',
ISN   363           5      'DATA',/10X,'6 - EXIT PROGRAM',/5X,IH?)
ISN   364           READ(NI,500)IOT                    00004200
ISN   365           IF(ECHO)WRITE(NO,5500)IOT         00004210
ISN   366           IF(IOT.EQ.0) GO TO 3005            00004220
ISN   367           GO TO(3010,3100,3200,3300,4000,5000),IOT
ISN   368           3005  COUT=.TRUE.                  00004230
ISN   369           3010  IPG=IPG+1                    00004240
ISN   370           CALL HEADG(IPG)                   00004250
ISN   371           WRITE(NO,3601)                    00004260
ISN   372           3601  FORMAT(5X,'*** OVERALL SYSTEM DESIGN ***',/)
ISN   373           WRITE(NO,3602)OSYS                 00004270
ISN   374           3602  FORMAT(5X,'SYSTEM FLOW RATE',10X,F6.1,' GPM')
ISN   375           WRITE(NO,3603)(WUNIT(IWAW,I),I=1,4) 00004280
ISN   376           3603  FORMAT(/5X,'INFLUENT WATER ANALYSIS',7X,4A4,/)
ISN   377           DO 3020 I=2,14                     00004290
ISN   378           WRITE(NO,3604)IONS(I-1),WAN(1,I)  00004300
ISN   379           3604  FORMAT(10X,A4,21X,F10.4)     00004310
ISN   380           3020  CONTINUE                    00004320
ISN   381           WRITE(NO,3605)WAN(1,15)           00004330
ISN   382           3605  FORMAT(/5X,'INFLUENT TEMPERATURE',6X,F6.1,' F')
ISN   383           WRITE(NO,3606)                    00004340
ISN   384           3606  FORMAT(/5X,'SYSTEM CONFIGURATION',/)
ISN   385           DD 3030 I=1,NV                     00004350
ISN   386           IVT=IVES(I,1)+3                  00004360
ISN   387           GO TO(3021,3022,3023,3023,3024,3025),IVT
ISN   388           00004370
ISN   389           00004380
ISN   390           00004390
ISN   391           00004400
ISN   392           00004410
ISN   393           00004420
ISN   394           00004430

```

```

*.....1.....2.....3.....4.....5.....6.....7*.....8
ISN      383      3021 WRITE(NO,3607)I
ISN      384      3607 FORMAT(10X,'VESSEL ',I1,12X,'VACUUM DEGASIFIER')
ISN      385          GO TO 3030
ISN      386      3022 WRITE(NO,3608)I
ISN      387      3608 FORMAT(10X,'VESSEL ',I1,12X,'FORCED DRAFT DEGASIFIER')
ISN      388          GO TO 3030
ISN      389      3023 WRITE(NO,3609)I
ISN      390      3609 FORMAT(10X,'VESSEL ',I1,12X,'CATION EXCHANGER')
ISN      391          GO TO 3030
ISN      392      3024 WRITE(NO,3610)I
ISN      393      3610 FORMAT(10X,'VESSEL ',I1,12X,'ANION EXCHANGER')
ISN      394          GO TO 3030
ISN      395      3025 WRITE(NO,3611)I
ISN      396      3611 FORMAT(10X,'VESSEL ',I1,12X,'MIXED BED EXCHANGER')
ISN      397      3030 CONTINUE
ISN      398          WRITE(NO,3612)
ISN      399      3612 FORMAT(/5X,'NUMBER OF VESSELS IN PARALLEL',/)
ISN      400          DO 3040 I=1,NV
ISN      401          WRITE(NO,3613)I,IVES(I,2)
ISN      402      3613 FORMAT(10X,'VESSEL ',I1,12X,I1)
ISN      403      3040 CONTINUE
ISN      404          WRITE(NO,3614)
ISN      405      3614 FORMAT(/5X,'REGENERANT CHEMICALS',/10X,
1          'CATION RESIN',8X,'93 PERCENT SULFURIC ',
2          'ACID',/10X,'ANION RESIN',9X,'50 PERCENT ',
3          'SODIUM HYDROXIDE')
ISN      406          IF(COUT) GO TO 3100
ISN      407          GO TO 3002
ISN      408      3100 IPG=IPG+1
ISN      409          CALL HEADG(IPG)
ISN      410          WRITE(NO,3620)
ISN      411      3620 FORMAT(5X,'**** OVERALL SYSTEM PERFORMANCE ****',/)
ISN      412          WRITE(NO,3621)QG,QN,TOP
ISN      413      3621 FORMAT(5X,'THROUGHPUT',9X,'GALLONS PER REGENERATION',
1          '/10X,'GROSS',11X,F10.0,/10X,'NET',13X,F10.0,
2          '/5X,'OPERATING TIME',11X,F7.2,' HOURS')
ISN      414          WRITE(NO,3622)(WUNIT(IWAW,I),I=1,4)
ISN      415      3622 FORMAT(/5X,'EFFLUENT WATER ANALYSIS',7X,4A4,/)
ISN      416          DO 3110 I=2,14
ISN      417          WRITE(NO,3604)IONS(I-1),WAN(NV+1,I)
ISN      418      3110 CONTINUE
ISN      419          WRITE(NO,3623)TA,TC
ISN      420      3623 FORMAT(/5X,'TOTAL REGENERANT',3X,'GALLONS PER ',
1          'REGENERATION',/10X,'ACID',18X,F6.2,
2          '/10X,'CAUSTIC',15X,F6.2)
ISN      421          IF(COUT) GO TO 3220
ISN      422          GO TO 3002
ISN      423      3200 WRITE(NO,3630)NV
ISN      424      3630 FORMAT(/5X,'ENTER VESSEL NUMBER OR NUMBERS',
1          '/10X,'FORMATS - N OR',/18X,'- N M',
2          '/10X,'WHERE: N - INITIAL VESSEL',
3          '/18X,'M - FINAL VESSEL',
4          '/10X,'EXAMPLE: 1 ',I1,' - OUTPUT FOR ALL ',
5          'VESSELS',/5X,IH?)
ISN      425          READ(NI,3500)IVI,IVF
ISN      426      3500 FORMAT(I1,1X,I1)

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN 427 IF[ECHO]WRITE(NO,3560)IVI,IVF 00005000
ISN 428 3560 FORMAT(1X,I1,1X,I1) 00005010
ISN 430 IF(IVF.NE.0) GO TO 3210 00005020
ISN 431 IVF=IVI 00005030
ISN 432 GO TO 3230 00005040
ISN 433 3210 IF(IVI.GT.IVF) GO TO 3200 00005050
ISN 434 GO TO 3230 00005060
ISN 435 3220 IVI=1 00005070
ISN 436 IVF=NV 00005080
ISN 437 3230 DO 3290 I=IVI,IVF 00005090
ISN 438 IPG=IPG+1 00005100
ISN 439 CALL HEADG(IPG) 00005110
ISN 440 WRITE(NO,3640) 00005120
ISN 441 3640 FORMAT(5X,'*** VESSEL ',I1,' DESIGN***',//) 00005130
ISN 442 IF(IVES(I,1).LT.0) GO TO 3280 00005140
ISN 443 WRITE(NO,3641)VES(I,1),VES(I,7),VES(I,2),VES(I,6),VES(I,24) 00005150
ISN 444 3641 FORMAT(5X,'OUTSIDE DIAMETER (INCHES)',11X,F10.1, 00005160
1 //5X,'WALL THICKNESS (INCHES)',15X,F10.3, 00005170
2 //5X,'STRAIGHT SIDE (INCHES)',14X,F10.1, 00005180
3 //5X,'AREA (SQUARE FEET)',19X,F10.2, 00005190
4 //5X,'FLOW RATE PER VESSEL (GPM)',10X,F10.1) 00005200
ISN 445 IF(IVES(I,3).EQ.20)IRES=1 00005210
ISN 447 IF(IVES(I,3).EQ.22)IRES=2 00005220
ISN 449 IF(IVES(I,3).EQ.24)IRES=3 00005230
ISN 451 WRITE(NO,3642)(RESIN(IRES,J),J=1,2) 00005240
ISN 452 3642 FORMAT(5X,'RESIN TYPE',29X,'DOWEX ',2A4) 00005250
ISN 453 TVOL=VES(1,6)*(VES(1,4)+VES(1,5))/12.0 00005260
ISN 454 WRITE(NO,3643)VES(1,5),VES(1,3),VES(1,4),TVOL,VES(1,12) 00005270
ISN 455 3643 FORMAT(5X,'EFFECTIVE RESIN DEPTH (INCHES)',6X,F10.1, 00005280
1 //5X,'EFFECTIVE RESIN VOLUME (CU FT)',6X,F10.1, 00005290
2 //5X,'INEFFECTIVE RESIN DEPTH (INCHES)',4X,F10.1, 00005300
3 //5X,'TOTAL RESIN VOLUME (CU FT)',10X,F10.1, 00005310
4 //5X,'CAPACITY EFFECTIVENESS (PERCENT)',4X,F10.1) 00005320
ISN 456 IF(IVES(I,1).EQ.1)WRITE(NO,3644)VES(I,10) 00005330
ISN 458 3644 FORMAT(5X,'REGENERANT LEVEL (LB 93% H2SO4/CU FT)',5X, 00005340
1 F4.1) 00005350
ISN 459 IF(IVES(I,1).EQ.2)WRITE(NO,3645)VES(I,10) 00005360
ISN 461 3645 FORMAT(5X,'REGENERANT LEVEL (LB 100% NaOH/CU FT)',5X, 00005370
1 F4.1) 00005380
ISN 462 IF(IVES(I,1).EQ.2)WRITE(NO,3646)VES(I,31) 00005390
ISN 464 3646 FORMAT(5X,'REGENERATION TEMPERATURE (F)',8X,F10.1) 00005400
ISN 465 GO TO 3290 00005410
ISN 466 3280 IF(IVES(I,1).EQ.-1)WRITE(NO,3650)(WUNIT(IWAU,J),J=1,4), 00005420
1 WAN(I+1,14) 00005430
ISN 468 3650 FORMAT(5X,'FORCED DRAFT DEGASIFIER',14X,4A4, 00005440
1 //5X,'EFFLUENT CARBON DIOXIDE',17X,F10.4) 00005450
ISN 469 IF(IVES(I,1).EQ.-2)WRITE(NO,3651)(WUNIT(IWAU,J),J=1,4), 00005460
1 WAN(I+1,14) 00005470
ISN 471 3651 FORMAT(5X,'VACUUM DEGASIFIER',20X,4A4, 00005480
1 //5X,'EFFLUENT CARBON DIOXIDE',17X,F10.4) 00005490
ISN 472 3290 CONTINUE 00005500
ISN 473 IF(COUT) GO TO 3320 00005510
ISN 474 GO TO 3002 00005520
ISN 475 3300 WRITE(NO,3630) 00005530
ISN 476 READ(INI,3600)IVI,IVF 00005540
ISN 477 IF[ECHO]WRITE(NO,3560)IVI,IVF 00005550

```

```

*.....1.....2.....3.....4.....5.....6.....7*.....8
ISN 479 IF(IVF.NE.O) GO TO 3310 00005560
ISN 480 IVF=IV1 00005570
ISN 481 GO TO 3320 00005580
ISN 482 3310 IF(IVI.GT.IVF) GO TO 3300 00005590
ISN 483 3320 DO 3380 I=IV1,IVF 00005600
ISN 484 IPG=IPG+1 00005610
ISN 485 CALL HEADG(IPG) 00005620
ISN 486 WRITE(NO,3660)I 00005630
ISN 487 3660 FORMAT(5X,'*** VESSEL ',I1,' PERFORMANCE***',//) 00005640
ISN 488 IF(IVES(I,1).LT.O) GO TO 3380 00005650
ISN 489 UTIL=VES(I,8)/VES(I,8)*R100 00005660
ISN 490 WRITE(NO,3661)VES(I,13),VES(I,8),VES(I,9),UTIL,VES(I,14) 00005670
ISN 491 3661 FORMAT(5X,'CAPACITY:',/10X,'RESIN (KGR AS CAC03/CU FT)', 00005680
1 5X,F10.2,/10X,'VESSEL (KGR AS CAC03)',11X,F10.2, 00005690
2 /10X,'LOAD (KGR AS CAC03)',13X,F10.2,/10X, 00005700
3 'UTILIZATION (PERCENT)',11X,F10.2,/5X, 00005710
4 'THROUGHPUT (GAL/REGEN)',13X,F10.0) 00005720
ISN 492 WRITE(NO,3662)(WUNIT(IWAW,J),J=1,4) 00005730
ISN 493 3662 FORMAT(/5X,'EFFLUENT WATER ANALYSIS',7X,4A4,/) 00005740
ISN 494 DO 3330 J=2,14 00005750
ISN 495 WRITE(NO,3604)IDNS(J-1),WAN(I+1,J) 00005760
ISN 496 3330 CONTINUE 00005770
ISN 497 WRITE(NO,3663) 00005780
ISN 498 3663 FORMAT(/5X,'REGENERATION SUMMARY:',//12X, 00005790
1 'STEP',15X,'FLOW',10X,'VOLUME',8X, 00005800
2 'DURATION',/31X,'(GPM)',11X,'(GAL)',9X, 00005810
3 '[MIN]',/) 00005820
ISN 499 WRITE(NO,3664)VES(I,20),VES(I,15),VES(I,25) 00005830
ISN 500 3664 FORMAT(5X,'BACKWASH',13X,F10.1,5X,F10.0,5X,F10.2) 00005840
ISN 501 WRITE(NO,3665) 00005850
ISN 502 3665 FORMAT(5X,'REGN APPLICATION',/10X,'REGENERANT') 00005860
ISN 503 IVTP=IVES(I,1) 00005870
ISN 504 GO TO(3340,3350),IVTP 00005880
ISN 505 3340 IF(VES(I,22).LT.O) GO TO 3345 00005890
ISN 506 WRITE(NO,3666)VES(I,22),VES(I,17),VES(I,26) 00005900
ISN 507 3666 FORMAT(15X,'AT 6% H2SO4',F10.1,5X,F10.0,5X,F10.2) 00005910
ISN 508 WRITE(NO,3667)VES(I,21),VES(I,16),VES(I,26) 00005920
ISN 509 3667 FORMAT(10X,'DILUTION WATER',2X,F10.1,5X,F10.0,5X,F10.2) 00005930
ISN 510 GO TO 3360 00005940
ISN 511 3345 WRITE(NO,3668)RO(I,1),RVOL(I,1),TSTEP(I,1) 00005950
ISN 512 3668 FORMAT(15X,'AT 2% H2SO4',F10.1,5X,F10.0,5X,F10.2) 00005960
ISN 513 IF(ISTEP(I).LT.2) GO TO 3346 00005970
ISN 514 WRITE(NO,3669)RO(I,2),RVOL(I,2),TSTEP(I,2) 00005980
ISN 515 FORMAT(15X,'AT 4% H2SO4',F10.1,5X,F10.0,5X,F10.2) 00005990
ISN 516 IF(ISTEP(I).LT.3) GO TO 3346 00006000
ISN 517 WRITE(NO,3666)RO(I,3),RVOL(I,3),TSTEP(I,3) 00006010
ISN 518 IF(ISTEP(I).LT.4) GO TO 3346 00006020
ISN 519 WRITE(NO,3670)RO(I,4),RVOL(I,4),TSTEP(I,4) 00006030
ISN 520 3670 FORMAT(15X,'AT 8% H2SO4',F10.1,5X,F10.0,5X,F10.2) 00006040
ISN 521 3346 WRITE(NO,3671) 00006050
ISN 522 3671 FORMAT(10X,'DILUTION WATER') 00006060
ISN 523 WRITE(NO,3668)VES(I,21),DVOL(I,1),TSTEP(I,1) 00006070
ISN 524 IF(ISTEP(I).LT.2) GO TO 3360 00006080
ISN 525 WRITE(NO,3669)VES(I,21),DVOL(I,2),TSTEP(I,2) 00006090
ISN 526 IF(ISTEP(I).LT.3) GO TO 3360 00006100
ISN 527 WRITE(NO,3666)VES(I,21),DVOL(I,3),TSTEP(I,3) 00006110

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      528      IF(ISTEP(1).LT.4) GO TO 3360                00006120
ISN      529      WRITE(NO,3670)VES(1,21),DVOL(1,4),TSTEP(1,4) 00006130
ISN      530      GO TO 3360                                00006140
ISN      531      3350 WRITE(NO,3672)VES(1,22),VES(1,17),VES(1,26) 00006150
ISN      532      3672 FORMAT(15X,'AT 3% NADH',1X,F10.1,5X,F10.0,5X,F10.2) 00006160
ISN      533      WRITE(NO,3671)                            00006170
ISN      534      WRITE(NO,3672)VES(1,21),VES(1,16),VES(1,26) 00006180
ISN      535      3360 WRITE(NO,3673)VES(1,23),VES(1,18),VES(1,27) 00006190
ISN      536      3673 FORMAT(5X,'SLOW RINSE',1X,F10.1,5X,F10.0,5X,F10.2) 00006200
ISN      537      WRITE(NO,3674)VES(1,24),VES(1,19),VES(1,28) 00006210
ISN      538      3674 FORMAT(5X,'FAST RINSE',1X,F10.1,5X,F10.0,5X,F10.2) 00006220
ISN      539      3380 IF(IVES(1,1).EQ.-1)WRITE(NO,3650){WUNIT(IWAU,J),J=1,4}, 00006230
ISN      541      1 WAN(I+1,14)                                00006240
ISN      541      1 IF(IVES(1,1).EQ.-2)WRITE(NO,3651){WUNIT(IWAU,J),J=1,4}, 00006250
ISN      541      1 WAN(I+1,14)                                00006260
ISN      543      3390 CONTINUE                                00006270
ISN      544      GO TO 3002                                  00006280
ISN      545      4000 CONTINUE                                00006290
ISN      546      WRITE(NO,4600)                              00006300
ISN      547      4600 FORMAT(//1X,'****EDIT MENU****',//5X, 00006310
ISN      547      1 '0 - RUN CURRENT CASE',/5X, 00006320
ISN      547      2 '1 - LIST PROBLEM IDENTIFICATION',/5X, 00006330
ISN      547      3 '2 - LIST SYSTEM DESIGN DATA',/5X, 00006340
ISN      547      4 '3 - LIST VESSEL DESIGN DATA',/5X, 00006350
ISN      547      5 '4 - LIST VESSEL DESIGN DEFAULTS',/5X, 00006360
ISN      547      6 '5 - EDIT PROBLEM IDENTIFICATION',/5X, 00006370
ISN      547      7 '6 - EDIT SYSTEM DESIGN DATA',/5X, 00006380
ISN      547      8 '7 - EDIT VESSEL DESIGN DATA',/5X, 00006400
ISN      547      9 '8 - EDIT VESSEL DESIGN DEFAULTS',/5X, 00006410
ISN      547      0 '9 - NEW PROBLEM',/5X,1H?) 00006420
ISN      546      READ(N1,500)IEM                             00006430
ISN      549      IF(ECHO)WRITE(NO,5500)IEM                 00006440
ISN      551      IF(IEM.EQ.0)GO TO 1000                    00006450
ISN      552      GO TO(4010,4020,4030,4040,4100,4200,4300,4400,10),IEM 00006460
ISN      553      4010 WRITE(NO,4605)                        00006470
ISN      554      4605 FORMAT(/5X,'****PROBLEM IDENTIFICATION****') 00006480
ISN      555      WRITE(NO,4606){TITLE(1),I=1,10},{IDNUM(J),J=1,4} 00006490
ISN      556      4606 FORMAT(/5X,'TITLE: ',10A4,//5X,'ID NO: ',4A4) 00006500
ISN      557      WRITE(NO,4607){UNAME(1),I=1,6},{DATE(J),J=1,5} 00006510
ISN      558      4607 FORMAT(/5X,'USER NAME: ',6A4,//5X,'DATE: ',5A4) 00006520
ISN      559      WRITE(NO,4610)                              00006530
ISN      560      4610 FORMAT(//1X,'****ENTER SELECTION****',/5X, 00006540
ISN      560      1 '0 - RETURN TO EDIT MENU',/5X, 00006550
ISN      560      2 '1 - RUN CURRENT CASE',/1X,1H?) 00006560
ISN      561      READ(N1,500)ISL                             00006570
ISN      562      IF(ECHO)WRITE(NO,5500)ISL                 00006580
ISN      564      ISL=ISL+1                                   00006590
ISN      565      GO TO (4000,1000),ISL                      00006600
ISN      566      4020 WRITE(NO,4611)                        00006610
ISN      567      4611 FORMAT(/5X,'****SYSTEM DESIGN DATA****',/) 00006620
ISN      568      WRITE(NO,3602)OSYS                         00006630
ISN      569      WRITE(NO,3603){WUNIT(IWAU,I),I=1,4}      00006640
ISN      570      DD 4021 I=2,14                             00006650
ISN      571      WRITE(NO,3604)IONS(1-1),WAN(1,I)         00006660
ISN      572      4021 CONTINUE                                00006670
ISN      573      WRITE(NO,3605)WAN(1,15)                  00006670

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN 574 WRITE(NO,3606) 00006680
ISN 575 DO 4027 I=1,NV 00006690
ISN 576 IVT=IVES(I,1)+3 00006700
ISN 577 GO TO (4022,4023,4025,4026),IVT 00006710
ISN 578 4022 WRITE(NO,3607)I 00006720
ISN 579 GO TO 4027 00006730
ISN 580 4023 WRITE(NO,3608)I 00006740
ISN 581 GO TO 4027 00006750
ISN 582 4024 WRITE(NO,3609)I 00006760
ISN 583 GO TO 4027 00006770
ISN 584 4025 WRITE(NO,3610)I 00006780
ISN 585 GO TO 4027 00006790
ISN 586 4026 WRITE(NO,3611)I 00006800
ISN 587 4027 CONTINUE 00006810
ISN 588 WRITE(NO,3612) 00006820
ISN 589 DO 4028 I=1,NV 00006830
ISN 590 WRITE(NO,3613)I,IVES(I,2) 00006840
ISN 591 CONTINUE 00006850
ISN 592 WRITE(NO,4610) 00006860
ISN 593 READ(NI,500)ISL 00006870
ISN 594 IF(ECHO)WRITE(NO,5500)ISL 00006880
ISN 596 ISL=ISL+1 00006890
ISN 597 GO TO (4000,1000),ISL 00006900
ISN 598 4030 WRITE(NO,3630)NV 00006910
ISN 599 READ(NI,3500)IVI,IVF 00006920
ISN 600 IF(ECHO)WRITE(NO,3560)IVI,IVF 00006930
ISN 602 IF(IVF.NE.0)GO TO 4031 00006940
ISN 603 IVF=IVI 00006950
ISN 604 GO TO 4032 00006960
ISN 605 4031 IF(IVI.GT.IVF)GO TO 4030 00006970
ISN 606 4032 DO 4038 I=IVI,IVF 00006980
ISN 607 WRITE(NO,3640)I 00006990
ISN 608 IF(IVES(I,1).LT.0)GO TO 4038 00007000
ISN 609 WRITE(NO,4620)VES(I,1),VES(I,7),VES(I,2) 00007010
ISN 610 4620 FORMAT(5X,'OUTSIDE DIAMETER(INCHES)',11X,F10.1, 00007020
1 //5X,'WALL THICKNESS(INCHES)',15X,F10.3, 00007030
2 //5X,'STRAIGHT SIDE(INCHES)',14X,F10.1) 00007040
ISN 611 IF(IVES(I,3).EQ.20)IRES=1 00007050
ISN 613 IF(IVES(I,3).EQ.22)IRES=2 00007060
ISN 615 IF(IVES(I,3).EQ.24)IRES=3 00007070
ISN 617 WRITE(NO,3642)(RESIN(IRES,J),J=1,2) 00007080
ISN 618 WRITE(NO,4621)VES(I,5),VES(I,4),VES(I,12) 00007090
ISN 619 4621 FORMAT(/5X,'EFFECTIVE RESIN DEPTH(INCHES)',6X,F10.1, 00007100
1 //5X,'INEFFECTIVE RESIN DEPTH(INCHES)',4X,F10.1, 00007110
2 //5X,'CAPACITY EFFECTIVENESS(PERCENT)',4X,F10.1) 00007120
ISN 620 IF(IVES(I,1).EQ.1)WRITE(NO,3644)VES(I,10) 00007130
ISN 622 IF(IVES(I,1).EQ.2)WRITE(NO,3645)VES(I,10) 00007140
ISN 624 IF(IVES(I,1).EQ.2)WRITE(NO,3646)VES(I,31) 00007150
ISN 626 GO TO 4039 00007160
ISN 627 4038 IF(IVES(I,1).EQ.-1)WRITE(NO,3650)(WUNIT(IWAU,J),J=1,4), 00007170
1 WAN(I+1,14) 00007180
ISN 629 IF(IVES(I,1).EQ.-2)WRITE(NO,3651)(WUNIT(IWAU,J),J=1,4), 00007190
1 WAN(I+1,14) 00007200
ISN 631 4039 CONTINUE 00007210
ISN 632 WRITE(NO,4610) 00007220
ISN 633 READ(NI,500)ISL 00007230

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      634          IF(ECHO)WRITE(ND,5500)ISL                00007240
ISN      636          ISL=ISL+1                                00007250
ISN      637          GO TO (4000,1000),ISL                    00007260
ISN      638          4040 WRITE(ND,3630)NV                     00007270
ISN      639          READ(NI,3500)IVI,IVF                     00007280
ISN      640          IF(ECHO)WRITE(ND,3560)IVI,IVF            00007290
ISN      642          IF(IVF.NE.0) GO TO 4041                   00007300
ISN      643          IVF=IVI                                    00007310
ISN      644          GO TO 4042                                 00007320
ISN      645          4041 IF(IVI.GT.IVF) GO TO 4040            00007330
ISN      646          4042 DD 4080 I=IVI,IVF                    00007340
ISN      647          WRITE(ND,4630)I                            00007350
ISN      648          4630 FORMAT(5X,'***VESSEL ',I1,' DEFAULTS***',//) 00007360
ISN      649          IF(IVES(I,1).LT.0) GO TO 4060             00007370
ISN      650          4631 FORMAT(5X,'BACKWASH TIME(MIN): ',25X,F10.1) 00007380
ISN      651          IF(IVES(I,3).EQ.201)IRES=1               00007390
ISN      653          IF(IVES(I,3).EQ.221)IRES=2               00007400
ISN      655          IF(IVES(I,3).EQ.241)IRES=3               00007410
ISN      657          GO TO (4043,4044,4045),IRES              00007420
ISN      658          4043 BDEX=50.0                            00007430
ISN      659          FRV=25.0=VES(I,3)                         00007440
ISN      660          GO TO 4046                                 00007450
ISN      661          4044 BDEX=50.0                            00007460
ISN      662          FRV=100.0=VES(I,3)                        00007470
ISN      663          APTM=60.0                                  00007480
ISN      664          GO TO 4046                                 00007490
ISN      665          4045 BDEX=50.0                            00007500
ISN      666          FRV=75.0=VES(I,3)                         00007510
ISN      667          4046 IF(VES(I,30).NE.0)BDEX=VES(I,30)    00007520
ISN      669          WRITE(ND,4632)BDEX                        00007530
ISN      670          4632 FORMAT(/5X,'BED EXPANSION(%)':',28X,F10.1) 00007540
ISN      671          IF(IRES.NE.2) GO TO 4047                  00007550
ISN      672          IF(VES(I,26).NE.0)APTM=VES(I,26)        00007560
ISN      674          WRITE(ND,4633)APTM                        00007570
ISN      675          4633 FORMAT(/5X,'ANION REGENERANT APPLICATION TIME(MIN): ', 00007580
ISN      676          1 5X,F10.1)                               00007590
ISN      676          4047 IF(VES(I,18).NE.0)GO TO 4048         00007600
ISN      677          SRV=(VES(I,3)/2.0+0.75*VES(I,6))*1.5*7.48 00007610
ISN      678          GO TO 4049                                 00007620
ISN      679          4048 SRV=VES(I,18)                         00007630
ISN      680          4049 WRITE(ND,4634)SRV                    00007640
ISN      681          4634 FORMAT(/5X,'SLOW RINSE VOLUME(GAL)':',21X,F10.1) 00007650
ISN      682          IF(VES(I,19).NE.0)FRV=VES(I,19)         00007660
ISN      684          WRITE(ND,4635)FRV                         00007670
ISN      685          4635 FORMAT(/5X,'FAST RINSE VOLUME(GAL)':',21X,F10.1) 00007680
ISN      686          4060 CONTINUE                             00007690
ISN      687          WRITE(ND,4610)                             00007700
ISN      688          READ(NI,500)ISL                           00007710
ISN      689          IF(ECHO)WRITE(ND,5500)ISL                00007720
ISN      691          ISL=ISL+1                                  00007730
ISN      692          GO TO (4000,1000),ISL                     00007740
ISN      693          4100 CONTINUE                               00007750
ISN      694          4200 CONTINUE                               00007760
ISN      695          4300 CONTINUE                               00007770
ISN      696          4400 WRITE(ND,3630)NV                     00007780
ISN      697          READ(NI,3500)IVI,IVF                      00007790

```

```

      *.....1.....2.....3.....4.....5.....6.....7.....8
ISN      698      IF[ECHO]WRITE(NO,3560)IVI,IVF      00007800
ISN      700      IF[IVF.NE.O]GO TO 4401      00007810
ISN      701      IVF=IVI      00007820
ISN      702      GO TO 4402      00007830
ISN      703      4401 IF[IVI.GT.IVF] GO TO 4400      00007840
ISN      704      4402 DD 4500 I=IVI,IVF      00007850
ISN      705      IF[IVES(1,1).LT.O] GO TO 4500      00007860
ISN      706      4403 WRITE(NO,4650)I      00007870
ISN      707      4650 FORMAT(SX,'****EDIT VESSEL ',11,' DEFAULTS****',
1          /10X,'1 - CHANGE BACKWASH TIME',      00007880
2          /10X,'2 - CHANGE BACKWASH BED EXPANSION',      00007890
3          /10X,'3 - CHANGE SLOW RINSE VOLUME',      00007900
4          /10X,'4 - CHANGE FAST RINSE VOLUME')      00007920
ISN      708      IF[IVES(1,1).EQ.2]WRITE(NO,4651)      00007930
ISN      710      4651 FORMAT(10X,'5 - CHANGE ANION REGENERANT APPLICATION TIME')      00007940
ISN      711      READ(NI,500)ISL      00007950
ISN      712      IF[ECHO]WRITE(NO,5500)ISL      00007960
ISN      714      GO TO (4410,4420,4430,4440,4450),ISL      00007970
ISN      715      4410 WRITE(NO,4655)      00007980
ISN      716      4655 FORMAT(/5X,'ENTER BACKWASH TIME(MINUTES)',/5X,1H?)      00007990
ISN      717      READ(NI,510)VES(1,25)      00008000
ISN      718      IF[ECHO]WRITE(NO,5510)VES(1,25)      00008010
ISN      720      GO TO 4460      00008020
ISN      721      4420 WRITE(NO,4656)      00008030
ISN      722      4656 FORMAT(/5X,'ENTER BACKWASH BED EXPANSION(PERCENT)',/5X,1H?)      00008040
ISN      723      READ(NI,510)VES(1,30)      00008050
ISN      724      IF[ECHO]WRITE(NO,5510)VES(1,30)      00008060
ISN      726      GO TO 4460      00008070
ISN      727      4430 WRITE(NO,4657)      00008080
ISN      728      4657 FORMAT(/5X,'ENTER SLOW RINSE VOLUME(GALLONS)',/5X,1H?)      00008090
ISN      729      READ(NI,510)VES(1,18)      00008100
ISN      730      IF[ECHO]WRITE(NO,5510)VES(1,18)      00008110
ISN      732      GO TO 4460      00008120
ISN      733      4440 WRITE(NO,4658)      00008130
ISN      734      4658 FORMAT(/5X,'ENTER FAST RINSE VOLUME(GALLONS)',/5X,1H?)      00008140
ISN      735      READ(NI,510)VES(1,19)      00008150
ISN      736      IF[ECHO]WRITE(NO,5510)VES(1,19)      00008160
ISN      738      GO TO 4460      00008170
ISN      739      4450 WRITE(NO,4659)      00008180
ISN      740      4659 FORMAT(/5X,'ENTER REGENERANT APPLICATION TIME(MINUTES)',
1          /5X,1H?)      00008200
ISN      741      READ(NI,510)VES(1,26)      00008210
ISN      742      IF[ECHO]WRITE(NO,5510)VES(1,26)      00008220
ISN      744      4460 WRITE(NO,4665)      00008230
ISN      745      4665 FORMAT(/1X,'****ENTER SELECTION****',/5X,
1          '0 - CONTINUE TO EDIT DEFAULTS',/5X,      00008250
2          '1 - RETURN TO EDIT MENU',/5X,      00008260
3          '2 - RUN CURRENT CASE',/1X,1H?)      00008270
ISN      746      READ(NI,500)ISL      00008280
ISN      747      IF[ECHO]WRITE(NO,5500)ISL      00008290
ISN      748      ISL=ISL+1      00008300
ISN      750      GO TO (4470,4000,1000),ISL      00008310
ISN      751      4470 WRITE(NO,4666)      00008320
ISN      752      4666 FORMAT(/1X,'****ENTER SELECTION****',/5X,
1          '0 - SAME VESSEL',/5X,      00008330
2          '1 - NEXT VESSEL',/1X,1H?)      00008340

```


*.....1.....2.....3.....4.....5.....6.....7.....8

ISN	753	READ(NI,500)ISL	00008360
ISN	754	IF[ECHO]WRITE(NO,5500)ISL	00008370
ISN	756	ISL=ISL+1	00008380
ISN	757	GO TO (4403,4500),ISL	00008390
ISN	758	4500 CONTINUE	00008400
ISN	759	5000 STOP	00008410
ISN	760	END	00008420

*** VS FORTRAN ERROR MESSAGES ***

IFX00301 CNTL O(I) TRMFLG HAS BEEN SPECIFIED BUT SYSTEM IS NOT A TERMINAL. TRMFLG CANCELED.

STATISTICS SOURCE STATEMENTS = 668, PROGRAM SIZE = 39060 BYTES, PROGRAM NAME = MAIN PAGE: 1.

STATISTICS 1 DIAGNOSTIC GENERATED. SEVERITY CODE IS 0.

***** END OF COMPILATION 1 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

      *.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1          BLOCK DATA
ISN      2          DIMENSION IVES(9,8),VES(9,32),MBV(2,20),
                   1          WAN(10,15),IMBV(2,5),ISTEP(9),RQ(9,4),
                   2          RVOL(9,4),DVOL(9,4),TSTEP(9,4)
ISN      3          COMMON /DESD/WAN,VES,IVES
ISN      4          COMMON /DESM/MBV,IMBV
ISN      5          COMMON /STEP/ISTEP,RQ,RVOL,DVOL,TSTEP
ISN      6          COMMON /ID/NI,NO,IOUT
ISN      7          DATA WAN/150*0.0/
ISN      8          DATA VES/288*0.0/
ISN      9          DATA IVES/72*0.0/
ISN     10          DATA MBV/40*0.0/
ISN     11          DATA IMBV/10*0.0/
ISN     12          DATA NI,NO,IOUT/5,6,1/
ISN     13          DATA ISTEP/9*0/
ISN     14          END
                   00008430
                   00008440
                   00008450
                   00008460
                   00008470
                   00008480
                   00008490
                   00008500
                   00008510
                   00008520
                   00008530
                   00008540
                   00008550
                   00008560
                   00008570
                   00008580

```

STATISTICS SOURCE STATEMENTS = 14, PROGRAM SIZE = 0 BYTES, PROGRAM NAME = BLKDT# PAGE: 17.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 2 *****

OPTIONS IN EFFECT: NGLIST NOMAP NOXREF NOGOSTMT NODACK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1      SUBROUTINE WATCON (IWAU,WAN,CNA)                00008590
ISN      2      LOGICAL QL                                  00008600
ISN      3      DIMENSION WAN(10,15),CFS(13)                00008610
ISN      4      COMMON/ID/NI,ND,IOUT                        00008620
ISN      5      DATA CFE,CFS/50.0,50.0,2.5,4.11,2.17,1.28,2.94,1.67,
ISN          1      0.82,1.04,1.41,0.81,0.835,1.14/          00008630
ISN      6      QL=.FALSE.                                  00008640
ISN      7      IF(IOUT GE.5)QL=.TRUE.                      00008650
ISN      8      CNA=O                                        00008660
ISN      9      IND=IWAU-2                                  00008670
ISN     10      IF(IND)100,120,110                          00008680
ISN     11      DD 101 I=2,14                               00008690
ISN     12      WAN(1,1)=WAN(1,1)+CFS(I-1)                 00008700
ISN     13      101 CONTINUE                               00008710
ISN     14      GO TO 120                                  00008720
ISN     15      110 DD 111 I=2,14                          00008730
ISN     16      WAN(1,1)=WAN(1,1)+CFE                     00008740
ISN     17      111 CONTINUE                               00008750
ISN     18      120 CAT=WAN(1,2)+WAN(1,3)+WAN(1,4)+WAN(1,5)+WAN(1,6)
ISN     19      ANI=WAN(1,7)+WAN(1,8)+WAN(1,9)+WAN(1,10)+WAN(1,11)
ISN     20      1      +WAN(1,12)                          00008760
ISN     21      DIF=ANI-CAT                                00008770
ISN     22      IF(DIF.LE.1.0) GO TO 130                   00008780
ISN     23      IF(DIF.GE.-1.0) GO TO 130                  00008790
ISN     24      WAN(1,5)=WAN(1,5)+DIF                      00008800
ISN     25      CNA=WAN(1,5)                               00008810
ISN     26      IF(IND) 121,130,122                       00008820
ISN     27      121 CNA=WAN(1,5)/CFS(4)                   00008830
ISN     28      GO TO 130                                  00008840
ISN     29      122 CNA=WAN(1,5)/CFE                       00008850
ISN     30      130 IF(QL)WRITE(ND,600){WAN(1,1),I=1,15} 00008860
ISN     31      600 FORMAT(1X,E12.5)                      00008870
ISN     32      RETURN                                     00008880
ISN     33      END                                        00008890
ISN     34

```

STATISTICS SOURCE STATEMENTS = 32, PROGRAM SIZE = 1944 BYTES, PROGRAM NAME = WATCON PAGE: 18.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 3 *****

OPTIONS IN EFFECT: NDLIST NOMAP NOXREF NOGDSTMT NODECK SOURCE NOTERM OBJECT FIXED NDTTEST NOTRMFLG SRCFLG NOSYM
 OPT(0) LANGLVL(66) NDFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

      *.....1.....2.....3.....4.....5.....6.....7.....8
ISN   1      SUBROUTINE DECON (IWAU,WAN,J)                00008930
ISN   2      LOGICAL QL                                  00008940
ISN   3      DIMENSION WAN(10,15)                        00008950
ISN   4      COMMON/IO/NI,NO,IOUT                       00008960
ISN   5      DATA CFS,CFE/1.14,50.0/                  00008970
ISN   6      QL=.FALSE.                                  00008980
ISN   7      IF(IOUT.GE.5)QL=.TRUE.                     00008990
ISN   8      I=J+1                                       00009000
ISN   9      IND=IWAW-2                                   00009010
ISN  10      IF(IND)100,120,110                          00009020
ISN  11      100 WAN(I,14)=WAN(J,14)*CFS                 00009030
ISN  12      GO TO 120                                    00009040
ISN  13      110 WAN(I,14)=WAN(J,14)*CFE                 00009050
ISN  14      120 IF(QL)WRITE(NO,600)(WAN(I,J),J=1,15)    00009060
ISN  15      600 FORMAT(1X,E12.5)                        00009070
ISN  16      RETURN                                       00009080
ISN  17      END                                         00009090

```

STATISTICS SOURCE STATEMENTS = 17, PROGRAM SIZE = 1122 BYTES, PROGRAM NAME = DECON PAGE: 19.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 4 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMPLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

      *.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1      SUBROUTINE CRESIN (J)                                00009100
ISN      2      LOGICAL QL                                        00009110
ISN      3      DIMENSION WAN(10,15),IVES(9,8),YES(9,32)          00009120
ISN      4      COMMON/ID/N1,NO,IQUT                                00009130
ISN      5      COMMON/DESD/WAN,YES,IVES                          00009140
ISN      6      COMMON/CWAT/TC,ALK,TMA,PNA,PALK,PMG,PCA,PMGN      00009150
ISN      7      QL=.FALSE.                                        00009160
ISN      8      IF(IQUT.GE.5)QL=.TRUE.                            00009170
ISN      9      R100=100.0                                        00009180
ISN     10      TC=WAN(J,2)+WAN(J,3)+WAN(J,4)+WAN(J,5)+WAN(J,6)    00009190
ISN     11      PNA=(WAN(J,5)+WAN(J,6))/TC+R100                    00009200
ISN     12      PMG=WAN(J,4)/TC+R100                               00009210
ISN     13      PCA=WAN(J,3)/TC+R100                              00009220
ISN     14      TH=WAN(J,3)+WAN(J,4)                             00009230
ISN     15      IF(TH.GT.0.0) GO TO 50                            00009240
ISN     16      PMGN=0.0                                          00009250
ISN     17      GO TO 51                                          00009260
ISN     18      50 PMGN=WAN(J,4)/TH+R100                          00009270
ISN     19      51 ALK=WAN(J,7)+WAN(J,8)+WAN(J,9)                 00009280
ISN     20      TMA=ALK+WAN(J,10)+WAN(J,11)+WAN(J,12)            00009290
ISN     21      PALK=ALK/TMA+R100                                 00009300
ISN     22      IR=IVES(J,3)                                     00009310
ISN     23      IF(QL)WRITE(ND,601)TC,ALK,TMA,PNA,              00009320
ISN     24      1 PALK,PMG,PCA,PMGN,IR                          00009330
ISN     25      601 FORMAT(1X,'TC= ',E12.5,'/1X','ALK= ',E12.5,'/1X,  00009340
ISN     26      1 'TMA= ',E12.5,'/1X','PNA= ',E12.5,'/1X','PALK= ',  00009350
ISN     27      2 E12.5,'/1X','PMG= ',E12.5,'/1X','PCA= ',E12.5,'/1X,  00009360
ISN     28      3 'PMGN= ',E12.5,'/1X','IR= ',I3)                00009370
ISN     29      I=IR/100                                         00009380
ISN     30      GO TO(100,200,300,400),I                        00009390
ISN     31      100 I=(IR-100)/10+1                               00009400
ISN     32      GO TO (101,110),I                                00009410
ISN     33      101 CONTINUE                                     00009420
ISN     34      110 CONTINUE                                     00009430
ISN     35      GO TO 1000                                        00009440
ISN     36      200 I=(IR-200)/10+1                               00009450
ISN     37      GO TO (201,203,211),I                            00009460
ISN     38      201 IF(QL)WRITE(ND,602)                          00009470
ISN     39      602 FORMAT(1X,'DHCRS')                          00009480
ISN     40      CALL DHCRS(J)                                    00009490
ISN     41      IF(QL)WRITE(ND,602)                              00009500
ISN     42      GO TO 999                                         00009510
ISN     43      203 CONTINUE                                     00009520
ISN     44      211 CONTINUE                                     00009530
ISN     45      GO TO 1000                                        00009540
ISN     46      300 I=(IR-300)/10+1                               00009550
ISN     47      GO TO (301,311),I                                00009560
ISN     48      301 CONTINUE                                     00009570
ISN     49      311 CONTINUE                                     00009580
ISN     50      GO TO 1000                                        00009590
ISN     51      400 I=(IR-400)/10+1                               00009600
ISN     52      GO TO 401                                         00009610
ISN     53      401 CONTINUE                                     00009620

```

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NDECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMLG SRCFLG WOSYM
 DPT(0) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

      *.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1      SUBROUTINE DHCRS(J)                                00009700
ISN      2      REAL NCAP                                          00009710
ISN      3      LOGICAL QL                                         00009720
ISN      4      DIMENSION WAN(10,15),IVES(9,8),VES(9,32),DNAL(9),
1DML(9),DBL(9),DPNC(6),DPAC(3),DMC(6,3),DBC(6,3),
2DCT(5),DFT(5),DBW(9),DBE(9)                                     00009730
ISN      5      COMMON/ID/NI,NO,IDUT                                00009740
ISN      6      COMMON/DESD/WAN,VES,IVES                            00009750
ISN      7      COMMON/CWAT/TC,ALK,TMA,PNA,PALK,PMG,PCA,PMGN      00009760
ISN      8      DATA DNAL/0.0,20.0,40.0,50.0,60.0,70.0,80.0,
190.0,100.0/                                                    00009770
ISN      9      DATA DML/-1.243,-0.4142,-0.2629,-0.1745,-0.1157,
1-0.08441,-0.06028,-0.04237,-0.03445/                          00009780
ISN     10      DATA DBL/2.503,2.503,2.719,2.715,2.707,2.743,
12.787,2.825,2.843/                                             00009790
ISN     11      DATA B1,B2,B3,B4/1.000814,-6.109762E-3,
1-8.648535E-6,-3.016536E-7/                                    00009800
ISN     12      DATA DPNC/0.0,20.0,40.0,60.0,80.0,100.0/       00009810
ISN     13      DATA DPAC/0.0,50.0,100.0/                        00009820
ISN     14      DATA DMC/0.1232112,0.1113266,0.1020957,0.0921048,
10.0752088,0.0882422,0.1232112,0.1122203,0.1008939,
20.0977334,0.0838716,0.0971294,0.1232112,0.1143136,
30.1029766,0.0977334,0.0838716,0.0971294/                     00009830
ISN     15      DATA DBC/-0.4836166,-0.357857,-0.258914,-0.0763162,
1-0.2511519,-0.1556087,-0.4836166,-0.4331589,
2-0.3055134,-0.3119608,-0.0582378,-0.5628272,
3-0.4836166,-0.5296028,-0.4232008,-0.6274264,
4-0.6671997,-0.7571206/                                       00009840
ISN     16      DATA PM,BP,PPM,BPP/-0.0003,0.03,0.0075,-0.75/   00009850
ISN     17      DATA B1,B2,B3,B4/-2.466667E+1,7.591991,
1-1.433682E-1,9.469597E-4/                                    00009860
ISN     18      DATA FF1,FF2,FF3,FF4/1.145102E+2,-3.056652,3.154240E-2,
1-1.242890E-4/                                                00010010
ISN     19      DATA DCT/0.0,25.0,50.0,75.0,100.0/             00010020
ISN     20      DATA DFT/0.5,0.5,1.0,1.5,2.25/                 00010030
ISN     21      DATA DBW/0.0,2.0,4.0,6.0,8.0,10.0,12.0,14.0,14.72/
1100.0/                                                         00010040
ISN     22      DATA DBE/0.0,10.0,21.2,34.7,49.5,64.0,79.0,93.9,
1100.0/                                                         00010050
ISN     23      TDS=0.0                                           00010060
ISN     24      QL=.FALSE.                                         00010070
ISN     25      IF(IOUT.GE.5) QL=.TRUE.                            00010080
ISN     26      DO 1 K=2,6                                          00010090
ISN     27      TDS=TDS+WAN(J,K)                                    00010100
ISN     28      1 CONTINUE                                         00010110
ISN     29      WAN(J,1)=TDS                                        00010120
ISN     30      DO 2 I=1,15                                         00010130
ISN     31      WAN(J+1,I)=WAN(J,I)                                00010140
ISN     32      2 CONTINUE                                         00010150
ISN     33      R100=100.0                                         00010160
ISN     34      RL=VES(J,10)                                       00010170
ISN     35      RLL=ALOG(RL)                                       00010180
ISN     36      IF(PNA.NE.0.0)GO TO 3                              00010190
ISN     37      PNAL=0.0                                           00010200
ISN     38
    
```

```
*.....1.....2.....3.....4.....5.....6.....7.....8
ISN 54 GO TO 1000 0000630
ISN 55 999 RETURN 0000640
ISN 56 1000 WRITE (ND,600)J 0000650
ISN 57 600 FORMAT(5X,'***SELECT ANOTHER CATION RESIN***',
1 /5X,'*** FOR VESSEL ',I1,'***') 0000660
ISN 58 RETURN 0000680
ISN 59 END 0000690
```

STATISTICS SOURCE STATEMENTS = 55, PROGRAM SIZE = 3224 BYTES, PROGRAM NAME = CRESIN PAGE: 20.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 5 *****

```

*.....1.....2.....3.....4.....5.....6.....7.*.....8
ISN      39          TNAL=0.0                      00010230
ISN      40          GO TO 4                          00010240
ISN      41          3 FA=A1+PALK*(A2+PALK*(A3+PALK*A4)) 00010250
ISN      42          CM=F1(PNA,9,DNAL,DML)             00010260
ISN      43          CB=F1(PNA,9,DNAL,DBL)             00010270
ISN      44          PNAL=(RLL-CB)/CM                  00010280
ISN      45          TNAL=FA+TMA*PNAL/R100            00010290
ISN      46          IF(OL)WRITE(ND,610)PNAL,FA        00010300
ISN      48          PNAL=TNAL*R100/TC                 00010310
ISN      48          4 WAN(J+1,5)=TNAL                 00010320
ISN      50          IF(PMGN.GT.0.0) GO TO 5           00010330
ISN      51          CMG=0.0                            00010340
ISN      52          GO TO 6                            00010350
ISN      53          5 CMG=(PM*PNA+BP)*PMGN+PPM*PNA+BPP 00010360
ISN      54          6 CCAP=F2(PNA,PALK,6,3,DPNC,DPAC,DMC,DBC,RLL)+CMG 00010370
ISN      55          FTP=R100/(R100-PNAL)              00010380
ISN      56          IF(VES(J,5).GT.18.0) GO TO 10     00010390
ISN      57          FBD=(VES(J,5)/18.0)=0.71          00010400
ISN      58          GO TO 20                           00010410
ISN      59          10 IF(VES(J,5).GT.60.0) GO TO 15   00010420
ISN      60          X=VES(J,5)                         00010430
ISN      61          FBD=(B1+X*(B2+X*(B3+X*B4)))/R100  00010440
ISN      62          GO TO 20                           00010450
ISN      63          15 FBD=1.2                         00010460
ISN      64          20 AREA=VES(J,6)                  00010470
ISN      65          OPA=VES(J,29)/AREA                 00010480
ISN      66          IF(OPA.GT.5.0) GO TO 30            00010490
ISN      67          FSR=1.0                            00010500
ISN      68          GO TO 40                           00010510
ISN      69          30 FSR=(FF1+OPA*(FF2+OPA*(FF3+OPA*FF4)))/R100 00010520
ISN      70          40 FEF=VES(J,12)/R100              00010530
ISN      71          CCAP=CCAP+FBD*FSR*FTP             00010540
ISN      72          IF(OL)WRITE(ND,610)CCAP,CCAP,FBD,FSR,FTP,CMG 00010550
ISN      74          610 FORMAT(1X,E12.5)               00010560
ISN      75          VES(J,11)=CCAP                    00010570
ISN      76          NCAP=CCAP*FEF                     00010580
ISN      77          VES(J,13)=NCAP                     00010590
ISN      78          CAP=VES(J,3)*NCAP                  00010600
ISN      79          VES(J,8)=CAP                       00010610
ISN      80          IF(VES(J,30).GT.0.0) GO TO 50     00010620
ISN      81          VES(J,30)=50.0                     00010630
ISN      82          50 BWRA=F1(VES(J,30),9,DBE,DBW)*(1.0+0.008*(WAN(J,15) 00010640
ISN      83          1 -77.0))                          00010650
ISN      83          BWR=BWRA*AREA                      00010660
ISN      84          IF(OL)WRITE(ND,610)BWRA,BWR        00010670
ISN      86          VES(J,20)=BWR                      00010680
ISN      87          RR=F1(PCA,5,DCT,DFT)+VES(J,3)      00010690
ISN      88          VES(J,21)=RR                      00010700
ISN      89          JP=J+1                             00010710
ISN      90          WAN(JP,2)=TMA-TNAL-ALK             00010720
ISN      91          WAN(JP,3)=0.0                      00010730
ISN      92          WAN(JP,4)=0.0                      00010740
ISN      93          WAN(JP,14)=WAN(J,14)+WAN(J,8)/2.0+WAN(J,9) 00010750
ISN      94          WAN(JP,8)=0.0                      00010760
ISN      95          WAN(JP,9)=0.0                      00010770
ISN      96          WAN(JP,7)=0.0                      00010780

```


*.....1.....2.....3.....4.....5.....6.....7.....8

ISN	97	IF(VES(J,19).GT.0.0) GO TO 100	00010790
ISN	98	FRV=25.0*VES(J,3)	00010800
ISN	99	VES(J,19)=FRV	00010810
ISN	100	100 RETURN	00010820
ISN	101	END	00010830

STATISTICS SOURCE STATEMENTS = 97, PROGRAM SIZE = 5806 BYTES, PROGRAM NAME = DHCRS PAGE: 22.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 6 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7*.....8
ISN      1      SUBROUTINE ARESIN (J)                                00010840
ISN      2      DIMENSION WAN(10,15),IVES(9,8),YES(9,32)          00010850
ISN      3      COMMON /IO/N1,NO,IOUT                                00010860
ISN      4      COMMON /DESD/WAN,YES,IVES                            00010870
ISN      5      COMMON /AWAT/TA,TMA,PSI,PCLM,PWA,PCLT              00010880
ISN      6      R100=100.0                                           00010890
ISN      7      TMA=WAN(J,10)+WAN(J,11)+WAN(J,12)                  00010900
ISN      8      TWA=WAN(J,13)+WAN(J,14)                             00010910
ISN      9      ERR=WAN(J,7)+WAN(J,8)+WAN(J,9)                     00010920
ISN     10      IF(ERR)1001,1,1001                                   00010930
ISN     11      1 TA=TWA+TMA                                          00010940
ISN     12      PWA=TWA/TA*R100                                       00010950
ISN     13      PSI=WAN(J,13)/TA*R100                                  00010960
ISN     14      PCLM=(WAN(J,11)+WAN(J,12))/TMA*R100                00010970
ISN     15      PCLT=(WAN(J,11)+WAN(J,12))/TA*R100                 00010980
ISN     16      IR=IVES(J,3)                                          00010990
ISN     17      IF(IOUT.EQ.5)WRITE(NO,601)TA,TMA,PSI,PCLM,         00011000
ISN     18      1 PWA,PCLT,IR                                          00011010
ISN     19      601 FORMAT(1X,'TA= ',E12.5,/1X,'TMA= ',E12.5,/1X,   00011020
ISN     20      1 'PSI= ',E12.5,/1X,'PCLM= ',E12.5,/1X,           00011030
ISN     21      2 'PWA= ',E12.5,/1X,'PCLT= ',E12.5/1X,           00011040
ISN     22      3 'IR= ',I3)                                          00011050
ISN     20      I=IR/100                                              00011060
ISN     21      GO TO (100,200,300,400),I                            00011070
ISN     22      100 I=(IR-100)/10-1                                   00011080
ISN     23      GO TO (120,130,140),I                                00011090
ISN     24      120 CONTINUE                                          00011100
ISN     25      130 CONTINUE                                          00011110
ISN     26      140 CONTINUE                                          00011120
ISN     27      GO TO 1000                                             00011130
ISN     28      200 I=(IR-200)/10-1                                   00011140
ISN     29      GO TO (221,231,240),I                                00011150
ISN     30      221 IF(IOUT.EQ.5)WRITE(NO,602)                       00011160
ISN     31      602 FORMAT(1X,'DSBRP')                               00011170
ISN     32      CALL DSBRP(J)                                         00011180
ISN     33      IF(IOUT.EQ.5)WRITE(NO,602)                           00011190
ISN     34      GO TO 999                                              00011200
ISN     35      231 CONTINUE                                          00011210
ISN     36      GO TO 1000                                             00011220
ISN     37      240 I=IR-240                                           00011230
ISN     38      GO TO (241,242),I                                    00011240
ISN     39      241 IF(IOUT.EQ.5)WRITE(NO,603)                       00011250
ISN     40      603 FDRMAT(1X,'DWGR2')                               00011260
ISN     41      CALL DWGR2(J)                                         00011270
ISN     42      IF(IOUT.EQ.5)WRITE(NO,603)                           00011280
ISN     43      GO TO 999                                              00011290
ISN     44      242 CONTINUE                                          00011300
ISN     45      GO TO 1000                                             00011310
ISN     46      300 I=(IR-300)/10-1                                   00011320
ISN     47      GO TO (321,331,341),I                                00011330
ISN     48      321 CONTINUE                                          00011340
ISN     49      331 CONTINUE                                          00011350
ISN     50      341 CONTINUE                                          00011360

```

*.....1.....2.....3.....4.....5.....6.....7.....8

ISN	55	GO TO 1000	00011370
ISN	56	400 I=[IR-400]/10-1	00011380
ISN	57	GO TO 421	00011390
ISN	58	421 CONTINUE	00011400
ISN	59	GO TO 1000	00011410
ISN	60	999 RETURN	00011420
ISN	61	1000 WRITE(ND,600)J	00011430
ISN	62	600 FORMAT(5X,'****SELECT ANOTHER ANION RESIN****',	00011440
		1 /5X,'****FOR VESSEL',11,'****')	00011450
ISN	63	1001 CONTINUE	00011460
ISN	64	RETURN	00011470
ISN	65	END	00011480

STATISTICS SOURCE STATEMENTS = 60, PROGRAM SIZE = 3326 BYTES, PROGRAM NAME = ARESIN PAGE: 25.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 7 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 DPT(O) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

ISN	1	2	3	4	5	6	7	8
ISN	1	SUBROUTINE DSBRP(J)						00011490
ISN	2	REAL NCAP						00011500
ISN	3	LOGICAL OL						00011510
ISN	4	DIMENSION WAN(10,15),IVES(9,8),YES(9,32),DPX(11),						00011520
	1	DSL75(11,4),DSL95(11,4),DSL12(11,4),						00011530
	2	DCM75(11,4),DCM95(11,4),DCM12(11,4),						00011540
	3	DCW75(11,4),DCW95(11,4),DCW12(11,4),						00011550
	4	DRTP(3),DRG(4)						00011560
ISN	5	COMMON/IO/NI,NO,IOUT						00011570
ISN	6	COMMON/DESD/WAN,YES,IVES						00011580
ISN	7	COMMON/AWAT/TA,TMA,PSI,PCLM,PWA,PCLT						00011590
ISN	8	DATA BWM/23.33333/						00011600
ISN	9	DATA DRG/3.5,5.0,7.5,10.0/						00011610
ISN	10	DATA DPX/0.0,10.0,20.0,30.0,40.0,50.0,60.0,						00011620
	1	70.0,80.0,90.0,100.0/						00011630
ISN	11	DATA DSL75/0.0,0.06,0.145,0.270,0.445,0.85,						00011640
	2	1.10,1.25,1.40,1.50,1.60,0.0,0.025,						00011650
	3	0.06,0.105,0.145,0.210,0.270,0.3275,						00011660
	4	0.3775,0.4225,0.4575,0.0,0.02,0.0375,						00011670
	5	0.0575,0.075,0.105,0.130,0.155,0.170,						00011680
	6	0.1875,0.200,0.0,0.0075,0.02,0.0325,						00011690
	7	0.045,0.0675,0.0850,0.1075,0.125,0.140,						00011700
	8	0.150/						00011710
ISN	12	DATA DSL95/0.0,0.06,0.12,0.18,0.24,0.30,0.36,0.42,						00011720
	1	0.48,0.54,0.60,0.0,0.02,0.04,0.06,0.085,						00011730
	2	0.11,0.14,0.17,0.21,0.25,0.30,0.0,0.015,						00011740
	3	0.025,0.04,0.055,0.07,0.085,0.1,0.12,						00011750
	4	0.135,0.15,0.0,0.01,0.02,0.025,0.0325,						00011760
	5	0.045,0.06,0.075,0.090,0.11,0.125/						00011770
ISN	13	DATA DSL12/0.0,0.025,0.06,0.1,0.15,0.195,0.24,						00011780
	1	0.28,0.315,0.345,0.375,0.0,0.0075,0.0175,						00011790
	2	0.03,0.045,0.07,0.0975,0.12,0.135,0.145,						00011800
	3	0.15,0.0,0.005,0.01,0.015,0.025,0.035,						00011810
	4	0.045,0.06,0.0725,0.0875,0.1,0.0,0.0,						00011820
	5	0.0,0.005,0.01,0.0175,0.025,0.035,						00011830
	6	0.0425,0.0525,0.0625/						00011840
ISN	14	DATA DCM75/11.13,11.53,11.90,12.23,12.53,12.86,13.23,						00011850
	1	13.53,13.93,14.47,15.1,12.87,13.23,13.60,						00011860
	2	13.90,14.17,14.5,14.8,15.1,15.47,15.9,16.37,						00011870
	3	14.67,14.96,15.23,15.5,15.8,16.0,16.3,16.67,						00011880
	4	17.0,17.5,18.03,18.57,18.07,18.33,18.56,						00011890
	5	18.83,17.0,17.27,17.57,17.93,18.43,18.97/						00011900
ISN	15	DATA DCM95/10.1,10.9,11.6,12.23,12.77,13.2,13.6,14.0,						00011910
	1	14.47,14.87,15.33,12.77,13.27,13.77,14.1,						00011920
	2	14.43,14.77,15.07,15.4,15.77,16.13,16.6,						00011930
	3	14.3,14.77,15.13,15.5,15.83,16.17,16.5,						00011940
	4	16.33,17.27,17.67,18.13,15.57,15.9,						00011950
	5	16.23,16.5,16.8,17.07,17.33,17.6,17.97,						00011960
	6	18.4,18.9/						00011970
ISN	16	DATA DCM12/11.1,11.67,12.1,12.5,12.9,13.3,13.7,14.1,						00011980
	1	14.6,15.1,15.7,12.9,13.27,13.67,14.07,						00011990
	2	14.5,14.9,15.3,15.8,16.3,16.9,17.67,14.5,						00012000
	3	14.93,15.4,15.8,16.3,16.53,16.9,17.3,17.67,						00012010

```

* .....1.....2.....3.....4.....5.....6.....7.....8
4      18.1,18.6,15.9,16.3,16.6,16.9,17.2,17.2,      00012020
5      17.53,17.87,18.2,18.5,19.1/      00012030
ISN 17 DATA DCW75/16.5,16.2,15.83,15.33,14.73,14.1,13.5,      00012040
1      12.87,12.2,11.6,11.0,17.83,17.67,17.47,17.07,      00012050
2      16.67,16.1,15.47,14.8,14.1,13.5,12.87,18.72,      00012060
3      18.67,18.50,18.23,17.90,17.50,17.07,16.67,16.2,      00012070
4      15.8,15.33,19.3,19.2,19.1,18.84,18.59,18.28,      00012080
5      17.90,17.53,17.13,16.83,16.43/      00012090
ISN 18 DATA DCW95/16.57,16.5,16.33,16.13,15.8,15.2,14.67,      00012100
1      14.2,13.8,13.4,13.0,17.84,17.84,17.83,17.73,      00012110
2      17.53,17.2,16.87,16.5,16.1,15.8,15.5,18.8,      00012120
3      18.67,18.63,18.57,18.47,18.3,18.07,17.73,      00012130
4      17.3,17.0,16.83,19.3,19.2,19.1,19.07,19.0,      00012140
5      18.9,18.73,18.4,17.93,17.6,17.3/      00012150
ISN 19 DATA DCW12/16.53,16.47,16.33,16.3,16.2,16.07,15.83,      00012160
1      15.6,15.3,15.07,14.8,18.27,18.2,18.17,18.13,      00012170
2      18.1,18.0,17.9,17.6,17.6,17.4,17.2,11*18.7,      00012180
3      11*19.2/      00012190
ISN 20 DATA C1,C2,C3,C4/8.981469E-1,-4.292541E-3,3.210956E-5,      00012200
1      -1.107226E-7/      00012210
ISN 21 DATA S1,S2,S3,S4/8.87E-1,2.895979E-1,-2.999709E-1,      00012220
2      1.238345E-1/      00012230
ISN 22 DATA SNL1,SNL2,SNL3/8.317886E+1,3.050159E+1,-3.203408/      00012240
ISN 23 DATA T1,T2,T3,T4,T5/4.801963E+2,-2.547444E+1,      00012250
1      5.330862E-1,-4.696193E-3,1.622378E-5/      00012260
ISN 24 DATA DRTP/75.0,95.0,120.0/      00012270
ISN 25 QL=.FALSE.      00012280
ISN 26 IF(IOUT.GE.5) QL=.TRUE.      00012290
ISN 28 ICAP=0      00012300
ISN 29 R100=100.0      00012310
ISN 30 RL=VES(J,10)      00012320
ISN 31 IF(RL.GT.10.0)RL=10.0      00012330
ISN 33 TDS=0.0      00012340
ISN 34 DO 1 I=1,15      00012350
ISN 35 WAN(J+1,I)=WAN(J,I)      00012360
ISN 36 1 CONTINUE      00012370
ISN 37 DO 2 K=7,14      00012380
ISN 38 TDS=TDS+WAN(J,K)      00012390
ISN 39 2 CONTINUE      00012400
ISN 40 WAN(J,1)=TDS      00012410
ISN 41 TNAL=WAN(J,5)      00012420
ISN 42 RGTP=VES(J,31)      00012430
ISN 43 IF(RGTP.LT.75.0) GO TO 105      00012440
ISN 44 IF(RGTP.GT.120.0) GO TO 105      00012450
ISN 45 DO 10 I=2,3      00012460
ISN 46 IM=I-1      00012470
ISN 47 IF(RGTP.LT.DRTP(I)) GO TO 15      00012480
ISN 48 10 CONTINUE      00012490
ISN 49 15 IF((TMA-TNAL/TA).LT.0.05)ICAP=1      00012500
ISN 51 IF(IM.NE.1) GO TO 20      00012510
ISN 52 SL1=F3(PSI,RL,11,4,DPX,DRG,DSL75)      00012520
ISN 53 SL2=F3(PSI,RL,11,4,DPX,DRG,DSL95)      00012530
ISN 54 RDT=(RGTP-75.0)/20.0      00012540
ISN 55 IF(ICAP)16,16,17      00012550
ISN 56 16 CP1=F3(PWA,RL,11,4,DPX,DRG,DCM75)      00012560
ISN 57 CP2=F3(PWA,RL,11,4,DPX,DRG,DCM95)      00012570

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      58          GO TO 25                                00012580
ISN      59          17 CP1=F3(PSI,RL,11,4,DPX,DRG,DCW75)    00012590
ISN      60          CP2=F3(PSI,RL,11,4,DPX,DRG,DCW95)    00012600
ISN      61          GO TO 25                                00012610
ISN      62          20 SL1=F3(PSI,RL,11,4,DPX,DRG,DSL95)    00012620
ISN      63          SL2=F3(PSI,RL,11,4,DPX,DRG,DSL12)    00012630
ISN      64          RDT=(RGTP-95.0)/25.0                    00012640
ISN      65          IF(ICAP)21,21,22                          00012650
ISN      66          21 CP1=F3(PWA,RL,11,4,DPX,DRG,DCM95)    00012660
ISN      67          CP2=F3(PWA,RL,11,4,DPX,DRG,DCM12)    00012670
ISN      68          GO TO 25                                00012680
ISN      69          22 CP1=F3(PSI,RL,11,4,DPX,DRG,DCW95)    00012690
ISN      70          CP2=F3(PSI,RL,11,4,DPX,DRG,DCW12)    00012700
ISN      71          25 DSL=SL2-SL1                            00012710
ISN      72          DCP=CP2-CP1                              00012720
ISN      73          IF(OL)WRITE(NO,610)ICAP,IM              00012730
ISN      75          610 FORMAT(1X,11)                          00012740
ISN      76          IF(OL)WRITE(NO,611)SL1,SL2,CP1,CP2,RDT  00012750
ISN      78          611 FORMAT(1X,E12.5)                      00012760
ISN      79          TSL=RDT+DSL+SL1                          00012770
ISN      80          GCAP=RDT+DCP+CP1                          00012780
ISN      81          IF(ICAP)26,26,27                          00012790
ISN      82          26 FCC=C1+PCLT=(C2+PCLT*(C3+PCLT*C4))  00012800
ISN      83          GO TO 30                                  00012810
ISN      84          27 FCC=1.0                                00012820
ISN      85          30 SREP=VES(J,32)                          00012830
ISN      86          IF(SREP.GT.0.0) GO TO 31                  00012840
ISN      87          SREP=0.1                                   00012850
ISN      88          VES(J,32)=SREP                            00012860
ISN      89          31 IF(SREP=0.1)32,33,33                   00012870
ISN      90          32 RDX=SREP/0.1                           00012880
ISN      91          FCS=RDX*0.91                              00012890
ISN      92          GO TO 35                                   00012900
ISN      93          33 IF(SREP=1.0)133,34,34                  00012910
ISN      94          133 FCS=S1+SREP=(S2+SREP*(S3+SREP*S4))  00012920
ISN      95          GO TO 35                                   00012930
ISN      96          34 FCS=1.0                                00012940
ISN      97          35 IF(TNAL.LE.4.76) GO TO 135             00012950
ISN      98          FSN=1.55785                               00012960
ISN      99          GO TO 235                                  00012970
ISN      100         135 FSN=(SNL1+TNAL*(SNL2+TNAL*SNL3))/R100 00012980
ISN      101         235 TP=WAN(J,15)                           00012990
ISN      102         IF(TP.GE.50.0) GO TO 36                   00013000
ISN      103         FST=0.5                                    00013010
ISN      104         GO TO 37                                    00013020
ISN      105         36 FST=(T1+TP*(T2+TP*(T3+TP*(T4+TP*T5)))/R100 00013040
ISN      106         37 CSL=TSL+FSN+FST                        00013050
ISN      107         CCAP=GCAP+FCC+FCS                         00013060
ISN      108         IF(OL)WRITE(NO,611)TSL,FSN,FST,GCAP,FCC,FCS 00013070
ISN      109         VES(J,11)=CCAP                             00013080
ISN      110         FEF=VES(J,12)/R100                       00013090
ISN      111         NCAP=CCAP*FEF                              00013100
ISN      112         VES(J,13)=NCAP                            00013110
ISN      113         CAP=VES(J,3)*NCAP                         00013120
ISN      114         VES(J,8)=CAP                              00013130
ISN      115         IF(VES(J,30).GT.0.0) GO TO 38             00013140
ISN      116

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN 117      VES(J,30)=50.0                                00013140
ISN 118      38 BWRA=VES(J,30)/BWM=(1.0+0.008*(TP-77.0))    00013150
ISN 119      BWR=BWRA=VES(J,6)                             00013160
ISN 120      VES(J,20)=BWR                                 00013170
ISN 121      IF(VES(J,26))40,40,41                         00013180
ISN 122      40 VES(J,26)=60.0                             00013190
ISN 123      41 I=J+1                                      00013200
ISN 124      WAN(I,2)=0.0                                  00013210
ISN 125      WAN(I,10)=0.0                                 00013220
ISN 126      WAN(I,11)=TNAL                               00013230
ISN 127      WAN(I,12)=0.0                                00013240
ISN 128      WAN(I,13)=CSL                                00013250
ISN 129      WAN(I,14)=0.0                                00013260
ISN 130      IF(VES(J,19).GT.0.0) GO TO 110                00013270
ISN 131      VES(J,19)=100.0=VES(J,3)                     00013280
ISN 132      GO TO 110                                     00013290
ISN 133      105 WRITE(N0,600)                             00013300
ISN 134      600 FORMAT(5X,'***REGENERATION TEMPERATURE OUT ', 00013310
            1 'OF BOUNDS***')                             00013320
ISN 135      110 RETURN                                    00013330
ISN 136      END                                          00013340

```

STATISTICS SOURCE STATEMENTS = 130, PROGRAM SIZE = 8462 BYTES, PROGRAM NAME = DSB RP PAGE: 27.
STATISTICS NO DIAGNOSTICS GENERATED.
***** END OF COMPILATION 8 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1      SUBROUTINE DWGR2(J)                                00013350
ISN      2      REAL NCAP                                        00013360
ISN      3      LOGICAL OL                                       00013370
ISN      4      DIMENSION WAN(10,15),VES(9,8),IVES(9,32),DRL(4),    00013380
ISN      5      1 DCPC(4),DCPS(4)                                00013390
ISN      6      COMMON/10/NI,NO,1DUT                                00013400
ISN      7      COMMON/DESD/WAN,VES,IVES                          00013410
ISN      8      COMMON/AWAT/TA,TMA,PSI,PCLM,PWA,PCLT             00013420
ISN      9      DATA DRL/2,3,4,5/                                00013430
ISN     10      DATA DCPC/23.75,28.0,30.0,30.25/                00013440
ISN     11      DATA DCPS/20.0,24.0,25.0,25.25/                 00013450
ISN     12      DATA BWM,BWB/10.0,-1.3/                          00013460
ISN     13      TNAL=WAN(J,5)                                     00013470
ISN     14      OL=.FALSE.                                        00013480
ISN     15      IF(1DUT.GE.5) OL=.TRUE.                           00013490
ISN     16      R100=100.0                                        00013500
ISN     17      RL=VES(J,10)                                     00013510
ISN     18      IF(RL.GT.5.0)RL=5.0                              00013520
ISN     19      TDS=0.0                                         00013530
ISN     20      DO 1 I=1,15                                      00013540
ISN     21      WAN(J+1,I)=WAN(J,I)                              00013550
ISN     22      1 CONTINUE                                       00013560
ISN     23      DO 2 K=7,12                                      00013570
ISN     24      TDS=TDS+WAN(J,K)                                00013580
ISN     25      2 CONTINUE                                       00013590
ISN     26      WAN(J,1)=TDS                                     00013600
ISN     27      SA=WAN(J,10)                                    00013610
ISN     28      TEA=TMA-TNAL                                    00013620
ISN     29      FSA=SA/TEA                                       00013630
ISN     30      FCA=1.0-FSA                                       00013640
ISN     31      CPS=F1(RL,4,DRL,DCPC)                            00013650
ISN     32      CPC=F1(RL,4,DRL,DCPC)                            00013660
ISN     33      IF(OL)WRITE(NO,610)FSA,FCA,CPS,CPC              00013670
ISN     34      610 FORMAT(1X,E12.5)                              00013680
ISN     35      GCAP=FSA*CPS+FCA*CPC                             00013690
ISN     36      FEF=VES(J,12)/R100                               00013700
ISN     37      NCAP=GCAP*FEF                                     00013710
ISN     38      VES(J,11)=GCAP                                    00013720
ISN     39      VES(J,13)=NCAP                                    00013730
ISN     40      CAP=VES(J,3)*NCAP                                 00013740
ISN     41      VES(J,8)=CAP                                     00013750
ISN     42      TP=WAN(J,15)                                     00013760
ISN     43      IF(VES(J,30).GT.0.0) GO TO 6                    00013770
ISN     44      VES(J,30)=50.0                                    00013780
ISN     45      6 BWRA=(VES(J,30)-BWB)/BWM*(1.0+0.008*(TP-77.0)) 00013790
ISN     46      BWR=BWRA*VES(J,6)                                00013800
ISN     47      VES(J,20)=BWR                                    00013810
ISN     48      IF(VES(J,26))10,10,11                            00013820
ISN     49      10 VES(J,21)=0.5*VES(J,3)                        00013830
ISN     50      11 I=J+1                                         00013840
ISN     51      WAN(I,2)=0.0                                     00013850
ISN     52      WAN(I,10)=0.0                                    00013860
ISN     53      WAN(I,11)=TNAL                                   00013870
ISN     54
ISN     55

```


.....1.....2.....3.....4.....5.....6.....7......8

ISN	56	WAN(1,12)=0.0	00013880
ISN	57	IF(VES(J,19).GT.0.0) GO TO 110	00013890
ISN	58	YES(J,19)=75.0+VES(J,3)	00013900
ISN	59	110 RETURN	00013910
ISN	60	END	00013920

STATISTICS SOURCE STATEMENTS = 57, PROGRAM SIZE = 3288 BYTES, PROGRAM NAME = DWGR2 PAGE: 31.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 9 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NDFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7*.....8
ISN      1      SUBROUTINE CREGN(J)                                00013930
ISN      2      LOGICAL QL                                        00013940
ISN      3      DIMENSION WAN(10,15),IVES(9,8),VES(9,32),RO(9,4),  00013950
ISN          1      RYDL(9,4),DVOL(9,4),TSTEP(9,4),ISTEP(9)      00013960
ISN      4      COMMON/IO/NI,NO,IOUT                               00013970
ISN      5      COMMON/DESD/WAN,VES,IVES                         00013980
ISN      6      COMMON/STEP/ISTEP,RO,RVOL,DVOL,TSTEP            00013990
ISN      7      DATA SRV2,SRV4,SRV6,SRV8/4*0.0/                 00014000
ISN      8      DATA T2,T4,TS,T8/4*0.0/                        00014010
ISN      9      DATA SWV2,SWV4,SWV6,SWV8/4*0.0/                 00014020
ISN     10      DATA RH05,RH0C/15.2,2.88/                       00014030
ISN     11      DATA RH02,RH04,RH06,RH08/0.1689,0.3422,0.5200,  00014040
ISN          1      0.7025/                                       00014050
ISN     12      QL=.FALSE.                                       00014060
ISN     13      IF(IOUT.GE.5) QL=.TRUE.                           00014070
ISN     15      OS=VES(J,29)                                       00014080
ISN     16      AREA=VES(J,6)                                       00014090
ISN     17      VOL=VES(J,3)                                       00014100
ISN     18      VES(J,15)=VES(J,20)+VES(J,25)                     00014110
ISN     19      IF(IVES(J,6)-2) 10,20,30                          00014120
ISN     20      10 RL=VES(J,10)                                       00014130
ISN     21      TAW=RL*VOL                                           00014140
ISN     22      TAV=TAW/RH05                                         00014150
ISN     23      IF(WAN(J,3).GT.0.5) GO TO 11                       00014160
ISN     24      NSTEP=1                                             00014170
ISN     25      ORW=VES(J,21)                                       00014180
ISN     26      SRV6=TAW/RH06                                         00014190
ISN     27      SWW6=TAW*0.94/0.06                                   00014200
ISN     28      SWV6=SWW6/8.34                                       00014210
ISN     29      T6=SWV6/ORW                                           00014220
ISN     30      OA6=TAV/T6                                           00014230
ISN     31      GO TO 15                                             00014240
ISN     32      11 STEP=1.0                                           00014250
ISN     33      ISTEP(J)=1                                           00014260
ISN     34      IF(RL.LT.4.0) GO TO 12                               00014270
ISN     35      STEP=2.0                                           00014280
ISN     36      ISTEP(J)=2                                           00014290
ISN     37      IF(RL.LT.6.0) GO TO 12                               00014300
ISN     38      STEP=3.0                                           00014310
ISN     39      ISTEP(J)=3                                           00014320
ISN     40      IF(RL.LT.8.0) GO TO 12                               00014330
ISN     41      STEP=4.0                                           00014340
ISN     42      ISTEP(J)=4                                           00014350
ISN     43      12 IF(QL)WRITE(ND,610)STEP                          00014360
ISN     45      610 FORMAT(1X,E12.5)                                00014370
ISN     46      IF(RL.LE.8.0) GO TO 13                              00014380
ISN     47      F24=4.0/RL                                           00014390
ISN     48      F68=1.0-F24                                           00014400
ISN     49      SAW={TAW+F24}/2.0                                    00014410
ISN     50      SAV={TAV+F24}/2.0                                    00014420
ISN     51      SAW6={TAW+F68}/2.0                                  00014430
ISN     52      SAV6={TAV+F68}/2.0                                  00014440
ISN     53      SAW8=SAW6                                           00014450

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN   54      SAV8=SAV6                00014460
ISN   55      GO TO 14                 00014470
ISN   56      13 SAW=TAW/STEP           00014480
ISN   57      SAV=TAV/STEP             00014490
ISN   58      SAV6=SAV                 00014500
ISN   59      SAW6=SAW                 00014510
ISN   60      SAV8=SAV                 00014520
ISN   61      SAW8=SAW                 00014530
ISN   62      14 ORV=VES(J,21)          00014540
ISN   63      SRV2=SAW/RHD2            00014550
ISN   64      SWW2=SAW*49.0            00014560
ISN   65      SWV2=SWW2/8.34           00014570
ISN   66      T2=SWV2/ORW              00014580
ISN   67      QA2=SAV/T2               00014590
ISN   68      IF(STEP.LT.2.0) GO TO 15  00014600
ISN   69      SRV4=SAW/RHD4            00014610
ISN   70      SWW4=SAW*24.0            00014620
ISN   71      SWV4=SWW4/8.34           00014630
ISN   72      T4=SWV4/ORW              00014640
ISN   73      QA4=SAV/T4               00014650
ISN   74      IF(STEP.LT.3.0) GO TO 15  00014660
ISN   75      SRV6=SAW6/RHD6           00014670
ISN   76      SWW6=SAW6*0.84/0.06      00014680
ISN   77      SWV6=SWW6/8.34           00014690
ISN   78      T6=SWV6/ORW              00014700
ISN   79      QA6=SAV6/T6              00014710
ISN   80      IF(STEP.LT.4.0) GO TO 15  00014720
ISN   81      SRV8=SAW8/RHD8           00014730
ISN   82      SWW8=SAW8*0.92/0.08      00014740
ISN   83      SWV8=SWW8/8.34           00014750
ISN   84      T8=SWV8/ORW              00014760
ISN   85      QA8=SAV8/T8              00014770
ISN   86      15 TTR=T2+T4+T6+T8        00014780
ISN   87      TRV=SRV2+SRV4+SRV6+SRV8  00014790
ISN   88      TWV=SWV2+SWV4+SWV6+SWV8  00014800
ISN   89      IF(OL)WRITE(ND,610)T2,T4,T6,T8,SWV2,SWV4,SWV6,SWV8 00014810
ISN   91      VES(J,22)=-1.0           00014820
ISN   92      IF(NSTEP.EQ.1) VES(J,22)=QA6 00014830
ISN   94      GO TO 40                 00014840
ISN   95      20 CONTINUE              00014850
ISN   96      30 CONTINUE              00014860
ISN   97      40 SRV=VES(J,18)          00014870
ISN   98      IF(SRV.GT.0.0) GO TO 41   00014880
ISN   99      SRV=(VOL/2.0+0.75*AREA)=1.5+7.48 00014890
ISN  100      VES(J,18)=SRV            00014900
ISN  101      41 TSR=SRV/ORW           00014910
ISN  102      OFR=VES(J,24)            00014920
ISN  103      IF(OFR.GT.0.0) GO TO 42   00014930
ISN  104      OFR=OS                    00014940
ISN  105      42 TFR=VES(J,19)/OFR     00014950
ISN  106      VES(J,16)=TWV            00014960
ISN  107      VES(J,17)=TAV            00014970
ISN  108      VES(J,23)=ORW            00014980
ISN  109      VES(J,24)=OFR            00014990
ISN  110      VES(J,26)=TTR            00015000
ISN  111      VES(J,27)=TSR            00015010

```

* 1 2 3 4 5 6 7 8

```

ISN      112      VES(J,28)=TFR                                00015020
ISN      113      VES(J,14)=VES(J,8)/WAN(J,1)*17100.0        00015030
ISN      114      RQ(J,1)=QA2                                00015040
ISN      115      RQ(J,2)=QA4                                00015050
ISN      116      RQ(J,3)=QA8                                00015060
ISN      117      RQ(J,4)=QA8                                00015070
ISN      118      RVOL(J,1)=SAV                               00015080
ISN      119      RVOL(J,2)=SAV                               00015090
ISN      120      RVOL(J,3)=SAV6                             00015100
ISN      121      RVOL(J,4)=SAV8                             00015110
ISN      122      DVOL(J,1)=SWV2                             00015120
ISN      123      DVOL(J,2)=SWV4                             00015130
ISN      124      DVOL(J,3)=SWV6                             00015140
ISN      125      DVOL(J,4)=SWV8                             00015150
ISN      126      TSTEP(J,1)=T2                              00015160
ISN      127      TSTEP(J,2)=T4                              00015170
ISN      128      TSTEP(J,3)=T6                              00015180
ISN      129      TSTEP(J,4)=T8                              00015190
ISN      130      RETURN                                      00015200
ISN      131      END                                        00015210
    
```

STATISTICS SOURCE STATEMENTS = 127, PROGRAM SIZE = 6202 BYTES, PROGRAM NAME = CREGN PAGE: 33.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 10 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NDTST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

*.....1.....2.....3.....4.....5.....6.....7.....8

```

ISN      1      SUBROUTINE AREGN(J)                                00015220
ISN      2      LOGICAL QL                                        00015230
ISN      3      DIMENSION WAN(10,15),IVES(9,8),VES(9,32)        00015240
ISN      4      COMMON/ID/N1,ND,IOUT                               00015250
ISN      5      COMMON/DESD/WAN,VES,IVES                         00015260
ISN      6      DATA RH0N,RH03/6.25,0.26/                       00015270
ISN      7      QL=.FALSE.                                       00015280
ISN      8      IF(IOUT.GE.5) QL=.TRUE.                          00015290
ISN     10      QS=VES(J,29)                                       00015300
ISN     11      AREA=VES(J,6)                                       00015310
ISN     12      VOL=VES(J,3)                                       00015320
ISN     13      VES(J,15)=VES(J,20)+VES(J,25)                    00015330
ISN     14      RL=VES(J,10)                                       00015340
ISN     15      TCW=RL*VOL                                          00015350
ISN     16      TCV=TCW/RH0N                                       00015360
ISN     17      TRV=TCW/RH03                                       00015370
ISN     18      TWW=TCW*0.97/0.03                                   00015380
ISN     19      TWV=TWW/8.34                                        00015390
ISN     20      IF(VES(J,21).LE.0.0) GO TO 30                    00015400
ISN     21      ORW=VES(J,21)                                       00015410
ISN     22      TTR=TWV/ORW                                         00015420
ISN     23      GO TO 35                                           00015430
ISN     24      30 TTR=VES(J,26)                                       00015440
ISN     25      ORW=TWV/TTR                                         00015450
ISN     26      35 OC=TCV/TTR                                         00015460
ISN     27      SRV=VES(J,18)                                       00015470
ISN     28      IF(SRV.GT.0.0) GO TO 41                            00015480
ISN     29      -SRV=(VOL/2.0+0.75*AREA)+1.5=7.48                00015480
ISN     30      VES(J,18)=SRV                                       00015500
ISN     31      41 TSR=SRV/ORW                                       00015510
ISN     32      OFR=VES(J,24)                                       00015520
ISN     33      IF(OFR.GT.0.0) GO TO 42                            00015530
ISN     34      OFR=QS                                             00015540
ISN     35      42 TFR=VES(J,19)/OFR                                  00015550
ISN     36      VES(J,16)=TWV                                       00015560
ISN     37      VES(J,17)=TCV                                       00015570
ISN     38      VES(J,21)=ORW                                       00015580
ISN     39      VES(J,22)=OC                                         00015590
ISN     40      VES(J,23)=ORW                                       00015600
ISN     41      VES(J,24)=QS                                         00015610
ISN     42      VES(J,26)=TTR                                       00015620
ISN     43      VES(J,27)=TSR                                       00015630
ISN     44      VES(J,28)=TFR                                       00015640
ISN     45      VES(J,14)=VES(J,8)/WAN(J,1)*17100.0              00015650
ISN     46      RETURN                                             00015660
ISN     47      END                                               00015670
    
```

STATISTICS SOURCE STATEMENTS = 46, PROGRAM SIZE = 2494 BYTES, PROGRAM NAME = AREGN PAGE: 36.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 11 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NDSYM
 OPT(O) LANCLVL(66) NDFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

      = ..... 1 ..... 2 ..... 3 ..... 4 ..... 5 ..... 6 ..... 7 ..... 8
ISN   1      SUBROUTINE MASBAL(NV,TDP,QG,ON,TA,TC)          00015680
ISN   2      LOGICAL OL                                   00015690
ISN   3      DIMENSION WAN(10,15),IVES(9,8),VES(9,32),ICAT(5), 00015700
ISN   4      1 IAN(5),RVES(10)                            00015710
ISN   5      COMMON/IO/NI,NO,IOUT                          00015720
ISN   6      COMMON/DESD/WAN,VES,IVES                      00015730
ISN   7      DATA ICAT,IAN/10*0./                          00015740
ISN   8      DATA TADW,TCDW/2*0.0/                        00015750
ISN   9      DATA RVES/10*0.0/                            00015760
ISN  10      J=0                                           00015770
ISN  11      K=0                                           00015780
ISN  12      TA=0.0                                         00015790
ISN  13      TC=0.0                                         00015800
ISN  14      OL=.FALSE.                                     00015810
ISN  15      IF(IOUT.GE.5) OL=.TRUE.                       00015820
ISN  16      DO 10 I=1,NV                                    00015830
ISN  17      IF(IVES(I,1).LT.0) GO TO 10                   00015840
ISN  18      IF(IVES(I,1)-2)1,2,3                          00015850
ISN  19      1 J=J+1                                        00015860
ISN  20      ICAT(J)=1                                     00015870
ISN  21      GO TO 10                                      00015880
ISN  22      2 K=K+1                                       00015890
ISN  23      IAN(K)=1                                      00015900
ISN  24      GO TO 10                                      00015910
ISN  25      3 IOB=1                                        00015920
ISN  26      10 CONTINUE                                  00015930
ISN  27      DO 12 I=1,5                                    00015940
ISN  28      IF(ICAT(I))15,15,11                          00015950
ISN  29      11 J=ICAT(I)                                  00015960
ISN  30      VP=IVES(J,2)                                  00015970
ISN  31      TA=TA+VES(J,17)*VP                            00015980
ISN  32      TADW=TADW+VES(J,16)*VP+VES(J,18)*VP         00015990
ISN  33      12 CONTINUE                                  00016000
ISN  34      15 DO 17 I=1,5                                00016010
ISN  35      IF (IAN(I))20,20,16                          00016020
ISN  36      16 J=IAN(I)                                   00016030
ISN  37      VP=IVES(J,2)                                  00016040
ISN  38      TC=TC+VES(J,17)*VP                            00016050
ISN  39      TCDW=TCDW+VES(J,16)*VP+VES(J,18)*VP        00016060
ISN  40      17 CONTINUE                                  00016070
ISN  41      20 RVES(NV+1)=TCDW                            00016080
ISN  42      IF(OL)WRITE(ND,610)TA,TADW,TC,TCDW          00016090
ISN  43      DO 30 I=1,NV                                  00016100
ISN  44      J=NV-I+1                                      00016110
ISN  45      K=J+1                                        00016120
ISN  46      VP=IVES(J,2)                                  00016130
ISN  47      RVES(J)=RVES(K)+VES(J,15)*VP+VES(J,19)*VP   00016140
ISN  48      30 CONTINUE                                  00016150
ISN  49      VP=IVES(1,2)                                  00016160
ISN  50      RVES(1)=RVES(2)+TADW+VES(1,15)*VP+VES(1,19)*VP 00016170
ISN  51      CAPLMT=VES(1,14)*VP-RVES(2)                 00016180
ISN  52      DO 40 I=2,NV                                  00016190
ISN  53      IF(IVES(I,1))40,40,35                        00016200
ISN  54
  
```

.....1.....2.....3.....4.....5.....6.....7......8

```

ISN      55      35 VP=IVES(1,2)                                00016210
ISN      56      CAPNET=VES(1,14)=VP-RVES(I+1)                00016220
ISN      57      IF(CAPNET.GE.CAPLMT) GO TO 40                 00016230
ISN      58      CAPLMT=CAPNET                                  00016240
ISN      59      J=1                                           00016250
ISN      60      40 CONTINUE                                     00016260
ISN      61      NV1=NV+1                                       00016270
ISN      62      IF(QL)WRITE(ND,610){RVES(I),I=1,NV1},CAPLMT  00016280
ISN      64      610 FORMAT(1X,E12.5)                             00016290
ISN      65      DO 50 I=1,NV                                     00016300
ISN      66      VP=IVES(1,2)                                    00016310
ISN      67      VES(1,14)=[CAPLMT+RVES(I+1)]/VP              00016320
ISN      68      VES(1,9)=VES(1,14)=WAN(I,1)/17100.0          00016330
ISN      69      50 CONTINUE                                     00016340
ISN      70      TOP=VES(J,14)/VES(J,29)/60.0                 00016350
ISN      71      VP1=IVES(1,2)                                    00016360
ISN      72      OG=VES(1,14)=VP1+RVES(1)                      00016370
ISN      73      VPN=IVES(NV,2)                                  00016380
ISN      74      ON=VES(NV,14)=VPN-RVES(NV+1)                  00016390
ISN      75      IF(QL)WRITE(ND,610)OG,ON                      00016400
ISN      77      RETURN                                          00016410
ISN      78      END                                            00016420

```

STATISTICS SOURCE STATEMENTS = 74, PROGRAM SIZE = 4388 BYTES, PROGRAM NAME = MASBAL PAGE: 37.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 12 *****

OPTIONS IN EFFECT: NDLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

*.....#.....1.....2.....3.....4.....5.....6.....7.#.....8

ISN	1	FUNCTION F1(A,N,X,Y)	00016430
ISN	2	DIMENSION X(N),Y(N)	00016440
ISN	3	COMMON/IO/NI,NO,IOUT	00016450
ISN	4	IF(IOUT.EQ.5)WRITE(NO,600)	00016460
ISN	6	500 FORMAT(1X,'F1')	00016470
ISN	7	IF(A-X(1))3,3,1	00016480
ISN	8	1 IF(A-X(N))4,2,2	00016490
ISN	9	2 F1=Y(N)	00016500
ISN	10	RETURN	00016510
ISN	11	3 F1=Y(1)	00016520
ISN	12	RETURN	00016530
ISN	13	4 DO 5 I=2,N	00016540
ISN	14	IM=I-1	00016550
ISN	15	IF(A.LT.X(I)) GO TO 6	00016560
ISN	16	5 CONTINUE	00016570
ISN	17	6 RDX=(A-X(IM))/(X(1)-X(IM))	00016580
ISN	18	DY=Y(1)-Y(IM)	00016590
ISN	19	F1=Y(IM)+RDX*DY	00016600
ISN	20	RETURN	00016610
ISN	21	END	00016620

STATISTICS SOURCE STATEMENTS = 20, PROGRAM SIZE = 1480 BYTES, PROGRAM NAME = F1 PAGE: 39.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 13 *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGDSTMT NNODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1      FUNCTION F2(A,B,N,M,X,Y,ZM,ZB,ZX)                00016630
ISN      2      LOGICAL QL                                       00016640
ISN      3      DIMENSION X(N),Y(M),ZM(N,M),ZB(N,M),Z(2,2)      00016650
ISN      4      COMMON/IO/NI,NO,IOUT                               00016660
ISN      5      QL=.FALSE.                                         00016670
ISN      6      IF(IOUT.GE.5) QL=.TRUE.                             00016680
ISN      7      IF(QL)WRITE(NO,600)                                00016690
ISN     10      600 FORMAT(1X,'F2')                                  00016700
ISN     11      IF((A.LE.X(1)).AND.(B.LE.Y(1))) GO TO 100         00016710
ISN     12      IF((A.LE.X(1)).AND.(B.GE.Y(M))) GO TO 110         00016720
ISN     13      IF((A.GE.X(N)).AND.(B.LE.Y(1))) GO TO 120         00016730
ISN     14      IF((A.GE.X(N)).AND.(B.GE.Y(M))) GO TO 130         00016740
ISN     15      IF(A.LE.X(1)) GO TO 200                            00016750
ISN     16      IF(A.GE.X(N)) GO TO 210                            00016760
ISN     17      IF(B.LE.Y(1)) GO TO 240                            00016770
ISN     18      IF(B.GE.Y(M)) GO TO 250                            00016780
ISN     19      DO 10 I=2,N                                         00016790
ISN     20      IM=I-1                                             00016800
ISN     21      IF(A.LT.X(I)) GO TO 15                              00016810
ISN     22      10 CONTINUE                                         00016820
ISN     23      15 DO 20 J=2,M                                       00016830
ISN     24      JM=J-1                                             00016840
ISN     25      IF(B.LT.Y(J)) GO TO 25                             00016850
ISN     26      20 CONTINUE                                         00016860
ISN     27      25 DO 40 II=1,2                                       00016870
ISN     28      I=IM+II-1                                           00016880
ISN     29      DO 30 JJ=1,2                                       00016890
ISN     30      J=JM+JJ-1                                           00016900
ISN     31      Z(II,JJ)=(ZX-ZB(I,J))/ZM(I,J)                       00016910
ISN     32      IF(QL)WRITE(NO,610)ZB(I,J),ZM(I,J)                 00016920
ISN     34      610 FORMAT(1X,E12.5,5X,E12.5)                         00016930
ISN     35      30 CONTINUE                                         00016940
ISN     36      40 CONTINUE                                         00016950
ISN     37      RDX=(A-X(IM))/(X(1)-X(IM))                          00016960
ISN     38      RDY=(B-Y(JM))/(Y(J)-Y(JM))                          00016970
ISN     39      DZ1=Z(1,2)-Z(1,1)                                    00016980
ISN     40      DZ2=Z(2,2)-Z(2,1)                                    00016990
ISN     41      F2=RDY*(RDX*(DZ2-DZ1)+DZ1)+RDX*(Z(2,1)-Z(1,1))+Z(1,1) 00017000
ISN     42      IF(QL)WRITE(NO,611)X(IM),X(I),Y(JM),Y(J),Z(1,1),Z(1,2), 00017010
ISN          1      Z(2,1),Z(2,2)
ISN     44      611 FORMAT(1X,E12.5)                                  00017020
ISN     45      RETURN                                              00017030
ISN     46      100 F2=(ZX-ZB(1,1))/ZM(1,1)                          00017040
ISN     47      RETURN                                              00017050
ISN     48      110 F2=(ZX-ZB(1,M))/ZM(1,M)                          00017060
ISN     49      RETURN                                              00017070
ISN     50      120 F2=(ZX-ZB(N,1))/ZM(N,1)                          00017080
ISN     51      RETURN                                              00017090
ISN     52      130 F2=(ZX-ZB(N,M))/ZM(N,M)                          00017100
ISN     53      RETURN                                              00017110
ISN     54      200 I=1                                              00017120
ISN     55      GO TO 215                                           00017130
ISN     56      210 I=N                                             00017140

```

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      57      215 DO 220 J=2,M                00017160
ISN      58          JM=J-1                      00017170
ISN      59          IF(B.LT.Y(J)) GO TO 225     00017180
ISN      60      220 CONTINUE                    00017190
ISN      61      225 DO 230 JJ=1,2              00017200
ISN      62          J=JM+JJ-1                  00017210
ISN      63          Z(1,JJ)=(ZX-ZB(1,J))/ZM(1,J) 00017220
ISN      64      230 CONTINUE                    00017230
ISN      65          RDY=(B-Y(JM))/(Y(J)-Y(JM)) 00017240
ISN      66          DZ1=Z(1,2)-Z(1,1)          00017250
ISN      67          F2=RDY*DZ1+Z(1,1)          00017260
ISN      68          RETURN                      00017270
ISN      69      240 J=1                        00017280
ISN      70          GO TO 255                   00017280
ISN      71      250 J=M                        00017290
ISN      72      255 DO 260 I=2,M              00017300
ISN      73          IM=I-1                     00017310
ISN      74          IF (A.LT.X(I)) GO TO 265   00017320
ISN      75      260 CONTINUE                    00017330
ISN      76      265 DO 270 II=1,2             00017340
ISN      77          I=IM+II-1                  00017350
ISN      78          Z(1,II)=(ZX-ZB(1,J))/ZM(1,J) 00017360
ISN      79      270 CONTINUE                    00017370
ISN      80          RDX=(A-X(IM))/(X(I)-X(IM)) 00017380
ISN      81          DZ1=Z(1,2)-Z(1,1)          00017390
ISN      82          F2=RDX*DZ1+Z(1,1)          00017400
ISN      83          RETURN                      00017410
ISN      84          END                        00017420

```

STATISTICS SOURCE STATEMENTS = 80, PROGRAM SIZE = 5402 BYTES, PROGRAM NAME = F2 PAGE: 40.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 14 *****

.....1.....2.....3.....4.....5.....6.....7......8

ISN	56	GO TO 255	00017970
ISN	57	250 J=M	00017980
ISN	58	255 DO 260 I=2,N	00017990
ISN	59	IM=I-1	00018000
ISN	60	IF(A.LT.X(I)) GO TO 265	00018010
ISN	61	260 CONTINUE	00018020
ISN	62	265 RDX=(A-X(IM))/(X(I)-X(IM))	00018030
ISN	63	DZ1=Z(I,J)-Z(IM,J)	00018040
ISN	64	F3=RDY*DZ1+Z(IM,J)	00018050
ISN	65	RETURN	00018060
ISN	66	END	00018070

STATISTICS SOURCE STATEMENTS = 63, PROGRAM SIZE = 4344 BYTES, PROGRAM NAME = F3 PAGE: 42.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION IS *****

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGDSTMT NODUCK SOURCE NOTERM OBJECT FIXED NOTEST NODTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7.....8
ISN      1      FUNCTION F3(A,B,N,M,X,Y,Z)                00017440
ISN      2      LOGICAL QL                                00017450
ISN      3      DIMENSION X(N),Y(M),Z(N,M)                00017460
ISN      4      COMMON/IO/NI,NO,IOUT                       00017470
ISN      5      QL=.FALSE.                                00017480
ISN      6      IF(IOUT.GE.5) QL=.TRUE.                    00017490
ISN      7      IF(QL)WRITE(ND,600)                        00017500
ISN      8      600 FORMAT(1X,'F3')                        00017510
ISN     10      IF((A.LE.X(1)).AND.(B.LE.Y(1))) GO TO 100  00017520
ISN     11      IF((A.LE.X(1)).AND.(B.GE.Y(M))) GO TO 110  00017530
ISN     12      IF((A.GE.X(N)).AND.(B.LE.Y(1))) GO TO 120  00017540
ISN     13      IF((A.GE.X(N)).AND.(B.GE.Y(M))) GO TO 130  00017550
ISN     14      IF(A.LE.X(1)) GO TO 200                    00017560
ISN     15      IF(A.GE.X(N)) GO TO 210                    00017570
ISN     16      IF(B.LE.Y(1)) GO TO 240                    00017580
ISN     17      IF(B.GE.Y(M)) GO TO 250                    00017590
ISN     18      DO 10 I=2,N                                00017600
ISN     19      IM=I-1                                     00017610
ISN     20      IF(A.LT.X(1)) GO TO 15                      00017620
ISN     21      10 CONTINUE                                00017630
ISN     22      15 DO 20 J=2,M                              00017640
ISN     23      JM=J-1                                     00017650
ISN     24      IF(B.LT.Y(J)) GO TO 25                      00017660
ISN     25      20 CONTINUE                                00017670
ISN     26      25 RDX=(A-X(IM))/(X(1)-X(IM))                00017680
ISN     27      RDY=(B-Y(JM))/(Y(J)-Y(JM))                00017690
ISN     28      DZ1=Z(IM,J)-Z(IM,JM)                       00017700
ISN     29      DZ2=Z(1,J)-Z(1,JM)                         00017710
ISN     30      F3=RDY*(RDX*(DZ2-DZ1)+DZ1)+RDX*(Z(1,JM)-Z(IM,JM))+Z(IM,JM) 00017720
ISN     31      IF(QL)WRITE(ND,610)X(IM),X(1),Y(JM),Y(J),Z(IM,JM),Z(IM,J), 00017730
ISN     32      1      Z(1,JM),Z(1,J)                       00017740
ISN     34      610 FORMAT(1X,E12.5)                        00017750
ISN     35      RETURN                                     00017760
ISN     36      100 F3=Z(1,1)                               00017770
ISN     37      RETURN                                     00017780
ISN     38      110 F3=Z(1,M)                               00017790
ISN     39      RETURN                                     00017800
ISN     40      120 F3=Z(N,1)                               00017810
ISN     41      RETURN                                     00017820
ISN     42      130 F3=Z(N,M)                               00017830
ISN     43      RETURN                                     00017840
ISN     44      200 I=1                                     00017850
ISN     45      GO TO 215                                   00017860
ISN     46      210 I=N                                     00017870
ISN     47      215 DO 220 J=2,M                            00017880
ISN     48      JM=J-1                                     00017890
ISN     49      IF(B.LT.Y(J)) GO TO 225                    00017900
ISN     50      220 CONTINUE                                00017910
ISN     51      225 RDY=(B-Y(JM))/(Y(J)-Y(JM))            00017920
ISN     52      DZ1=Z(1,J)-Z(1,JM)                         00017930
ISN     53      F3=RDY*DZ1+Z(1,JM)                         00017940
ISN     54      RETURN                                     00017950
ISN     55      240 J=1                                     00017960

```

LEVEL 1.3.0 (MAY 1983)

VS FORTRAN

DATE: NOV 16, 1983

TIME: 15:48:17

PAGE: 44

OPTIONS IN EFFECT: NOLIST NDMAP NOXREF NOGDSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```
*.....1.....2.....3.....4.....5.....6.....7*.....8
ISN      1      SUBROUTINE CONWAT(IWAW,WAN,I)                00018080
ISN      2      LOGICAL OL                                00018080
ISN      3      DIMENSION WAN(10,15),CFS(13)              00018100
ISN      4      COMMON/IO/NI,NO,IOUT                      00018110
ISN      5      DATA CFE,CFS/50.0,50.0,2.5,4.11,2.17,1.28,2.94,1.67,
1          0.82,1.04,1.41,0.81,0.835,1.14/                00018120
ISN      6      OL=.FALSE.                                00018130
ISN      7      IF(IOUT.GE.5)OL=.TRUE.                    00018140
ISN      8      CNA=0                                      00018150
ISN      9      IND=IWAW-2                                  00018160
ISN     10      IF(IND)100,120,110.                        00018170
ISN     11      100 DD 101 I=2,14                          00018180
ISN     12      WAN(1,I)=WAN(1,I)/CFS(I-1)                00018190
ISN     13      101 CONTINUE                               00018200
ISN     14      GO TO 120                                  00018210
ISN     15      110 DD 111 I=2,14                          00018220
ISN     16      WAN(1,I)=WAN(1,I)/CFE                     00018230
ISN     17      111 CONTINUE                               00018240
ISN     18      120 IF(OL)WRITE(ND,600){WAN(1,I),I=1,15} 00018250
ISN     19      600 FORMAT(1X,E12.5)                     00018260
ISN     20      RETURN                                     00018270
ISN     21      END                                       00018280
ISN     22      END                                       00018290
```

STATISTICS SOURCE STATEMENTS = 21, PROGRAM SIZE = 1386 BYTES, PROGRAM NAME = CONWAT PAGE: 44.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 16 *****

OPTIONS IN EFFECT: NDLIST NOMAP NOXREF NOGOSTMT NODCK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(I) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

*.....1.....2.....3.....4.....5.....6.....7.....8

```

ISN      1      SUBROUTINE HEADG(IPG)                                00018300
ISN      2      DIMENSION TITLE(10),IDNUM(4),UNAME(6),DATE(5)      00018310
ISN      3      COMMON/IO/NI,NO,IOUT                                00018320
ISN      4      COMMON/HDG/TITLE,IDNUM,UNAME,DATE                    00018330
ISN      5      WRITE(NO,600)                                        00018340
ISN      6      600 FORMAT(1H1,/5X,70(1H_)//5X,'DEMNERALIZATION SYSTEM PERF', 00018350
                1 'ORMANCE ', 'SIMULATION',4X,'VERSION: 830901-1.0') 00018360
ISN      7      WRITE(NO,601){TITLE(I),I=1,10},{IDNUM(J),J=1,4}    00018370
ISN      8      601 FORMAT(/5X,10A4,3X,'ID NO: ',4A4)              00018380
ISN      9      WRITE(NO,602){UNAME(I),I=1,6},{DATE(J),J=1,5},IPG 00018390
ISN     10      602 FORMAT(5X,'USER NAME: ',6A4,'DATE: ',5A4,'PAGE: ',12) 00018400
ISN     11      WRITE(NO,603)                                        00018410
ISN     12      603 FORMAT(5X,70(1H_)//)                             00018420
ISN     13      RETURN                                             00018430
ISN     14      END                                                00018440

```

STATISTICS SOURCE STATEMENTS = 14, PROGRAM SIZE = 1128 BYTES, PROGRAM NAME = HEADG PAGE: 45.

STATISTICS NO DIAGNOSTICS GENERATED.

***** END OF COMPILATION 17 *****

APPENDIX D

PERFORMANCE PROGRAM OUTPUT

PERFORMANCE PROGRAM OUTPUT

Four output listings are included as a part of this Appendix. The cases represented by these listings include simulations of the following: three and six bed demineralizer performance reported by Webb and Carr (29), and a two bed system proposed as Case 1 in Applebaum (1). The input dialogue for Applebaum Case 1 is provided as an example of the form in which input is provided to the program. Two performance simulations were made on the six bed demineralizer of Webb and Carr. One simulation used the original design water analysis as a basis and the other three bed demineralizer design water analysis. The listings may be identified as follows:

- A-1.1 Applebaum Case 1 two bed demineralizer,
- W-3.1 Webb and Carr three bed demineralizer,
- W-6.1 Webb and Carr six bed demineralizer (original design water analysis)
- W-6.2 Webb and Carr six bed demineralizer (three bed demineralizer design water analysis).


```

* * * * *
* DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION *
* * * * *
* VERSION: 830901-1.0 *
* BY: A.J.WILSON *
* * * * *

```

**** ENTER PROBLEM IDENTIFICATION ****

ENTER TITLE (40 CHARACTERS MAXIMUM)
?
APPLEBAUM CASE 1

ENTER PROBLEM ID NUMBER (15 CHARACTERS MAXIMUM)
?
A-1.1

ENTER USER NAME (25 CHARACTERS MAXIMUM)
?
A.J.WILSON

ENTER DATE (20 CHARACTERS MAXIMUM)
?
NOVEMBER 21, 1983

****ENTER SYSTEM DESIGN DATA****

ENTER NUMBER OF VESSELS IN SERIES (9 MAXIMUM)
?
3

ENTER NUMBER OF VESSELS IN SERIES WITH PARALLEL VESSELS
?
0

ENTER VESSEL TYPE
CX-CATION EXCHANGER
AX-ANION EXCHANGER
FG-FORCED DRAFT DEGASIFIER
VG-VACUUM DEGASIFIER

POSITION 1 ?

CX POSITION 2 ?

FG POSITION 3 ?

AX

ENTER SYSTEM FLOW RATE(GPM)
?
0.26600E+03

ENTER WATER ANALYSIS UNITS

1-MG/L AS SUCH
2-MG/L AS CaCO3
3-MEQ/L

?

2

ENTER INFLUENT WATER ANALYSIS

H+ ?
0.0000E+00
CA++ ?
0.3500E+02
MG++ ?
0.2200E+02
NA+ ?
0.5500E+02
K+ ?
0.0000E+00
DH- ?
0.0000E+00
CO3= ?
0.6900E+02
HCO3 ?
0.0000E+00
SO4= ?
0.2100E+02
CL- ?
0.2200E+02
NO3- ?
0.0000E+00
SIO2 ?
0.6179E+01
CO2 ?
0.0000E+00

ENTER INFLUENT TEMPERATURE(F)

?
0.5000E+02

****ENTER VESSEL DESIGN DATA****

*** VESSEL 1 ***

ENTER VESSEL DIAMETER (INCHES)
?
0.6600E+02
ENTER VESSEL SIDE SHEET (INCHES)
?
0.6000E+02
ENTER EFFECTIVE RESIN DEPTH (INCHES)
?
0.3000E+02
ENTER INEFFECTIVE RESIN DEPTH (INCHES)
?
0.3000E+01
ENTER VESSEL WALL THICKNESS (INCHES)
?
0.1750E+00
ENTER CATION RESIN TYPE

```

      200-LIST OF DOWEX RESIN TYPE CODES
?
201
  ENTER CATION RESIN REGENERANT LEVEL (LB/CU FT)
  ?
  0.50000E+01
  ENTER CATION RESIN CAPACITY EFFECTIVENESS (PERCENT)
  ?
  0.80000E+02
  ENTER DEGASIFIER EFFLUENT CO2 CONCENTRATION
  ?
  0.57000E+01
*** VESSEL 3 ***
  ENTER VESSEL DIAMETER (INCHES)
  ?
  0.66000E+02
  ENTER VESSEL SIDE SHEET (INCHES)
  ?
  0.60000E+02
  ENTER EFFECTIVE RESIN DEPTH (INCHES)
  ?
  0.30000E+02
  ENTER INEFFECTIVE RESIN DEPTH (INCHES)
  ?
  0.30000E+01
  ENTER VESSEL WALL THICKNESS (INCHES)
  ?
  0.17500E+00
  ENTER ANION RESIN TYPE
    200-LIST OF DOWEX RESIN TYPE CODES
?
221
  ENTER REGENERANT TEMPERATURE(F)
  ?
  0.75000E+02
  ENTER ANION RESIN REGENERANT LEVEL (LB/CU FT)
  ?
  0.50000E+01
  ENTER ANION RESIN CAPACITY EFFECTIVENESS (PERCENT)
  ?
  0.95000E+02
  RUN CURRENT CASE OR EDIT
  1-RUN
  2-EDIT
?
2

****EDIT MENU****
  0 - RUN CURRENT CASE
  1 - LIST PROBLEM IDENTIFICATION
  2 - LIST SYSTEM DESIGN DATA

```

3 - LIST VESSEL DESIGN DATA
4 - LIST VESSEL DESIGN DEFAULTS
8 - EDIT VESSEL DESIGN DEFAULTS
9 - NEW PROBLEM
?

1

****PROBLEM IDENTIFICATION****

TITLE: APPLEBAUM CASE 1

ID NO: A-1.1

USER NAME: A.J.WILSON

DATE: NOVEMBER 21, 1983

****ENTER SELECTION****

0 - RETURN TO EDIT MENU
1 - RUN CURRENT CASE

?

0

****EDIT MENU****

0 - RUN CURRENT CASE
1 - LIST PROBLEM IDENTIFICATION
2 - LIST SYSTEM DESIGN DATA
3 - LIST VESSEL DESIGN DATA
4 - LIST VESSEL DESIGN DEFAULTS
8 - EDIT VESSEL DESIGN DEFAULTS
9 - NEW PROBLEM
?

2

****SYSTEM DESIGN DATA****

SYSTEM FLOW RATE 266.0 GPM

INFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
Ca++	35.0000
Mg++	22.0000
Na+	55.0000
K+	0.0000
OH-	0.0000
CO3-	88.0000
HCO3	0.0000
SO4-	21.0000
Cl-	22.0000
NO3-	0.0000
SiO2	6.1790
CO2	0.0000

INFLUENT TEMPERATURE 50.0 F

SYSTEM CONFIGURATION

VESSEL 1	CATION EXCHANGER
VESSEL 2	FORCED DRAFT DEGASIFIER
VESSEL 3	ANION EXCHANGER

NUMBER OF VESSELS IN PARALLEL

VESSEL 1 0
VESSEL 2 0
VESSEL 3 0

****ENTER SELECTION****
0 - RETURN TO EDIT MENU
1 - RUN CURRENT CASE

?
0

****EDIT MENU****

0 - RUN CURRENT CASE
1 - LIST PROBLEM IDENTIFICATION
2 - LIST SYSTEM DESIGN DATA
3 - LIST VESSEL DESIGN DATA
4 - LIST VESSEL DESIGN DEFAULTS
8 - EDIT VESSEL DESIGN DEFAULTS
9 - NEW PROBLEM
?

3

ENTER VESSEL NUMBER OR NUMBERS
FORMATS - N OR
 - N M
WHERE: N - INITIAL VESSEL
 M - FINAL VESSEL
EXAMPLE: 1 3 - OUTPUT FOR ALL VESSELS

?
1 3

**** VESSEL 1 DESIGN****

OUTSIDE DIAMETER(INCHES)	66.0
WALL THICKNESS(INCHES)	0.175
STRAIGHT SIDE(INCHES)	60.0
RESIN TYPE	DOWEX HCR-S
EFFECTIVE RESIN DEPTH(INCHES)	30.0
INEFFECTIVE RESIN DEPTH(INCHES)	3.0
CAPACITY EFFECTIVENESS(PERCENT)	80.0
REGENERANT LEVEL (LB 93% H2SO4/CU FT)	5.0

**** VESSEL 2 DESIGN****

FORCED DRAFT DEGASIFIER	MG/L AS CAC03
EFFLUENT CARBON DIOXIDE	5.7000

**** VESSEL 3 DESIGN****

OUTSIDE DIAMETER(INCHES)	66.0
WALL THICKNESS(INCHES)	0.175
STRAIGHT SIDE(INCHES)	60.0

RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH(INCHES)	30.0
INEFFECTIVE RESIN DEPTH(INCHES)	3.0
CAPACITY EFFECTIVENESS(PERCENT)	95.0
REGENERANT LEVEL (LB 100% NAOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	75.0

****ENTER SELECTION****
 0 - RETURN TO EDIT MENU
 1 - RUN CURRENT CASE

?
 0

****EDIT MENU****

0 - RUN CURRENT CASE
 1 - LIST PROBLEM IDENTIFICATION
 2 - LIST SYSTEM DESIGN DATA
 3 - LIST VESSEL DESIGN DATA
 4 - LIST VESSEL DESIGN DEFAULTS
 5 - EDIT VESSEL DESIGN DEFAULTS
 9 - NEW PROBLEM

?
 4

ENTER VESSEL NUMBER OR NUMBERS
 FORMATS - N OR
 - N M
 WHERE: N - INITIAL VESSEL
 M - FINAL VESSEL
 EXAMPLE: 1 3 - OUTPUT FOR ALL VESSELS

?
 1 3

****VESSEL 1 DEFAULTS****

BED EXPANSION(%):	50.0
SLOW RINSE VOLUME(GAL):	527.5
FAST RINSE VOLUME(GAL):	1469.2

****VESSEL 2 DEFAULTS****

****VESSEL 3 DEFAULTS****

BED EXPANSION(%):	50.0
ANION REGENERANT APPLICATION TIME(MIN):	60.0
SLOW RINSE VOLUME(GAL):	527.5
FAST RINSE VOLUME(GAL):	5876.7

****ENTER SELECTION****

```

0 - RETURN TO EDIT MENU
1 - RUN CURRENT CASE
?
0

****EDIT MENU****

0 - RUN CURRENT CASE
1 - LIST PROBLEM IDENTIFICATION
2 - LIST SYSTEM DESIGN DATA
3 - LIST VESSEL DESIGN DATA
4 - LIST VESSEL DESIGN DEFAULTS
8 - EDIT VESSEL DESIGN DEFAULTS
9 - NEW PROBLEM
?
8

ENTER VESSEL NUMBER OR NUMBERS
FORMATS - N OR
        - N M
WHERE:  N - INITIAL VESSEL
        M - FINAL VESSEL
EXAMPLE: 1 3 - OUTPUT FOR ALL VESSELS
?
1 3
****EDIT VESSEL 1 DEFAULTS****
1 - CHANGE BACKWASH TIME
2 - CHANGE BACKWASH BED EXPANSION
3 - CHANGE SLOW RINSE VOLUME
4 - CHANGE FAST RINSE VOLUME
1

ENTER BACKWASH TIME(MINUTES)
?
0.10000E+02

****ENTER SELECTION****
0 - CONTINUE TO EDIT DEFAULTS
1 - RETURN TO EDIT MENU
2 - RUN CURRENT CASE
?
0

****ENTER SELECTION****
0 - SAME VESSEL
1 - NEXT VESSEL
?
1
****EDIT VESSEL 3 DEFAULTS****
1 - CHANGE BACKWASH TIME
2 - CHANGE BACKWASH BED EXPANSION
3 - CHANGE SLOW RINSE VOLUME
4 - CHANGE FAST RINSE VOLUME
5 - CHANGE ANION REGENERANT APPLICATION TIME
5

ENTER REGENERANT APPLICATION TIME(MINUTES)
?
0.90000E+02

****ENTER SELECTION****
0 - CONTINUE TO EDIT DEFAULTS

```

- 1 - RETURN TO EDIT MENU
- 2 - RUN CURRENT CASE

2

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830801-1.0

APPLEBAUM CASE 1

IC NO: A-1.1

USER NAME: A.J.WILSON

DATE: NOVEMBER 21, 1983

PAGE: 1

*** OUTPUT SELECTION ***

ENTER OUTPUT TYPE

- 0 - COMPLETE
- 1 - SYSTEM DESIGN
- 2 - SYSTEM PERFORMANCE
- 3 - VESSEL DESIGN
- 4 - VESSEL PERFORMANCE
- 5 - EDIT INPUT DATA
- 6 - EXIT PROGRAM

?

o

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

APPLEBAUM CASE 1
USER NAME: A.J.WILSON

ID NO: A-1.1
DATE: NOVEMBER 21, 1983 PAGE: 4

**** VESSEL 1 DESIGN****

OUTSIDE DIAMETER (INCHES)	66.0
WALL THICKNESS (INCHES)	0.175
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	23.51
FLOW RATE PER VESSEL (GPM)	266.0
RESIN TYPE	DDWEX HCR-S
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	58.8
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	64.6
CAPACITY EFFECTIVENESS (PERCENT)	80.0
REGENERANT LEVEL (LB 93% H2SO4/CU FT)	5.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

APPLEBAUM CASE 1
USER NAME: A.J.WILSON

ID NO: A-1.1
DATE: NOVEMBER 21, 1983 PAGE: 6

**** VESSEL 3 DESIGN****

OUTSIDE DIAMETER (INCHES)	66.0
WALL THICKNESS (INCHES)	0.175
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	23.51
FLOW RATE PER VESSEL (GPM)	266.0
RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	58.8
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	64.6
CAPACITY EFFECTIVENESS (PERCENT)	95.0
REGENERANT LEVEL (LB 100% NaOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	75.0

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

APPLEBAUM CASE 1 ID NO: A-1.1
 USER NAME: A.J.WILSON DATE: NOVEMBER 21, 1983 PAGE: 7

**** VESSEL 1 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 13.60
 VESSEL (KGR AS CaCO3) 799.11
 LOAD (KGR AS CaCO3) 799.11
 UTILIZATION (PERCENT) 100.00
 THROUGHPUT (GAL/REGEN) 122007.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	39.4615
Ca++	0.0000
Mg++	0.0000
Na+	3.5384
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	21.0000
CL-	22.0000
NO3-	0.0000
SiO2	6.1790
CO2	34.5000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	148.7	1487.	10.00
REGN APPLICATION			
RECENERANT			
AT 2% H2SO4	0.4	10.	23.50
AT 4% H2SO4	0.8	10.	11.51
DILUTION WATER			
AT 2% H2SO4	36.7	863.	23.50
AT 4% H2SO4	36.7	423.	11.51
SLOW RINSE	36.7	527.	14.36
FAST RINSE	266.0	1468.	5.52

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION. 830801-1.0

APPLEBAUM CASE 1 ID NO: A-1.1
 USER NAME: A.J.WILSON DATE: NOVEMBER 21, 1983 PAGE: 9

**** VESSEL 3 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 10.31
 VESSEL (KGR AS CaCO3) 605.72
 LOAD (KGR AS CaCO3) 372.06
 UTILIZATION (PERCENT) 61.43
 THROUGHPUT (GAL/REGEN) 115933.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
Ca++	0.0000
Mg++	0.0000
Na+	3.5384
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3-	0.0000
SO4-	0.0000
CL-	3.5384
NO3-	0.0000
SIO2	0.0238
CO2	0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	38.5	197.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	0.5	47.	90.00
DILUTION WATER			
AT 3% NaOH	12.7	1139.	90.00
SLOW RINSE	12.7	527.	41.67
FAST RINSE	266.0	5877.	22.09

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR THREE BED
USER NAME: A.J.WILSON

ID NO: W-3.1
DATE: NOVEMBER 3, 1983 PAGE: 2

**** OVERALL SYSTEM DESIGN ****

SYSTEM FLOW RATE 270.0 GPM

INFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
CA++	30.0000
MG++	38.0000
NA+	17.0000
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	66.0000
SO4-	4.0000
CL-	14.0000
NO3-	1.0000
SIO2	1.6700
CO2	0.0000

INFLUENT TEMPERATURE 55.0 F

SYSTEM CONFIGURATION

VESSEL 1	CATION EXCHANGER
VESSEL 2	VACUUM DEGASIFIER
VESSEL 3	ANION EXCHANGER
VESSEL 4	CATION EXCHANGER
VESSEL 5	ANION EXCHANGER

NUMBER OF VESSELS IN PARALLEL

VESSEL 1	1
VESSEL 2	1
VESSEL 3	1
VESSEL 4	1
VESSEL 5	1

REGENERANT CHEMICALS

CATION RESIN	93 PERCENT SULFURIC ACID
ANION RESIN	50 PERCENT SODIUM HYDROXIDE

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 820901-1.0

WEBB AND CARR THREE BED
USER NAME: A.J.WILSON

ID NO: W-3.1
DATE: NOVEMBER 3, 1983 PAGE: 3

**** OVERALL SYSTEM PERFORMANCE ****

THROUGHPUT	GALLONS PER REGENERATION
GROSS	539660.
NET	491215.

OPERATING TIME	30.75 HOURS
----------------	-------------

EFFLUENT WATER ANALYSIS	MG/L AS CaCO3
-------------------------	---------------

H+	0.0000
CA++	0.0000
MG++	0.0000
NA+	0.3310
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.3310
NO3-	0.0000
SIO2	0.0329
CO2	0.0000

TOTAL REGENERANT	GALLONS PER REGENERATION
ACID	52.40
CAUSTIC	80.71

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR THREE BED
USER NAME: A. J. WILSON

ID NO: W-3.1
DATE: NOVEMBER 3, 1983 PAGE: 5

**** VESSEL 2 DESIGN****

VACUUM DEGASIFIER	MG/L AS CaCO3
EFFLUENT CARBON DIOXIDE	5.7000

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR THREE BED
USER NAME: A.J.WILSON

ID NO: W-3.1
DATE: NOVEMBER 3, 1983 PAGE: 6

**** VESSEL 3 DESIGN****

OUTSIDE DIAMETER (INCHES)	78.0
WALL THICKNESS (INCHES)	0.750
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	31.92
FLOW RATE PER VESSEL (GPM)	270.0
RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	79.8
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	87.8
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 100% NaOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	120.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR THREE BED ID NO: W-3.1
 USER NAME: A.J.WILSON DATE: NOVEMBER 3, 1983 PAGE: 9

**** VESSEL 1 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 16.28
 VESSEL (KGR AS CaCO3) 3172.15
 LOAD (KGR AS CaCO3) 2517.27
 UTILIZATION (PERCENT) 79.36
 THROUGHPUT (GAL/REGEN) 508415.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	18.1455
Ca++	0.0000
Mg++	0.0000
Na+	0.8545
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	4.0000
CL-	14.0000
NO3-	1.0000
SiO2	1.6700
CO2	66.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	323.8	3238.	10.00
REGN APPLICATION			
REGENERANT			
AT 2% H2SO4	1.5	45.	29.13
DILUTION WATER			
AT 2% H2SO4	137.5	4006.	29.13
SLOW RINSE	137.5	1503.	10.93
FAST RINSE	270.0	4871.	18.04

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR THREE BED
 USER NAME: A.J.WILSON

ID NO: W-3.1
 DATE: NOVEMBER 3, 1983 PAGE: 13

**** VESSEL 5 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 7.15
 VESSEL (KGR AS CaCO3) 215.38
 LOAD (KGR AS CaCO3) 24.78
 UTILIZATION (PERCENT) 11.51
 THROUGHPUT (GAL/REGEN) 484157.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
Ca++	0.0000
Mg++	0.0000
Na+	0.3310
K+	0.0000
OH-	0.0000
CO2=	0.0000
HCO3	0.0000
SO4=	0.0000
CL-	0.3310
NO3-	0.0000
SiO2	0.0329
CO2	0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	21.3	106.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	0.3	17.	60.00
DILUTION WATER			
AT 3% NaOH	6.8	409.	60.00
SLOW RINSE	6.8	270.	39.69
FAST RINSE	270.0	3012.	11.16

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1 0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 2

**** OVERALL SYSTEM DESIGN ****

SYSTEM FLOW RATE 175.0 GPM

INFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
CA++	35.0000
MG++	81.0000
NA+	142.0000
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	94.0000
SO4-	8.0000
CL-	157.0000
NO3-	1.0000
SIO2	5.0100
CO2	0.0000

INFLUENT TEMPERATURE 55.0 F

SYSTEM CONFIGURATION

VESSEL 1	CATION EXCHANGER
VESSEL 2	VACUUM DEGASIFIER
VESSEL 3	ANION EXCHANGER
VESSEL 4	CATION EXCHANGER
VESSEL 5	ANION EXCHANGER
VESSEL 6	CATION EXCHANGER
VESSEL 7	ANION EXCHANGER

NUMBER OF VESSELS IN PARALLEL

VESSEL 1	1
VESSEL 2	1
VESSEL 3	1
VESSEL 4	1
VESSEL 5	1
VESSEL 6	1
VESSEL 7	1

REGENERANT CHEMICALS

CATION RESIN	92 PERCENT SULFURIC ACID
ANION RESIN	50 PERCENT SODIUM HYDROXIDE

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 630601-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 3

**** OVERALL SYSTEM PERFORMANCE ****

THROUGHPUT	GALLONS PER REGENERATION
GROSS	279009.
NET	222178.

OPERATING TIME 21.80 HOURS

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
CA++	0.0000
MG++	0.0000
NA+	0.8922
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.8922
NO3-	0.0000
SIO2	0.0002
CO2	0.0000

TOTAL REGENERANT	GALLONS PER REGENERATION
ACID	92.91
CAUSTIC	81.70

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE 5

**** VESSEL 2 DESIGN****

VACUUM DEGASIFIER

MG/L AS CaCO3

EFFLUENT CARBON DIOXIDE

5.7000

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830801-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 7

**** VESSEL 4 DESIGN****

OUTSIDE DIAMETER (INCHES)	48.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	12.05
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX HCR-S
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	30.1
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	33.1
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 93% H2SO4/CU FT)	6.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 8

**** VESSEL 5 DESIGN****

OUTSIDE DIAMETER (INCHES)	48.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	12.05
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	30.1
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	33.1
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 100% NaOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	120.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 9

**** VESSEL 6 DESIGN****

OUTSIDE DIAMETER (INCHES)	42.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	60.0
AREA (SQARE FEET)	9.17
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX HCR-S
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	22.9
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	25.2
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 93% H2SO4/CU FT)	9.0

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-5.1
DATE: NOVEMBER 4, 1983 PAGE: 10

**** VESSEL 7 DESIGN****

OUTSIDE DIAMETER (INCHES)	42.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	9.17
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	22.9
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	25.2
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 100% NaOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	120.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
 USER NAME: A.J.WILSON

ID NO: W-6.1
 DATE: NOVEMBER 4, 1983 PAGE: 11

**** VESSEL 1 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 23.37
 VESSEL (KGR AS CaCO3) 3593.52
 LOAD (KGR AS CaCO3) 3635.67
 UTILIZATION (PERCENT) 91.04
 THROUGHPUT (GAL/REGEN) 240969.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	151.6874
Ca++	0.0000
Mg++	0.0000
Na+	12.3126
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	6.0000
CL-	157.0000
NO3-	1.0000
SiO2	6.0100
CO2	94.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	284.0	2840.	10.00
REGN APPLICATION			
RECENERANT			
AT 2% H2SO4	1.0	22.	23.50
AT 4% H2SO4	2.0	22.	11.51
AT 6% H2SO4	3.0	22.	7.51
DILUTION WATER			
AT 2% H2SO4	85.4	2008.	23.50
AT 4% H2SO4	85.4	983.	11.51
AT 6% H2SO4	85.4	642.	7.51
SLOW RINSE	85.4	1318.	15.43
FAST RINSE	175.0	4272.	24.41

DEMNERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WE25 AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 13

**** VESSEL 3 PERFORMANCE****

CAPACITY:
RESIN (KGR AS CaCO3/CU FT) 25.41
VESSEL (KGR AS CaCO3) 2445.26
LOAD (KGR AS CaCO3) 2236.26
UTILIZATION (PERCENT) 81.45
THROUGHPUT (GAL/REGEN) 233171.

EFFLUENT WATER ANALYSIS	MG/L AS CaCO3
H+	0.0000
CA++	0.0000
MG++	0.0000
NA+	12.3126
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	12.3126
NO3-	0.0000
SiO2	5.0100
CO2	5.7000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	116.2	581.	5.00
REGN APPLICATION			
REGENERANT			
AT 2% NaOH	2.0	49.	24.81
DILUTION WATER			
AT 3% NaOH	48.1	1194.	24.81
SLOW RINSE	48.1	771.	16.03
FAST RINSE	175.0	7217.	41.24

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
 USER NAME: A.J.WILSON

ID NO: W-6.1
 DATE: NOVEMBER 4, 1983 PAGE: 15

**** VESSEL 5 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 10.23
 VESSEL (KGR AS CaCO3) 308.18
 LOAD (KGR AS CaCO3) 308.18
 UTILIZATION (PERCENT) 100.00
 THROUGHPUT (GAL/REGEN) 228899.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+ 0.0000
 Ca++ 0.0000
 Mg++ 0.0000
 NA+ 4.1179
 K+ 0.0000
 OH- 0.0000
 CO3- 0.0000
 HCO3 0.0000
 SO4- 0.0000
 CL- 4.1179
 NO3- 0.0000
 SiO2 0.0179
 CO2 0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	21.3	106.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	0.4	24.	60.00
DILUTION WATER			
AT 3% NaOH	9.7	584.	60.00
SLOW RINSE	9.7	270.	27.78
FAST RINSE	175.0	3012.	17.21

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.1
DATE: NOVEMBER 4, 1983 PAGE: 16

**** VESSEL 6 PERFORMANCE****

CAPACITY:
RESIN (KGR AS CaCO3/CU FT) 20.39
VESSEL (KGR AS CaCO3) 467.27
LOAD (KGR AS CaCO3) 54.91
UTILIZATION (PERCENT) 11.75
THROUGHPUT (GAL/REGEN) 228021.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	3.2257
Ca++	0.0000
Mg++	0.0000
Na+	0.8922
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	4.1178
NO3-	0.0000
SIO2	0.0178
CO2	0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	61.0	305.	5.00
REGN APPLICATION			
REGENERANT			
AT 5% H2SO4	0.4	14.	68.82
DILUTION WATER	11.5	3379.	68.82
SLOW RINSE	11.5	206.	17.95
FAST RINSE	175.0	573.	3.27

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
 USER NAME: A.J.WILSON

ID NO: W-6.1
 DATE: NOVEMBER 4, 1983 PAGE: 17

**** VESSEL 7 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 8.26
 VESSEL (KGR AS CaCO3) 189.71
 LOAD (KGR AS CaCO3) 54.56
 UTILIZATION (PERCENT) 28.77
 THROUGHPUT (GAL/REGEN) 225648.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
Ca++	0.0000
Mg++	0.0000
Na+	0.8922
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.8922
NO3-	0.0000
SiO2	0.0002
CO2	0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	16.2	81.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	0.3	18.	60.00
DILUTION WATER			
AT 3% NaOH	7.4	444.	60.00
SLOW RINSE	7.4	206.	27.78
FAST RINSE	175.0	2292.	13.10

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 2

**** OVERALL SYSTEM DESIGN ****

SYSTEM FLOW RATE 175.0 GPM

INFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
CA++	30.0000
MG++	38.0000
NA+	17.0000
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	56.0000
SO4-	4.0000
CL-	14.0000
NO3-	1.0000
SIO2	1.6700
CO2	0.0000

INFLUENT TEMPERATURE 55.0 F

SYSTEM CONFIGURATION

VESSEL 1	CATION EXCHANGER
VESSEL 2	VACUUM DEGASIFIER
VESSEL 3	ANION EXCHANGER
VESSEL 4	CATION EXCHANGER
VESSEL 5	ANION EXCHANGER
VESSEL 6	CATION EXCHANGER
VESSEL 7	ANION EXCHANGER

NUMBER OF VESSELS IN PARALLEL

VESSEL 1	1
VESSEL 2	1
VESSEL 3	1
VESSEL 4	1
VESSEL 5	1
VESSEL 6	1
VESSEL 7	1

REGENERANT CHEMICALS

CATION RESIN	83 PERCENT SULFURIC ACID
ANION RESIN	50 PERCENT SODIUM HYDROXIDE

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 3

**** OVERALL SYSTEM PERFORMANCE ****

THROUGHPUT	GALLONS PER REGENERATION
GROSS	773428.
NET	716598.

OPERATING TIME 70.04 HOURS

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
CA++	0.0000
MG++	0.0000
NA+	0.0352
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.0352
NO3-	0.0000
SiO2	0.0021
CO2	0.0000

TOTAL REGENERANT	GALLONS PER REGENERATION
ACID	92.91
CAUSTIC	91.70

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A. J. WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 5

**** VESSEL 2 DESIGN****

VACUUM DEGASIFIER	MG/L AS CaCO3
EFFLUENT CARBON DIOXIDE	5.7000

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 7

**** VESSEL 4 DESIGN****

OUTSIDE DIAMETER (INCHES)	48.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	12.05
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX HCR-S
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	30.1
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	33.1
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 93% H2SO4/CU FT)	6.0

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 8

**** VESSEL 5 DESIGN****

OUTSIDE DIAMETER (INCHES)	48.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	80.0
AREA (SQUARE FEET)	12.05
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	30.1
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	33.1
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 100% NAOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	120.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 10

**** VESSEL 7 DESIGN****

OUTSIDE DIAMETER (INCHES)	42.0
WALL THICKNESS (INCHES)	0.500
STRAIGHT SIDE (INCHES)	60.0
AREA (SQUARE FEET)	9.17
FLOW RATE PER VESSEL (GPM)	175.0
RESIN TYPE	DOWEX SBR-P
EFFECTIVE RESIN DEPTH (INCHES)	30.0
EFFECTIVE RESIN VOLUME (CU FT)	22.9
INEFFECTIVE RESIN DEPTH (INCHES)	3.0
TOTAL RESIN VOLUME (CU FT)	25.2
CAPACITY EFFECTIVENESS (PERCENT)	90.0
REGENERANT LEVEL (LB 100% NaOH/CU FT)	5.0
REGENERATION TEMPERATURE (F)	120.0

DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 12

**** VESSEL 2 PERFORMANCE****

VACUUM DEGASIFIER	MG/L AS CaCO3
EFFLUENT CARBON DIOXIDE	5.7000

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED ID NO: W-6.2
 USER NAME: A.J.WILSON DATE: NOVEMBER 4, 1983 PAGE: 13

**** VESSEL 3 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 24.74
 VESSEL (KGR AS CaCO3) 2381.08
 LOAD (KGR AS CaCO3) 808.43
 UTILIZATION (PERCENT) 33.95
 THROUGHPUT (GAL/REGEN) 727590.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
Ca++	0.0000
Mg++	0.0000
Na+	0.4861
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.4861
NO3-	0.0000
SiO2	1.8700
CO2	5.7000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	116.2	581.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	2.0	49.	24.81
DILUTION WATER			
AT 3% NaOH	48.1	1194.	24.81
SLOW RINSE	48.1	771.	16.03
FAST RINSE	175.0	7217.	41.24

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
 USER NAME: A.J.WILSON

ID NO: W-8.2
 DATE: NOVEMBER 4, 1983 PAGE: 14

**** VESSEL 4 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 22.71
 VESSEL (KGR AS CaCO3) 684.07
 LOAD (KGR AS CaCO3) 20.65
 UTILIZATION (PERCENT) 3.02
 THROUGHPUT (GAL/REGEN) 726437.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.3235
Ca++	0.0000
Mg++	0.0000
Na+	0.1626
K+	0.0000
OH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.4861
NO3-	0.0000
SiO2	1.6700
CO2	5.7000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	80.1	401.	5.00
REGN APPLICATION			
REGENERANT			
AT 6% H2SO4	0.5	12.	47.34
DILUTION WATER	15.1	3331.	47.34
SLOW RINSE	15.1	270.	17.85
FAST RINSE	175.0	753.	4.30

DEMNERALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
USER NAME: A.J.WILSON

ID NO: W-6.2
DATE: NOVEMBER 4, 1983 PAGE: 15

**** VESSEL 5 PERFORMANCE****

CAPACITY:
RESIN (KGR AS CaCO3/CU FT) 13.74
VESSEL (KGR AS CaCO3) 414.00
LOAD (KGR AS CaCO3) 332.31
UTILIZATION (PERCENT) 80.27
THROUGHPUT (GAL/REGEN) 723318.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
CA++	0.0000
MG++	0.0000
NA+	0.1626
K+	0.0000
BH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.1626
NO3-	0.0000
SIO2	0.0089
CO2	0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	21.3	106.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	0.4	24.	60.00
DILUTION WATER			
AT 3% NaOH	9.7	584.	60.00
SLOW RINSE	9.7	270.	27.78
FAST RINSE	175.0	3012.	17.21

DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION VERSION: 830901-1.0

WEBB AND CARR SIX BED
 USER NAME: A.J.WILSON

ID NO: W-6.2
 DATE: NOVEMBER 4, 1983 PAGE: 17

**** VESSEL 7 PERFORMANCE****

CAPACITY:
 RESIN (KGR AS CaCO3/CU FT) 14.98
 VESSEL (KGR AS CaCO3) 343.38
 LOAD (KGR AS CaCO3) 7.26
 UTILIZATION (PERCENT) 2.11
 THROUGHPUT (GAL/REGEN) 720067.

EFFLUENT WATER ANALYSIS MG/L AS CaCO3

H+	0.0000
Ca++	0.0000
Mg++	0.0000
Na+	0.0352
K+	0.0000
DH-	0.0000
CO3-	0.0000
HCO3	0.0000
SO4-	0.0000
CL-	0.0352
NO3-	0.0000
SiO2	0.0021
CO2	0.0000

REGENERATION SUMMARY:

STEP	FLOW (GPM)	VOLUME (GAL)	DURATION (MIN)
BACKWASH	16.2	81.	5.00
REGN APPLICATION			
REGENERANT			
AT 3% NaOH	0.3	18.	60.00
DILUTION WATER			
AT 3% NaOH	7.4	444.	60.00
SLOW RINSE	7.4	206.	27.78
FAST RINSE	175.0	2292.	13.10

REQUESTED OPTIONS (EXECUTE): LANGLVL(66),NOTERM

OPTIONS IN EFFECT: NOLIST NOMAP NOXREF NOGOSTMT NODECK SOURCE NOTERM OBJECT FIXED NOTEST NOTRMFLG SRCFLG NOSYM
 OPT(O) LANGLVL(66) NOFIPS FLAG(1) NAME(MAIN) LINECOUNT(60) CHARLEN(500) SDUMP

```

*.....1.....2.....3.....4.....5.....6.....7*.....8
ISN      1      LOGICAL ECHO,DIAG,SUBI,COUT                00000010
ISN      2      DIMENSION IVES(9,8),VES(9,32),MBY(2,20),WAN(10,15), 00000020
              1      VT(6),IONS(13),LLP(9),CAT(2),ANI(2),      00000030
              2      IMBY(2,5),WUNIT(3,4),TITLE(10),IDNUM(4),UNAME(6), 00000040
              3      DATE(5),RESIN(3,2),RO(9,4),RVOL(9,4),DVOL(9,4), 00000050
              4      TSTEP(9,4),ISTEP(9)                    00000060
ISN      3      COMMON/IO/NI,NO,IOUT                      00000070
ISN      4      COMMON/DESD/WAN,VES,IVES                  00000080
ISN      5      COMMON/DESM/MBY,IMBY                      00000090
ISN      6      COMMON/HDG/TITLE,IDNUM,UNAME,DATE        00000100
ISN      7      COMMON/STEP/ISTEP,RO,RVOL,DVOL,TSTEP     00000110
ISN      8      DATA VT/2HVT,2HCX,2HAX,2HMX,2HFG,2HYG/  00000120
ISN      9      DATA IONS/4HH-,4HCA+,4HMG+,4HNA+,4HK+  00000130
              1      4HOH-,4HCO3-,4HCO3,4HSD4-,4HCL-,  00000140
              2      4HNO3-,4HSIO2,4HCO2 /                00000150
ISN     10      DATA CAT,ANI/4HCATI,2HON,4HANIO,2HN /    00000160
ISN     11      DATA ECHO,DIAG,SUBI/3=,TRUE,/,COUT/,FALSE, / 00000170
ISN     12      DATA WUNIT(1,1),WUNIT(1,2),WUNIT(1,3),WUNIT(1,4)/ 00000180
              1      4HMG/L,4H AS ,4HSUCH,4H /            00000190
ISN     13      DATA WUNIT(2,1),WUNIT(2,2),WUNIT(2,3),WUNIT(2,4)/ 00000200
              1      4HMG/L,4H AS ,4HCACO,4H3 /           00000210
ISN     14      DATA WUNIT(3,1),WUNIT(3,2),WUNIT(3,3),WUNIT(3,4)/ 00000220
              1      4HMEQ/,4HL ,4H /                    00000230
ISN     15      DATA RESIN(1,1),RESIN(1,2)/4HHCR-,4HS /  00000240
ISN     16      DATA RESIN(2,1),RESIN(2,2)/4HSBR-,4HP /  00000250
ISN     17      DATA RESIN(3,1),RESIN(3,2)/4HWGR-,4H2 /  00000260
ISN     18      10 IMB=0                                    00000270
ISN     19      IPG=0                                       00000280
ISN     20      PI=3.141593                                  00000290
ISN     21      R100=100.0                                  00000300
ISN     22      WRITE (NO,500)                              00000310
ISN     23      600 FORMAT(1H1,/,5X,1H+,13(3X,1H+),/,5X,1H+,3X, 00000320
              1      'DEMINEALIZATION SYSTEM PERFORMANCE SIMULATION', 00000330
              2      2X,1H+,/,5X,1H+,13(3X,1H+),/,5X,1H+,3X, 00000340
              3      'VERSION: 830901-1.0',28X,1H+,/,5X,1H+,  00000350
              4      3X,'BY: A.J.WILSON',34X,1H+,/,5X,1H+,  00000360
              5      13(3X,1H+),/))                          00000370
ISN     24      WRITE(NO,560)                                00000380
ISN     25      560 FORMAT(1X,'**** ENTER PROBLEM IDENTIFICATION ****', 00000390
              1      '/5X,'ENTER TITLE (40 CHARACTERS MAXIMUM)', 00000400
              2      '/5X,1H?)'                              00000410
ISN     26      READ(NI,520)(TITLE(I),I=1,10)              00000420
ISN     27      520 FORMAT(15A4)                            00000430
ISN     28      IF(ECHO)WRITE(NO,5520)(TITLE(I),I=1,10)   00000440
ISN     30      5520 FORMAT(1X,15A4)                        00000450
ISN     31      WRITE(NO,561)                                00000460
ISN     32      561 FORMAT(/5X,'ENTER PROBLEM ID NUMBER (15 CHARACTERS ', 00000470
              1      'MAXIMUM)',/5X,1H?)                    00000480
ISN     33      READ(NI,520)(IDNUM(I),I=1,4)              00000490
ISN     34      IF(ECHO)WRITE(NO,5520)(IDNUM(I),I=1,4)   00000500
ISN     36      WRITE(NO,562)                                00000510

```

VITA

Andrew James Wilson

Candidate for the Degree of

Doctor of Philosophy

Thesis: DEMINERALIZATION SYSTEM PERFORMANCE SIMULATION

Major Field: Chemical Engineering

Biographical:

Personal Data: Born in St. Joseph, Missouri, August 13, 1951, the son of Mr. and Mrs. James W. Wilson; married to Priscilla R. Logan on June 25, 1976.

Education: Graduated from Raytown South High School, Raytown, Missouri, in May, 1969; received Bachelor of Science degree in Chemical Engineering from University of Missouri-Rolla in 1974; enrolled as special student at Calvary Bible College in 1975; received Master of Science in Chemical Engineering from the University of Missouri-Columbia in 1979; received Doctor of Philosophy in Chemical Engineering from Oklahoma State University in December, 1983.

Professional Experience: Cooperative Engineer, Phillips Petroleum, 1970-73; Process Engineer, Phillips Petroleum, 1974; Chemical Engineer, Black and Veatch Consulting Engineers, 1976-81.