

THE EFFECT OF A 180° BEND ON TURBULENT
HEAT TRANSFER COEFFICIENT
IN A PIPE

By

MAHMOOD MOSHFEGHIAN

Bachelor of Science

Oklahoma State University

Stillwater, Oklahoma

1974


Submitted to the Faculty of the Graduate College
of the Oklahoma State University
in partial fulfillment of the requirements
for the Degree of
MASTER OF SCIENCE
July, 1975


Thesis
1975
M. 911e
cop. 2


OCT 23 1975


THE EFFECT OF A 180° BEND ON TURBULENT
HEAT TRANSFER COEFFICIENT
IN A PIPE

Thesis Approved:



Thesis Adviser






Dean of the Graduate College

923569

PREFACE

Heat transfer when water flow through a 180° bend tube was studied. A Reynolds range from 7,300 to 27,000 was investigated for a bend radius of 9.875 inches and 7/8-inch OD x 0.052-inch wall thickness. The test section was Inconel tube and was heated electrically by passing DC current through the tube wall.

I am very grateful to my adviser, Dr. K. J. Bell for his expert guidance and much valued counsel during the course of my study. I am also grateful to my Advisory Committee which consisted of Drs. J. H. Erbar and J. D. Parker, for their very helpful criticisms and suggestions given. I would like also to extend my appreciation to Dr. M. N. Farukki for providing me the computer program.

I thank the School of Chemical Engineering of Oklahoma State University for providing me financial assistance during the course of my study.

I am grateful to Mr. E. E. McCroskey, the storeroom manager for his assistance in the fabrication of the equipment. I also thank Mr. Reza Ahmadnia and Mr. Ahmad Moshfeghian for helping me to draw the computer flow charts and diagrams of this work.

Finally, I would like to express my appreciation to my father, Mr. Ali A. Moshfeghian for encouraging and providing me financial support through my education.

TABLE OF CONTENTS

Chapter	Page
I. INTRODUCTION,	1
II. LITERATURE SURVEY	3
III. EQUIPMENT	6
Loop Description	6
Test Section Description	6
Temperature Measurements	8
Pressure Measurements.	11
Flow Measurements,	11
Electrical Measurements,	11
IV. EXPERIMENTAL PROCEDURE.	12
Thermocouple Calibration	12
Manometer Calibration,	13
Rotameter Calibration,	13
Heat Loss Calibration,	13
Loop Operating Procedure	13
V. EXPERIMENTAL RESULTS AND DISCUSSION	15
Local Results,	15
Average Results,	26
Error Analysis	32
VII. CONCLUSIONS AND RECOMMENDATION.	33
BIBLIOGRAPHY.	35
APPENDIX A.	36
APPENDIX B.	41
APPENDIX C.	52
APPENDIX D.	55

Chapter	Page
APPENDIX E.	67
APPENDIX F.	78

LIST OF TABLES

Table	Page
I. Ratio of Heat Transfer Coefficients from Present Work to Those Predicted by Literature.	28
II. Calibration Data for Rotameter.	37
III. Calibration Data for Inlet and Outlet Thermocouples During In-Situ Calibration of Surface Thermocouples on the Test Section	38
IV. Calibration Data for Heat Loss from Test Section.	39
V. Calibration Data for Calibration of Outside Surface Thermocouples	40
VI. Run 209 - Outside Surface Temperature ^o F.	59
VII. Run 209 - Calculated Inside Surface Temperatures, ^o F.	60
VIII. Run 209 - Radial Heat Flux for Inside Surface, Btu/Hr-Ft ²	61
XI. Peripheral Heat Transfer Coefficients at Station 1.	65

LIST OF FIGURES

Figure	Page
1. Secondary Flow in Curved Tube.	2
2. Test Section Set-Up and Flow Direction Used by Lis (1), Ede (2), and Tailby (3)	4
3. Heat Transfer Loop (5)	7
4. Inconel Test Section (5)	9
5. Peripheral Distribution of Heat Transfer Coefficients, Run 207.	17
6. Peripheral Distribution of Heat Transfer Coefficients, Run 207.	18
7. Peripheral Distribution of Heat Transfer Coefficients, Run 207.	19
8. Peripheral Distribution of Heat Transfer Coefficients, Run 210.	20
9. Peripheral Distribution of Heat Transfer Coefficients, Run 210.	21
10. Peripheral Distribution of Heat Transfer Coefficients, Run 210.	22
11. Peripheral Distribution of Heat Transfer Coefficients, Run 215.	23
12. Peripheral Distribution of Heat Transfer Coefficients, Run 215.	24
13. Peripheral Distribution of Heat Transfer Coefficients, Run 215.	25
14. \overline{Nu} Number as a Function of Re and Position in Test Section.	31

NOMENCLATURE

A	- area
C_p	- specific heat, Btu/(lbm ^o F)
d_i	- inside tube diameter, inches
d_o	- outside tube diameter, inches
G	- mass velocity, lbm/(hr-ft ²)
h	- peripheral heat transfer coefficient, Btu/(hr-ft ² - ^o F)
\bar{h}	- averaged heat transfer coefficient around tube, Btu/(hr-ft ² - ^o F)
j	- = $NuPr^{-0.4} (\mu_w/\mu_i)^{-0.14}$, dimensionless number
K	- thermal conductivity, Btu/(hr-ft- ^o F)
Nu	- Nusselt number, hd_i/K dimensionless number
Pr	- Prandtl number, $C_p \mu/K$, dimensionless number
Q, q	- heat flow rate, Btu/hr
Q/A, q/A	- heat flux, Btu/(hr-ft ²)
R	- bend radius, measured to the longi- tudinal axis of tube, inches
r	- tube radius, inches
T	- fluid temperature, ^o F or ^o C

t_b	- bulk fluid temperature, °F
$t_{w,i}$	- inside wall temperature, °F
v	- fluid velocity, ft/sec.
w	- mass flow rate of fluid, lbm/hr
x	- axial distance along the tube from the entrance of straight section downstream of the bend, inches
X	- axial distance along the tube from the mid-point of 180° bend, inches

Greek Letters

μ	- fluid viscosity at fluid bulk temperature, centipoise or lbm/(ft-hr)
μ_w	- fluid viscosity at wall temperature, centipoise, or lbm/(ft-hr)
ρ	- electrical resistivity, (ohms-in ²)/in., or density lbm/ft ³ or gm/ml

Subscripts

avg	- average
b	- bulk fluid
i	- inside of tube
in	- inlet of test section
o	- outside of tube
out	- outlet of test section
w	- wall

CHAPTER I

INTRODUCTION

U-tubes (two lengths of straight tube joined by a 180° bend at one end) are commonly used in a large variety of tubular heat exchangers: for example, a continuous length of tubing may be bent back and forth across a duct. U-tubes are also used in shell-and-tube heat exchangers having entry and exit headers at the same end.

For a fully developed flow inside a straight horizontal tube, it is expected that the temperature profile would be symmetric about a horizontal axis passing through the center of the tube. However, for a fluid flowing axially in a curved tube, it is known that an induced secondary flow, as shown in Figure 1, is superimposed on the primary flow. Therefore, one would expect that the secondary flow enhances the heat transfer in the direction normal to the tube axis. Additionally, one would expect the heat transfer coefficients around the tube would be far from uniform, being probably highest on the outer side (position 5 in Figure 1) and lowest on the inner side (position 1). These results have been generally verified by experiments reported in the literature.

The present investigation was undertaken to study the effect of a 180° bend on heat transfer to water in a tube.

Experiments were made with water flowing through an electrically-heated tube to explore the variation of the local tube-to-water

heat transfer coefficient upstream of the 180° bend, in the bend, and downstream from the bend. The test section used was an Inconel tube of $7/8$ -inch OD x 0.052-inch wall thickness and a bend radius to the axis of 9.875 inches.




Figure 1. Secondary Flow in Curved Tube

Ⓒ

CHAPTER II

LITERATURE SURVEY

Despite the obvious importance of the effect of 180° bend, there is only a limited number of investigations reported in the literature.

Lis et al. (1) investigated the turbulent heat transfer in a vertical pipe, with upwards flow, preceded by a 180° bend (Figure 2). Based on their experimental data, they state the general shape of the curve of heat transfer coefficient against non-dimensional axial position (x/d) did not change very much with Reynolds number, and a simplified correlation for averaged heat transfer coefficient around the tube is as follows:

$$j_x = 0.0239 Re_x^{-0.064} (R/r)^{-0.062} \quad (1)$$

where

$$1 \leq x/d \leq 15, \quad 8000 \leq Re_x \leq 94000, \quad 5.5 \leq Pr \leq 9.7, \quad \text{and} \quad 2/1 \leq R/r \leq 4/1.$$

Ede (2) studied the effect of a 180° bend on heat transfer to water in a vertical tube. He reported that the flow visualization experiments for the laminar region have shown that circulation continues vigorously all around the bend, but appears to stop almost immediately once the straight part has been reached. For the turbulent region, he concluded that the velocity of the liquid near the outside of the bend is much higher than that near the inside, and




Figure 2. Test Section Set-Up and Flow Direction
Used by Lis (1), Ede (2), and Tailby
(3)

a secondary circulation develops; these conditions may extend for a considerable distance downstream. These secondary effects give rise to higher heat transfer coefficients than normal on the outside of the bend and lower on the inside, the average effect being an increase. For Reynolds numbers in the neighborhood of 5000 to 10,000, the possibility that an incipient laminar flow may develop has been tentatively advanced as an explanation of the production of unusually low heat-transfer coefficients.

Tailby et al. (3) also investigated the influence of 90° and 180° pipe bends on heat transfer from an internally flowing air stream in a vertical pipe with upwards flow. For a 180° bend, they also have derived an empirical correlation which includes the effect of curvature on heat transfer coefficient

$$\text{Nu} = 0.0341 \text{Re}^{0.82} \text{Pr}^{0.4} (x/d)^{-0.04} (R/r)^{-0.11} \quad (2)$$

where

$$7 \leq x/d \leq 30, \quad 4 \leq R/r \leq 14, \quad \text{and} \quad 10,000 \leq \text{Re} \leq 50,000$$

Finally, for air, the turbulent heat transfer rate and wall temperature distribution in rectangular ducts (aspect ratio 10) with a 180° bend were studied experimentally by Yang (4). He also concluded that the heat transfer coefficient is higher at the outside wall compared to that of the inside wall of the bend.

CHAPTER III

EQUIPMENT

The equipment was assembled by M. N. Farukhi, and most parts of this chapter and the following chapter are taken from his Ph.D. thesis (5).

Loop Description

The loop used here was essentially the same as that employed by Farukhi (5); there were some minor changes. A schematic diagram of the loop is shown in Figure 3. Liquid water was supplied to the system from a Colora[®] constant temperature bath which included a temperature controller, a mixer, and a small centrifugal pump. The water injection system was made from 1/2 inch copper, brass, and stainless steel tubing and fittings. Water from the bath was pumped by a 3 HP centrifugal pump through a 1/2 inch Manatrol[®] needle valve, and a Fischer and Porter[®] rotameter to the test section. Part of the water supplied by the pump was returned to the bath via a bypass line. The bypass flow rate was controlled by a 1/4 inch Manatrol[®] needle valve. From the test section the hot water was sent to a small heat exchanger to cool down the water to bath temperature.

Test Section Description

The test section was made from 7/8 inch OD x 0.052 inch wall Inconel 600 seamless tube. Inconel 600 was used because of its high




Figure 3. Heat Transfer Loop (5)

electrical resistance. The test section has a bend radius of 9.875 inches measured to the longitudinal axis of the tube. The test section is shown in Figure 4. The test section was annealed after bending so that stress relieving would be avoided during testing.

The test section was thermally insulated by wrapping it with several layers of bonded fiberglass tape and two inches of fiberglass sheets. The outside surface of insulation was then wrapped with aluminum foil so that radiation losses would be minimized.

The test section was also electrically isolated from the loop by connecting it with a short piece of neoprene tubing at each end.

Four pressure taps with 1/16 inch hole were silver-soldered to the test section. The taps were electrically isolated from the recording instrument by connecting them with silicone rubber tubing.

The test section was heated by passing DC current generated by a Lincolnweld[®] SA-750 motor generator set. Two thick copper bars were silver-soldered to the test section to serve as electrodes for connection to the motor generator.

Temperature Measurements

The test section was fitted with 88 thermocouples; their locations are shown in Figure 4. All the thermocouples were made from 30 AWG wire since the thinner wire was more flexible and had smaller induced stress and conduction losses.

The thermocouples were glued and mounted to the test section by the procedure outlined below.

1. A bead of Saureisen[®] No. 33 cement was placed at each thermocouple location.





Figure 4. Inconel Test Section (5)

2. After the bead dried completely it was sanded flat to about 1/2 mm thickness.

3. The hot junction of thermocouple wire was placed at the designated location and the wire was temporarily held in place with adhesive tape.

4. Another bead of cement was then placed on the hot junction so that the thermocouple was completely glued to the surface.

5. After the cement dried the thermocouple was held to the tube by a strap of wire. A three inch span was allowed between the hot junction and the strap of wire holding the thermocouple to the tube to minimize conduction errors.

The 88 thermocouples were placed at eleven stations along the test section. At each station, 8 thermocouples were located peripherally around the tube. The positions of stations and their thermocouple locations for upstream, in the bend, and downstream are shown in Figure 4.

The following fluid temperatures were also measured for each experimental run (see Figure 4 for their locations in the loop).

1. Water inlet temperature.
2. Water outlet temperature.

The inlet and outlet water temperatures were measured by ungrounded, sheathed thermocouples with hot junctions exposed to the fluid flow. The thermocouple assemblies were attached to the inlet and outlet lines by Swagelok[®] fittings.

All the surface thermocouples were connected to an array of barrier strips which in turn were connected to 11 rotary switches. The terminal lugs used on the barrier strips were made of either iron

or constantan and this feature eliminated any problems associated with creation of new thermocouples due to variation in room temperature. The rotary switches, however, were mounted on a panel and the connections were enclosed in a constant temperature box. The outputs from rotary switches were brought to a master rotary switch which was connected to a Leeds and Northrup Numatron[®]. The Numatron incorporated a reference junction compensator and the output was displayed in digital form in degrees Fahrenheit. The Numatron was calibrated prior to usage according to manufacturer's specification.

Pressure Measurements

The six pressure taps, as shown in Figure 4, were connected to a manifold by a series of Whitey valves. The switching system was connected in such a manner that any of the six taps could be activated and read on a Meriam[®] U-type manometer against atmospheric pressure.

Flow Measurements

The flow rate of water was measured by reading the output on a calibrated Fischer and Porter[®] rotameter.

Electrical Measurements

The current to the test section was measured by a Weston[®] Model 931 ammeter in conjunction with a 50 MW shunt. The voltage drop across the test section was measured by a Weston[®] Model 931 voltmeter.

CHAPTER IV

EXPERIMENTAL PROCEDURE

Thermocouple Calibration

All surface thermocouples were calibrated in situ by using saturated steam as reference temperature. To calibrate the thermocouples, the laboratory steam was allowed to go through a steam separator and liquid water was trapped out of stream. Then the saturated dry steam at atmospheric pressure was sent to the test section and the thermocouple outputs were recorded after a run time of approximately eight hours. The calibration runs were performed two times. During the runs, the atmospheric pressure and room temperature were also recorded so that the surface temperatures could be compared with saturated steam temperature. During calibration, the pressure in test section at six different locations was measured by a manometer against atmospheric pressure. The inlet and outlet water thermocouples were also calibrated during the calibration runs of surface thermocouples by comparing the inlet and outlet thermocouples reading with steam temperature at atmospheric pressure.

The thermocouple readings for all runs were corrected by assuming that the conduction losses were proportional to the difference between the thermocouple reading and room temperature for each run as compared to the difference during calibration (see Appendix A for more detail).

Manometer Calibration

The reading of the U-type manometer was set at zero for the condition of no flow through the test section. Liquid mercury was used as the indicator in the manometer.

Rotameter Calibration

The rotameter used for measuring liquid flow rate in the heat transfer loop was calibrated by taking known mass samples collected during a measured time interval at the operating conditions. The samples were collected at least two times for each reading. The calibration table for the rotameter is shown in Appendix A.

Heat Loss Calibration

Heat losses for the test section were measured by slowly bleeding dry saturated steam at atmospheric pressure through the system and collecting a known amount of mass of condensate for a specific time interval. The samples were collected several times during the run, starting after about eight hours of run time.

Heat losses for each run were calculated by assuming that the losses were proportional to the difference between the test section temperature and the room temperature for each as compared to the calibration run.

Loop Operating Procedure

The following step-by-step procedure was followed for each run.

1. The generator was turned on and left to warm up for about two hours with no current flow to the test section.

2. The pump was started and water was pumped through the system at the desired flow rate.
3. Cooling water was sent to the shellside of the heat exchanger.
4. After about five minutes, heat was added to the test section at the prescribed rate by adjusting the current rate to the test section.
5. After steady conditions had been reached (usually two hours steady conditions were determined by recording operating conditions at intervals of one hour and obtaining the same values for two sets), the wall temperatures, inlet and outlet temperatures, current to the test section, voltage drop, and other operating conditions such as room temperature, and atmospheric pressure were measured and recorded.

In all runs, the water bath temperature was maintained at about 75°F.

CHAPTER V

EXPERIMENTAL RESULTS AND DISCUSSION

The following parametric ranges were covered during the course of study:

Reynolds Number	7,300 to 27,000
Prandtl Number	4.5 to 8.0
Mass Velocities	215,900 to 84,000 lbm/hr ft ²
Average Heat Fluxes	2,825 to 16,600 Btu/hr ft ²

A total of ten runs was made. In each run the outside wall temperatures, inlet and outlet temperatures, flow rate, current and voltage drop in the test section, room temperature, and atmospheric pressure were measured. The value of these experimental measurement is presented in Appendix B.

Local Results

The local heat transfer coefficient was calculated by the following equation

$$h = \frac{q/A}{t_{w_i} - t_B} \quad (3)$$

To compute the inside wall temperature, t_{w_i} , from the measured outside wall temperature is a very complicated problem due to the existence of peripheral temperature gradients in tube wall, nonuniform

wall thickness (for the bend section) and length of conduction path, and the temperature effects on the electrical and thermal conductivities. Small corrections are also necessary for heat losses from the system. The problem is solved by an 80-element relaxation calculation at each station which uses the outside surface temperatures and total heat generation as input and gives the local inside surface temperatures, heat fluxes, q/A , and apparent heat transfer coefficients as output. This method of heat transfer coefficient calculation was developed and applied by Owhadi (6), Crain (7), Singh (8), and Farukhi (5). In this work, to find the inside wall temperature, heat flux, and heat transfer coefficient, a modified computer program originally written by Farukhi (5) was applied. A sample calculation is presented in Appendix D, and the listing of the computer program is presented in Appendix F.

For all runs, the local heat transfer coefficient at each peripheral position was calculated and is presented in Appendix E. For runs 207, 210, and 215, the local heat transfer coefficients are plotted as a function of peripheral position for all eleven stations and are shown in Figures 5 through 13. Runs 207, 210, and 215 are chosen because they represent the lowest, intermediate, and the highest Reynolds numbers obtained in this work.

An overall analysis of these figures indicates that local heat transfer coefficient is independent of peripheral position in the straight section ahead of the bend. In general for stations 4, 5, and 6 located in the bend, the heat transfer coefficients are much larger at peripheral position 5 than peripheral position 1. Since peripheral position 5 is located at the outside wall and peripheral




Figure 5. Peripheral Distribution of Heat Transfer Coefficients, Run 207




Figure 6. Peripheral Distribution of Heat Transfer Coefficients, Run 207




Figure 7. Peripheral Distribution of Heat Transfer Coefficients, Run 207




Figure 8. Peripheral Distribution of Heat Transfer Coefficients, Run 210




Figure 9. Peripheral Distribution of Heat Transfer Coefficients, Run 210




Figure 10. Peripheral Distribution of Heat Transfer Coefficients, Run 210




Figure 11. Peripheral Distribution of Heat Transfer Coefficients, Run 215




Figure 12. Peripheral Distribution of Heat Transfer Coefficients, Run 215




Figure 13. Peripheral Distribution of Heat Transfer Coefficients, Run 215

position 1 at the inside wall of the bend, the increase in heat transfer coefficient might be due to a higher fluid velocity at the outside wall compared to the fluid velocity near the inside wall of the bend. The higher heat transfer coefficient at outside wall of the bend might also be due to an induced secondary flow superimposed on the primary flow in the bend as shown in Figure 1. For stations downstream from the bend, the heat transfer coefficient are larger at peripheral position 1, located at the top of the tube, compared to peripheral position 5 (note that the number of peripheral position for the straight section downstream of the bend has been rotated 180°) located at the bottom of tube. The credit for higher heat transfer coefficients at the top of the tube might be given to the secondary flow caused by presence of the bend. As expected, the effect of secondary flow caused by the bend disappears at stations far downstream from the bend.

These curvature effects are in good qualitative agreement with the investigation of Ede (1) and Lis et al. (2).

Average Results

For each station the average heat transfer coefficient was calculated by the following equation

$$\bar{h} = \frac{1}{8} \sum_{i=1}^8 (h_i) \quad (4)$$

where h_i is the local heat transfer coefficient at each peripheral position. The calculated average heat transfer coefficient for each station is presented in Appendix E.

The calculated average heat transfer coefficients from experimental data for each station were compared to literature data. The ratios of average heat transfer coefficients from this work to heat transfer coefficients predicted by Dittus-Boelter (9) and Sieder-Tate (10) equations and heat transfer coefficients obtained from the Eagle-Ferguson (11) chart are presented in Table I.

Table I indicates that in the straight section upstream of the bend, the heat transfer coefficients found in this study are in good agreement with the Eagle-Ferguson (11) chart. Also, the heat transfer coefficients in the bend section are larger than the heat transfer coefficients obtained from Eagle-Ferguson (11) chart. For the runs made, the maximum increase of heat transfer coefficient in the bend was 18 percent, for run 211. In general this difference increases as Reynolds number increases. The bend also causes the heat transfer coefficient to increase in the straight section downstream from the 180° bend. The maximum increase of heat transfer coefficient occurred at station 7, located at the entrance of the straight section downstream from the bend, and was 22 percent higher as compared to Eagle-Ferguson (11) chart, for the highest Reynolds number (Run 215) made. Again, the higher Reynolds numbers give the greater increases in heat transfer coefficients. Finally, the ratio approaches unity for stations far downstream from the bend.

The average Nusselt number, \overline{Nu} , for each station is calculated and plotted in Figure 14 as a function of X/d and Reynolds number. Figure 14 indicates the behavior of \overline{Nu} is independent of Reynolds number for a certain region of flow, (turbulent or transition); but its value increases with Reynolds number for a given station. Figure

TABLE I
 RATIO OF HEAT TRANSFER COEFFICIENTS FROM PRESENT WORK
 TO THOSE PREDICTED BY LITERATURE

No.	Re_D	Source	1	2	3	4	5	6	7	8	9	10	11
206	7,300	Dittus-Boelter (D-B)	0.95	0.91	0.92	1.06	1.01	1.01	0.99	0.80	0.94	0.90	0.90
		Sieder-Tate (S-T)	0.90	0.86	0.86	1.00	0.94	0.96	0.93	0.74	0.88	0.85	0.84
		Eagle-Ferguson (E-F)	1.02	0.98	0.98	1.14	1.08	1.10	1.06	0.85	1.00	0.97	0.96
207	7,270	D-B	0.98	0.95	0.95	1.10	1.03	1.03	1.02	0.84	0.96	0.92	0.93
		S-T	0.92	0.89	0.89	1.03	0.96	0.96	0.96	0.79	0.90	0.86	0.87
		E-F	1.05	1.02	1.02	1.13	1.10	1.10	1.09	0.90	1.02	0.98	0.99
208	13,400	D-B	0.95	0.93	0.94	1.04	1.03	1.06	1.03	0.95	0.89	0.85	0.83
		S-T	0.91	0.88	0.90	0.99	0.98	1.01	0.98	0.91	0.85	0.81	0.79
		E-F	1.01	0.98	1.00	1.11	1.10	1.13	1.10	1.01	0.95	0.91	0.89
209	16,580	D-B	0.93	0.88	0.87	0.95	0.93	0.97	1.02	0.97	0.94	0.93	0.89
		S-T	0.86	0.81	0.80	0.88	0.85	0.90	0.94	0.89	0.87	0.85	0.82
		E-F	0.99	0.94	0.93	1.01	0.99	1.04	1.08	1.03	1.00	0.99	0.95

TABLE I (Continued)

No.	Re_D	Source	1	2	3	4	5	6	7	8	9	10	11
210	17,000	D-B	0.92	0.87	0.87	0.94	0.91	0.96	1.02	0.94	0.93	0.92	0.91
		S-T	0.88	0.83	0.82	0.89	0.86	0.91	0.97	0.90	0.89	0.87	0.86
		E-F	0.98	0.93	0.92	0.99	0.96	1.02	1.09	1.00	0.99	0.98	0.97
211	19,850	D-B	1.01	0.95	0.95	1.06	1.06	1.11	1.14	1.07	1.00	0.96	0.94
		S-T	0.94	0.87	0.87	0.98	0.97	1.02	1.05	0.98	0.92	0.88	0.86
		E-F	1.08	1.01	1.01	1.13	1.12	1.18	1.21	1.13	1.06	1.03	0.99
212	19,350	D-B	0.92	0.89	0.89	0.99	0.99	1.06	1.11	1.06	1.03	1.01	0.95
		S-T	0.88	0.85	0.85	0.94	0.94	1.00	1.05	1.01	0.98	0.96	0.91
		E-F	0.98	0.95	0.94	1.05	1.05	1.12	1.17	1.13	1.09	1.07	1.01
213	22,370	D-B	0.96	0.93	0.92	1.03	1.03	1.08	1.13	1.05	0.99	0.96	0.91
		S-T	0.89	0.86	0.85	0.95	0.95	1.00	1.04	0.97	0.91	0.88	0.83
		E-F	1.02	0.99	0.98	1.10	1.09	1.15	1.20	1.12	1.05	1.02	0.96
214	23,950	D-B	0.95	0.93	0.93	1.05	1.03	1.08	1.11	1.03	0.97	0.95	0.92
		S-T	0.89	0.87	0.86	0.98	0.96	1.01	1.03	0.95	0.91	0.89	0.85

TABLE I (Continued)

No.	Re _D	Source	1	2	3	4	5	6	7	8	9	10	11
		E-F	1.01	0.99	0.98	1.11	1.10	1.15	1.17	1.09	1.04	1.01	0.97
215	27,320	D-B	0.93	0.91	0.91	1.05	1.04	1.10	1.15	1.06	0.99	0.96	0.92
		S-T	0.86	0.84	0.85	0.98	0.96	1.02	1.07	0.99	0.92	0.89	0.85
		E-F	0.98	0.96	0.97	1.12	1.10	1.17	1.22	1.13	1.05	1.02	0.98




Figure 14. \overline{Nu} Number as a Function of Re and Position in Test Section

14 also shows the \overline{Nu} is fairly constant in the straight section upstream of the bend but its value is enhanced in the bend for both the turbulent and transition regions. For the turbulent flow, the value of \overline{Nu} starts to decrease and approaches a constant value in the straight section downstream of the bend. For the same portion of the test section the behavior of \overline{Nu} number is different for the transition region, as the \overline{Nu} number decreases to a minimum and then goes back to a constant value.

Error Analysis

The heat balances for all ten runs were made and the results indicate a maximum of ± 5 percent error. The results of the heat balance calculation are presented in Appendix E.

The accuracy of the electrical measuring devices is reported to be within 2 percent of full scale reading. Also, the accuracy of rotameter is expected to be within 2 percent. The accuracy of inside wall temperature is expected to be within 1 percent and that of room temperature ± 0.5 percent. The accuracy of longitudinal test section dimensions is also expected to be within ± 0.1 percent.

If all of the above mentioned measurements were in error to the extent indicated and in the same direction, the maximum error in the heat flux would be about 4 percent. Based on the error analysis which was made by Singh (8) the above mentioned inaccuracy of measurements gives a maximum error of about 12 percent in the heat transfer coefficient calculation. However, the average error is about 6 percent.

CHAPTER VII

CONCLUSIONS AND RECOMMENDATION

Analysis of the experimental data obtained in this investigation of the 180° bend indicates that;

1. The local heat transfer coefficient in the straight section upstream of the bend is independent of peripheral position.
2. The peripheral heat transfer is far from uniform in the bend, being much higher at the outside and lower at the inside of the bend, resulting in a higher mean heat transfer coefficient as compared to a straight tube under similar conditions.
3. At any cross section in the bend, the distribution of peripheral heat transfer coefficient is almost symmetrical about a plane containing the longitudinal axis of tube and the radius of the bend.
4. At the entrance region of the downstream section of the bend, the distribution of peripheral heat transfer coefficient is symmetrical about the plane of the bend. Also, the peripheral heat transfer coefficient is highest at the outside wall of the bend and lowest at the inside wall. The nonuniform heat transfer coefficient results in a higher mean heat transfer coefficient as compared to a straight section under similar conditions without the bend. The nonuniform behavior of the local heat transfer coefficient disappears as fluid flows further down the tube.

No attempt was made to find a correlation(s) to predict the heat transfer coefficient in the bend and in the entrance region of the straight section downstream from the bend due to the lack of enough data. Therefore, using different bend to tube diameter ratios, different fluids and covering a wider range of Reynolds number, one could find a correlation(s) to predict the heat transfer coefficient for the bend and the entrance region of the straight section downstream of the bend.

BIBLIOGRAPHY

- (1) Lis, J. and M. J. Thelwell, "Experimental Investigation of Turbulent Heat Transfer in a Pipe Preceded by a 180° Bend," Proc. Inst. of Mech. Engrs., V. 178, Pt. 3I, 1963-64, p. 17.
- (2) Ede, A. J., "The Effect of a 180° Bend Heat Transfer to Water in a Tube," 3rd Intl. Heat Transfer Conf., Chicago, Ill., V. 1, 1966, p. 99.
- (3) Tailby, S. R. and P. W. Staddon, "The Influence of 90° and 180° Pipe Bend on Heat Transfer from an Internally Flowing Gas Stream," 4th Intl. Heat Transfer Conf., Paris-Vesailles, V. 2, FC4.5(1970).
- (4) Yang, J. W. and N. Liao, "Turbulent Heat Transfer in Rectangular Ducts with 180°-Bend," Heat Transfer, V. 2 -169, 1974.
- (5) Farukhi, M. N., "An Experimental Investigation of Forced Convective Boiling at High Qualities Inside Tubes Preceded by 180 Degree Bends," Ph.D. Thesis, Oklahoma State University, Stillwater, Oklahoma (1974).
- (6) Owhadi, A., K. J. Bell, and B. Crain, Jr., "Forced Convection Boiling Inside Helically Coiled Tubes," Intl. J. of Heat and Mass Transfer, V. 11, 1968, p. 1779.
- (7) Crain, Berry, Jr., "Forced Convection Heat Transfer to a Two-Phase Mixture of Water and Steam in a Helical Coil," Ph.D. Thesis, Oklahoma State University, Stillwater, Oklahoma (1973).
- (8) Singh, S. P., "Liquid Phase Heat Transfer in Helically Coiled Tubes," Ph.D. Thesis, Oklahoma State University, Stillwater, Oklahoma (1973).
- (9) Dittus, F. W. and L. M. K. Boelter, Univ. of Calif. (Berkeley) Eng. Pub., Vo. 2, 1930, p. 443.
- (10) Sieder, E. N. and C. E. Tate, "Heat Transfer and Pressure Drop of Liquids in Tubes," Ind. Eng. Chem., V. 28, 1936, p. 1429.
- (11) Eagle, A. and R. M. Ferguson, Pro. Roy. Soc., A 127, 540-566(1930).

APPENDIX A

CALIBRATION DATA

TABLE II
CALIBRATION DATA FOR ROTAMETER

Rotameter Setting	Mass Flow
% Maximum Flow	Rate, lbm/hr
10	355.0
20	651.0
30	937.0
40	1219.0
50	1530.0
60	1835.0
70	2118.0
80	2433.0
90	2744.0
100	3013.0

TABLE III
 CALIBRATION DATA FOR INLET AND OUTLET THERMOCOUPLES
 DURING IN-SITU CALIBRATION OF SURFACE THERMO-
 COUPLES ON THE TEST SECTION

Thermocouple Location	Saturated Steam Temperature, °F	Thermocouple Correction, °F	Average Room Temperature
Inlet	210.3	-0.7	76.5
Outlet	211.1	-0.9	

Therefore the correction correlation for inlet and outlet bulk fluid temperature are

$$(T_{in})_{corrected} = T_{in} - (0.7) \frac{(T_{in} - T_{room})}{(210.3 - 76.5)}$$

and

$$(T_{out})_{corrected} = T_{out} - (0.9) \frac{(T_{out} - T_{room})}{(211.1 - 76.5)}$$

TABLE IV
CALIBRATION DATA FOR HEAT LOSS FROM TEST SECTION

Average temperature of steam in test section	= 210.3°F
Room Temperature during calibration	= 76.0°F
Amount of mass of steam condensed	= 0.50 lbm/hr
Heat of vaporization of water at 210.3°F (λ)	= 971.36 Btu/lbm

$$\left. \begin{array}{l} \text{Heat loss from} \\ \text{heat transfer loop} \end{array} \right\} = Q = m\lambda$$

$$= (0.5)(971.36)$$

$$= 485 \text{ Btu/hr}$$

So heat loss during experimental run, Q_{loss} -Btu/hr

$$Q_{\text{loss}} = \frac{485 (T_{\text{avg}} - T_{\text{room}})}{(210.3 - 76.0)}$$

or, heat lost from the test section, q_{loss} -Btu/hr

$$q_{\text{loss}} = \left(\frac{\ell}{L_{\text{total}}} \right) Q_{\text{loss}}$$

where

ℓ = Length of test section.

and

L = Total length of heat transfer loop.

$$T_{\text{avg}} = (1/2)(T_{\text{in}} + T_{\text{out}}), \text{ } ^\circ\text{F}$$

TABLE V
 CALIBRATION DATA FOR CALIBRATION OF OUTSIDE
 SURFACE THERMOCOUPLES

Station Number	$\Delta = (\text{Steam Temperature}) - (\text{Thermocouple Temperature})$ Peripheral Position							
	1	2	3	4	5	6	7	8
1	-0.2	-0.3	-0.6	+0.1	+0.3	+0.5	-0.3	-0.4
2	+0.1	-0.6	-0.5	+0.1	-0.2	-0.2	-0.6	+1.3
3	-0.1	-0.6	-0.1	-0.6	0.0	-0.1	-0.2	-0.5
4	+0.5	-0.7	-0.6	-0.6	-0.2	-0.3	-0.2	-0.5
5	-0.5	-0.7	-0.6	-0.3	-0.6	-0.4	-0.4	-0.3
6	-0.6	-0.7	-0.1	-0.4	-0.6	-0.6	-0.7	-0.6
7	-0.7	-0.8	-0.6	-0.8	-0.8	-0.7	-0.7	-0.5
8	-0.5	-0.7	-1.0	-0.8	-0.5	-0.8	-0.5	-0.7
9	-0.9	-0.5	-0.9	-0.8	-0.3	-0.6	-0.5	-0.8
10	-0.7	-1.0	-0.6	-0.9	-0.4	-0.9	-1.0	-0.8
11.	-0.6	-0.8	-0.5	-0.8	-0.6	-0.9	-1.0	-0.7

- Note: 1. For correction of the surface thermocouples the effect of pressure drop along the pipe is not included even though the pressure taps indicated an average pressure drop of 0.5 in. Hg along the pipe.
2. Since the difference between the thermocouple reading and the true temperature of surface was small, no correction for surface temperatures was made through the further calculations.

APPENDIX B

EXPERIMENTAL DATA

RUN NUMBER 206

WATER FLOW RATE = 700.00 LBM/HOUP
CURRENT TO TUBE = 215.00 AMPS
VOLTAGE DROP IN TUBE = 8.40 VOLTS
ROOM TEMPERATURE = 79.90 DEGREES F
UNCORRECTED INLET TEMPERATURE = 83.00 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 91.90 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	94.2	97.6	98.6	104.1	109.2	112.4	96.3	99.8	98.2	99.7	101.9
2	93.6	97.4	98.4	99.1	102.2	103.2	97.0	101.3	99.2	100.3	102.9
3	93.2	96.5	97.0	95.9	97.0	97.5	98.9	102.0	100.7	101.4	103.3
4	93.4	95.9	96.0	94.4	94.9	95.4	104.0	102.9	101.9	101.9	103.3
5	93.8	96.0	95.6	93.9	94.2	94.5	112.0	103.1	102.4	102.2	102.7
6	94.2	96.3	96.6	94.3	94.6	94.8	103.3	101.4	100.9	101.2	102.1
7	94.5	97.0	97.5	95.7	96.7	97.2	97.1	100.5	99.2	99.9	101.4
8	94.6	97.6	98.0	99.3	102.9	104.1	95.7	99.3	98.3	99.5	101.4

RUN NUMBER 207

WATER FLOW RATE = 700.00 LBM/HOUR
CURRENT TO TUBE = 224.00 AMPS
VOLTAGE DROP IN TUBE = 8.70 VOLTS
ROOM TEMPERATURE = 80.20 DEGREES F
UNCORRECTED INLET TEMPERATURE = 82.30 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 91.80 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	94.3	97.8	98.8	104.4	109.8	113.4	96.1	99.0	98.2	99.6	101.9
2	93.7	97.5	98.6	99.5	102.6	104.2	96.9	100.6	99.8	100.8	103.2
3	93.1	96.6	97.2	95.9	97.3	97.8	99.2	102.1	101.3	102.1	103.8
4	93.4	96.1	96.0	94.4	95.0	95.5	104.8	103.8	102.5	102.7	103.8
5	93.7	95.9	95.7	93.7	94.1	94.8	113.3	103.8	103.0	103.0	103.3
6	94.1	96.2	96.6	94.3	94.8	95.1	104.1	102.2	101.3	101.8	102.6
7	94.4	97.0	97.4	95.9	97.2	97.6	97.3	100.9	99.8	100.4	101.9
8	94.5	97.5	98.4	99.8	103.4	104.9	96.0	99.9	98.8	100.0	101.9

RUN NUMBER 208

WATER FLOW RATE = 1534.80 LBM/HOUR
CURRENT TO TUBE = 245.00 AMPS
VOLTAGE DROP IN TUBE = 9.50 VOLTS
ROOM TEMPERATURE = 79.40 DEGREES F
UNCORRECTED INLET TEMPERATURE = 70.20 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 75.60 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	78.6	80.6	81.1	84.0	86.6	88.3	79.4	80.2	81.1	82.1	83.7
2	78.2	80.6	81.1	81.9	83.3	83.9	80.0	81.0	82.1	82.9	84.7
3	78.2	80.3	80.6	80.0	80.4	80.7	81.5	82.8	83.4	84.0	85.3
4	78.7	80.1	80.0	79.1	79.0	79.1	84.2	84.7	84.8	85.2	85.8
5	79.0	80.1	79.8	78.5	78.4	78.5	88.2	85.6	85.5	85.6	85.6
6	79.3	80.4	80.3	78.8	78.7	78.9	83.8	83.4	83.9	84.2	84.7
7	79.2	80.7	80.9	79.9	80.3	80.2	80.6	81.8	82.5	82.8	83.9
8	79.1	80.9	81.1	81.9	83.6	84.0	79.6	80.6	81.5	82.2	83.7

RUN NUMBER 209

WATER FLOW RATE = 1534.80 LBM/HOUR
CURRENT TO TUBE = 412.00 AMPS
VOLTAGE DROP IN TUBE = 16.20 VOLTS
ROOM TEMPERATURE = 82.10 DEGREES F
UNCORRECTED INLET TEMPERATURE = 82.60 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 98.20 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	105.6	111.4	113.3	120.5	126.2	129.4	107.8	109.3	111.0	112.5	117.0
2	104.4	111.2	113.3	114.9	118.5	119.6	109.6	111.6	113.1	114.6	119.1
3	103.9	110.2	111.6	110.2	111.9	111.6	113.2	115.6	116.6	117.5	120.9
4	105.0	109.7	110.4	107.8	108.0	107.9	119.6	120.5	120.1	120.9	122.4
5	106.1	110.3	109.5	106.6	106.6	106.3	127.9	123.0	122.4	122.3	122.6
6	106.8	110.3	110.6	107.3	107.1	107.3	117.6	117.1	117.9	118.4	119.8
7	106.9	111.5	112.2	109.8	111.3	111.2	110.3	112.6	113.8	114.1	117.7
8	106.6	111.5	113.0	114.9	118.8	119.9	107.7	109.7	111.3	112.9	117.1

RUN NUMBER 210

WATER FLOW RATE = 1832.10 LBM/HOUR
CURRENT TO TUBE = 235.00 AMPS
VOLTAGE DROP IN TUBE = 9.10 VOLTS
ROOM TEMPERATURE = 79.90 DEGREES F
UNCORRECTED INLET TEMPERATURE = 75.90 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 80.10 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	82.6	84.4	84.9	87.2	88.9	89.8	83.3	83.9	84.2	84.8	85.0
2	82.4	84.4	85.0	85.5	86.6	86.9	83.8	84.6	85.0	85.3	85.6
3	82.3	84.2	84.6	84.2	84.7	84.5	85.0	85.8	86.0	86.2	87.2
4	82.6	84.1	84.2	83.5	83.6	83.5	86.8	87.3	87.3	87.3	87.8
5	83.2	84.1	84.0	83.1	83.1	82.9	89.5	88.0	87.9	87.8	87.7
6	83.4	84.3	84.3	83.4	83.3	83.3	86.3	86.3	86.5	86.5	86.9
7	83.3	84.6	84.7	84.0	84.5	84.5	84.0	84.9	85.2	85.3	85.0
8	83.1	84.5	84.9	85.4	86.6	87.0	83.3	84.1	84.5	84.9	85.9

RUN NUMBER 211

WATER FLOW RATE = 1832.10 LBM/HOUR
CURRENT TO TUBE = 482.00 AMPS
VOLTAGE DROP IN TUBE = 18.80 VOLTS
ROOM TEMPERATURE = 83.00 DEGREES F
UNCORRECTED INLET TEMPERATURE = 81.80 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 99.50 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	107.8	113.8	115.8	123.7	129.4	132.8	109.7	111.6	113.9	116.2	121.7
2	106.5	113.9	115.7	117.7	121.4	122.8	111.9	114.3	116.8	118.8	124.1
3	102.6	113.3	114.3	112.5	113.9	114.2	116.1	119.0	120.7	122.2	128.6
4	108.1	113.0	113.0	109.7	109.6	109.7	122.6	124.5	125.3	126.3	130.0
5	109.6	112.8	112.1	108.1	107.9	107.8	131.8	127.6	128.0	128.3	125.4
6	110.5	113.5	113.7	109.1	108.8	108.8	120.6	120.4	122.4	123.0	122.0
7	110.1	114.5	115.2	111.9	113.1	113.1	112.6	115.5	117.4	118.1	122.0
8	109.5	114.7	116.0	117.9	121.6	122.7	109.9	112.3	114.5	116.4	121.2

RUN NUMBER 212

WATER FLOW RATE = 2129.40 LBM/HOUR
CURRENT TO TUBE = 265.00 AMPS
VOLTAGE DROP IN TUBE = 10.40 VOLTS
ROOM TEMPERATURE = 79.90 DEGREES F
UNCORRECTED INLET TEMPERATURE = 73.70 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 78.40 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	81.7	83.5	84.1	86.4	88.2	89.1	81.8	82.3	82.7	83.3	84.8
2	81.3	83.4	83.9	84.4	85.4	85.8	82.5	83.0	83.6	84.0	85.6
3	81.0	83.0	83.4	82.9	83.2	83.2	83.7	84.3	84.6	85.0	86.3
4	81.5	83.0	83.0	82.1	82.0	81.9	85.6	86.1	86.0	86.3	87.0
5	82.0	83.0	82.8	81.7	81.5	81.3	88.6	86.9	86.9	87.0	87.0
6	82.3	83.1	83.2	81.9	81.7	81.6	85.0	84.9	85.3	85.3	86.0
7	82.2	83.4	83.6	82.7	83.0	82.9	82.6	83.4	83.8	83.8	85.0
8	82.0	83.6	84.1	84.3	85.5	85.8	81.8	82.3	82.9	83.3	84.8

RUN NUMBER 213

WATER FLOW RATE = 2129.40 LBM/HOUR
CURRENT TO TUBE = 496.00 AMPS
VOLTAGE DROP IN TUBE = 19.50 VOLTS
ROOM TEMPERATURE = 80.50 DEGREES F
UNCORRECTED INLET TEMPERATURE = 79.80 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 96.20 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	105.3	110.9	113.3	120.3	125.4	128.5	106.8	108.6	110.6	112.6	117.8
2	104.1	110.9	112.3	114.5	117.8	119.1	108.9	111.0	113.2	115.1	120.2
3	103.6	110.1	111.3	109.7	111.1	111.2	112.7	115.5	117.1	118.6	122.5
4	105.3	110.0	110.2	107.2	107.0	106.9	118.7	120.8	121.7	122.9	125.1
5	107.1	110.2	109.6	105.5	105.3	105.0	127.5	123.8	124.6	125.0	125.8
6	108.1	110.7	111.0	106.6	106.0	106.0	116.7	117.0	119.0	119.6	121.9
7	107.4	111.5	112.4	109.2	110.2	110.2	109.3	112.0	113.8	114.6	118.0
8	106.9	111.5	113.1	114.6	118.0	119.2	106.7	109.2	111.0	112.7	117.3

RUN NUMBER 214

WATER FLOW RATE = 2426.70 LBM/HOUR
CURRENT TO TUBE = 459.00 AMPS
VOLTAGE DROP IN TUBE = 18.00 VOLTS
ROOM TEMPERATURE = 79.50 DEGREES F
UNCORRECTED INLET TEMPERATURE = 76.70 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 88.70 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	97.9	102.1	103.9	109.2	113.7	115.7	97.9	99.7	101.3	102.8	106.6
2	96.6	102.0	103.3	103.8	106.3	107.6	99.5	101.6	103.2	104.3	108.1
3	95.6	100.6	101.4	100.0	101.2	101.3	102.7	105.0	106.0	106.9	109.6
4	96.8	100.4	100.5	98.0	97.9	97.9	107.5	109.0	109.6	110.4	111.7
5	98.5	100.3	99.8	96.8	96.6	96.3	114.4	111.3	112.0	112.1	112.4
6	99.0	100.7	100.8	97.5	97.1	97.2	105.9	105.9	107.4	107.7	109.1
7	98.6	101.3	101.9	99.4	100.5	100.6	100.2	102.2	103.3	103.6	106.1
8	98.6	101.9	103.2	103.7	106.6	107.7	98.2	100.0	101.4	102.4	105.8

RUN NUMBER 215

WATER FLOW RATE = 2724.00 LBM/HOUR
CURRENT TO TUBE \ = 520.00 AMPS
VOLTAGE DROP IN TUBE = 20.50 VOLTS
ROOM TEMPERATURE = 83.40 DEGREES F
UNCORRECTED INLET TEMPERATURE = 77.10 DEGREES F
UNCORRECTED OUTLET TEMPERATURE = 91.00 DEGREES F

OUTSIDE SURFACE TEMPERATURES - DEGREES F

	1	2	3	4	5	6	7	8	9	10	11
1	102.8	107.6	109.5	115.4	120.6	123.2	101.6	103.4	105.4	107.5	111.9
2	101.2	107.3	108.7	108.6	111.8	113.3	103.6	105.6	107.8	109.4	113.7
3	99.8	105.5	106.4	104.5	105.9	106.0	107.2	109.6	111.1	112.4	115.5
4	101.4	105.6	105.2	102.3	102.0	101.6	112.7	114.6	115.8	116.9	118.6
5	103.7	105.7	104.8	100.9	100.6	100.1	120.8	117.6	119.0	119.4	119.9
6	104.5	106.0	105.7	101.6	101.1	100.7	110.8	111.0	113.2	113.8	115.4
7	103.7	106.5	107.0	104.0	104.9	104.8	103.9	106.5	108.0	108.3	111.0
8	103.8	107.2	108.8	107.8	111.9	113.0	101.6	103.8	105.6	106.9	110.8

APPENDIX C

REGRESSION CORRELATIONS FOR ESTIMATING

THE PHYSICAL PROPERTIES OF WATER

AND INCONEL 600

WATER

The following physical correlations which were developed by Singh (8) based on the CRC Handbook of Chemistry and Physics were used to compute the physical properties of water.

Density in gm/ml:

$$\rho = 0.999986 + (0.1890)(10^{-4})(T, ^\circ\text{C}) - (0.5886)(10^{-5})(T, ^\circ\text{C})^2 + (0.1548)(10^{-7})(T, ^\circ\text{C})^3$$

Range: $^\circ\text{C}$ to 100°C

Viscosity in centipoise:

$$\log_{10} \frac{\mu_T}{\mu_{20}} = \frac{1.3272(20-T) - 0.001053(T-20)^2}{T + 105}$$

where

T = water temperature, $^\circ\text{C}$

and

μ_{20} = viscosity of water at $20^\circ\text{C} = 1.002$ cp.

Range: 20°C to 100°C

Specific heat in Btu/lb- $^\circ\text{F}$:

$$C_p = 1.01881 - (0.4802)(10^{-3})(T, ^\circ\text{F}) + (0.3274)(10^{-5})(T, ^\circ\text{F})^2 - (0.604)(10^{-8})(T, ^\circ\text{F})^3$$

Range: 32°F to 212°F

Thermal conductivity in Btu/hr-ft- $^{\circ}$ F:

$$K = 0.30289 + (0.7029)(10^{-3})(T, ^{\circ}\text{F}) - (0.1178)(10^{-5})(T, ^{\circ}\text{F})^2 \\ - (0.550)(10^{-9})(T, ^{\circ}\text{F})^3$$

Range: 44 $^{\circ}$ F to 206 $^{\circ}$ F

INCONEL 600

The following physical correlations which were developed by Farukhi (5) were used to compute the physical properties of Inconel 600.

Electrical resistivity in Ohms-in²/in:

$$\rho = (40.40292 + 2.515385 \times 10^{-3} \times T)(10^{-6})$$

T = temperature, $^{\circ}$ F

Thermal conductivity in Btu/(hr-ft- $^{\circ}$ F):

$$K = 0.8313769 + (3.846154)(10^{-3})(T, ^{\circ}\text{F})$$

APPENDIX D

SAMPLE CALCULATIONS

Calculations for experimental data run 209 are presented as a sample calculation. The experimental data values for run 209 are presented on page 45 in Appendix B. The sample calculations given here are based on the following assumptions and conditions:

1. Electrical resistivity and thermal conductivity of tube walls are function of temperature.
2. Peripheral wall conduction exists.
3. Axial conduction is negligible.
4. Steady state conditions exist.
5. Heat losses to the atmosphere are present.

A computer program written originally by Farukhi (5) was modified to perform the calculations for all the data runs on IBM 360/65 computer.

Calculation of the Overall Heat Balance

Heat input rate, Btu/hr = Q_{input}

$$Q_{\text{input}} = \left\{ \begin{array}{l} \text{current} \\ \text{in tube} \end{array} \right\} \left\{ \begin{array}{l} \text{voltage drop} \\ \text{across tube} \end{array} \right\} \quad (3.41213)$$

$$= (412.0)(16.2)(3.41213)$$

$$= 22,773.9 \text{ Btu/hr.}$$

Heat output rate, Btu/hr = Q_{output}

$$Q_{\text{output}} = (W)(C_p) [(t_{b \text{ out}}) - (t_{b \text{ in}})]$$

The inlet and outlet bulk water temperatures measured by the thermocouples were corrected, based on their calibration. Calibration data for these thermocouples are given in Table III in Appendix A.

$$\left. \begin{array}{l} \text{corrected inlet} \\ \text{water temperature} \end{array} \right\} = 82.6 - \frac{0.7(82.6-82.10)}{210.3-76.5}$$

$$= 82.6^{\circ}\text{F}$$

$$\left. \begin{array}{l} \text{corrected outlet} \\ \text{water temperature} \end{array} \right\} = 98.2 - \frac{0.9(98.2-82.1)}{211.1-76.5}$$

$$= 98.09^{\circ}\text{F}$$

$$\left. \begin{array}{l} \text{average water temperature} \\ \text{in the tube } (T_{\text{avg}}) \end{array} \right\} = 0.5(98.09+82.6) = 90.34^{\circ}\text{F}$$

From Appendix C,

$$C_p = 1.01881 - (0.4802)(10^{-3})(T) + (0.3274)(10^{-5})(T^2) - (0.604)(10^{-8})(T^3)$$

$$\text{at } T = 90.35^{\circ}\text{F}$$

$$C_p = 1.01881 - (0.4802)(10^{-3})(90.34) + (0.3274)(10^{-5})(90.34^2) - (0.604)(10^{-8})(90.34^3)$$

$$= 0.998 \text{ Btu/lb-}^{\circ}\text{F}$$

$$Q_{\text{output}} = (1534.8)(0.998)(98.09-82.6)$$

$$= 23,726.0 \text{ Btu/hr}$$

$$\text{Heat loss rate, Btu/hr} = Q_{\text{loss}}$$

Calibration data for heat losses to the atmosphere are given in Table IV, Appendix A.

$$Q_{\text{loss}} = \frac{485(90.34-82.1)}{(210.3-76.0)} \times \frac{113.267}{166.767}$$

$$= 20.2 \text{ Btu/hr}$$

$$\left\{ \begin{array}{l} \text{Percent error in} \\ \text{heat balance} \end{array} \right\} = \frac{(Q_{\text{input}} - Q_{\text{loss}}) - Q_{\text{output}}}{0.5 [(Q_{\text{input}} - Q_{\text{loss}}) + Q_{\text{output}}]} \quad (100)$$

$$= \frac{22,773.9 - 20.2 - 23,726.0}{0.5(22,773.9 - 20.2 + 23,726.0)} \quad (100)$$

$$= -4.18\%$$

Calculation of the Local Inside Wall Temperature and the Inside Wall Radial Heat Flux

As indicated in Chapter V, a numerical solution developed and applied by Owhadi (6), Crain (7), Singh (8), and Farukhi (5) was used to compute the inside wall temperatures from the measured outside wall temperatures and the inside wall radial heat flux at each thermocouple location. The trial-and-error solution is complex and hence a sample calculation will not be given here; however, the derivation of equations are given in Appendix B of Farukhi's (5) thesis. Tables VI to IX give the outside surface temperatures, the computed inside wall temperatures and the inside wall radial heat fluxes for every thermocouple located on the test section.

TABLE VI

RUN @) (- OUTSIDE SURFACE TEMPERATURES, °F

Peripheral Position	Station Number										
	1	2	3	4	5	6	7	8	9	10	11
1	105.6	111.4	113.3	120.5	126.2	129.4	107.8	109.3	111.0	112.5	117.0
2	104.4	111.2	113.3	114.9	118.5	119.6	109.6	111.6	113.1	114.6	119.1
3	103.9	110.2	111.6	110.2	111.9	111.6	113.2	115.6	116.6	117.5	120.9
4	105.0	109.7	110.4	107.8	108.0	107.9	119.6	120.5	120.1	120.9	122.4
5	106.1	110.3	109.5	106.6	106.6	106.3	127.9	123.0	122.4	122.3	122.6
6	106.8	110.3	110.6	107.3	107.1	107.3	117.6	117.1	117.9	118.4	119.8
7	106.9	111.5	112.2	109.8	111.3	111.2	110.3	112.6	113.8	114.1	117.7
8	106.6	111.5	113.0	114.9	118.8	119.9	107.7	109.7	111.3	112.9	117.1

TABLE VII

RUN 209 - CALCULATED INSIDE SURFACE TEMPERATURE, °F

Peripheral Position	Station Number										
	1	2	3	4	5	6	7	8	9	10	11
1	103.1	108.9	110.8	117.8	123.5	126.8	105.2	106.7	108.4	109.9	114.4
2	101.9	108.7	110.8	112.2	115.8	116.9	107.4	109.1	110.6	112.1	116.6
3	101.3	107.7	110.1	107.6	109.4	109.0	110.6	113.1	114.1	114.9	118.4
4	102.5	107.2	107.9	105.4	105.6	105.5	117.1	118.0	117.6	118.4	119.9
5	103.6	107.8	106.9	104.3	104.4	104.0	125.6	120.6	119.9	119.9	120.1
6	104.3	107.8	108.1	104.9	104.7	104.9	115.0	114.6	115.4	115.9	117.3
7	104.4	109.0	109.7	107.2	108.7	108.6	107.7	110.1	111.3	111.5	115.1
8	104.1	109.0	110.5	112.2	116.1	117.2	105.1	107.1	108.7	110.4	114.6

TABLE VIII

RUN 209 - RADIAL HEAT FLUX FOR INSIDE SURFACE, BTU/HR-FT²

Peripheral Position	Station Number										
	1	2	3	4	5	6	7	8	9	10	11
1	10403.3	10412.1	10400.7	10915.2	10902.5	10441.7	10518.7	10574.8	10558.3	10564.7	10548.4
2	10454.4	10372.2	10321.4	11004.7	11118.7	11059.9	10523.9	10517.3	10501.1	10467.4	10405.9
3	10505.9	10445.8	10446.8	10516.5	10521.7	10631.3	10577.8	10470.6	10420.4	10449.5	10405.8
4	10415.1	10480.3	10435.2	9936.0	9893.6	9988.8	10528.9	10283.3	10351.5	10306.1	10348.0
5	10392.6	10383.7	10532.1	9483.4	9276.4	9525.3	9355.7	9939.9	10032.2	10118.2	10251.5
6	10380.2	10486.1	10447.0	9969.7	9960.4	10034.2	10591.7	10500.3	10443.2	10398.0	10463.0
7	10392.0	10349.4	10373.3	10533.3	10556.8	10660.1	10686.6	10511.1	10512.2	10597.5	10509.0
8	10375.6	10411.9	10389.5	10981.9	11049.8	11001.9	10575.0	10563.9	10546.9	10467.0	10452.1

Calculation of the local heat transfer coefficient for thermo-couple 1-1 (station 1, peripheral position 1):

$$\left. \begin{array}{l} \text{local heat transfer} \\ \text{coefficient (h)} \end{array} \right\} = \frac{(q/A)}{[(t_w)_1 - (t_b)_1]}$$

$$\begin{aligned} (t_b)_1 &= 82.6 + (98.09 - 82.6) \left(\frac{4.0}{113.276} \right) \\ &= 83.1^\circ\text{F} \\ &= \frac{10403.3}{103.1 - 83.1} = 520.2 \text{ Btu/hr-ft}^2\text{-}^\circ\text{F} \end{aligned}$$

Calculation of the Relevant Dimensionless Numbers

Reynolds Number: Re

$$\text{Re} = \frac{(d_i)(G)}{(\mu)}$$

From Appendix C,

$$\log_{10} \left(\frac{\mu_T}{\mu_{20}} \right) = \frac{1.3272(20-T) - 0.001053(T-20)^2}{T + 105}$$

where

T measured in $^\circ\text{C}$ and $\mu_{20} = 1.002 \text{ cp}$.

at $(t_b)_1 = 83.1^\circ\text{F} = 28.39^\circ\text{C}$

$$\log_{10} \left(\frac{\mu_T}{1.002} \right) = \frac{1.3272(20 - 28.39) - 0.001053(28.39 - 20)^2}{28.39 + 105}$$

$$\mu_T = (1.002)(0.8241) = 0.8257 \text{ cp}$$

or

$$\mu_T = (0.8257)(2.42) = 1.9983 \text{ lbm/ft-hr.}$$

Similarly for average inside surface temperature, $(T_w)_{avg}$:

$$\begin{aligned} (T_w)_{avg} &= \frac{1}{8} \sum_{i=1}^8 (T_{w_i}) \\ &= 1/8(103.1+101.9+101.3+102.5+103.6+104.3+104.4+104.1) \\ &= 103.15^\circ\text{F} \\ &= 39.52^\circ\text{C} \end{aligned}$$

$$\begin{aligned} \text{So at } (T_w)_{avg} = 39.52 \quad : \quad \mu_w &= 0.6589 \text{ cp} \\ &= 1.5946 \text{ lbm/ft-hr} \end{aligned}$$

$$G = \frac{W}{\frac{\pi}{4}(d_i)^2} = \frac{1534.8}{\frac{\pi}{4}\left(\frac{771}{12}\right)} = 473,386 \text{ lbm/ft}^2\text{-hr}$$

$$Re = \frac{(0.771/12)(473,386)}{1.9983} = 15,220$$

Prandtl Number: Pr

$$Pr = \frac{(C_p)(\mu)}{K}$$

From Appendix C,

$$\begin{aligned} C_p &= 1.01881 - (0.4802)(10^{-3})(T) + (0.3274)(10^{-5})(T^2) \\ &\quad - (0.604)(10^{-8})(T^3) \end{aligned}$$

At $(t_b)_1 = 83.1^\circ\text{F}$

$$C_p = 1.01881 - (0.4802)(10^{-3})(83.1) + (0.3274)(10^{-5})(83.12) - (0.604)(10^{-8})(83.1^3)$$

$$\begin{aligned}
 & -(0.604)(10^{-8})(83.1^3) \\
 & = 0.998 \text{ Btu/lbm-}^{\circ}\text{F}
 \end{aligned}$$

From Appendix C,

$$\begin{aligned}
 K &= 0.30289 + (0.7029)(10^{-3})(T) - (0.1178)(10^{-5})(T^2) \\
 & \quad - (0.550)(10^{-9})(T^3)
 \end{aligned}$$

$$\text{At } (t_{b1}) = 83.1^{\circ}\text{F}$$

$$\begin{aligned}
 K &= 0.30289 + (0.7029)(10^{-3})(83.1) - (0.1178)(10^{-5})(83.1^2) \\
 & \quad - (0.550)(10^{-9})(83.1^3) \\
 & = 0.353 \text{ Btu/hr-ft-}^{\circ}\text{F}
 \end{aligned}$$

$$\text{So, Pr} = \frac{(0.998)(1.9983)}{0.353} = 5.65$$

Nusselt Number: Nu

$$\begin{aligned}
 \text{Nu} &= \frac{(h)(d_1)}{K} \\
 &= \frac{(520.2)(0.771/12)}{0.353} \\
 &= 94.7
 \end{aligned}$$

Similarly, the other peripheral heat transfer coefficients at station 1 could be calculated in the same manner, and results are presented in Table IX.

TABLE IX
PERIPHERAL HEAT TRANSFER COEFFICIENTS AT STATION 1

	Peripheral Position							
	1	2	3	4	5	6	7	8
$h, \text{Btu}/(\text{hr-ft}^2-\text{°F})$	520.2	557.6	576.1	538.0	507.8	490.3	488.7	494.8

The average heat transfer coefficient at station 1 can be calculated using equation 4.

$$\bar{h} = \frac{1}{8} \sum_{i=1}^8 (h_i) \quad (4)$$

$$\begin{aligned} \bar{h} &= 1/8(520.2+557.6+576.1+538.0+507.8+490.3+488.7+494.8) \\ &= 521.7 \text{ Btu}/(\text{hr-ft}^2-\text{°F}) \end{aligned}$$

Comparison of Experimental Data with Literature

1. Sieder-Tate equation:

$$\begin{aligned} \bar{h} &= 0.027 \left(\frac{K}{d_i} \right) (\text{Re})^{0.8} (\text{Pr})^{0.333} \left(\frac{\mu}{\mu_w} \right)^{0.14} \\ &= 0.027 \left(\frac{0.353}{0.771/12} \right) (15,220)^{0.8} (5.65)^{0.333} \left(\frac{1.9983}{1.5946} \right)^{0.14} \\ &= 604.4 \text{ Btu}/(\text{hr-ft}^2-\text{°F}) \end{aligned}$$

$$\left. \begin{array}{l} \text{ratio of heat transfer} \\ \text{coefficients (experimental to} \\ \text{Sieder-Tate)} \end{array} \right\} = \frac{521.7}{604.4} = 0.86$$

2. Eagle-Ferguson Chart

From Appendix C, density of water, ρ :

$$\rho = 0.999986 + (0.1890)(10^{-4})(T, ^\circ\text{C}) - (0.5886)(10^{-5})(T, ^\circ\text{C})^2 \\ + (0.1548)(10^{-7})(T, ^\circ\text{C})^3$$

for $(t_b)_1 = 83.1^\circ\text{F} = 28.39^\circ\text{C}$

$$\rho = 0.999986 + (0.1890)(10^{-4})(28.39) - (0.5886)(10^{-5})(28.39)^2 \\ + (0.1548)(10^{-7})(28.39)^3 \\ = 0.996 \text{ gm/ml} \\ = 62.11 \text{ lbm/ft}^3$$

Water velocity at station 1:

$$V = \frac{W}{\rho A} \\ V = \frac{1534.8}{(62.11) \left(\frac{\pi}{4}\right) \left(\frac{0.771}{12}\right)^2 (3600)} \\ = 2.12 \text{ ft/sec}$$

From Eagle-Ferguson Chart at $V = 2.12 \text{ ft/sec}$ and $(t_b)_1 = 83.1^\circ\text{F}$:

$$\bar{h} = 527.0 \text{ Btu}/(\text{hr-ft}^2\text{-}^\circ\text{F})$$

$$\left\{ \begin{array}{l} \text{ratio of heat transfer} \\ \text{coefficients (experimental} \\ \text{to Eagle-Ferguson)} \end{array} \right\} = \frac{521.7}{527.0} = 0.99$$

APPENDIX E

CALCULATED RESULTS

 RUN NUMBER 206

AVERAGE REYNOLDS NUMBER = 7306.54
 AVERAGE PRANDTL NUMBER = 5.34
 MASS FLUX = 215904.25 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 2824.61 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 6162.30 BTU/HR
 Q=M*C*(T2-T1) = 6171.67 BTU/HR
 HEAT LOST = 18.79 BTU/HR
 HEAT BALANCE ERROR PERCENT = -0.46

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	275.9	254.9	239.5	155.6	114.8	89.6	401.8	288.7	358.4	312.1	296.0
2	295.5	256.8	241.6	268.0	222.0	220.3	374.1	239.6	314.9	293.6	262.1
3	311.0	286.0	284.8	349.7	337.7	344.3	313.0	230.8	265.8	257.7	253.7
4	301.8	306.9	317.6	397.1	399.0	406.8	203.7	211.2	235.8	248.5	252.6
5	288.3	300.4	338.0	403.8	412.3	443.4	82.3	202.7	220.9	236.6	270.4
6	276.5	292.4	293.5	402.9	420.0	455.2	212.1	245.6	261.4	264.3	286.3
7	268.0	270.0	266.7	362.0	356.6	362.8	397.4	262.8	316.9	308.7	313.5
8	263.8	252.7	257.4	260.4	204.5	199.2	457.1	283.8	351.8	320.5	312.1

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	285.1	277.5	279.9	324.9	308.3	315.2	305.2	245.6	290.9	280.3	280.8

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITRL	0.95	0.91	0.92	1.06	1.01	1.03	0.99	0.80	0.94	0.90	0.90
SIDTAT	0.90	0.86	0.86	1.00	0.94	0.96	0.93	0.74	0.88	0.85	0.84
HFFCHT	1.02	0.98	0.98	1.14	1.08	1.10	1.06	0.85	1.00	0.97	0.96

 RUN NUMBER 207

AVERAGE REYNOLDS NUMBER = 7272.66
 AVERAGE PRANDTL NUMBER = 5.36
 MASS FLUX = 215904.25 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 3067.73 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 6649.55 BTU/HR
 Q=M*C*(T2-T1) = 6589.09 BTU/HR
 HEAT LOST = 17.04 BTU/HR
 HEAT BALANCE ERROR PERCENT = 0.66

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	278.9	259.5	248.3	166.1	121.6	95.2	437.5	337.5	387.0	343.9	324.1
2	297.3	266.3	249.4	269.5	228.9	215.7	399.5	275.0	310.3	295.6	275.0
3	321.2	294.8	290.0	365.2	339.8	351.2	320.1	243.9	268.4	258.8	261.4
4	306.3	308.9	331.3	406.3	405.9	419.3	205.3	207.3	241.0	248.2	261.9
5	298.0	316.4	344.2	429.3	434.4	433.8	84.6	207.7	225.0	236.6	275.2
6	285.8	307.0	305.6	413.7	419.9	449.5	212.9	242.4	271.1	268.2	294.8
7	277.5	280.2	284.7	366.6	348.7	363.6	409.8	270.0	314.0	312.8	320.4
8	274.4	268.5	256.6	260.2	210.5	200.7	449.9	294.6	348.6	319.4	316.0

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	292.4	287.7	298.8	334.6	313.7	316.1	315.0	259.8	295.7	285.4	291.1

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DIT5L	0.99	0.95	0.95	1.10	1.03	1.03	1.02	0.84	0.96	0.92	0.93
SIDTAT	0.92	0.89	0.89	1.03	0.96	0.96	0.96	0.79	0.90	0.86	0.87
HEFCHT	1.05	1.02	1.02	1.17	1.10	1.10	1.09	0.90	1.02	0.98	0.99

 RUN NUMBER 208

AVERAGE REYNOLDS NUMBER = 13395.61
 AVERAGE PRANDTL NUMBER = 6.52
 MASS FLUX = 473385.44 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 3683.93 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 7941.73 BTU/HR
 Q=M*C*(T2-T1) = 8243.61 BTU/HR
 HEAT LOST = -16.19 BTU/HR
 HEAT BALANCE ERROR PERCENT = -3.53

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	506.8	479.3	462.9	368.3	299.5	254.3	766.4	695.2	624.3	551.7	509.2
2	539.1	474.4	458.9	464.9	418.7	408.3	683.1	603.4	525.5	488.5	437.7
3	540.0	497.0	493.0	573.2	572.3	578.2	538.6	460.4	442.0	425.1	410.5
4	497.4	511.6	540.9	619.0	667.8	714.0	388.7	365.4	373.6	367.9	384.9
5	479.6	512.5	560.0	659.3	701.5	764.0	232.9	323.3	339.2	347.6	393.2
6	458.5	489.5	515.5	659.7	715.0	742.7	404.9	432.0	417.7	414.8	441.4
7	467.4	469.9	471.6	581.4	583.1	636.2	629.3	528.9	498.1	499.1	492.4
8	470.2	455.1	461.2	464.1	401.2	399.6	736.0	642.7	577.5	540.1	502.4

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	494.9	486.1	495.5	548.7	544.9	562.2	547.5	506.4	474.8	454.4	446.5

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.95	0.93	0.94	1.04	1.03	1.06	1.03	0.95	0.89	0.85	0.83
S'DTAT	0.91	0.88	0.90	0.99	0.98	1.01	0.98	0.91	0.85	0.81	0.79
HEFCHT	1.01	0.98	1.00	1.11	1.10	1.13	1.10	1.01	0.95	0.91	0.89

 RUN NUMBER 209

AVERAGE REYNOLDS NUMBER = 16576.16
 AVERAGE PRANDTL NUMBER = 5.14
 MASS FLUX = 473385.44 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 10404.93 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 22773.91 BTU/HR
 Q=M*C*(T2-T1) = 23726.84 BTU/HR
 HEAT LOST = 20.65 BTU/HR
 HEAT BALANCE ERROR PERCENT = -4.19

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	521.1	489.2	463.8	383.6	329.2	294.2	814.3	775.4	724.4	690.2	625.2
2	557.6	491.7	459.9	481.4	437.5	432.6	715.1	659.3	629.2	600.5	547.5
3	576.1	520.3	504.4	574.7	553.6	601.0	577.7	524.3	515.5	513.8	500.1
4	538.0	535.6	534.8	618.7	646.7	705.4	425.8	412.7	436.2	433.5	463.5
5	507.8	514.3	566.6	632.7	658.6	750.5	280.9	361.5	384.2	401.2	454.7
6	490.3	519.9	530.1	641.1	692.5	740.5	466.4	489.2	485.5	489.3	531.3
7	488.7	483.6	486.4	588.6	573.8	616.9	694.8	619.9	604.5	627.0	597.7
8	494.8	486.9	469.6	480.3	429.4	425.1	825.9	752.4	708.9	665.4	615.1

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	521.8	505.2	502.0	550.1	540.2	570.8	600.1	574.3	561.1	552.6	541.9

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.93	0.88	0.87	0.95	0.93	0.97	1.02	0.97	0.94	0.93	0.89
SIDTAT	0.86	0.81	0.80	0.88	0.85	0.90	0.74	0.89	0.87	0.85	0.82
HEFCHT	0.99	0.94	0.93	1.01	0.99	1.04	1.08	1.03	1.00	0.99	0.95

 RUN NUMBER 210

AVERAGE REYNOLDS NUMBER = 17064.03
 AVERAGE PRANDTL NUMBER = 6.06
 MASS FLUX = 565083.06 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 3385.06 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 7296.84 BTU/HR
 Q=M*C*(T2-T1) = 7641.82 BTU/HR
 HEAT LOST = -4.73 BTU/HR
 HEAT BALANCE ERROR PERCENT = -4.55

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	596.2	538.2	514.4	415.5	357.4	322.1	871.4	798.1	784.4	713.2	656.1
2	615.6	535.2	500.9	521.3	470.5	463.9	775.7	681.3	652.3	643.4	582.8
3	630.5	555.8	537.7	606.3	583.2	642.2	608.7	547.6	548.2	547.9	528.3
4	596.2	565.0	576.5	648.0	664.5	727.6	463.6	432.3	445.1	458.5	476.9
5	532.5	566.2	600.0	668.7	689.5	800.6	299.5	384.9	402.4	419.7	483.9
6	517.1	546.8	565.7	661.3	714.2	768.0	497.1	506.8	505.5	521.6	553.1
7	527.2	516.8	527.5	631.0	605.0	641.1	754.9	644.1	632.9	648.2	659.9
8	542.1	528.7	511.5	529.0	468.7	456.4	874.7	758.1	724.3	694.5	665.2

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	569.6	544.1	541.8	585.1	569.1	602.7	643.2	594.2	586.9	580.9	575.3

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.92	0.87	0.87	0.94	0.91	0.96	1.02	0.94	0.93	0.92	0.91
SIDTAT	0.88	0.83	0.82	0.89	0.86	0.91	0.97	0.90	0.89	0.87	0.86
HEFCHT	0.98	0.93	0.92	0.99	0.96	1.02	1.09	1.00	0.99	0.98	0.97

 RUN NUMBER 211

AVERAGE REYNOLDS NUMBER = 19844.54
 AVERAGE PRANDTL NUMBER = 5.12
 MASS FLUX = 565083.06 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 14248.03 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 30919.33 BTU/HR
 Q=M*C*(T2-T1) = 32139.99 BTU/HR
 HEAT LOST = 19.03 BTU/HR
 HEAT BALANCE ERROR PERCENT = -3.93

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	650.7	626.3	594.4	496.5	434.7	391.2	1078.6	1006.1	915.5	836.7	740.3
2	682.2	618.8	593.0	612.4	560.1	550.2	923.9	841.1	764.3	720.2	659.3
3	890.0	638.3	634.1	734.1	725.3	761.6	728.2	655.8	631.6	614.5	533.8
4	629.0	646.4	674.0	800.3	854.9	929.6	548.7	516.1	518.7	515.8	500.2
5	598.5	654.7	710.8	835.7	886.1	1002.2	365.8	447.1	458.3	469.4	619.7
6	574.8	632.6	650.9	832.1	904.2	993.9	595.4	620.4	587.1	593.2	734.1
7	587.2	602.7	607.4	760.2	759.3	813.1	897.9	784.7	744.4	754.9	720.0
8	599.7	596.8	586.5	604.8	553.1	550.1	1063.0	955.2	876.9	822.1	757.9

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT,HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	651.5	627.1	631.4	709.5	709.7	749.0	775.2	728.3	687.1	665.9	658.1

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	1.01	0.95	0.95	1.06	1.06	1.11	1.14	1.07	1.00	0.96	0.94
SIDTAT	0.94	0.87	0.87	0.98	0.97	1.02	1.05	0.98	0.92	0.88	0.85
HEFCHT	1.08	1.01	1.01	1.13	1.12	1.18	1.21	1.13	1.06	1.03	0.99

 RUN NUMBER 212

AVERAGE REYNOLDS NUMBER = 19352.41
 AVERAGE PRANDTL NUMBER = 6.23
 MASS FLUX = 656780.69 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 4305.91 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 9403.82 BTU/HR
 Q=M*C*(T2-T1) = 9946.20 BTU/HR
 HEAT LOST = -9.59 BTU/HR
 HEAT BALANCE ERROR PERCENT = -5.50

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	636.1	597.5	566.9	479.0	415.4	378.7	1069.0	1002.8	971.4	892.4	794.0
2	678.2	603.2	581.3	607.1	562.7	550.2	909.2	861.8	797.0	775.3	683.6
3	719.2	646.0	627.3	713.8	715.6	757.7	728.3	684.0	675.7	657.5	616.0
4	656.4	642.2	667.1	768.7	822.0	909.1	555.7	521.0	547.1	541.7	554.1
5	608.2	643.0	692.5	783.5	846.0	985.2	359.0	462.0	476.4	484.4	551.7
6	581.7	634.5	645.2	801.5	880.8	978.4	602.5	624.7	606.5	627.8	643.6
7	592.3	605.0	609.6	739.3	742.2	802.9	905.7	796.1	774.5	812.9	766.1
8	609.0	586.7	564.4	615.4	552.8	547.9	1070.8	1009.3	924.2	889.5	786.7

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	635.1	619.8	619.3	688.5	692.2	738.8	775.0	745.2	721.6	710.2	674.5

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.92	0.89	0.89	0.99	0.99	1.06	1.11	1.06	1.03	1.01	0.95
SIDTAT	0.88	0.85	0.85	0.94	0.94	1.00	1.05	1.01	0.98	0.96	0.91
HEFCHT	0.98	0.95	0.94	1.05	1.05	1.12	1.17	1.13	1.09	1.07	1.01

 RUN NUMBER 213

AVERAGE REYNOLDS NUMBER = 22369.27
 AVERAGE PRANDTL NUMBER = 5.30
 MASS FLUX = 656780.69 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 15085.61 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 33002.11 BTU/HR
 Q=M*C*(T2-T1) = 34614.22 BTU/HR
 HEAT LOST = 18.66 BTU/HR
 HEAT BALANCE ERROR PERCENT = -4.82

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	710.3	682.4	633.0	546.9	485.5	439.6	1164.7	1087.3	1002.2	927.7	819.7
2	753.8	678.2	645.8	672.2	620.8	608.9	1001.7	924.6	849.4	799.3	719.3
3	778.3	708.3	694.6	794.4	779.3	824.4	802.4	721.6	695.1	674.0	649.3
4	709.4	710.3	731.9	851.9	911.9	1000.6	610.9	568.3	567.8	558.3	578.4
5	651.4	703.7	758.9	897.8	945.0	1081.3	410.0	493.8	496.8	506.0	556.6
6	621.9	687.7	703.0	886.4	979.4	1071.5	666.0	676.4	638.4	644.1	665.6
7	645.8	660.3	657.9	817.6	820.9	876.3	989.6	871.9	825.8	828.7	815.6
8	656.3	660.9	638.9	667.4	612.8	603.7	1177.5	1038.9	973.8	918.7	839.8

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	690.9	686.5	683.0	766.8	769.5	813.3	852.9	797.9	756.2	732.1	705.5

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.96	0.93	0.92	1.03	1.03	1.08	1.13	1.05	0.99	0.95	0.91
SIDIAT	0.89	0.86	0.85	0.95	0.95	1.00	1.04	0.97	0.91	0.88	0.83
HEFCHT	1.02	0.99	0.98	1.10	1.09	1.15	1.20	1.12	1.05	1.02	0.96

 RUN NUMBER 214

AVERAGE REYNOLDS NUMBER = 23942.32
 AVERAGE PRANDTL NUMBER = 5.68
 MASS FLUX = 748478.31 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 12914.80 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 28191.01 BTU/HR
 Q=M*C*(T2-T1) = 28879.81 BTU/HR
 HEAT LOST = 7.95 BTU/HR
 HEAT BALANCE ERROR PERCENT = -2.44

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	730.2	701.4	654.8	574.3	500.3	463.6	1239.4	1113.4	1023.9	951.0	853.1
2	792.1	701.6	675.5	738.3	685.7	658.2	1073.7	954.2	885.6	856.8	773.5
3	852.3	769.7	759.5	870.1	843.6	888.7	849.1	759.9	742.9	730.3	711.8
4	783.3	774.5	798.5	936.5	992.7	1075.7	648.0	608.3	609.6	601.8	631.7
5	704.1	780.8	841.2	972.1	1022.3	1172.9	441.8	532.0	531.5	545.3	602.7
6	686.3	761.3	783.6	975.9	1067.1	1150.3	706.6	725.9	686.6	696.7	730.9
7	705.9	734.5	734.9	909.5	888.2	937.2	1026.3	913.9	885.6	906.8	891.3
8	702.0	708.8	681.4	740.8	671.4	652.2	1203.6	1083.7	1014.8	982.4	902.4

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	744.5	741.6	741.2	839.7	833.9	874.8	898.6	836.4	797.6	783.9	762.2

RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE

	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.95	0.93	0.93	1.05	1.03	1.08	1.11	1.03	0.97	0.95	0.92
SIDTAT	0.89	0.87	0.86	0.98	0.96	1.01	1.03	0.95	0.91	0.89	0.85
HEFCHT	1.01	0.99	0.98	1.11	1.10	1.15	1.17	1.09	1.04	1.01	0.97

 RUN NUMBER 215

AVERAGE REYNOLDS NUMBER = 27321.78
 AVERAGE PRANDTL NUMBER = 5.58
 MASS FLUX = 840175.94 LBM/(SQ.FT-HR)
 AVERAGE HEAT FLUX = 16584.82 BTU/(SQ.FT-HR)
 Q=AMP*VOLT = 36373.30 BTU/HR
 Q=M*C*(T2-T1) = 37559.80 BTU/HR
 HEAT LOST = 1.61 BTU/HR
 HEAT BALANCE ERROR PERCENT = -3.21

PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
1	781.7	752.6	710.8	630.3	553.2	507.1	1426.0	1305.3	1183.8	1070.1	958.0
2	848.4	760.6	736.2	832.8	760.6	731.0	1215.5	1110.0	1004.5	952.7	865.3
3	924.6	841.1	829.4	962.5	933.1	982.0	963.6	873.5	839.1	814.2	795.0
4	841.5	830.5	881.1	1027.3	1102.8	1236.8	733.2	683.4	670.5	658.1	684.0
5	747.0	827.0	902.1	1064.2	1122.6	1301.2	498.3	589.5	575.8	583.9	638.6
6	720.5	814.8	856.9	1080.9	1181.7	1333.9	801.5	817.3	756.3	757.7	795.0
7	754.2	795.2	803.3	989.1	993.7	1062.1	1204.8	1047.2	1000.4	1029.6	1025.3
8	744.8	767.8	734.1	869.4	753.9	738.6	1427.9	1264.1	1165.2	1116.2	1025.4

AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT-HR-DEG.F)

	1	2	3	4	5	6	7	8	9	10	11
HAVG	795.3	798.7	806.8	932.1	925.2	986.6	1033.8	961.3	899.4	872.8	848.3


RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOSE PREDICTED BY LITERATURE


	1	2	3	4	5	6	7	8	9	10	11
DITBL	0.93	0.91	0.91	1.05	1.04	1.10	1.15	1.06	0.99	0.96	0.92
SIDTAT	0.86	0.84	0.85	0.98	0.96	1.02	1.07	0.99	0.92	0.89	0.85
HEFCHT	0.98	0.96	0.97	1.12	1.10	1.17	1.22	1.13	1.05	1.02	0.98


APPENDIX F


COMPUTER PROGRAM LISTING


AND FLOW CHARTS




































FORTRAN IV G LEVEL 21

MAIN

DATE = 75141

13/33/32

```

0048      DO 12 IPR=1,8
0049          AMPS(ISL,IPR) = TAMP*OHMS/RESIS(ISL,IPR)
0050          AMP=AMP+AMPS(ISL,IPR)
0051      12 CONTINUE
C      CALCULATE TEMPERATURES AT NODE 2
0052          ISL=1
0053          DO 13 IPR=1,8
0054              IMINS=IPR-1
0055              IPLUS=IPR+1
0056              NMINS = ISL - 1
0057              NPLUS = ISL + 1
0058              IF(IMINS.EQ.0) IMINS=8
0059              IF(IPLUS.EQ.9) IPLUS=1
0060              A= AMPS(ISL,IPP)*AMPS(ISL,IPR)*3.41213/XAREA(ISL,IPR)
0061              B= QLOSS(ITSECT)/(LEND(ITSECT)* (TORIG(ITSECT)-TROOMC(ITSECT))*8.)
0062              IF(IST.EQ.4.OR.IST.EQ.5.OR.IST.EQ.6) GO TO 101
0063              C=DELR/(2.0*24.0*DPHI)*(CONDK(ISL,IPR)+CONDK(ISL,IPLUS))/R(ISL)
0064              D= DELR/(2.0*24.0*DPHI)* (CONDK(ISL,IPR)+CONDK(ISL,IMINS))/R(ISL)
0065              X= DPHI/(24.0*DELR)*(CONDK(ISL,IPR)+CONDK(NPLUS,IPR))*(R(NPLUS)+
1DELR/2.0)
0066              GO TO 102
0067      101 CONTINUE
0068          C = DELTAR(IPR)/(2.0*24.0*DPHI)*(CONDK( ISL,IPR)+CONDK(ISL,IPLUS))/
1R456(ISL,IPR)
0069          D = DELTAR(IPR)/(2.0*24.0*DPHI)*(CONDK( ISL,IPR)+CONDK( ISL,IMINS))/
1R456( ISL,IPR)
0070          X =DPHI/(24.0*DELTAR(IPR))*(CONDK( ISL,IPR)+CONDK(NPLUS,IPR))*(R456
1(NPLUS,IPR)+DELTAR(IPR)/2.0)
0071      102 CONTINUE
0072          TWALL(NPLUS,IPR) = TWALL( ISL,IPR)- (A*RSVTY( ISL,IPR)+B*(TROOM-TWAL
1L( ISL,IPR))+ C*(TWALL( ISL,IPLUS)-TWALL( ISL,IPR))+D*(TWALL( ISL,IMIN
2S)-TWALL( ISL,IPR)))/X
0073      13 CONTINUE
C      CALCULATE REMAINING NODAL TEMPERATURES
0074          DO 14 ISL=2,NNODE
0075          DO 14 IPR=1,8
0076              IMINS=IPR-1
0077              IPLUS=IPR+1
0078              NMINS=ISL-1
0079              NPLUS=ISL+1
0080              IF(IMINS.EQ.0) IMINS= 8
0081              IF(IPLUS.EQ.9) IPLUS = 1
0082              A = 3.41213*AMPS (ISL,IPR)*AMPS(ISL,IPR)/ XAREA(ISL,IPR)
0083              IF (IST.EQ.4.OR.IST.EQ.5.OR.IST.EQ.6) GO TO 103
0084              B = DPHI/(24.0*DELR)*(CONDK( ISL,IPR)+CONDK(NMINS,IPR))*(R(NMINS)
1-DELR/2.0)
0085              C = DELR/(24.0*DPHI)*(CONDK( ISL,IPR)+CONDK( ISL,IPLUS))/ R( ISL)
0086              D = DELR/(24.0*DPHI)*(CONDK( ISL,IPR)+CONDK( ISL,IMINS))/ R( ISL)
0087              X = DPHI/(24.0*DELR)*(CONDK( ISL,IPR)+CONDK(NPLUS,IPR))*(R(NPLUS)
1+DELR/2.0)
0088              GO TO 104
0089      103 CONTINUE
0090          B =DPHI/(24.0*DELTAR(IPR))*(CONDK( ISL,IPR)+CONDK(NMINS,IPR))*(R456
1(NMINS,IPR)-DELTAR(IPR)/2.0)
0091          C =DELTAR(IPR)/(24.0*DPHI)*(CONDK( ISL,IPR)+CONDK( ISL,IPLUS))/R456(
1ISL,IPR)
0092          D =DELTAR(IPR)/(24.0*DPHI)*(CONDK( ISL,IPR)+CONDK( ISL,IMINS))/R456(
1ISL,IPR)

```



```

FORTRAN IV G LEVEL 21                MAIN                DATE = 75141                13/33/32

0093          X =DPHI/(24.0*DELTAR(IPR))*(CONDK(ISL,IPR)+CONDK(NPLUS,IPR))*(R456
              1(NPLUS,IPR)+DELTAR(IPR)/2.0)
0094          104 CONTINUE
0095          TWALL(NPLUS,IPR)= TWALL(ISL,IPR) - (A*RSVTY(ISL,IPR)+B*(TWALL(NMIN
              1S,IPR)-TWALL(ISL,IPR)) +C* (TWALL(ISL,IPLUS)-TWALL(ISL,IPR))+ D*(
              2WALL(ISL,IMINS)-TWALL(ISL,IPR)))/X
0096          14 CONTINUE
0097          DO 15 IPR=1,8
0098          TCHK2(IPR) = TWALL(NODES,IPR)
0099          15 CONTINUE
0100          DO 16 IPR =1,8
0101          IF (ABS(TCHK2(IPR)-TCHK1(IPR)).GT.0.005) GO TO 17
0102          16 CONTINUE
0103          GO TO 20
0104          17 DO 18 IPR=1,8
0105          18 TCHK1(IPR) = TCHK2(IPR)
0106          KOUNT = KOUNT+1
0107          GO TO 19
0108          20 DO 21 IPR=1,8
0109          TISURF(IST,IPR)=TWALL(NODES,IPR)
0110          21 CONTINUE
0111          C CALCULATE POWER GENERATED IN EACH SEGMENT IN BTU/HOUR
0112          POWER =0.0
0113          DO 22 ISL=1,NODES
0114          DO 22 IPR=1,8
0115          POWER=POWER+AMPS(ISL,IPR)*AMPS(ISL,IPR)*RESIS(ISL,IPR)
0116          22 CONTINUE
0117          POWERS(IST)=POWER*3.41213
0118          C CALCULATE POWER GENERATED IN SEGMENTS 12 & 13 BY SAVING VARIABLES FOR
0119          C STATIONS 1,2,10,AND 11
0120          IF(IST.GT.2) GO TO 23
0121          IF(IST.EQ.2) GO TO 24
0122          DO 25 ISL=1,NODES
0123          DO 25 IPR=1,8
0124          25 TSAVE1(ISL,IPR)=TWALL(ISL,IPR)
0125          GO TO 23
0126          24 DO 26 ISL=1,NODES
0127          DO 26 IPR=1,8
0128          26 TSAVE2(ISL,IPR)=TWALL(ISL,IPR)
0129          DO 27 ISL=1,NODES
0130          DO 27 IPR=1,8
0131          27 TWALL(ISL,IPR)=(TSAVE1(ISL,IPR)+TSAVE2(ISL,IPR))/2.0
0132          CALL ERSTVT
0133          RINV=0.0
0134          DO 28 ISL=1,NODES
0135          DO 28 IPR=1,8
0136          RESIS(ISL,IPR) = RSVTY(ISL,IPR)*L(12,IPR)/XAREA(ISL,IPR)
0137          RINV=RINV+1.0/RESIS(ISL,IPR)
0138          C REDEFINE WALL TEMPERATURES AT STATION 2
0139          TWALL(ISL,IPR) = TSAVE2(ISL,IPR)
0140          28 CONTINUE
0141          OHMS12=1.0/RINV
0142          POWER=0.0
0143          DO 29 ISL=1,NODES
0144          DO 29 IPR=1,8
0145          AMPS(ISL,IPR)= TAMPS*OHMS12/RESIS(ISL,IPR)
0146          29 POWER=POWER +AMPS(ISL,IPR)*AMPS(ISL,IPR)*RESIS(ISL,IPR)
0147          POWERS(12)=POWER*3.41213

```


```

FORTRAN IV G LEVEL 21                MAIN                DATE = 75141                13/33/32


0144      23 IF(IST.LT.10) GO TO 40
0145      IF(IST.EQ.11) GO TO 30
0146      DO 31 ISL=1,NODES
0147      DO 31 IPR=1,8
0148      31 TSAVE1(ISL,IPR)=TWALL(ISL,IPR)
0149      GO TO 40
0150      30 DO 32 ISL=1,NODES
0151      DO 32 IPR=1,8
0152      32 TSAVE2(ISL,IPR)=TWALL(ISL,IPR)
0153      DO 33 ISL=1,NODES
0154      DO 33 IPR=1,8
0155      33 TWALL(ISL,IPR)=(TSAVE1(ISL,IPR)+TSAVE2(ISL,IPR))/2.0
0156      CALL ERSTVT
0157      RINV=0.0
0158      DO 34 ISL=1,NODES
0159      DO 34 IPR=1,8
0160      RESIS(ISL,IPR) = RSVTY(ISL,IPR)*L( 13,IPR)/XAREA(ISL,IPR)
0161      RINV=RINV+1.0/RESIS(ISL,IPR)
C REDEFINE WALL TEMPERATURES AT STATION 10
0162      TWALL(ISL,IPR) = TSAVE2(ISL,IPR)
0163      34 CONTINUE
0164      OHMS13=1.0/RINV
0165      POWER=0.0
0166      DO 35 ISL=1,NODES
0167      DO 35 IPR=1,8
0168      AMPS(ISL,IPR)= TAMPS*OHMS13/RESIS(ISL,IPR)
0169      35 POWER=POWER + AMPS(ISL,IPR)*AMPS(ISL,IPR)*RESIS(ISL,IPR)
0170      POWERS(13)=POWER*3.41213
0171      40 CONTINUE
0172      CALL QFLUX
0173      9999 CONTINUE
C CALCULATE TOTAL POWER GENERATED IN BTU/HOUR
0174      TPOWER=0.0
0175      DO 61 ISTAT=1,13
0176      61 TPOWER=TPOWER+POWERS(ISTAT)
0177      CALL TLIQD
0178      GO TO 1
0179      3333 STOP
0180      END

```

SUBROUTINE ERSTVT



SUBROUTINE THCOND



FORTRAN IV G LEVEL 21 ERSTVT DATE = 75141 13/33/32

```

0001      SUBROUTINE ERSTVT
0002      COMMON/ERESIS/RSVTY(11,8)
0003      COMMON /TEMP1/ TWALL(11,8),AMPS(11,8),RESIS(11,8),POWERS(13)
           1,TPOWER
0004      COMMON/GEOM2/RBENDS,RBENDL,DOUT,DIN,PHI,DPHI,DELR,NODES,NSLICE
C ELECTRICAL RESISTIVITY OF INCONEL 600 IN OHMS-SQIN/IN
0005      DO 12 ISL=1,NODES
0006      DO 12 IPR=1,8
0007      RSVTY(ISL,IPR)=(40.40292+2.515385E-3*TWALL(ISL,IPR))*1.0E-6
0008      12 CONTINUE
0009      RETURN
0010      END

```


FORTRAN IV G LEVEL 21 THCOND DATE = 75141 13/33/32

```

0001      SUBROUTINE THCOND
0002      COMMON/TCOND/CONDK(11,8)
0003      COMMON /TEMP1/ TWALL(11,8),AMPS(11,8),RESIS(11,8),POWERS(13)
           1,TPOWER
0004      COMMON/GEOM2/RBENDS,RBENDL,DOUT,DIN,PHI,DPHI,DELR,NODES,NSLICE
C THERMAL CONDUCTIVITY OF INCONEL 600 IN BTU/(HR-FT-DEGF)
0005      DO 12 ISL=1,NODES
0006      DO 12 IPR=1,8
0007      CONDK(ISL,IPR) =8.313769+3.846154E-3*TWALL(ISL,IPR)
0008      12 CONTINUE
0009      RETURN
0010      END

```

SUBROUTINE READ




```


FORTRAN IV G LEVEL 21                READS                DATE = 75141                13/33/32


0001          SUBROUTINE READS
0002          COMMON/READ1/TROOM,TCYAVG,PATM,VOLTS,TAMPS,MS,MW,NRJN
0003          COMMON/READ2/TIN,TOUT,PIN,POUT,P1,P2,P3,P4
0004          COMMON/READ3/TOSURF(11,8),TISURF(11,8)
0005          REAL*4 MW
0006          READ (5,1)                RUN,MW,TAMPS,VOLTS,TROOM,TIN,TOUT
0007          1  FORMAT(7F10.3)
0008          READ (5,2)((TOSURF(IST,IPR),IPR=1,8),IST=1,11)
0009          2  FORMAT(8F10.1)
0010          NRUN = RUN +0.1
0011          WRITE(6,101) NRUN,MW,TAMPS,VOLTS,TROOM,TIN,TOUT
0012          101 FORMAT(33X,15('-'))/33X,'RUN NUMBER ',I3/33X,15('-')//
              1  15X,'WATER FLOW RATE                =' ,F8.2,2X,'LBM/HOUR' /
              2  15X,'CURRENT TO TUBE                =' ,F8.2,2X,'AMPS' /
              3  15X,'VOLTAGE DROP IN TUBE           =' ,F8.2,2X,'VOLTS' /
              4  15X,'ROOM TEMPERATURE              =' ,F8.2,2X,'DEGREES F' /
              5  15X,'UNCORRECTED INLET TEMPERATURE =' ,F8.2,2X,'DEGREES F' /
              6  15X,'UNCORRECTED OUTLET TEMPERATURE =' ,F8.2,2X,'DEGREES F' /
              7)
0013          WRITE(6,102)
0014          102 FORMAT(///20X,' OUTSIDE SURFACE TEMPERATURES - DEGREES F'///
              1  9X,'1',6X,'2',6X,'3',6X,'4',6X,'5',6X,'6',6X,'7',6X,'8',
              26X,'9',6X,'10',5X,'11'///)
0015          WRITE(6,103)(IPR,(TOSURF(IST,IPR),IST=1,11),IPR=1,8)
0016          103 FORMAT(3X,I1,F8.1,10F7.1 )
0017          RETURN
0018          END

```

SUBROUTINE TLIQD







FORTRAN IV G LEVEL 21

TLIQD

DATE = 75141

13/33/32

```

0001      SUBROUTINE TLIQD
0002      COMMON/READ1/TROOM,TCYAVG,PATM,VOLTS,TAMPS,MS,MW,NRUN
0003      COMMON/READ2/TIN,TOUT,PIN,POUT,P1,P2,P3,P4
0004      COMMON/READ3/TOSURF(11,8),TISURF(11,8)
0005      COMMON /TEMP1/ TWALL(11,8),AMPS(11,8),RESIS(11,8),POWERS(13)
          1,TPOWER
0006      COMMON /GEOM1/ XAREA(11,8),R(11,8),L(13,8),LTC(11),LEND(2),DELTA R(
          18),R456(11,8),LIN(2),LOUT(2),LTOTAL(2)
0007      COMMON/GEOM2/RBENDS,RBENDL,DOUT,DIN,PHI,DPHI,DELR,NODES,NSLICE
0008      COMMON /THERM1/TSAT(13),TSTART,TEND,QLOSS(2)
0009      COMMON /THERM2/HTCOFF(11,8),QUALTY(13),HSTART,HEND,XSTART,XEND,ENT
          1H(13)
0010      COMMON /QFLUX1/ QFLXID(11,8)
0011      COMMON /TLIQ1/ TBULK(13),HLIQ(13)
0012      COMMON /TLIQ2/ HTDBL(11),HNUSLT(11),HSTATE(11),HAVA(11)
0013      DOUBLE PRECISION T,P
0014      REAL*4 LIN,LOUT,LTOTAL,L,LTC,LEND,MW,MS,MTOT
0015      ITSECT=1
0016      IF(NRUN.GT.199) ITSECT=2
          C CALCULATION OF FLUID BULK TEMPERATURE AT EACH STATION,DEG.F
          DO 1 IST=1,11
0017              TBULK(IST) = TIN+(TOUT-TIN)*LTC(IST)/LEND(ITSECT)
0018          1 CONTINUE
0019              AID=3.1416*DIN*DIN/4.0/144.0
0020              GW=MW/AID
          C CALCULATION OF PERIPHERAL HEAT TRANSFER COEFFICIENT FROM EXPERIMENTAL
          C DATA,BTU/(HR-SQ.FT-DEG.F)
          DO 2 IST=1,11
0022              DO 2 IPR=1,8
0023                  HTCOFF(IST,IPR) =QFLXID(IST,IPR)/(TISURF(IST,IPR)-TBULK(IST))
0024          2 CONTINUE
          C CALCULATION OF INPUT AND OUTPUT HEAT TRANSFER RATE,BTU/HR.
0026              QGCALC=TPOWER
0027              QGEXPT =TAMPS*VOLTS*3.41213
0028              T=(TOUT+TIN)/2.0
0029              SPHT=1.01881-0.4802E-3*T+0.3274E-5*T**2-0.604E-8*T**3
0030              QBALNC=MW*SPHT*(TOUT-TIN)
0031              QIN=QGCALC-QLOSS(ITSECT)
0032              DO 3 IST=1,11
0033                  T=TBULK(IST)
0034                  COND=0.30289+0.7029E-3*T-0.1178E-5*T**2-0.55E-9*T**3
0035                  SPHT=1.01881-0.4802E-3*T+0.3274E-5*T**2-0.604E-8*T**3
          C EAGLE FERGUSON CHART CHART HEAT TRANSFER COEFFICIENT,
          C BTU/HR-SQ.FT-DEG.F
0036              XK=1.01E-3*T+0.919
0037              T=10.0*(T-32.0)/18.0
0038              ROU=62.37*(0.999986+0.189E-4*T+0.5886E-5*T**2+0.1548E-7*T**3)
0039              V=GW/ROU/3600.0
0040              BB=5.653*XK
0041              HEF=EXP(BB+0.805*ALOG(V))
0042              VISC=2.420*1.002*10.0**((1.3272*(20.0-T)-0.001053*(T-20.0)**2)/(T+
          1105.0))
0043              REYNO=GW*DIN/12.0/VISC
0044              PRNO=VISC*SPHT/COND
          C DITTUS-BOETLER HEAT TRANSFER COEFFICIENT,BTU/(HR-SQ.FT-DEG.F)
0045              HTDB=0.023*REYNO**0.8*PRNO**0.4*COND/DIN*12.0
0046              TIS=0.0
          C AVERAGE HEAT TRANSFER COEFFICIENT AT EACH STATION FROM EXPERIMENTAL

```

```

FCRTRAN IV G LEVEL 21                TLIQD                DATE = 75141                13/33/32

      C DATA,BTU/HR-SQ.FT-DEG.F
0047      HAV=0.0
0048      DO 4 IPR=1,8
0049      TIS=TIS+TISURF(IST,IPR)
0050      4 HAV      =HAV+HTCOFF(IST,IPR)
      C SIEDER-TATE HEAT TRANSFER COEFFICIENT AT EACH STATION,
      C BTU/HR-SQ.FT-DEG.F
0051      T=TIS/8.0
0052      T=10.0*(T-32.0)/18.0
0053      VISWL=2.42*1.002*10.0**((1.3272*(20.0-T)-0.001053*(T-20.0)**2)/(T+
1105.0))
0054      HSTATE(IST)=0.027*REYNO**0.8*PRNO**0.333*(VISC/VISWL)**0.14*COND/
1DIN*12.0
0055      HAVG(IST)=HAV/8.0
      C RATIO OF HEAT TRANSFER COEFFICIENTS:THIS WORK TO SIEDER-TATE,
      C EAGLE-FERGUSON CHART,DITTUS-BOETLER.
0056      HSTATE(IST)=HAVG(IST)/HSTATE(IST)
0057      HNUSLT(IST)=HAVG(IST)/HEF
0058      HTDBL(IST)=HAVG(IST)/HTDB
0059      3 CONTINUE
0060      WRITE(6,100)
0061      100 FORMAT(1H1)
0062      T=(TIN+TOUT)/2.0
0063      COND=0.30289+0.7029E-3*T-0.1178E-5*T**2-0.55E-9*T**3
0064      SPHT=1.01881-0.4802E-3*T+0.3274E-5*T**2-0.604E-8*T**3
0065      T=10.0*(T-32.0)/18.0
0066      VISC=2.420*1.002*10.0**((1.3272*(20.0-T)-0.001053*(T-20.0)**2)/(T+
1105.0))
0067      PRNO=VISC*SPHT/COND
0068      REYNO=GW*DIN/12.0/VISC
0069      QFLXAV=QIN/(3.1416*DIN/12.0*LEND(ITSECT)/12.0)
0070      WRITE(6,112)NRUN,REYNO,PRNO,GW,QFLXAV
0071      112 FORMAT(33X,15('-')/33X,'RUN NUMBER ',I3/33X,15('-')//
6      10X,' AVERAGE REYNOLDS NUMBER      =',F9.2/
1      10X,' AVERAGE PRANDTL NUMBER        =',F9.2/
2      10X,' MASS FLUX                      =',F9.2,2X,' LBM/(SQ.FT-
3HR)'/
4      10X,' AVERAGE HEAT FLUX            =',F9.2,2X,' BTU/(SQ.FT-
5HR)')
0072      QPCT=(QGEXPT-QLOSS(ITSECT)-QBALNC)/(1.5*(QGEXPT-QLOSS(ITSECT)+QBALN
9C))
0073      QPCT=100.0*QPCT
0074      WRITE(6,789)QGEXPT,QBALNC,QLOSS(ITSECT),QPCT
0075      789 FORMAT(10X,'Q=AMP*VOLT          =',F9.2,2X,' BTU/HR' /
110X,'Q=M*C*(T2-T1)                        =',F9.2,2X,' BTU/HR' /
310X,' HEAT LOST                            =',F9.2,2X,' BTU/HR' /
510X,' HEAT BALANCE ERROR PERCENT          =',F9.2)
0076      WRITE(6,333)
0077      333 FORMAT(/,15X,' PERIPHERAL HEAT TRANSFER COEFFICIENT BTU/(SQ.FT-HR-D
$EG.F)')
0078      WR ITE(6,8888)
0079      8888 FORMAT(/,13X,'1',6X,'2',6X,'3',6X,'4',6X,'5',6X,'6',6X,'7',6X,'8',
16X,'9',6X,'10',5X,'11')
0080      WRITE(6,12)(IPR,(HTCOFF(IST,IPR),IST=1,11),IPR=1,8)
0081      12 FORMAT(3X,I2,4X,11F7.1)
0082      WRITE(6,101)
0083      101 FORMAT(/,15X,' AVERAGE HEAT TRANSFER COEFFICIENT-BTU/(SQ.FT.HR-DEG.
2F)')

```

FORTRAN IV G LEVEL 21


TLIQD

DATE = 75141

13/33/32

```
0084      WRITE(6,8888)
0085      WRITE(6,13)(HAVG(IST),IST=1,11)
0086      13 FORMAT(5X,'HAVG',11F7.1)
0087      WRITE(6,102)
0088      102 FORMAT(/6X,' RATIO OF CALCULATED HEAT TRANSFER COEFFICIENT TO THOS
          *E PREDICTED BY LITERATURE')
0089      WRITE(6,8888)
0090      WRITE(6,14)(HTDBL(IST),IST=1,11)
0091      14 FORMAT(4X,'DITBL',11F7.2)
0092      WRITE(6,15)(HSTATE(IST),IST=1,11)
0093      15 FORMAT(3X,'S IDTAT',11F7.2)
0094      WRITE(6,16)(HNUSLT(IST),IST=1,11)
0095      16 FORMAT(3X,'HEFCHT',11F7.2)
0096      WRITE(6,100)
0097      RETURN
0098      END
```

SUBROUTINE QFLUX




```

FORTRAN IV G LEVEL 21                QFLUX                DATE = 75141                13/33/32

0001          SUBROUTINE QFLUX
0002          COMMON /MAIN1/ IST,KOUNT
0003          COMMON /GEOM1/ XAREA(11,8),R(11 ),L(13,8),LTC(11),LEND(2),DELTAR(
18),R456(11,8),LIN(2),LOUT(2),LTOTAL(2)
0004          COMMON/GEOM2/RBENDS,RBENDL,DOUT,DIN,PHI,DPHI,DELR,NODES,NSLICE
0005          COMMON/TCOND/CONDK(11,8)
0006          COMMON /TEMP1/ TWALL(11,8),AMPS(11,8),RESIS(11,8),POWERS(13)
1,TPOWER
0007          COMMON /QFLUX1/ QFLXID(11,8)
0008          COMMON/ERESIS/RSVTY(11,8)
0009          COMMON /QFLUX2/ Q1,Q2,Q4,QGEN
C  CALCULATE HEAT FLUX AT INSIDE SURFACE BY MAKING A HEAT BALANCE
0010          ISL=NODES
0011          DO 10 IPR=1,8
0012          IPLUS=IPR+1
0013          IMINS=IPR-1
0014          IF (IPLUS.EQ.9) IPLUS=1
0015          IF (IMINS.EQ.0) IMINS=8
0016          IF (IST.EQ.4.OR.IST.EQ.5.OR.IST.EQ.6) GO TO 8
0017          Q1 = DPHI/(24.0*DELR)*(CONDK(ISL-1,IPR)+CONDK(ISL,IPR))*(R(ISL-1)
1-DELR/2.0)*(TWALL(ISL-1,IPR)-TWALL(ISL,IPR))
0018          Q2 = DELR/(2.0*24.0*DPHI)/R(ISL)*(CONDK(ISL,IPLUS)+CONDK(ISL,IPR))
1*(TWALL(ISL,IPLUS)-TWALL(ISL,IPR))
0019          Q4 = DELR/(2.0*24.0*DPHI)/R(ISL)*(CONDK(ISL,IMINS)+CONDK(ISL,IPR))
1*(TWALL(ISL,IMINS)-TWALL(ISL,IPR))
0020          QGEN =3.41213*AMPS(ISL,IPR)*AMPS(ISL,IPR)*RSVTY(ISL,IPR)/XAREA(ISL
1,IPR)
0021          QFLXID(IST,IPR) = (Q1+Q2+Q4+QGEN)/(R(NODES)*DPHI)*144.0
0022          GO TO 9
0023          8 CONTINUE
0024          Q1 = DPHI/(24.0*DELTAR(IPR))*(CONDK(ISL-1,IPR)+CONDK(ISL,IPR))*
1(R456(ISL-1,IPR)-DELTAR(IPR)/2.0)*(TWALL(ISL-1,IPR)-TWALL(ISL,IPR
2))
0025          Q2 = DELTAR(IPR)/(2.0*24.0*DPHI)/R456(ISL,IPR)*(CONDK(ISL,IPLUS)+
1CONDK(ISL,IPR))*(TWALL(ISL,IPLUS)-TWALL(ISL,IPR))
0026          Q4 = DELTAR(IPR)/(2.0*24.0*DPHI)/R456(ISL,IPR)*(CONDK(ISL,IMINS)+
1CONDK(ISL,IPR))*(TWALL(ISL,IMINS)-TWALL(ISL,IPR))
0027          QGEN =3.41213*AMPS(ISL,IPR)*AMPS(ISL,IPR)*RSVTY(ISL,IPR)/XAREA(ISL
1,IPR)
0028          QFLXID(IST,IPR) = (Q1+Q2+Q4+QGEN)/(R456(NODES,IPR)*DPHI)*144.0
0029          9 CONTINUE
0030          10 CONTINUE
0031          RETURN
0032          END

```

SUBROUTINE CORECT




```


FCRTRAN IV G LEVEL 21                CORECT                DATE = 75141                13/33/32


0001          SUBROUTINE CORECT
0002          COMMON/READ1/TROOM,TCYAVG,PATM,VOLTS,TAMPS,MS,MW,NRJN
0003          COMMON/READ2/TIN,TOUT,PIN,POUT,P1,P2,P3,P4
0004          COMMON /GEOM1/ XAREA(11,8),R(11  ),L(13,8),LTC(11),LEND(2),DELTAR(
          18),R456(11,8),LIN(2),LOUT(2),LTOTAL(2)
0005          COMMON /THERM1/TSAT(13),TSTART,TEND,QLOSS(2)
0006          REAL*4 LEND,LTOTAL
C CORRECT INLET AND OUTLET MIXTURE TEMPERATURES AND CALCULATE TEST
C SECTION HEAT LOSSES
0007          ITSECT =1
0008          IF (NRUN.GT.199) ITSECT=2
0009          IF (NRUN.GT.199) GO TO 11
0010          TIN = TIN -.7/(210.7-72.0)*(TIN-TROOM)
0011          TOUT=TOUT-.9/(210.7-72.0)*(TOUT-TROOM)
0012          QLOSST= 596.0/(211.5-78.2)*((TIN+TOUT)/2.0-TROOM)
0013          GO TO 12
0014          11 CONTINUE
0015          TIN = TIN -.7/(210.3-76.5)*(TIN-TROOM)
0016          TOUT=TOUT -.9 / ( 211.1-76.5)*(TOUT-TROOM)
0017          QLOSST= 485.0/(210.3-76.0)*((TIN+TOUT)/2.0-TROOM)
0018          12 CONTINUE
0019          QLOSS(ITSECT)=QLOSST*LEND(ITSECT)/LTOTAL(ITSECT)
0020          RETURN
0021          END


```



SUBROUTINE GEOM











FORTRAN IV G LEVEL 21

GEOM

DATE = 75141

13/33/32

```

0001      SUBROUTINE GEOM
0002      COMMON/READ1/TROOM,TCYAVG,PATM,VOLTS,TAMPS,MS,MW,NRUN
0003      COMMON /GEOM1/ XAREA(11,8),R(11 ),L(13,8),LTC(11),LEND(2),DELTAR(
18),R456(11,8),LIN(2),LOUT(2),LTOTAL(2)
0004      COMMON/GEOM2/RBENDS,RBENDL,DOUT,DIN,PHI,DPHI,DELR,NODES,NSLICE
0005      COMMON /MAIN1/ IST,KOUNT
0006      DIMENSION THICK1(6),THICK2(6),THICK3(6),THICK4(6),THICK5(6)
1,THICK6(6),THICK7(6),THICK8(6)
0007      REAL * 4 L,LTC,LEND,MW,MS,LIN,LOUT,LTOTAL
0008      ITSECT=1
0009      IF(NRUN.GT.199) ITSECT =2
0010      NSLICE=10
0011      LIN(1)=12.0+8.0
0012      LIN(2)=20.0+8.0
0013      LOUT(1)=12.0+5.5
0014      LOUT(2)=20.0+5.5
0015      RBENDS=4.75 A
0016      RBENDL=9.875 B
0017      DOUT = 0.875
0018      DIN = 0.771
0019      THICK=0.052
0020      NODES= NSLICE + 1
0021      PHI = 2*3.1416
0022      DPHI = PHI/8.0
0023      PIE14 = 1.0/4.0*3.1416
0024      PIE38 = 3.0/8.0*3.1416
0025      DO 10 IPR=1,8
0026      L(1,IPR )=8.0
0027      L(2,IPR )=6.0
0028      L(3,IPR) =3.0
0029      L(7,IPR) =3.0
0030      L(8,IPR )=6.0
0031      L(9,IPR )=6.0
0032      L(10,IPR)=6.0
0033      L(11,IPR)=8.0
0034      10 CONTINUE
0035      IF (NRUN.GT.199) GO TO 101
0036      THICK1(5) = 0.05665
0037      THICK2(5) = 0.054325
0038      THICK3(5) = 0.052
0039      THICK4(5) = 0.05005
0040      THICK5(5) = 0.0481
0041      THICK6(5) = THICK4(5)
0042      THICK7(5) = THICK3(5)
0043      THICK8(5) = THICK2(5)
0044      THICK1(4) = (THICK1(5)+THICK)/2.0
0045      THICK2(4) = (THICK2(5)+THICK)/2.0
0046      THICK3(4) = (THICK3(5)+THICK)/2.0
0047      THICK4(4) = (THICK4(5)+THICK)/2.0
0048      THICK5(4) = (THICK5(5)+THICK)/2.0
0049      THICK6(4) = (THICK6(5)+THICK)/2.0
0050      THICK7(4) = (THICK7(5)+THICK)/2.0
0051      THICK8(4) = (THICK8(5)+THICK)/2.0
0052      THICK1(6) = (THICK1(4)+THICK)/2.0
0053      THICK2(6) = (THICK2(4)+THICK)/2.0
0054      THICK3(6) = (THICK3(4)+THICK)/2.0
0055      THICK4(6) = (THICK4(4)+THICK)/2.0
0056      THICK5(6) = (THICK5(4)+THICK)/2.0

```

FORTRAN IV G LEVEL 21

GEOM


DATE = 75141

13/33/32

```

0057      THICK6(5) = (THICK6(4)+THICK)/2.0
0058      THICK7(6) = (THICK7(4)+THICK)/2.0
0059      THICK8(6) = (THICK8(4)+THICK)/2.0
0060      L(4,1) = (RBENDS-DIN/2.0-THICK1(4)/2.0)*PIE38
0061      L(4,3)=RBENDS*PIE38
0062      L(4,5) = (RBENDS+DIN/2.0+THICK5(4)/2.0)*PIE38
0063      L(4,2)=(L(4,1)+L(4,3))/2.0
0064      L(4,4)=(L(4,3)+L(4,5))/2.0
0065      L(4,6)=L(4,4)
0066      L(4,7)=L(4,3)
0067      L(4,8)=L(4,2)
0068      DO 11 IPR=1,8
0069      L(12,IPR)=41.0
0070      L(13,IPR)=29.0
0071      11 CONTINUE
0072      GO TO 102
0073      101 CONTINUE
0074      THICK1(5) = 0.05415
0075      THICK2(5) = 0.053075
0076      THICK3(5) = 0.052
0077      THICK4(5) = 0.051025
0078      THICK5(5) = 0.05005
0079      THICK6(5) = THICK4(5)
0080      THICK7(5) = THICK3(5)
0081      THICK8(5) = THICK2(5)
0082      THICK1(4) = (THICK1(5)+THICK)/2.0
0083      THICK2(4) = (THICK2(5)+THICK)/2.0
0084      THICK3(4) = (THICK3(5)+THICK)/2.0
0085      THICK4(4) = (THICK4(5)+THICK)/2.0
0086      THICK5(4) = (THICK5(5)+THICK)/2.0
0087      THICK6(4) = (THICK6(5)+THICK)/2.0
0088      THICK7(4) = (THICK7(5)+THICK)/2.0
0089      THICK8(4) = (THICK8(5)+THICK)/2.0
0090      THICK1(6) = THICK1(4)
0091      THICK2(6) = THICK2(4)
0092      THICK3(6) = THICK3(4)
0093      THICK4(6) = THICK4(4)
0094      THICK5(6) = THICK5(4)
0095      THICK6(6) = THICK6(4)
0096      THICK7(6) = THICK7(4)
0097      THICK8(6) = THICK8(4)
0098      L(4,1) = (RBENDL-DIN/2.0-THICK1(5)/2.0)*PIE38
0099      L(4,3)=RBENDL*PIE38
0100      L(4,5) = (RBENDL+DIN/2.0+THICK5(4)/2.0)*PIE38
0101      L(4,2)=(L(4,1)+L(4,3))/2.0
0102      L(4,4)=(L(4,3)+L(4,5))/2.0
0103      L(4,6)=L(4,4)
0104      L(4,7)=L(4,3)
0105      L(4,8)=L(4,2)
0106      DO 20 IPR=1,8
0107      L(12,IPR)=29.0
0108      L(13,IPR)=16.0
0109      20 CONTINUE
0110      102 CONTINUE
0111      DO 21 IPR=1,8
0112      L(5,IPR)=L(4,IPR)/PIE38*PIE14
0113      L(6,IPR)=L(4,IPR)
0114      21 CONTINUE

```



FORTRAN IV G LEVEL 21

GEOM

DATE = 75141

13/33/32

```

0115      LTC(1)=4.0
0116      LTC(2)=LTC(1) +48.0
0117      IF(NRUN.GT.199) LTC(2 )= LTC(1)+35.0
0118      LTC(3)=LTC(2) +6.0
0119      LTC(4)=LTC(3) +3.1416*RBENDS/4.0
0120      IF(NRUN.GT.199) LTC(4)= LTC(3)+ 3.1416*RBENDL/4.0
0121      LTC(5)=LTC(4) +3.1416*RBENDS/4.0
0122      IF(NRUN.GT.199) LTC(5 )= LTC(4)+3.1416*RBENDL/4.0
0123      LTC(6)=LTC(5)+3.1416*RBENDS/4.0
0124      IF(NRUN.GT.199) LTC(6 )= LTC(5)+ 3.1416*RBENDL/4.0
0125      LTC(7)=LTC(6) +3.1416*RBENDS/4.0
0126      IF(NRUN.GT.199) LTC(7 )= LTC(6)+3.1416*RBENDL/4.0
0127      LTC(8)=LTC(7) +6.0
0128      LTC(9)=LTC(8) +6.0
0129      LTC(10)=LTC(9) +6.0
0130      LTC(11)=LTC(10)+36.0
0131      IF (NRUN.GT.199) LTC(11) = LTC(10) + 23.0
0132      LEND(ITSECT) = LTC(11)+4.0
0133      LTOTAL(ITSECT)=LOUT(ITSECT)+LIN(ITSECT)+LEND(ITSECT)
0134      RETURN
0135      ENTRY GEOMST
0136      DELR = (DOUT-DIN)/2.0/NSLICE
0137      R(1) = DOUT/2.0
0138      DO 103 I=1,NSLICE
0139      103 R(I+1)=R(I)-DELR
0140      DO 104 IPR=1,8
0141      XAREA (1,IPR)=(R(1)-DELR/4.0)*DPHI*DELR/2.0
0142      104 XAREA(NODES,IPR)=(R(NODES)+DELR/4.0) *DPHI*DELR/2.0
0143      DO 105 I=2,NSLICE
0144      DO 105 IPR=1,8
0145      105 XAREA (I,IPR)= R(I)*DPHI*DELR
0146      RETURN
0147      ENTRY GEOMBT
0148      DELTAR(1) = THICK1(IST)/NSLICE
0149      DELTAR(2) = THICK2(IST)/NSLICE
0150      DELTAR(3) = THICK3(IST)/NSLICE
0151      DELTAR(4) = THICK4(IST)/NSLICE
0152      DELTAR(5) = THICK5(IST)/NSLICE
0153      DELTAR(6) = THICK6(IST)/NSLICE
0154      DELTAR(7) = THICK7(IST)/NSLICE
0155      DELTAR(8) = THICK8(IST)/NSLICE
0156      DO 202 IPR=1,8
0157      202 R456(NODES,IPR) = DIN/2.0
0158      DO 203 ISL=1,NSLICE
0159      DO 203 IPR=1,8
0160      203 R456(NODES-ISL,IPR)=R456(NODES-ISL+1,IPR)+DELTAR(IPR)
0161      DO 204 IPR=1,8
0162      XAREA(1,IPR) = (R456(1,IPR)-DELTAR(IPR)/4.0)*DPHI*DELTAR(IPR)/2.0
0163      204 XAREA(NODES,IPR)=(R456(NODES,IPR)+DELTAR(IPR)/4.0)*DPHI*DELTAR(IPR
1)/2.0
0164      DO 205 ISL=2,NSLICE
0165      DO 205 IPR=1,8
0166      205 XAREA(ISL,IPR)=R456(ISL,IPR)*DPHI*DELTAR(IPR)
0167      RETURN
0168      END

```


NOMENCLATURE FOR COMPUTER PROGRAM

AID	- cross section of tube, ft^2
AMPS	- fraction of the total current flowing through each segment of each slice of the tube wall, amps
COND	- thermal conductivity of water, $\text{Btu}/(\text{hr-ft-}^\circ\text{F})$
CONDK	- thermal conductivity of Inconel 600, $\text{Btu}/(\text{hr-ft-}^\circ\text{F})$
DELR	- radius increment, inches
DELTAR	- thickness of one slice, inches
DIN	- inside diameter of tube, inches
DOUT	- outside diameter of tube, inches
DPHI	- $\pi/4$
GW	- mass velocity, $\text{lbm}/(\text{hr-ft}^2)$
HAV	- average heat transfer coefficient at each station, $\text{Btu}/(\text{hr-ft}^2\text{-}^\circ\text{F})$
HEF	- Eagle-Ferguson heat transfer coefficient, $\text{Btu}/(\text{hr-ft}^2\text{-}^\circ\text{F})$
HSTATE	- Sieder-Tate heat transfer coefficient, $\text{Btu}/(\text{hr-Ft}^2\text{-}^\circ\text{F})$
HTCOFF	- peripheral heat transfer coefficient, $\text{Btu}/(\text{hr-Ft}^2\text{-}^\circ\text{F})$

- HTDB	- Dittus-Boelter heat transfer coefficient, $\text{Btu}/(\text{hr-ft}^2\text{-}^\circ\text{F})$
- IMINS	- peripheral index
- IPLUS	- peripheral index
- IPR	- peripheral index
- ISL	- slice number
IST	- station number
- ITSECT	- index for small (1) and large (2) test section
KOUNT	- counter
L	- heating length, inches
LEND	- length of test section, inches
LTC	- distance between each station and start of heating, inches
MW	- mass flow rate, lbm/hr
- NMINS	- peripheral index
- NPLUS	- peripheral index
NODES	- number of slices
NRUN	- run number
.OHMS	- electrical resistance
PHI	- 2π
- PIE14	- $\pi/4$
- PIE38	- $3\pi/8$
- POWER	- power generated in each segment, Btu/hr
- PRNO	- Prandtl number

— QBALNC	- heat output = $mC_p (T_{out} - T_{in})$ Btu/hr
— QFLAXAV	- average heat flux, Btu/(hr-ft ²)
— QFLXID	- heat flux at each peripheral position, Btu/(hr-ft ²)
— QGEXPT	- heat input = (V)(I), Btu/hr
— QLOSS	- heat loss from test section, Btu/hr
— QLOST	- heat loss from heat transfer loop, Btu/hr
— QPCT	- heat balance error percent
R	- radius to the slice (straight sections), inches
R456	- radius to the slice (bend section), inches
— REYNO	- Reynolds number
— ROU	- density of water, gm/ml or lbm/ft ³
— RSVTY	- electrical resistivity
— SPHT	- specific of water, Btu/(lbm-°F)
— TAMP	- total current to the test section, amps
— TBULK	- fluid bulk temperature, °F
— TCHOK1	- first guess for inside wall temperature, °F
— TCHCK2	- inside surface temperature, °F
— THICK	- wall thickness of tube, inches
— TIN	- inlet bulk temperature of water, °F

— TIS	= average inside surface temperature, °F
TISURF	- inside surface temperature, °F
TOSURF	- outside surface temperature, °F
— TOUT	- outlet bulk temperature of water, °F
TROOM	- room temperature, °F
TWALL	- nodal temperatures of wall, °F
— V	- water velocity, ft/sec
— VISC	- water viscosity, lbm/(ft-hr)
— VISC	- water viscosity at wall temperature, lbm/(ft-hr)
VOLTS	- voltage drop in test section, volts.

VITA

Mahmood Moshfeghian

Candidate for the Degree of

Master of Science

Thesis: THE EFFECT OF A 180° BEND ON TURBULENT HEAT TRANSFER
COEFFICIENT IN A PIPE

Major Field: Chemical Engineering

Biographical:

Personal Data: Born in Shiraz, Iran, June 2, 1951, the son of
Ali-Akbahr and Johnbibi Moshfeghian.

Education: Graduated from Sadat High School, Bushehr and Razi
High School, Shiraz, Iran, in 1970; received the Bachelor of
Science degree in Chemical Engineering from the Oklahoma
State University in May, 1974; completed the requirements
for the Master of Science degree in Chemical Engineering
in July, 1975.

Professional Experience: Graduate Teaching Assistant, School of
Chemical Engineering, Oklahoma State University, 1974-75.