
MEMORANDUM

DATE: March 15, 2018

TO: Whom it may concern

FROM: Coty Forretser
Chandler Parsons
Quentin Price

SUBJECT: Successful Preliminary Design of Dimethyl Ether Plant

As desired, a dimethyl ether (DME) product was created from methanol (MeOH) at a rate of 6497 barrels/day with a purity of 99.95%, respectively. The process was modeled, simulated, and optimized using Aspen HYSYS. Hand calculations were used to validate these results.

Economic analyses were conducted based on 15-year MACRS depreciation over a 20-year project life starting in the year 2019. The estimated net present value is \$207,200,000 with discounted cash flow rate of return 11.1%. Based on both NPV and DCFROR analyses, the DME system was determined to be economically attractive.

A detailed report of the preliminary design study is attached to this memo.

CHE 4224

Spring 2018

AIChE 2018 Student Design Competition

Manufacture of Dimethyl Ether for Transport

March 15, 2018

Group Number _____

Group Members

Coty Forrester

Chandler Parsons

John Quentin Price

CHE 4224

Spring 2018

AICHE 2018 Student Design Competition

Manufacture of Dimethyl Ether for Transport

March 15, 2018

Group Number _____

Table of Contents

I.	Executive Summary.....	1
II.	Introduction.....	2
III.	Process Flow Diagram.....	3
IV.	Material Balances.....	4
V.	Process Description.....	10
VI.	Energy Balance and Utility Requirements.....	12
VII.	Equipment List and Unit Description.....	13
	a. Pumps.....	13
	b. Heat Exchangers.....	14
	c. Distillation Columns.....	15
	i. Column T-100.....	15
	ii. Column T-101.....	16
	d. Reactor.....	17
VIII.	Equipment Specification Sheets.....	18
IX.	Equipment Cost Summary.....	33
	a. Column cost estimates.....	33
	b. Heat exchanger cost estimates.....	33
	c. Pump cost estimates.....	33
	d. Reactor cost estimate.....	34
X.	Fixed Capital Investment Summary.....	36
XI.	Controls System Summary.....	38
XII.	Safety, Health, and Environmental Considerations.....	39
	a. Safety.....	39
	b. Health.....	40
	c. Environment.....	40
XIII.	Economic Analysis.....	42
	a. Estimation of operating expenses and revenue.....	42
	b. DCFROR analysis.....	45
	c. Sensitivity analysis.....	45
XIV.	Conclusions.....	47

XV.	Recommendations.....	48
XVI.	References.....	49
XVII.	Appendix I – Cash Flow Chart (2018-2039).....	49
XVIII.	Appendix II – Sizing and Costing Sheets.....	51
	a. Macrs depreciation chart.....	52
	b. Sizing pumps.....	53
	c. Costing pumps.....	54
	d. Sizing heat exchangers.....	56
	e. Costing heat exchangers.....	61
	f. Column sizing and costing.....	64
	g. Reactor sizing and costing.....	65
XIX.	Appendix III – Misc.....	66
	a. Polymath report.....	66
XX.	Appendix IV – Aspen HYSYS report.....	67

Tables and Figures

I. Tables

a.	Table 1: Stream table (1).....	4
b.	Table 2: Stream table (2).....	4
c.	Table 3: Stream table (3).....	5
d.	Table 4: Stream table (4).....	5
e.	Table 5: Stream table (5).....	6
f.	Table 6: Stream table (6).....	6
g.	Table 7: Stream table (7).....	7
h.	Table 8: Stream table (8).....	7
i.	Table 9: Stream table (9).....	8
j.	Table 10: Stream table (10).....	8
k.	Table 11: Stream table (11).....	9
l.	Table 12: Stream table (12).....	9
m.	Table 13: Pump specifications.....	13
n.	Table 14: T-100 Specification Sheet.....	18
o.	Table 15: T-101 Specification Sheet.....	19
p.	Table 16: GBR-100 Specification Sheet.....	20
q.	Table 17: P-100 Specification Sheet.....	21
r.	Table 18: P-101 Specification Sheet.....	22
s.	Table 19: P-102 Specification Sheet.....	23
t.	Table 20: P-103 Specification Sheet.....	24
u.	Table 21: P-104 Specification Sheet.....	25
v.	Table 22: E-100 Specification Sheet.....	26
w.	Table 23: E-101 Specification Sheet.....	27
x.	Table 24: E-102 Specification Sheet.....	28
y.	Table 25: E-104 Specification Sheet.....	29
z.	Table 26: E-103 Specification Sheet.....	30
aa.	Table 27: R-100 Specification Sheet.....	31
bb.	Table 28: R-101 Specification Sheet.....	32

cc. Table 29: Purchase, bare module, and total module costs for all required equipment	
(1).....	35
dd. Table 30: Purchase, bare module, and total module costs for all required equipment	
(2).....	37
ee. Table 31: Data and costs of purchasing methanol and lubricant.....	42
ff. Table 32: Utility costs for each piece of equipment and utility type.....	44
II. Figures	
a. Figure 1:Process Flow Diagram (PFD).....	3
b. Figure 2: Tornado chart for process NPV.....	46
c. Figure 3: Tornado chart for process DCFROR.....	46

Executive Summary

The objective of this design is to synthesize a stream of dimethyl ether (99.95 mass percent) for use as an alternative fuel source in diesel engines. This is accomplished through the dehydration of methanol over a Gamma Alumina catalyst. The products of this reaction are then sent through two distillation columns, one to separate the DME from the water and methanol, and the other to separate the methanol from the water. The methanol is recycled to the feed of the reactor, and the waste water is sent to a treatment facility. The equipment necessary to implement this design includes six pumps, seven heat exchangers, two distillation columns, and one reactor vessel. Utilities for this process include high pressure steam, cooling water, catalyst, and power. The manufacture and installation costs of the equipment amounts to \$2,850,000, and the cost of the utilities per year is \$20,200,000. Methanol is purchased and shipped to the facility (110,500,000 gal/year), along with a lubricant (60,000 gal/year) for the DME product that is added to achieve a concentration of 900 PPM. The total cost for these raw materials is \$167,500,000 per year. DME is produced at a rate of 99,600,000 gal/year, with a flexible selling price set at \$2.40/gal, so that a profit is still achieved while the selling price is low enough to attract consumers to the alternative fuel. Thus, DME revenues amount to \$227,000,000 per year. Economic analysis found that the NPV is \$207,000,000 and DCFROR is 11.1% with a hurdle rate of 8% and a project life of 20 years. Sensitivity analysis indicates that a low sale price or high raw material cost could cause the DCFROR to dip below the hurdle rate (although the NPV remains positive). However, because the selling price of DME was conservative (average ultra-low sulfur diesel prices over the last 12 years was \$3.13/gal), the selling price would likely be higher. Therefore, this team is comfortable with recommending that this project go forward.

Introduction

The primary focus of this project is the synthesis of dimethyl ether (DME) from methanol (MeOH). The reaction chosen to produce the DME is an exothermic equilibrium reaction that uses an acid catalyst. The acid catalyst that was chosen for this reaction is gamma alumina oxide ($\gamma\text{-Al}_2\text{O}_3$). Interest in creating DME has been generated due to the fact that DME could serve as a cleaner burning alternative to ultra-low sulfur diesel.

A production rate of 250,000 US gal/day of DME is required, which should be capable of supporting a shipping region consisting of 2000 trucks. The process also needs to be capable of operating with a turn down rate of 50% from normal production without any issues. A MeOH mixture consisting of 0.9972 mass% MeOH and 0.0028 mass% water will be considered the feed material. The feed will be delivered by railcar from the Lake Charles MeOH plant at a price of 0.02 \$/gal. The final DME fuel product must contain at least 98.5 mass% DME, and the fuel is not allowed to exceed 0.05 mass% of MeOH and 0.03 mass% of water. Lubricant is also purchased and added to the DME product stream at concentrations of 900 PPM.




Table 1: Stream table (1)

Name	Meth feed	meth feed 3	reactor feed
Stream Number	1	2	3
Vapour Fraction	0	1	1
Temperature [C]	25	136	250
Pressure [kPa]	100	790	790
Molar Flow [kgmole/h]	1251	1576	1576
Mass Flow [kg/h]	40000	49823	49823
Liquid Volume Flow [m ³ /h]	50	62	62
Heat Flow [kJ/h]	-299840727	-311018979	-300871246

Table 2: Stream table (2)

Name	reactor out	D1 feed	Meth H ₂ O
Stream Number	4	5	6
Vapour Fraction	1	1	0
Temperature [C]	367	274	145
Pressure [kPa]	790	790	840
Molar Flow [kgmole/h]	1576	1576	955
Mass Flow [kg/h]	49824	49824	21207
Liquid Volume Flow [m ³ /h]	66	66	24
Heat Flow [kJ/h]	-300871247	-311018980	-248743896

Table 3: Stream table (3)

Name	Meth Recycle	Waste Water	meth feed 2
Stream Number	7	8	9
Vapour Fraction	1	0	0
Temperature [C]	136	174	35
Pressure [kPa]	870	890	100
Molar Flow [kgmole/h]	650	630	1576
Mass Flow [kg/h]	19647	11385	49823
Liquid Volume Flow [m ³ /h]	24	11	62
Heat Flow [kJ/h]	-131193114	-172111575	-377787545

Table 4: Stream table (4)

Name	Purge	D1 feed cooled	DME outlet
Stream Number	10	11	12
Vapour Fraction	0	0	1
Temperature [C]	367	74	38
Pressure [kPa]	790	790	820
Molar Flow [kgmole/h]	0	1576	1253
Mass Flow [kg/h]	0	49824	57706
Liquid Volume Flow [m ³ /h]	0	66	86
Heat Flow [kJ/h]	0	-377813544	-229701575

Table 5: Stream table (5)

Name	meth feed 2 high P	Cooled meth recycle	meth to rctr
Stream Number	13	14	15
Vapour Fraction	0	0	0
Temperature [C]	36	76	76
Pressure [kPa]	790	870	910
Molar Flow [kgmole/h]	1576	650	325
Mass Flow [kg/h]	49823	19647	9823
Liquid Volume Flow [m ³ /h]	62	24	12
Heat Flow [kJ/h]	-377728593	-155889805	-77944197

Table 6: Stream table (6)

Name	meth to tower	DME out2	DME reflux
Stream Number	16	17	18
Vapour Fraction	0	0	0
Temperature [C]	76	37	37
Pressure [kPa]	910	820	860
Molar Flow [kgmole/h]	325	1253	632
Mass Flow [kg/h]	9823	57706	29090
Liquid Volume Flow [m ³ /h]	12	86	43
Heat Flow [kJ/h]	-77944197	-253341929	-127707274

Table 7: Stream table (7)

Name	DME product	meth to rctr	meth to tower
Stream Number	19	15	16
Vapour Fraction	0	0	0
Temperature [C]	37	76	76
Pressure [kPa]	860	910	910
Molar Flow [kgmole/h]	626	325	325
Mass Flow [kg/h]	28853	9823	9823
Liquid Volume Flow [m ³ /h]	43	12	12
Heat Flow [kJ/h]	-126668336	-77944197	-77944197

Table 8: Stream table (8)

Name	DME out2	DME reflux	DME product
Stream Number	17	18	19
Vapour Fraction	0	0	0
Temperature [C]	37	37	37
Pressure [kPa]	820	860	860
Molar Flow [kgmole/h]	1253	632	626
Mass Flow [kg/h]	57706	29090	28853
Liquid Volume Flow [m ³ /h]	86	43	43
Heat Flow [kJ/h]	-253341929	-127707274	-126668336

Table 9: Stream table (9)

Name	DME reflux 1	METH reflux	meth to rctr 2
Stream Number	20	21	22
Vapour Fraction	0	0	0
Temperature [C]	37	76	76
Pressure [kPa]	860	910	910
Molar Flow [kgmole/h]	626	325	325
Mass Flow [kg/h]	28853	9825	9823
Liquid Volume Flow [m ³ /h]	43	12	12
Heat Flow [kJ/h]	-126668336	-77952879	-77946818

Table 10: Stream table (10)

Name	Meth H ₂ O Pumped	D1 feed pumped	CMR2
Stream Number	23	24	25
Vapour Fraction	0	0	0
Temperature [C]	145	74	76
Pressure [kPa]	880	830	910
Molar Flow [kgmole/h]	955	1576	650
Mass Flow [kg/h]	21207	49824	19647
Liquid Volume Flow [m ³ /h]	24	66	24
Heat Flow [kJ/h]	-248742458	-377809637	-155888394

Table 11: Stream table (11)

Name	DME out3	WWT	normal op
Stream Number	26	27	28
Vapour Fraction	0	0	0
Temperature [C]	37	174	74
Pressure [kPa]	860	930	830
Molar Flow [kgmole/h]	1253	630	788
Mass Flow [kg/h]	57706	11385	24912
Liquid Volume Flow [m ³ /h]	86	11	33
Heat Flow [kJ/h]	-253336672	-172110884	-188904818

Table 12: Stream table (12)

Name	turn down
Stream Number	29
Vapour Fraction	0
Temperature [C]	74
Pressure [kPa]	830
Molar Flow [kgmole/h]	788
Mass Flow [kg/h]	24912
Liquid Volume Flow [m ³ /h]	33
Heat Flow [kJ/h]	-188904818

Process Description

The purpose of the design is to create a process that is capable of producing dimethyl ether (DME), an economically viable replacement for diesel fuel from methanol (MeOH) by using an acid catalyst.

To accomplish this design, a mixture of 99.5 mole percent methanol is fed into the process at a rate of 40,000 kg/h. This feed stream is mixed with a recycle stream from the second distillation column and then fed to a pump. This pump serves to increase the stream pressure by 100 psia to a total pressure of 115 psia, which allows for easier heating and condensation later in the process, and its outlet stream is fed to a heater. The heater vaporizes and increases the temperature of the stream to decrease the burden on the subsequent heat exchanger, which utilizes the outlet stream of the reactor to preheat the reactor's inlet stream to 250°C. After being heated to 250°C the stream is fed to the reactor. Once in the reactor the methanol is dehydrated using a gamma-alumina oxide catalyst ($\gamma\text{-Al}_2\text{O}_3$) and the process is allowed to reach equilibrium upon which it is discharged from the reactor. The reactor discharge is then fed to the heat exchanger as previously stated. After passing through the heat exchanger, the reactor outlet needs to be condensed and cooled further and is fed to a cooler which drops its temperature from 274°C to 74°C. Next, the stream is fed to a pump which raises its pressure by 5.8 psia to a total of 120 psia in order to move the fluid into the first distillation column.

The stream is split into two and is fed into the column at stages 4 and 9. The split serves to prevent weeping in the column during turn down by changing the feed location of the majority of the mixture. Column T-100 is operating with a top and bottoms pressure of 119 psia and 122 psia respectively. The vapor product leaving the column is mixture of DME and MeOH with mass fractions of 0.9995 and 0.0005 respectively. The vapor product is then fed to a cooler in order to condense it. Once the DME mixture has been condensed, it is pumped out and into two different streams of nearly equal flow rates, the first of which is a recycle stream, and the second is the outlet stream for the DME product. The bottoms product leaving the column is pumped to a second distillation column to separate excess MeOH from the water that was produced in the reactor.

Column T-101 operates with a top and bottoms pressure of 126 psia and 129 psia respectively. The vapor product has mass fractions of 0.8679 MeOH, 0.0926 water, and 0.0395 DME. After exiting the tower, the vapor stream is fed to a cooler to condense it. Once it has passed through the cooler the stream is fed to a pump to generate the pressure needed to separate

the stream into two streams and send them to their recycle points. One stream is sent back into the tower as reflux, and the other is recycled back to the beginning of the process where it is merged with the initial feed stream. The bottoms product has mass fractions of 0.9923 water and 0.0077 MeOH. This stream is pumped to a waste water disposal facility.

Energy Balance and Utility Requirements

Utility requirements for this plant include cooling water, high pressure steam, power, and catalyst. The necessary amount of cooling water was calculated based on the heat transfer in each cooler. With heat known, the mass flow rate could be found via Equation 1 once heat capacity and change in temperature were calculated. Temperature change was calculated based on a known inlet temperature and either the maximum allowable temperature of water at 115 degrees F or a temperature that allowed for sufficient heat transfer (this applies only to E-104). The heat capacity of water was assumed to be nearly constant and was calculated based on an equation found in the NIST database (1).

$$q = (\dot{m} * C_p * \Delta T) \quad \text{Equation 1}$$

Steam flow requirements were calculated in a similar manner. Once the heat transfer was known, the mass flow rate was determined by dividing q by the change in enthalpy of steam at its given temperature and pressure, as recorded in the stream tables by Moran et al (2). Power requirements were simply found by converting the brake horsepower into kilowatts. The $\gamma\text{-Al}_2\text{O}_5$ catalyst mass necessary for the process was determined via Equation 2, where the reaction rate was found in kinetic data described in the original problem statement. Once volume was known, the density of the catalyst was used to determine the weight of catalyst required. Last, the weight of catalyst was divided by its average lifespan to determine the amount needed per year. See table 32 for further information regarding the utility consumption values.

$$V=Fao * \int_0^X \frac{dx}{-ra} \quad \text{Equation 2}$$

Equipment List and Unit Descriptions

The equipment utilized in this design was sized in accordance with information from both literature, course notes, and data from an Aspen HYSYS simulation. This design required the use of six pumps, seven heat exchangers (including two kettle reboilers on the columns), two distillation columns, and one reactor.

Pumps

For all pumps used in this process, this team specified the pressure changes between inlet and outlet streams, and the flow rates were determined by mass balances conducted by Aspen HYSYS. Of the six pumps used in this design, five were employed for the purpose of moving liquid streams from one piece of equipment to the next. These pumps were designed to increase stream pressure by 5.8 psi, as this was judged to be sufficient for that purpose. P-100, however, was included in order to increase the pressure of the stream entering E-100 by 100.1 psi, so that throughout the process methanol, DME, water, or any mixture of the three would have low enough dew points such that they could be condensed without the use of refrigerants. Flow rates through and pressure increases across each pump were used in tandem with Figure 12-3 in the GPSA handbook (3) to determine that a single stage centrifugal pump was the best type to use for all pumps. Pump efficiencies were all found in or inferred from Figure 12-7 in the GPSA handbook (3). Pertinent equations used to size the pumps may be found below, and relevant data may be found in Table 13.

Table 13: Pump specifications

Pump No.	Q (gpm)	ΔP (psi)	Pump Efficiency	Bhp
100	275	100.1	0.6	26.74
101	104	5.8	0.45	0.78
102	292	5.8	0.6	1.65
103	107	5.8	0.45	0.81
104	377	5.8	0.7	1.82
105	50.0	5.8	0.45	0.38

$$Hyd\ hp = \frac{Q(gpm)*\Delta P (psi)}{1715} \quad Equation\ 3$$

$$Brake\ hp = \frac{Hyd\ hp}{\eta_p} \quad Equation\ 4$$

Heat Exchangers

A total of seven heat exchangers were deemed necessary to accomplish the synthesis and subsequent purification of DME. There is one kettle reboiler for each distillation column and five shell and tube heat exchangers. High-pressure steam ($P=160$ psia, $T_{sat}=363.6^{\circ}\text{F}$) (4) was used in both kettle reboilers and the E-100 heat exchanger. Cooling water was used in E-102, E-103, and E-104. E-101 was used to decrease the amount of steam needed in E-100. The general approach to calculating the area for each heat exchanger is as follows.

The heat loss or gain by each stream is first calculated via Equation 5, where mass flow rate and enthalpy changes are provided by Aspen HYSYS. For the reboilers, however, the heat duty from Aspen HYSYS was used instead of calculated.

$$q = (\dot{m} * \Delta H) \quad Equation\ 5$$

The overall heat transfer coefficient is then determined with Equation 6. The inner and outer tube diameters were all estimated to be 0.60 inches and 0.75 inches, respectively (5). Heat transfer and fouling resistance values were ascertained from Table 4.1.1 of the CRC Handbook of Thermal Engineering (6).

$$U_0 = [\left(\frac{d_o}{h_i * d_i} \right) + (R_{fi} * \frac{d_o}{d_i}) + \left(\frac{d_o * \ln\left(\frac{d_o}{d_i}\right)}{2 * K_w} \right) + R_{fo} + \left(\frac{1}{h_o} \right)]^{-1} \quad Equation\ 6$$

The inlet and outlet stream temperatures in Aspen HYSYS are then used to calculate the LMTD. It should be noted that outlet temperatures for steam and cooling water were estimated. The steam is assumed to impart heat from its condensation alone, so an outlet temperature slightly under its saturation temperature was assumed. For cooling water, an outlet temperature of 115°F was used so that biological growth in the cooling water would be avoided. Note that this is not true of E-104, where the outlet temperature was designated to be 86°F so that a sufficient temperature difference could be maintained in the heat exchanger.

$$LMTD = \frac{(T_{hi} - T_{co}) - (T_{ho} - T_{ci})}{\ln\left(\frac{T_{hi} - T_{co}}{T_{ho} - T_{ci}}\right)} \quad Equation\ 7$$

With q , U_0 , and LMTD known, the area of the heat exchanger was determined via

Equation 8. A value of 0.9 was assigned to the correction factor F based on heuristics (4). All calculations and constants used for each heat exchanger can be found in the specification sheets below.

$$A_0 = \frac{q}{U_0 * F * LMTD} \quad \text{Equation 8}$$

Distillation columns

Column T-100

The column is fed a stream composed of 39.91 mole% DME, 17.1 mole% MeOH, and 42.98 mole% water. The feed is flowing at a rate of roughly 10000 barrels per day with a temperature of 73.7°C and a pressure of 120.4 psia. Before entering the column the feed is split between two streams. The stream for normal operation of the tower enters at stage 4, and the stream that is used during turn down operation of the tower enters at stage 9. This, along with the use of bubble cap trays as the bottom two trays of the column, is implemented to prevent the tower from weeping when it is operating at less than its full capacity.

A bottom operating pressure of 121.8 psia and a top operating pressure of 118.9 psia were selected for the column. The pressure difference between these two levels is the driving force for the vapor traveling in the column.

Internally the column is designed to have 10 trays, but due to a tray efficiency of 0.8, 13 actual trays are necessary. For this column, 11 of these are sieve trays, and 2 are bubble trays. The pressure drop between trays ranges between 0.3 psia and 0.4 psia.

Trays were spaced at 2 ft. Using this and the number of trays a height of 37.1 ft was calculated using the following equation.

$$\text{Column Height (ft)} = (\# \text{ of trays})(\text{tray spacing}) + 7 + (1 + \text{tray spacing}) \quad \text{Equation 9}$$

The reason for adding 7 feet and (1 + tray spacing) feet to the column height is to account for the extra space needed at the bottom and top of the column.

A column diameter of 5.09 ft allowed for the process to achieve the desired separation. The tray diameter is determined by the column diameter hence the tower diameter has to be designed around the desired surface area for liquid flow.

Carbon steel was selected as the material to construct the tower. There were no concerns about corosions with the materials flowing through it so carbon steel was selected because it was the cheapest material.

In order to cost and size the tower based on actual trays and not theoretical trays a tray efficiency (ϵ) of 80% was assumed (4). Actual trays can be calculated from theoretical trays based on the equation below.

$$\text{Number of actual trays} = \frac{\text{Number of theoretical trays}}{\epsilon} \quad \text{Equation 10}$$

The columns internals were altered until there was no potential issues with weeping, resulting in the choice of stages 4 and 9 as the inlets to the column.

The top product consisted of 0.9995 mass% DME and 0.0005 mass% MeOH flowing at roughly 13000 barrels per day. This stream was split between the final product stream and a reflux stream. The reflux stream was fed back into the tower at a rate of 6500 barrels per day. The Reflux ratio was calculated to be 1.

The bottoms product of the column was a mixture of 0.0179 mass% DME, 0.4066 mass% MeOH, and 0.5755 mass% water flowing to the reboiler at roughly 7600 barrels per day. The stream is split and 4050 barrels per day is returned to the tower as boilup. The other stream is pumped to column T-101 at a rate of 3550 barrels per day. The boil up ratio was calculated to be 0.84.

Column T-101

The column is fed the bottoms outlet stream from T-100. The composition of the stream is 0.0086 mole% DME, 0.2819 mole% MeOH, and 0.7095 mole% water. The feed is flowing at approximately 3500 barrels per day with a temperature of 145.4°C and a pressure of 127.6 psia. A bottom operating pressure of 129.1 psia and a top operating pressure of 126.2 psia were selected for the column. The fluids in column T-101 undergo the same process as the fluids in column T-100.

Internally the column has 13 actual trays all of which are sieve trays. The pressure drop between the trays ranges between 0.3 psia and 0.4 psia.

Trays were spaced at 2 feet. Using this and the number of trays a height of 37.1 feet was calculated using the same equation as that used for T-100.

A column diameter of 4.27 ft allowed for the column to achieve the desired separation. The materials in column T-101 pose no corrosion issues so carbon steel was selected as the material of construction. Carbon steel was selected because of the minimal risk of corrosion and the fact that it is the cheapest material. Just as in T-100, a tray efficiency of 0.8 was used.

The top products consists of a stream of 0.0395 mass% DME, 0.8679 mass% MeOH, and 0.0926 mass% water flowing at roughly 3700 barrels per day. This stream is split between a reflux stream and a recycle stream. The reflux stream is sent back to the tower at a rate of 1850 barrels per day. The reflux ration was calculated to be 1.

The bottoms product consists of a stream of 0.0077 mass% MeOH, and 0.9923 mass% water flowing to the reboiler to at a rate of 3500 barrels per day. The stream is split between the boilup and the waste water product which are flowing at 1780 and 1720 barrels per day respectively. The boilup ratio was calculated and found to be 1.01.

Reactor

The reactor feed stream consists of 0.0053 mole% DME, 0.9586 mole% MeOH, and 0.036 mole% water at a flow rate of 9400 barrels per day. The stream is entering the reactor at a temperature of 250°C and a pressure of 114.6 psia. The stream then undergoes a reaction with the γ -Al₂O₃ catalyst in the reactor and using the following equation the conversion rate of the reaction was determined (7).

$$FA = FA_0 (1 - X) \quad \text{equation 11}$$

The rate of conversion was found to be 82.2%. Then using polymath the rate of reaction was found (figure) to be 44.49 kmol/m³*h. This rate of reaction and the percent conversion were then used to find the volume of catalyst that would be needed for the reactor using equation 2.

After performing the calculations it was found that the volume of catalyst needed was 27.8 m³. Using the density of the catalyst the mass was found to be 24520 kg. Once the necessary mass of catalyst was found the void fraction of 0.4 and the following equation were used to calculate the volume of the reactor.

$$\text{Volume of reactor} = (\text{mass}/\text{density}) + ((\text{mass}/\text{density})*\text{void fraction}) \quad \text{equation 12}$$

The calculations showed that the reactor needed to be a volume of 40 m³.

After passing through the reactor the fluid stream is at a temperature of 367°C and a pressure of 114.6 psia. The composition of the outlet stream is 0.3991 mol% DME, 0.171 mol% MeOH, and 0.4298 mol% water.

Specification Sheets

Table 14: T-100 Specification Sheet

Distillation Column							
Identification:	Item	Distillation Column		Date:	<i>15 March, 2018</i>		
	Item No.	T-100		By:	CP, QP, CF		
	No. required	1					
Function:	To separate DME from water and methanol						
Operation:	Continuous						
Materials:	28	29	18	6	12		
Flow (lb/hr)	54920	54920	64130	46750	12720		
DME mole%	0.3991	0.3991	0.9993	0.0086	0.9993		
Methanol mole%	0.171	0.171	0.0007	0.2819	0.0007		
Water mole%	0.4298	0.4298	0	0.7095	0		
Design Data:	Number of trays (actual): 13			Reflux ratio: 1			
	Pressure: 171 psi			Tray spacing: 2 ft			
	Functional height: 37 ft			Skirt height: 1 inch			
	Material of Construction: Carbon Steel						
	Diameter: 5.08 ft						
	Tray Efficiency: 0.80						
	Feed Stage: stage 4 for normal op						
	Reflux Stage: 1						
Utilities:	N/A						
Controls	Pressure control at top of column, level control at the bottom						

Table 15: T-101 Specification Sheet

Distillation Column							
Identification:	Item	Distillation Column		Date:	<i>15 March, 2018</i>		
	Item No.	T-101		By:	CP, QP, CF		
	No. required	1					
Function:	To separate water from methanol						
Operation:	Continuous						
Materials:	21	6	7	8			
Flow (lb/hr)	21660	46750	43310	25100			
DME mole%	0.0264	0.0086	0.0259	0			
Methanol mole%	0.8177	0.2819	0.8187	0.0043			
Water mole%	0.1558	0.7095	0.1554	0.9957			
Design Data:	Number of trays (actual): 13			Reflux ratio: 1			
	Pressure: 179 psi			Tray spacing: 2 ft			
	Functional height: 37 ft						
	Material of Construction: Carbon Steel						
	Diameter: 4.26 ft						
	Tray Efficiency: 0.80						
	Feed Stage: stage 6						
	Reflux Stage: 1						
Utilities:	N/A						
Controls	Pressure control at top of column, level control at the bottom						

Table 16: GBR-100 Specification Sheet

Reactor				
Identification:	Item	Reactor	Date:	15 March, 2018
	Item No.	GBR-100	By:	CP, QP, CF
	No. required	1		
Function:	To boil bottoms product back into T-101			
Operation:	Continuous			
Materials:	3	4		
Flow (gpm)	275	292		
DME mole%	0.0053	0.3991		
Methanol mole%	0.9586	0.171		
Water mole%	0.03602	0.4298		
Design Data:	Reactor Volume: 40 m^3			
	Percent conversion: 82.2%			
	Inlet temperature: 250°C			
	Outlet temperature: 367°C			
	Pressure: 114.6 psia			
Utilities:	53943 lb of catalyst			
Controls	pressure control at the outlet			

Table 17: P-100 Specification Sheet

Pump					
Identification:	Item	Pump		Date:	15 March, 2018
	Item No.	P-100		By:	CP, QP, CF
	No. required	2			
Function:	To increase the pressure of the methanol feed stream				
Operation:	Continuous				
Materials:		9	13		
Flow (gpm)	274.9	274.9	274.9		
DME mole%		0.005338	0.005338		
Methanol mole%		0.9586	0.9586		
Water mole%		0.036	0.036		
Design Data:	Pump efficiency: 0.6				
	Pressure increase: 100.1 psi				
	Flow rate: 274.9 gpm				
	Material of Construction: Carbon steel				
	Hydraulic horsepower: 16.0				
	Brake horsepower: 26.7				
Utilities:	19.9 kW				
Controls	None directly associated with this piece of equipment				

Table 18: P-101 Specification Sheet

Pump					
Identification:	Item	Pump		Date:	15 March, 2018
	Item No.	P-101		By:	CP, QP, CF
	No. required	2			
Function:	To move the distillation feed to the column T-101				
Operation:	Continuous				
Materials:		6	23		
Flow (gpm)	104.0	104.0	104.0		
DME mole%		0.0086	0.0086		
Methanol mole%		0.2819	0.2819		
Water mole%		0.795	0.795		
Design Data:	Pump efficiency: 0.45				
	Pressure increase: 5.8 psi				
	Flow rate: 104.0 gpm				
	Material of Construction: Carbon steel				
	Hydraulic horsepower: 0.352				
	Brake horsepower: 0.782				
Utilities:	0.583 kW				
Controls	None directly associated with this piece of equipment				

Table 19: P-102 Specification Sheet

Pump					
Identification:	Item	Pump		Date:	15 March, 2018
	Item No.	P-102		By:	CP, QP, CF
	No. required	2			
Function:	To move the distillation feed to column T-100				
Operation:	Continuous				
Materials:		11	24		
Flow (gpm)	292.0	292.0	292.0		
DME mole%		0.3991	0.3991		
Methanol mole%		0.171	0.171		
Water mole%		0.4298	0.4298		
Design Data:	Pump efficiency: 0.6				
	Pressure increase: 5.8 psi				
	Flow rate: 292.2 gpm				
	Material of Construction: Carbon steel				
	Hydraulic horsepower: 0.987				
	Brake horsepower: 1.65				
Utilities:	1.23 kW				
Controls	None directly associated with this piece of equipment				

Table 20: P-103 Specification Sheet

Pump					
Identification:	Item	Pump		Date:	15 March, 2018
	Item No.	P-103		By:	CP, QP, CF
	No. required	2			
Function:	To move the methanol reflux stream to T-101 and recycle stream P-100				
Operation:	Continuous				
Materials:		14	25		
Flow (gpm)	107.5	107.5	107.5		
DME mole%		0.02589	0.02589		
Methanol mole%		0.8187	1.8187		
Water mole%		0.1554	0.1554		
Design Data:	Pump efficiency: 0.45				
	Pressure increase: 5.8 psi				
	Flow rate: 107.5 gpm				
	Material of Construction: Carbon steel				
	Hydraulic horsepower: 0.363				
	Brake horsepower: 0.808				
Utilities:	0.602 kW				
Controls	None directly associated with this piece of equipment				

Table 21: P-104 Specification Sheet

Pump					
Identification:	Item	Pump		Date:	15 March, 2018
	Item No.	P-104		By:	CP, QP, CF
	No. required	2			
Function:	To move DME reflux stream to T-100 and product stream to storage				
Operation:	Continuous				
Materials:		17	26		
Flow (gpm)	377.0	377.0	377.0		
DME mole%		0.9993	0.9993		
Methanol mole%		0.0007	1.0007		
Water mole%		0.000003421	0.000003421		
Design Data:	Pump efficiency: 0.7				
	Pressure increase: 5.8 psi				
	Flow rate: 377.0 gpm				
	Material of Construction: Carbon steel				
	Hydraulic horsepower: 1.27				
	Brake horsepower: 1.82				
Utilities:	1.36 kW				
Controls	None directly associated with this piece of equipment				

Table 22: E-100 Specification Sheet

Heat Exchanger						
Identification:	Item	Heater	Date:	15 March, 2018		
	Item No.	E-100	By:	CP, QP, CF		
	No. required	1				
Function:	To preheat methanol feed to E-101					
Operation:	Continuous					
Materials:	13	2				
Flow (gpm)	275	275				
DME mole%	0.0053	0.0053				
Methanol mole%	0.9586	0.9586				
Water mole%	0.036	0.036				
Design Data:	Area: 1917 ft ²		q: 63225288 Btu/h			
	LMDT: 290.86 R		Inner diameter: 0.0625 ft			
	hi: 352 Btu/ft ² *h*F		Outer diameter: 0.078 ft			
	ho: 352 Btu/ft ² *h*F		Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu					
	Rfo: 0.000568 ft ² *h*F/Btu					
	kw: 31 Btu/ft*h*F					
	Overall heat transfer coefficient: 125.91 Btu/(ft ² *°F*h)					
Utilities:	1427 lb/m high pressure steam					
Controls	utilities stream is controlled by the outlet temperature					

Table 23: E-101 Specification Sheet

Heat Exchanger							
Identification:	Item	Heat Exchanger		Date:	15 March, 2018		
	Item No.	E-101		By:	CP, QP, CF		
	No. required	1					
Function:	To vaporize methanol feed to GBR-100						
Operation:	Continuous						
Materials:	2	3	4	5			
Flow (gpm)	275	275	292	292			
DME mole%	0.0053	0.0053	0.3991	0.3991			
Methanol mole%	0.9586	0.9586	0.171	0.171			
Water mole%	0.036	0.036	0.4298	0.4298			
Design Data:	Area: 2050 ft ²			q: 9585312 Btu/h			
	LMDT: 229.17 R			Inner diameter: 0.0625 ft			
	hi: 53 Btu/ft ² *h*F			Outer diameter: 0.078 ft			
	ho: 53 Btu/ft ² *h*F			Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu						
	Rfo: 0.000568 ft ² *h*F/Btu						
	kw: 31 Btu/ft*h*F						
	Overall heat transfer coefficient: 22.72 Btu/(ft ² *°F*h)						
Utilities:	N/A						
Controls	N/A						

Table 24: E-102 Specification Sheet

Heat Exchanger						
Identification:	Item	Cooler	Date:	15 March, 2018		
	Item No.	E-102	By:	CP, QP, CF		
	No. required	1				
Function:	To condense feed to P-102					
Operation:	Continuous					
Materials:	5	11				
Flow (gpm)	292	292				
DME mole%	0.3991	0.3991				
Methanol mole%	0.171	0.171				
Water mole%	0.4298	0.4298				
Design Data:	Area: 3000 ft ²		q: 63319725 Btu/h			
	LMDT: 186.18 R		Inner diameter: 0.0625 ft			
	hi: 352 Btu/ft ² *h*F		Outer diameter: 0.078 ft			
	ho: 352 Btu/ft ² *h*F		Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu					
	Rfo: 0.000568 ft ² *h*F/Btu					
	kw: 31 Btu/ft*h*F					
	Overall heat transfer coefficient: 125.91 Btu/(ft ² *°F*h)					
Utilities:	3597 gpm cooling water					
Controls	utilities stream is controlled by the outlet temperature					

Table 25: E-104 Specification Sheet

Heat Exchanger						
Identification:	Item	Cooler	Date:	<i>15 March, 2018</i>		
	Item No.	E-104	By:	CP, QP, CF		
	No. required	1				
Function:	To condense feed to P-104					
Operation:	Continuous					
Materials:	12	17				
Flow (gpm)	379	379				
DME mole%	0.9993	0.9993				
Methanol mole%	0.0007	0.0007				
Water mole%	0	0				
Design Data:	Area: 12106 ft ²		q: 22370768 Btu/h			
	LMDT: 16.3 R		Inner diameter: 0.0625 ft			
	hi: 352 Btu/ft ² *h*F		Outer diameter: 0.078 ft			
	ho: 352 Btu/ft ² *h*F		Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu					
	Rfo: 0.000568 ft ² *h*F/Btu					
	kw: 31 Btu/ft*h*F					
	Overall heat transfer coefficient: 125.91 Btu/(ft ² *°F*h)					
Utilities:	7416 gpm cooling water					
Controls	utilities stream is controlled by the outlet temperature					

Table 26: E-103 Specification Sheet

Heat Exchanger						
Identification:	Item	Cooler	Date:	15 March, 2018		
	Item No.	E-103	By:	CP, QP, CF		
	No. required	1				
Function:	To condense feed to P-103					
Operation:	Continuous					
Materials:	7	14				
Flow (gpm)	108	108				
DME mole%	0.0259	0.0259				
Methanol mole%	0.8187	0.8187				
Water mole%	0.1554	0.1554				
Design Data:	Area: 1689 ft ²		q: 23410158 Btu/h			
	LMDT: 122.27 R		Inner diameter: 0.0625 ft			
	hi: 352 Btu/ft ² *h*F		Outer diameter: 0.078 ft			
	ho: 352 Btu/ft ² *h*F		Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu					
	Rfo: 0.000568 ft ² *h*F/Btu					
	kw: 31 Btu/ft*h*F					
	Overall heat transfer coefficient: 125.91 Btu/(ft ² *°F*h)					
Utilities:	1325 gpm cooling water					
Controls	utilities stream is controlled by the outlet temperature					

Table 27: R-100 Specification Sheet

Heat Exchanger							
Identification:	Item	Kettle Reboiler		Date:	<i>15 March, 2018</i>		
	Item No.	R-100		By:	CP, QP, CF		
	No. required	1					
Function:	To boil bottoms product back into T-100						
Operation:	Continuous						
Materials:	6	to reboiler	boilup				
Flow (gpm)	104	222.3	118.3				
DME mole%	0.0086	0.0328	0.0618				
Methanol mole%	0.2819	0.4094	0.5619				
Water mole%	0.7095	0.5578	0.3763				
Design Data:	Area: 1126 ft ²			q: 25656344 Btu/h			
	LMDT: 201.01 R			Inner diameter: 0.0625 ft			
	hi: 352 Btu/ft ² *h*F			Outer diameter: 0.078 ft			
	ho:352 Btu/ft ² *h*F			Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu						
	Rfo: 0.000568 ft ² *h*F/Btu						
	kw: 31 Btu/ft*h*F						
	Overall heat transfer coefficient: 125.91 Btu/(ft ² *°F*h)						
Utilities:	579.1 lb/m high pressure steam						
Controls	N/A						

Table 28: R-101 Specification Sheet

Heat Exchanger							
Identification:	Item	Kettle Reboiler		Date:	15 March, 2018		
	Item No.	R-101		By:	CP, QP, CF		
	No. required	1					
Function:	To boil bottoms product back into T-101						
Operation:	Continuous						
Materials:	8	to reboiler	boilup				
Flow (gpm)	50.3	102.4	52.1				
DME mole%	0	0	0				
Methanol mole%	0.0043	0.0132	0.0219				
Water mole%	0.9957	0.9868	0.9781				
Design Data:	Area: 1382 ft ²			q: 22168522 Btu/h			
	LMDT: 141.47 R			Inner diameter: 0.0625 ft			
	hi: 352 Btu/ft ² *h*F			Outer diameter: 0.078 ft			
	ho: 352 Btu/ft ² *h*F			Correction factor: 0.9			
	Rfi: 0.000568 ft ² *h*F/Btu						
	Rfo: 0.000568 ft ² *h*F/Btu						
	kw: 31 Btu/ft*h*F						
	Overall heat transfer coefficient: 125.91 Btu/(ft ² *°F*h)						
Utilities:	500.3 lb/m high pressure steam						
Controls	N/A						

Equipment Cost Summary

The cost of each piece of equipment was estimated via methods provided by Turton et al (4). The first step in this method for all equipment was the calculation of the “vanilla” purchase cost. This value is determined by two parameters. One is a set of constant values specific to each type of equipment, and the other is a dimension of the specific piece of equipment. For heat exchangers, area is the dimension used. Brake horsepower is used for pumps and volume is used for both distillation columns and reactors. Next, factors such as construction materials and design pressure (calculated by adding 50 psi to the operating pressure) were taken into account, which resulted in the calculation of a more accurate purchase cost.

Column cost estimates

Both columns were costed as vertical vessels. The diameter values were taken from Aspen HYSYS, and the vertical height was calculated by multiplying the number of trays by the tray spacing and adding 11 feet to account for the space above the first stage and below the last stage. The volume was then solved for, which enabled the team to synthesize a vanilla cost for the item. Carbon steel was selected for the material of construction, which meant that no additional cost was added. The design pressures were 171 psi and 179 psi in T-100 and T-101, respectively. The price of the trays was also accounted for in the column price. 24 of the 26 trays were costed as sieve trays, while the last two in T-100 were costed as bubble cap trays. Both were costed with carbon steel as the material of construction. The estimated costs associated with purchasing the equipment needed for this design can be found in Table 30 below.

Heat exchanger cost estimates

All heat exchangers were costed based on the surface area required for heat transfer. Each was designed to be constructed out of carbon steel, and the pressures of the inlet streams were used to calculate design pressure.

Pump cost estimates

All pump cost estimates were calculated based on the brake horsepower (in kilowatts) required by the pump. All pumps were constructed from carbon steel, and the pressure of the outlet

stream was used to calculate the required design pressure. Note that all pumps were spared since they are relatively cheap and must be available in order for the system to function. Thus, the purchased price value for each pump in Table 29 represents the cost of two such pumps.

Reactor cost estimate

As described in the reaction section of Equipment List and Unit Descriptions, the kinetics of the methanol reaction with the zeolite catalyst were utilized to determine the amount of catalyst required for the desired production of DME. This amount of catalyst was then used to estimate the volume of the reactor. Carbon steel was once again chosen as the material of design, and the pressure inside the reactor was used to calculate the design pressure.

Table 29: Purchase, bare module, and total module costs for all required equipment.

Item	Number used	Purchased Cost (C_p)
Pump 100	2	\$ 16,000
Pump 101	2	\$ 8,000
Pump 102	2	\$ 8,000
Pump 103	2	\$ 8,000
Pump 104	2	\$ 8,000
Pump 105	2	\$ 8,000
E-101	1	\$ 36,000
Cooler 102	1	\$ 46,000
Cooler 103	1	\$ 33,000
Cooler 104	1	\$ 167,000
Heater 100	1	\$ 36,000
Reboiler (T-100)	1	\$ 27,000
Reboiler (T-101)	1	\$ 30,000
Dist. Tower 1	1	\$ 43,000
Dist. Tower 2	1	\$ 30,000
Reactor	1	\$ 33,000
Trays (sieve)	24	\$ 3,000
Trays (bubble cap)	2	\$ 1,000
Total		\$ 535,000
Escalated Total		\$ 764,000

Fixed-Capital Investment Summary

Once the purchased cost of each piece of equipment was ascertained, the costs associated with installing the equipment were calculated. This was done via Equation 9 using B values gathered from Table A.4 created by Turton et al (4). Total module cost was also determined to account for contingencies (15% of bare module cost) and fees (3% of bare module cost), as shown by Equation 10. Values for calculated bare and total module costs can be found in Table 30.

$$C_{BM} = C_p^0 * (B_1 + (B_2 * F_m * F_p)) \quad \text{Equation 9}$$

$$C_{TM} = C_{BM} + (0.15 * C_{BM}) + (0.03 * C_{BM}) \quad \text{Equation 10}$$

Table 30: Purchase, bare module, and total module costs for all required equipment (2)

Item	Bare Module Cost (C _{BM})	Total Module Cost (C _{TM})
Pump 100	\$ 42,000	\$ 49,000
Pump 101	\$ 19,000	\$ 23,000
Pump 102	\$ 20,000	\$ 23,000
Pump 103	\$ 19,000	\$ 23,000
Pump 104	\$ 20,000	\$ 24,000
Pump 105	\$ 20,000	\$ 24,000
E-101	\$ 117,000	\$ 138,000
Cooler 102	\$ 150,000	\$ 177,000
Cooler 103	\$ 106,000	\$ 126,000
Cooler 104	\$ 537,000	\$ 633,000
Heater 100	\$ 114,000	\$ 135,000
Reboiler (T-100)	\$ 87,000	\$ 103,000
Reboiler (T-101)	\$ 96,000	\$ 113,000
Dist. Tower 1	\$ 121,000	\$ 142,000
Dist. Tower 2	\$ 88,000	\$ 104,000
Reactor	\$ 131,000	\$ 155,000
Trays (sieve)	\$ 3,000	\$ 3,000
Trays (bubble cap)	\$ 1,000	\$ 1,000
Total	\$ 1,688,000	\$ 1,992,000
Escalated Total	\$ 2,411,000	\$ 2,845,000

Controls System

A basic controls strategy was devised to better ensure our purity requirements were met, and that the process was being conducted in a safe manner. The controls system begins with a feed flow sensor that adjusts the inlet flowrate for the turndown flow stream entering T-100. This prevents the trays in T-100 from weeping when the tower is operating at less than full capacity. Following the feed flow rate sensor is a valve which is controlled by the outlet temperature of the stream after it passes through E-100 and E-101. Altering this flow rate after it has been merged with the recycle streams allows for the stream to achieve its desired temperature before entering GBR-100. The flow out of GBR-100 is controlled by the pressure inside the reactor, and as the pressure changes the flow rate of the outlet stream is adjusted to a rate that keeps the reactor operating safely. After the stream leaves the reactor and passes through the heat exchanger it enters the cooler in order to be condensed. An outlet temperature sensor has been placed on the cooler that controls the flow of cooling water through the reactor to ensure that the stream is fully condensed before it enters the pump going to T-100. T-100 has control systems at both of its outlet points. The columns overhead pressure is used to control the overhead flow rate leaving the column, and the level in the reboiler is used to control the bottoms flowrate out of the column. The columns overhead vapor stream then passes through E-104 where a temperature sensor is used to control the flow rate of cooling water making sure that the stream fully condenses. After passing through the pump the stream is then sent to either the final product outlet stream or T-100 reflux stream. The split is determined by a ratio control loop. The column's bottoms flow is pumped to T-101. T-101 is controlled in the same manner as T-100. The waste water outlet flow rate is controlled by monitoring the liquid level in the reboiler, and the columns overhead flowrate is controlled by the overhead pressure. The overhead flowrate then passes through E-103 where a temperature sensor is used to control the flow rate of cooling water to ensure that the stream fully condenses. After passing through the subsequent pump the stream is split between the columns reflux stream and the processes methanol recycle stream. In the same manner as column T-100 the split is determined by a ratio control loop.

The process also has concentration indicators installed at the top and bottom of both towers to ensure that the desired purities are being met.

Environment, Health, and Safety

Safety

A safe, healthy work environment is a basic requirement for any company. One way to ensure this environment is maintained is by following the rules and regulations laid out by the Occupational Health and Safety Administration (8). An essential part of guaranteeing the success of this process is causing all employees to receive the proper training and education they need to work safely.

While employers are responsible for providing a safe work environment, employees must help to maintain and positively contribute to this environment. Avoiding accidents can be accomplished by ensuring that the employees are well trained, and are not taking any egregious risks in their work due to incompetence or ignorance. Workers also need to maintain a healthy awareness of their surroundings, so as to be able to notice anything that may become a safety concern before it can do so. The ability to properly respond to these concerns is also necessary. Employees must be able to quickly and efficiently execute the training they received in order to respond to these issues. They also need to be able to easily locate any equipment or carry out any contingency plans. In this section of the report dangers specific to the process of producing dimethyl ether through the dehydration of methanol will be documented. More information about these chemicals can be found on the material safety data sheets provided by the company.

There are two areas that need to be addressed involving the process environment. The first area is that a closed system needs to be maintained for the process. Any leaks could cause delays in production and endanger workers. Throughout the majority of the process the mixture is maintained in a liquid state. If one is exposed to dimethyl ether in its liquid form they can quickly develop frostbite because the DME will quickly vaporize and pull the heat from the body parts in contact with it (9). The second area that needs to be addressed is the ventilation of the system. Dimethyl ether can displace air leading to suffocation, and methanol is corrosive to the respiratory tract (9,10). Both of these are dire situations for employees that can be prevented or mitigated through proper ventilation of the process environment.

Caution is also necessary during the execution of this process to ensure that the pressure and temperature levels throughout the system do not exceed acceptable bounds. The reaction that is occurring in the reactor is an exothermic reaction. If this reaction is not properly monitored

there is a danger that it could become a runaway reaction, and cause catastrophic damage. Therefore, the reactor has a few safety considerations that need to be addressed. A cooling jacket needs to be placed around the reactor to ensure that the reactors temperature does not exceed its safe operating limits. A relief valve also needs to be included in the design of the reactor. This valve will serve as a failsafe should the cooling jacket fail to control the reaction. The relief valve will allow the reactor contents to flow into a safe outlet to prevent pressure build up, or top rapidly drop the temperature in the reactor if necessary. For reasons such as this the control systems need to be properly monitored. Further, any panel alarms need to be responded to in a timely fashion. Both methanol and dimethyl ether are classified as highly flammable and explosive materials by the National Institute for Occupational Safety and Health (8,9). In order to prevent them from causing fires in the plants ignition sources need to be kept away from the process area. However, should they be ignited then steps need to be taken to ensure workers safety and minimize damage to the plant. The plant should be evacuated. Firefighting personnel should also be alerted to the fact that methanol should not be extinguished using a water jet. Using a dry chemical or carbon dioxide to extinguish the fire is necessary. Neither of these methods will react negatively with any dimethyl ether in the fire. To exercise caution all fires in the plant should be doused under the assumption that there is some methanol in the fires fuel.

Health

As stated in the safety section methanol can be corrosive to the respiratory tract, and poses other health risk upon exposure. Any employee exposed to methanol fumes should get a physical to ensure that no lasting damage was imparted to their lungs.

Environment

Employees need to be aware of any spill or leaks of the materials used in this process. They cannot be allowed to contaminate the environment surrounding the plant. Spills should be handled by approaching them from upwind to avoid contact with any vapors produced. Once in proximity of the spill it should be absorbed using proper materials and then disposed of safely.

This process uses a number of coolers. The cooling water system used by this system needs to be properly cared for through regular maintenance. This regular maintenance can prevent corrosion, fouling, and microbial growth. Corrosion and fouling can be mediated by adding certain

chemicals to the water. Frequent testing can also identify microbial growth in the water before it becomes a major problem. Microbial growth can promote fouling in the cooling water system, and it can also facilitate the spreading of disease within the plant. Legionella can grow in cooling water and if left unchecked can cause an outbreak of Legionnaires' disease amongst the employees (11). Prevent the spread of such diseases is a vital part of the safe operation of a plant.

The Clean Water Act laid out specifications for cooling water intake structures which are regulated by the EPA. To prevent wildlife from being pulled into the system screens had to be placed at the systems inlet. Even though these screens can prevent wildlife from being pulled in it can still be trapped against these screens, causing harm to them and to the process. These problems can be prevented by regularly checking the inlets for obstructions. Doing this can help minimize the effect the plants cooling water inlets have on the environment (12). However, the plants cooling water outlets can also have an adverse effect on the area surrounding the plant. The chemicals and heat that get added to the water as it travels through the plant can place undue stress on the environment if they are released without any treatment. In order to prevent the cooling water from negatively impacting the environment, as much of it as possible is recycled. The amount that cannot be recycled is treated before it is safely disposed.

Economic Analysis

Estimation of Operating Expenses and Revenue

The primary costs of operating this plant are those of purchasing utilities and raw materials. The only raw materials needed in this process are methanol and lubricant. The cost of purchasing and shipping methanol is given by Methanex, and flow rate data specified in Aspen HYSYS is used to determine the annual cost. The lubricant cost was provided in the project statement, and it has the same shipping cost as that of methanol. Note that all yearly amounts account for a service factor of 0.95. The calculations associated with the purchase and shipping of methanol and lubricant can be found in Table 31.

Table 31: Data and costs of purchasing methanol and lubricant

Methanol	Purchase price	1.49	\$/gal
	Shipping price	0.02	\$/gal
	Flow rate	7,584	barrel/day
	Yearly amount	110,449,584	gal/year
	Cost	\$166,779,000	\$/year
Lubricant	Purchase price	1.65	\$/lb
	Shipping price	0.02	\$/gal
	Concentration	900	ppm
	DME flow	60,430	lb/hr
	Lubricant flow rate	54.41	lb/hr
	specific gravity	0.898	
	density	56.0	lb/ft ³
	Volume flow rate	7.26	gal/hr
	Yearly amount	452,800	lb/yr
	Yearly amount	60,443	gal/yr
	Cost	\$748,000	\$/year

Utility requirements, addressed in the Energy Balance and Utility Requirements section, were also costed to account for operating costs of the plant. Each pump's power requirement was added together, multiplied by the number of hours in a day, the number of days in a year, and the

service factor (0.95) to calculate the number of kilowatt hours needed per year. This value was multiplied by a cost of \$0.07/kilowatt hour to determine the total cost of power for the process per year. For this design, 199,637 kilowatt hours were required, which results in an annual expense of \$1,618,000. The catalyst was also treated as a utility. Its cost was estimated by multiplying the weight required for the reactor by the price per unit weight, and then dividing by the average lifespan of the catalyst (in this case 10.5 months). Steam mass flow rates in the kettle reboilers and E-100 were converted to mass flow per year, and multiplied by a known cost of \$29.97/1000kg (4). Total amounts of required cooling water were calculated, and the units were converted to gallons per year. The average cost of cooling water in the United States was found (13), from which the total price of cooling water could be ascertained. A summary of utility prices can be found in Table 32.

Table 32: Utility costs for each piece of equipment and utility type

Equipment	Catalyst (\$/yr)	Steam(kg/yr)	Electric (kW)	Cooling Water (gpm)	
Pump 100	-	-	19.94	-	
Pump 101	-	-	0.58	-	
Pump 102	-	-	1.23	-	
Pump 103	-	-	0.60	-	
Pump 104	-	-	1.36	-	
Pump 105	-	-	0.28	-	
Cooler 102	-	-	-	3,597	
Cooler 103	-	-	-	1,325	
Cooler 104	-	-	-	7,416	
Heater 100	-	324,000,000	-	-	
Reboiler (D1)	-	131,000,000	-	-	
Reboiler (D2)	-	114,000,000	-	-	
Reactor	305,000				
Totals		569,000,000	24.0	12,338	
Totals Yearly		569,000,000	200,000	6,160,000,000	
Cost \$/unit		\$29.97/1000kg	\$0.07/kWh	\$0.0002131/gal	Total Cost/Yr
Total Costs	\$	\$	\$	\$	\$
	305,000	17,053,000	1,618,000	1,313,000	20,289,000

Revenue values are determined by the price of the DME and the yearly production. Production rates are calculated by Aspen HYSYS, and converted to yearly amounts via unit conversions and multiplication by the service factor. Selling price of the DME was chosen such that it would be less than the price average price of diesel, in order to increase the attractiveness of purchasing DME for consumers with diesel engines. The breakeven cost of DME is \$1.88 per

gallon, and the average price of diesel in since 2007 is \$3.13 per gallon (14). This team selected an estimated selling price of \$2.40 per gallon, so as to produce a significant profit while still appealing to consumer's desire for cheaper commodities.

DCFROR Analysis

Discounted Flow Rate or Return analysis was used to assess the economic attractiveness of this project. Revenues, capital costs, operating costs, taxes, and depreciation were all taken into account for this analysis. For depreciation of equipment employed at the plant, a 15-year MACRS rate was used. This was done because the plant equipment is similar to that used in a natural gas plant, for which 15-year MACRS is utilized (15). Taxes were estimated to be 40% of taxable income. As designated in the business objectives of the problem statement, a hurdle rate of 8% was used, and the plant was given a 20 year plant life. As mentioned earlier, this plant will break even if the DME is sold at \$1.88 per gallon. A detailed cash flow table can be found in Appendix I.

Sensitivity Analysis

A sensitivity analysis was performed to determine if the project posed any threat of becoming economically undesirable should costs or revenues fluctuate. For this sensitivity analysis, revenue, capital costs, utility costs, and raw material costs were the parameters varied in order to ascertain the stability of the project. The results can be found in Figure 2 below. Note that the DCFROR dips below the hurdle rate of 8% when the revenue costs decrease or the raw material costs increase sufficiently. This would normally be of concern, yet in this case the economic risk is mitigated by the fact that a conservative selling price for DME was selected. It could very easily be sold for a price of \$2.75/gal, which would eliminate the risk of the DCFROR dipping below the hurdle rate.

Figure 2: Tornado chart for process NPV





Figure 3: Tornado chart for process DCFROR



Conclusions

This team was able to synthesize a design capable of producing dimethyl ether for use as a fuel alternative for diesel engines.

To accomplish this, the use of seven heat exchangers, six pumps, two distillation columns, and one reactor are required. Of the heat exchangers, two are kettle reboilers that, along with heater E-100, use high pressure steam to impart energy to the process streams. Three others were coolers that condensed process streams with cooling water, and the last utilized the outlet stream of the reactor to heat the reactors feed stream. All heat exchangers other than the kettle reboilers are modeled as shell and tube heat exchangers. It costs a total of \$18,300,000 per year to operate all of the heat exchangers due to steam and cooling water requirements, and it will cost 2,000,000 to manufacture and install them. All pumps are spared and designed as single stage centrifugal pumps, requiring in total 24.0 kW of power to operate, costing \$1,600,000 per year to operate. In all, the pumps will cost \$240,000 to manufacture and install. Most pumps were utilized to move material from one piece of equipment to another, although P-100 is implemented for the sake of increasing the operating pressure of the reaction, distillation, and heating processes. The distillation columns will have a capital cost and installing cost of \$350,000, and the 26 trays necessary for their operation will cost \$6,800. A packed bed reactor is also required to convert methanol to DME, which will cost \$220,000 to manufacture and install, and which will have to be filled with gamma alumina catalyst approximately every 10.5 months, costing around \$310,000 each year.

Recommendations

After conducting both a technical and an economic analysis it was determined that the project should be pursued.

While synthesizing this project there were a few areas this team believed should be addressed in order to make this design more accurate or complete. First, tray efficiencies were assumed to be 80% based on heuristics, but could have been tested. This would have allowed for a more conservative column estimate in achieving the desired purity. Modelling the heat exchangers throughout the system with more realistic pressure drops would lead to a more accurate cost estimate for the heat exchangers and pumps since the pumps would consequentially be required to impart a larger pressure change. Larger pumps could have been used in the process to better ensure that the fluids in the process are capable of reaching their intended destinations since energy losses and changes in elevation in the pipes were not accounted for in this design. It is also recommended that expert advice be sought to determine the best selling price of DME to ensure that DME is favored over diesel at the pump. Additionally, a more in depth control system could have been designed, and the control system could have been costed as well.

References

- (1) NIST Chemistry WebBook, SRD 69
<https://webbook.nist.gov/cgi/cbook.cgi?ID=C7732185&Mask=2#Thermo-Condensed>
(accessed Mar 14, 2018)
- (2) Moran, M. J.; Shapiro, H. N.; Boettner, D. D.; Bailey, M. B. *Fundamentals of Engineering Thermodynamics*, 8th ed.; John Wiley & Sons: Hoboken, NJ, 2014.
- (3) Association, G. P. S. (2004). GPSA Handbook. Tulsa, Oklahoma, Gas Processors Suppliers Association
- (4) Turton, R. *Analysis, synthesis, and design of chemical processes*, 4th ed. Upper Saddle River, NJ, Prentice Hall, 2017.
- (5) Kreith, F. *The CRC Handbook of Thermal Engineering*; Springer Berlin: Berlin, pp 449-498, 2013.
- (6) Thermal Conductivity of Metals
https://www.engineeringtoolbox.com/thermal-conductivity-metals-d_858.html (accessed March 14, 2018).
- (7) Rosen, A. Rosen Review Chemical Engineering Reactor Design.
http://sites.tufts.edu/andrewrosen/files/2013/09/reactor_design_guide1.pdf
- (8) Labor, U. D. o. (n.d.). "OSHA Laws & Regulations." Occupational Safety and Health Administration. from <https://www.osha.gov/law-reg.html>
- (9) Prevention, C. f. D. C. a. (2015, July 22, 2015). "The National Institute for Occupational Safety and Health (NIOSH)." International Chemical Safety Cards (ICSC) Dimethyl Ether. Retrieved 3/12/18, 2018, from <https://www.cdc.gov/niosh/ipcsneng/neng0454.html>
- (10) Prevention, C. f. D. C. a. (2015, July 22, 2015). "The National Institute for Occupational Safety and Health (NIOSH)." International Chemical Safety Cards (ICSC) Methanol. Retrieved 3/12/18, 2018, from <https://www.cdc.gov/niosh/ipcsneng/neng0057.html>

- (11) Labor, U. D. o. (n.d.). "What water systems in workplaces are potential sources of Legionnaires' disease bacteria (LBD)??" Legionnaires' Disease. Retrieved 11/26/17, 2017, from <https://www.osha.gov/dts/osta/otm/legionnaires/pdf/sectionii.pdf>
- (12) Agency, U. S. E. P. (2017). "Cooling Water Intakes." Retrieved 11/26/17, 2017, from <https://www.epa.gov/cooling-water-intakes>.
- (13) Inratec (2017). "Cooling Water Price History and Forecast." Retrieved 11/26/17, 2017, from <https://www.inratec.us/chemical-markets/cooling-water-price>.
- (14) US Energy Information Administration. "Weekly Retail Gasoline and Diesel Prices" https://www.eia.gov/dnav/pet/pet_pri_gnd_a_EPD2DXL0_pte_dpgal_m.htm (accessed March 15, 2018).
- (15) Stermole, F. J.; Stermole, J. M. (2014). Economic Evaluation and Investment Decision Methods, 14th Edition. Investment Evaluations Corporation, Lakewood, Colorado

Appendix I – Cash Flow Chart (2018-2039)

End of Year	11	12	13	14	15	16	17	18	19	20
Products (gal/year)	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010
x Sales Price (\$/gal)	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2
Sales Revenue	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000
+ Salvage value										
- Royalties (basis)										
Net Revenue	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000
- Raw Material Costs	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)
- Other Op Costs	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)
- Depreciation	\$ (142,485)	\$ (142,244)	\$ (142,485)	\$ (142,244)	\$ (142,485)	\$ (71,122)				
- Amortization										
- Depletion										
- Loss Forward										
- Writeoff										
Taxable Income	\$ 51,827,515	\$ 51,827,756	\$ 51,827,515	\$ 51,827,756	\$ 51,827,515	\$ 51,898,878	\$ 51,970,000	\$ 51,970,000	\$ 51,970,000	\$ 51,970,000
- Tax @ 40%	\$ 20,731,006	\$ 20,731,102	\$ 20,731,006	\$ 20,731,102	\$ 20,731,006	\$ 20,759,551	\$ 20,788,000	\$ 20,788,000	\$ 20,788,000	\$ 20,788,000
Net Income	\$ 31,096,509	\$ 31,096,654	\$ 31,096,509	\$ 31,096,654	\$ 31,096,509	\$ 31,139,327	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000
+ Depreciation	\$ 142,485	\$ 142,244	\$ 142,485	\$ 142,244	\$ 142,485	\$ 71,122	\$ -	\$ -	\$ -	\$ -
+ Amortization	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
+ Depletion	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
+ Loss Forward	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
+ Writeoff	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
- Working Capital										
- Fixed Capital										
Cash Flow	\$ 31,238,994	\$ 31,238,898	\$ 31,238,994	\$ 31,238,898	\$ 31,238,994	\$ 31,210,449	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000
Discount Factor	0.429	0.397	0.368	0.340	0.315	0.292	0.270	0.2502490	0.2317121	0.2145482
Discounted Cash Flow	\$ 13,397,869	\$ 12,405,396	\$ 11,486,513	\$ 10,635,628	\$ 9,847,834	\$ 9,110,032	\$ 8,427,526	\$ 7,803,265	\$ 7,225,246	\$ 6,690,042

End of Year	11	12	13	14	15	16	17	18	19	20
Products (gal/year)	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010	\$ 99,599,010
x Sales Price (\$/gal)	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2	\$ 2
Sales Revenue	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000
+ Salvage value										
- Royalties (basis)										
Net Revenue	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000	\$ 239,038,000
- Raw Material Costs	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)	\$ (166,779,000)
- Other Op Costs	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)	\$ (20,289,000)
- Depreciation	\$ (142,485)	\$ (142,244)	\$ (142,485)	\$ (142,244)	\$ (142,485)	\$ (71,122)				
- Amortization										
- Depletion										
- Loss Forward										
- Writeoff										
Taxable Income	\$ 51,827,515	\$ 51,827,756	\$ 51,827,515	\$ 51,827,756	\$ 51,827,515	\$ 51,898,878	\$ 51,970,000	\$ 51,970,000	\$ 51,970,000	\$ 51,970,000
- Tax @ 40%	\$ 20,731,006	\$ 20,731,102	\$ 20,731,006	\$ 20,731,102	\$ 20,731,006	\$ 20,759,551	\$ 20,788,000	\$ 20,788,000	\$ 20,788,000	\$ 20,788,000
Net Income	\$ 31,096,509	\$ 31,096,654	\$ 31,096,509	\$ 31,096,654	\$ 31,096,509	\$ 31,139,327	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000
+ Depreciation	\$ 142,485	\$ 142,244	\$ 142,485	\$ 142,244	\$ 142,485	\$ 71,122	\$ -	\$ -	\$ -	\$ -
+ Amortization	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
+ Depletion	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
+ Loss Forward	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
+ Writeoff	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
- Working Capital										
- Fixed Capital										
Cash Flow	\$ 31,238,994	\$ 31,238,898	\$ 31,238,994	\$ 31,238,898	\$ 31,238,994	\$ 31,210,449	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000	\$ 31,182,000
Discount Factor	0.429	0.397	0.368	0.340	0.315	0.292	0.270	0.2502490	0.2317121	0.2145482
Discounted Cash Flow	\$ 13,397,869	\$ 12,405,396	\$ 11,486,513	\$ 10,635,628	\$ 9,847,834	\$ 9,110,032	\$ 8,427,526	\$ 7,803,265	\$ 7,225,246	\$ 6,690,042

Appendix II – Sizing and Costing Sheets

Macrs depreciation chart:

Macrs			
Cap Cost	15yr	Depreciation	Year
\$ 2,411,000	0.05	-\$ 120,550	1
	0.095	-\$ 229,045	2
	0.0855	-\$ 206,141	3
	0.077	-\$ 185,647	4
	0.0693	-\$ 167,082	5
	0.0623	-\$ 150,205	6
	0.059	-\$ 142,249	7
	0.059	-\$ 142,249	8
	0.0591	-\$ 142,490	9
	0.059	-\$ 142,249	10
	0.0591	-\$ 142,490	11
	0.059	-\$ 142,249	12
	0.0591	-\$ 142,490	13
	0.059	-\$ 142,249	14
	0.0591	-\$ 142,490	15
	0.0295	-\$ 71,125	16
Total		\$ (2,411,000)	

Sizing pumps:

Pump-100	Q(bbl/day)	9370	From fig 13-37, for product Pump efficiency ~ 0.6
	Q (gpm)	274.925	
	Delt. P (psi)	100.1	
	Head (ft)		
	Hyd hp	16.0466429	
	Brake hp	26.7444048	
		19.9433026 kW	
Pump-101	Q(bbl/day)	3505	From fig 13-37, for product Pump efficiency ~ 0.45
	Q (gpm)	104.0375	
	Delt. P (psi)	5.8	
	Head (ft)		
	Hyd hp	0.35184694	
	Brake hp	0.78188209	
		0.58304947 kW	
Pump-102	Q(bbl/day)	9953	From fig 13-37, for product Pump efficiency ~ 0.6
	Q (gpm)	291.958333	
	Delt. P (psi)	5.8	
	Head (ft)		
	Hyd hp	0.98738095	
	Brake hp	1.64563492	
		1.22714996 kW	
Pump-103	Q(bbl/day)	3565	From fig 13-37, for product Pump efficiency ~ 0.45
	Q (gpm)	107.479167	
	Delt. P (psi)	5.8	
	Head (ft)		
	Hyd hp	0.36348639	
	Brake hp	0.80774754	
		0.60233734 kW	
Pump-104	Q(bbl/day)	12990	From fig 13-37, for product Pump efficiency ~ 0.7
	Q (gpm)	376.71	
	Delt. P (psi)	5.8	
	Head (ft)		
	Hyd hp	1.27400466	
	Brake hp	1.82000666	
		1.35717897 kW	
Pump-105	Q(bbl/day)	1725	From fig 13-37, for product Pump efficiency ~ 0.45
	Q (gpm)	50.025	
	Delt. P (psi)	5.8	
	Head (ft)		
	Hyd hp	0.16918076	
	Brake hp	0.37595724	
		0.28035131 kW	

Costing Pumps:

			K1	3.3892	C1	0
			K2	0.0536	C2	0
			K3	0.1538	C3	0
		$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1.55
		5233		Fp		1
Reported	valued	$Cp = Cp^0 * Fm * Fp$		B1		1.89
NOT		8110		B2		1.35
Escalated		$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$		Pressure	17.9517241	
		20838				

			K1	3.3892	C1	0
			K2	0.0536	C2	0
			K3	0.1538	C3	0
		$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1.55
		2427		Fp		1
Reported	valued	$Cp = Cp^0 * Fm * Fp$		B1		1.89
NOT		3762		B2		1.35
Escalated		$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$		Pressure	17.9517241	
		9666				

			K1	3.3892	C1	0
			K2	0.0536	C2	0
			K3	0.1538	C3	0
		$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1.55
		2484		Fp		1
Reported	valued	$Cp = Cp^0 * Fm * Fp$		B1		1.89
NOT		3850		B2		1.35
Escalated		$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$		Pressure	17.9517241	
		9893				

Costing P-103			K1	3.3892	C1	0
			K2	0.0536	C2	0
			K3	0.1538	C3	0
			$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$	Fm		1.55
Reported valued NOT Escalated	2426			Fp		1
	$Cp = Cp^0 * Fm * Fp$			B1		1.89
	3760			B2		1.35
			$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$	Pressure	17.9517241	
			9661			

Costing P-104			K1	3.3892	C1	0
			K2	0.0536	C2	0
			K3	0.1538	C3	0
			$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$	Fm		1.55
Reported valued NOT Escalated	2506			Fp		1
	$Cp = Cp^0 * Fm * Fp$			B1		1.89
	3885			B2		1.35
			$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$	Pressure	17.9517241	
			9981			

Costing P-105			K1	3.3892	C1	0
			K2	0.0536	C2	0
			K3	0.1538	C3	0
			$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$	Fm		1.55
Reported valued NOT Escalated	2550			Fp		1
	$Cp = Cp^0 * Fm * Fp$			B1		1.89
	3952			B2		1.35
			$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$	Pressure	17.9517241	
			10155			

Sizing Heat Exchangers:

E-101		
ΔT (hot)	$q = (\text{mass flow}) * \Delta H$	
93.50	2809294 (W)	
	9585313 (Btu/h)	
$A_o = q/(U_o * MTD)$		
	191 (m^2)	
	2050 (ft^2)	
$LMTD = \{(T_{hi} - T_{co}) - (T_{ho} - T_{ci})\} / \ln((T_{hi} - T_{co}) / (T_{ho} - T_{ci}))$		
127.3		
$MTD = LMTD * F$	$U = [(d_o/h_i * d_i) + (R_{fi} * d_o/d_i) + (d_o * \ln(d_o/d_i) / 2 * K_w) + R_{fo} + (1/h_o)]^{-1}$	
	114.6	128.7
Fouling		
$F (T_{ho} > T_{co})$	0.9	
		$R_{fi} (m^2 * K/W)$
		0.0001
		$R_{fo} (m^2 * K/W)$
		0.0001
		K_w
		54
		$h_i (W/m^2)$
		300
		$h_o (W/m^2)$
		300
		$d_o (m)$
		$d_i (m)$

E-102		
ΔT (hot)	$q = (\text{mass flow}) * \Delta H$	
209.0	18557950 (W)	
	63319725.4 (Btu/h)	
mass flow water (mol/s)	Cp water (J/mol*K)	T(K)/1000
12589.1	75.8686773	0.29982
3597.4 (gpm)		
Ao = $q/(U_o * MTD)$		
278.8 (m^2)		
3000 (ft^2)		
LMTD = $\{(T_{hi} - T_{ci}) - (T_{ho} - T_{ci})\} / \ln((T_{hi} - T_{ci}) / (T_{ho} - T_{ci}))$		
103.431674		
MTD = LMTD * F	U = [(do/h _i *di)+(R _{fi} *do/di)+(do*ln(do/di)/2*K _w)+R _{fo} +(1/h _o)]^-1	
93.08850663	714.967581	
Fouling		
F (T _{ho} >T _{co})	0.9	
	R _{fi} (m^2*K/W)	0.0001
	R _{fo} (m^2*K/W)	0.0001
	K _w	54
	h _i (W/m^2)	2000
	h _o (W/m^2)	2000
	do (m)	0.0238
	di (m)	0.01905

E-104		
ΔT (hot)	$q = (\text{mass flow}) * \Delta H$	
1.0	6556497.22 (W)	
	22370768.5 (Btu/h)	
mass flow water (mol/s)	Cp water (J/mol*K)	T(K)/1000
25951.7	75.8686773	0.29982
7415.8 (gpm)		
Ao = $q/(U_o * MTD)$		
1125.3 (m^2)		
12106 (ft^2)		
LMTD = $\{(T_{hi} - T_{ci}) - (T_{ho} - T_{ci})\} / \ln((T_{hi} - T_{ci}) / (T_{ho} - T_{ci}))$		
9.055		
MTD = LMTD * F	U = [(do/h _i *di)+(R _{fi} *do/di)+(do*ln(do/di)/2*K _w)+R _{fo} +(1/h _o)]^-1	
8.150	715	
Fouling		
F (T _{ho} >T _{co})	0.9	
	R _{fi} (m^2*K/W)	0.0001
	R _{fo} (m^2*K/W)	0.0001
	K _w	54
	h _i (W/m^2)	2000
	h _o (W/m^2)	2000
	do (m)	0.0238
	di (m)	0.01905

E-103					
ΔT (hot)	$q = (\text{mass flow}) * \Delta H$		Delt H	H1 (kJ/kg)	H2 (kJ/kg)
60.0	6861125 (W)		1257	-6678	-7935
	23410158.5 (Btu/h)				
mass flow water (mol/s)	Cp water (J/mol*K)	T.ci.(K)/1000	°C		K
4637.6	75.8695522	0.29975	136.3	T.hi.	409.45
1325.2 (gpm)			76.26	T.ho.	349.41
Ao = $q/(U_o * MTD)$	$A'_{\text{o}} = A_o * F_1 * F_2 * F_3$		26.6	T.ci.	299.75
		0.0 (m^2)	46.1	T.co.	319.25
157.0 (m^2)				T.hi.-T.co.	90.2
1689 (ft^2)				T.ho.-T.ci.	49.66
LMTD = $\{(T.hi. - T.co.) - (T.ho. - T.ci.)\} / \ln((T.hi. - T.co.)/(T.ho. - T.ci.))$		kg/hr	19650		
67.92558011		g/s	5458		
MTD = LMTD * F	$U = [(do/h_i * di) + (R_{fi} * do/di) + (do * \ln(do/di) / 2 * K_w) + R_{fo} + (1/h_o)]^{-1}$				
61.1330221	714.967581				
Fouling		R _{fi} (m^2*K/W)	0.0001		
F (T.ho.>T.co.)	0.9	R _{fo} (m^2*K/W)	0.0001		
		kw (W/m*K)	54		
		h _i (W/m^2)	2000		
		h _o (W/m^2)	2000		
		do (m)	0.0238		
		di (m)	0.01905		

E-100					
ΔT (cold)	$q = (\text{mass flow}) * \Delta H$	Delt H	H1	H2	
100.0	18530272 (W)	1339	-7581	-6242	
	63225289 (Btu/h)				
Steam flow	=q/Theoretical work	h(fg) (J/kg)	°C		K
10.8 (kg/s)		1714100	254	T.hi.	527.15
323873829.7 kg/year			250	T.ho.	523.15
Ao = $q/(U_o * MTD)$			35.66	T.ci.	308.81
			135.7	T.co.	408.85
178.2 (m^2)				T.hi.-T.co.	118.3
1917 (ft^2)				T.ho.-T.ci.	214.34
LMTD = $\{(T.hi. - T.co.) - (T.ho. - T.ci.)\} / \ln((T.hi. - T.co.)/(T.ho. - T.ci.))$		Kg/h	49820		
161.5910715		g/s	13839		
MTD = LMTD * F	$J = [(do/h_i * di) + (R_{fi} * do/di) + (do * \ln(do/di) / 2 * K_w) + R_{fo} + (1/h_o)]^{-1}$				
145.4319644	714.967581				
Fouling		R _{fi} (m^2*K/W)	0.0001		
F (T.ho.>T.co.)	0.9	R _{fo} (m^2*K/W)	0.0001		
		Kw	54		
		h _i (W/m^2)	2000		
		h _o (W/m^2)	2000		
		do (m)	0.0238		
		di (m)	0.01905		

Reboiler for T-100					
ΔT (hot)	$q = (\text{mass flow}) * \Delta H$				
4.0	7519444 (W)				27070000
	25656344 (Btu/h)				
Steam flow	$=q/h_{fg}$	$h(fg) \text{ (J/kg)}$		$^{\circ}\text{C}$	K
	4.4 (kg/s)	1714100		254 T.hi.	527.15
131425552.8 kg/year				250 T.ho.	523.15
				135.2 T.ci.	408.35
				145.4 T.co.	418.55
	104.6 (m^2)			T.hi.-T.co.	108.6
	1126 (ft^2)			T.ho.-T.ci.	114.8
$LMTD = \{(T.hi. - T.co.) - (T.ho. - T.ci.)\} / \ln ((T.hi. - T.co.)/(T.ho. - T.ci.))$					
111.671316					
MTD = LMTD * F	$U = [(d_o/h_i * d_i) + (R_{fi} * d_o/d_i) + (d_o * \ln(d_o/d_i)/2 * K_w) + R_{fo} + (1/h_o)]^{-1}$				
100.504184	714.967581				
Fouling			$R_{fi} \text{ (m}^2\text{K/W)}$	0.0001	
F (T.ho.>T.co)	0.9		$R_{fo} \text{ (m}^2\text{K/W)}$	0.0001	
			K_w	54	
			$h_i \text{ (W/m}^2\text{)}$	2000	
			$h_o \text{ (W/m}^2\text{)}$	2000	
			$d_o \text{ (m)}$	0.0238	
			$d_i \text{ (m)}$	0.01905	

Reboiler for T-101					
	ΔT (hot)	$q = (\text{mass flow}) * \Delta H$		Duty	
T(K)/1000	4.0	6497222.22 (W)		23390000	
0.44585	Steam flow	= $q/\text{Theoretic h(fg)}$ (J/kg)		°C	K
	3.8 (kg/s)	1714100		254	T.hi.
	113559057.2 kg/year			250	T.ho.
	Ao = $q/(U_0 * MTD)$	$A'o = Ao * F1 * F2 * F3)$		172.7	T.ci.
	128.5 (m^2)	0.0 (m^2)		174.1	T.co.
	1382 (ft^2)				T.hi.-T.co.
					79.9
					T.ho.-T.ci.
					77.3
$LMTD = \{(T.hi. - T.co.) - (T.ho. - T.ci.)\} / \ln((T.hi. - T.co.)/(T.ho. - T.ci.))$					
78.5928324					
MTD = LMTD * F		$U = [(do/h_i * di) + (R_{fi} * do/di) + (do * \ln(do/di) / 2 * K_w) + R_{fo} + (1/h_o)]^{-1}$			
70.7335491		714.967581			
Fouling			R _{fi} (m^2*K/W)	0.0001	
F (T.ho.>T.co.)	0.9		R _{fo} (m^2*K/W)	0.0001	
			K _w	54	
			h _i (W/m^2)	2000	
			h _o (W/m^2)	2000	
			do (m)	0.0238	
			di (m)	0.01905	

Costing Heat Exchangers

	Costing E-101	K1	4.8306	C1	0.03881
		K2	-0.8509	C2	-0.11272
		K3	0.3187	C3	0.08183
	$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1
Reported	35259		Fp		1.02017
valued	$Cp = Cp^0 * Fm * Fp$		B1		1.63
NOT	35970		B2		1.66
Escalated	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$		Pressure shell		10.337931
	117183				
	Costing E-102	K1	4.8306	C1	0.03881
		K2	-0.8509	C2	-0.11272
		K3	0.3187	C3	0.08183
	$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1
Reported	45247.2		Fp		1.02
valued	$Cp = Cp^0 * Fm * Fp$		B1		1.63
NOT	46160		B2		1.66
Escalated	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$		Pressure shell (psi)		10.337931
	150378				
	Costing E-104	K1	4.8306	C1	0.03881
		K2	-0.8509	C2	-0.11272
		K3	0.3187	C3	0.08183
	$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1
Reported	159011.6		Fp		1.05142
valued	$Cp = Cp^0 * Fm * Fp$		B1		1.63
NOT	167188		B2		1.66
Escalated	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$				
	536721				

Costing E-103		K1	4.8306	C1	0.03881
		K2	-0.8509	C2	-0.11272
		K3	0.3187	C3	0.08183
$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1	
Reported	31538.1	Fp		1.05142	
valued	$Cp = Cp^0 * Fm * Fp$	B1		1.63	
NOT	33160	B2		1.66	
Escalated	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$	Pressure shell	11.137931		
	106452				

Costing E-100		K1	4.8306	C1	0.03881
		K2	-0.8509	C2	-0.11272
		K3	0.3187	C3	0.08183
$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1	
Reported	33887.5	Fp		1.05142	
valued	$Cp = Cp^0 * Fm * Fp$	B1		1.63	
NOT	35630	B2		1.66	
Escalated	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$	Pressure shell	15.88275862		
	114382				

Costing Reboiler for T-100		K1	4.8306	C1	0.03881
		K2	-0.8509	C2	-0.11272
		K3	0.3187	C3	0.08183
$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm		1	
Reported	25827.4	Fp		1.05142	
valued	$Cp = Cp^0 * Fm * Fp$	B1		1.63	
NOT	27155	B2		1.66	
Escalated	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$	Pressure shel	15.88275862		
	87177				

Costing Reboiler for T-101	K1	4.8306	C1	0.03881
	K2	-0.8509	C2	-0.11272
	K3	0.3187	C3	0.08183
Reported valued NOT Escalated	$Cp^0 = 10^{(K1+(K2*\log(A'o))+(k3*(\log(A'o))^2))}$		Fm	1
	28411.9		Fp	1.05142
	$Cp = Cp^0 * Fm * Fp$		B1	1.63
	29873		B2	1.66
	$Cbm = Cp^0 * (B1 + (B2 * Fm * Fp))$		Pressure shel	15.88275862
	95900			

Column Sizing and Costing

				Column Info->	DME	Lin m	L inft	P psia + S	--> P barg	Tray Spacing (ft)		
						11.3	37	171	10.8	2		
Chart												
Distillation Column	Cp =Cpo*Fm*Fp	Cpo	Fm (CS)	Fp formula	Cbm=Cpo*Fbm	P barg safety	Diam-m	K1	K2	K3	Volume	Fbm B1 B2
	\$ 42,536	\$ 19,164	1	2.2	\$ 120,533	10.8	1.55	3.4974	0.4485	0.1074	21.3	6.3 2.25 1.82
Trays-sieve(.07-12.3)	Cp =Cpo*Fm*Fp	Cpo	Fm (CS)	Fp formula	Cbm=Cpo*Fbm	P barg safety	Area-m^2	K1	K2	K3	Size factor	Fbm
11	\$ 216	\$ 216	1	1.0	\$ 216	Volume		1.9	2.9949	0.4465	0.3961	0.2 1.0
Trays-valve(0.7-10.5)												
2	\$ 558	\$ 558	1	1.0	\$ 558			1.9	3.3322	0.4838	0.3434	0.2 1.0
				Column Info->	WW	Lin m	L inft	P psia + S	--> P barg	Tray Spacing (ft)		
						11.3	37	179	11.3	2		
Chart												
Distillation Column	Cp =Cpo*Fm*Fp	Cpo	Fm (CS)	Fp formula	Cbm=Cpo*Fbm	P barg safety	Diam-m	K1	K2	K3	Volume	Fbm B1 B2
	\$ 29,933	\$ 14,889	1	2.0	\$ 87,980	11.3	1.30	3.4974	0.4485	0.1074	15.0	5.9 2.25 1.82
Trays-sieve(.07-12.3)	Cp =Cpo*Fm*Fp	Cpo	Fm (CS)	Fp formula	Cbm=Cpo*Fbm	P barg safety	Area-m^2	K1	K2	K3	Size factor	Fbm
13	\$ 123	\$ 123	1	1.0	\$ 123	Volume		1.3	2.9949	0.4465	0.3961	0.1 1.0
Trays-valve(0.7-10.5)												
0	\$ 315	\$ 315	1	1.0	\$ 315			1.3	3.3322	0.4838	0.3434	0.1 1.0

Reactor Sizing and Costing

-ra (kmol/((m^3)*h)	44.5
inlet mol conc.	0.96
outlet mol conc.	0.17
Molar flow (kmol/h)	1576
Fao (kmol/h)	1511
Fa (kmol/h)	269
X (percent conversion)	0.82
V=Fao $\int_0^X \frac{dx}{-ra}$ (m^3)	27.8
Density (kg/m^3)	882
Mass (kg)	24520
Mass (lb)	53943
price (\$4.65/lb)	250836
Avg. Price (\$4.95/lb)	267018
Price (\$5.25/lb)	283201
Avg. Price/Year (9mon life)	356025
Avg. Price/Year (10.5mon life)	305164
Avg. Price/Year (12mon life)	267018
Volume of reactor (m^3)	38.9
Costing size (m^3)	40.0
Pressure+S (psi)	165
Pressure (barg)	10.4

Reactor	Cp =Cpo*Fm*Fp	Cpo	Fm (CS)	Fp formula	Cbm=Cpo*Fbm
	\$ 32,742	\$ 32,742	1	1.0	\$ 130,969
P barg safety	K1	K2	K3	Volume	Fbm
	10.4	3.3496	0.7235	0.0025	40.0

Appendix III – Misc.

Polymath Report

POLYMAT Report

Explicit Equations

Calculated values of explicit variables

	Variable	Value
1	A	1.21E+06
2	e	2.71828
3	Ea	80.48
4	Kp	5.846006
5	P_MeOH	135.09
6	R	0.008314
7	Rate_MeOH	-44.48976
8	T	640.35

Explicit equations

- 1 $P_{\text{MeOH}} = .171 * 790$
- 2 $A = 1.21 * 10^6$
- 3 $Ea = 80.48$
- 4 $R = 8.314 * 10^{-3}$
- 5 $e = 2.71828$
- 6 $T = 273.15 + 367.2$
- 7 $\text{Rate}_{\text{MeOH}} = -A * (e^{(-Ea/(R*T))}) * P_{\text{MeOH}}$
- 8 $Kp = e^{(-9.76 + (3200/T) + (1.07 * \ln(T)) - (6.57 * (10^{-4}) * T) + (4.9 * (10^{-8}) * (T^2)) + (6050 / (T^2)))}$

Appendix IV – Aspen HYSYS report

See Following pages for Aspen HYSYS report

INPUT SUMMARY

FLUID PACKAGE: Basis-1

Property Package Type: Nrtl
Component List - 1: diM-Ether /Methanol /H2O /

Reaction Set: Set-1

Reaction 'Rxn-1':

Reactants: Methanol, Stoich Coeff -2 / diM-Ether,
Stoich Coeff 1 / H2O, Stoich
Coeff 1 /

Basis Data: Basis = Activity / Phase = VapourPhase /

FLOWSHEET: Main

Fluid Package: Basis-1

STREAM: Meth feed (Material Stream)
Temperature = 25 C
Pressure = 100 kPa
Mass Flow = 40000 kg/h
Composition Basis (In Mass Fractions):diM-Ether = 0/
Methanol = 0.997182655/
H2O = 0.00281734517/

UNIT OPERATION: E-100 (Heater)
Feed Stream = meth feed 2 high P
Product Stream = meth feed 3
Energy Stream = heater 1
Pressure Drop = 0 kPa
Delta Temp = 100 C

UNIT OPERATION: E-101 (Heat Exchanger)
TubeInletStream = meth feed 3
TubeOutletStream = reactor feed
ShellInletStream = reactor out
ShellOutletStream = D1 feed
TEMAType2 = F
TubeOuterDiameter = 20 mm
TubeInnerDiameter = 16 mm
TubeThickness = FEMPTY mm
HCurveName = meth feed 3-reactor feed
HCurveName = reactor out-D1 feed
ShellPressureDrop = 0 kPa
TubePressureDrop = 0 kPa

STREAM: meth feed 3 (Material Stream)

STREAM: heater 1 (Energy Stream)

STREAM: reactor feed (Material Stream)

Temperature = 250 C

STREAM: reactor out (Material Stream)

STREAM: D1 feed (Material Stream)

UNIT OPERATION: T-100 (Reboiled Absorber)

TwoLiquidCheck = 2 Liquid Check
TargetType = 0
Phase = Liquid
ShowEffDiagFlag = True
Specification Name = Boilup RatioSpecConvergedStatus =
InactiveSpecification Value =
10Specification Name = Comp
FractionSpecConvergedStatus = YesSpecification Value =
0.9995

UNIT OPERATION: T-101 (Reboiled Absorber)

TwoLiquidCheck = 2 Liquid Check
ShowEffDiagFlag = True
Specification Name = Ovhd Prod
RateSpecConvergedStatus = YesSpecification Value =
650 kgmole/hSpecification Name = Boilup
RatioSpecConvergedStatus =
InactiveSpecification Value = 4

STREAM: Meth H2O (Material Stream)

STREAM: reboiler 1 (Energy Stream)

STREAM: Meth Recycle (Material Stream)

STREAM: Waste Water (Material Stream)

STREAM: Reboiler 2 (Energy Stream)

UNIT OPERATION: MIX-100 (Mixer)
Feed Stream = Meth feed
Feed Stream = meth to rcr 2
Product Stream = meth feed 2

STREAM: meth feed 2 (Material Stream)

UNIT OPERATION: GBR-100 (Gibbs Reactor)
Feed Stream = reactor feed
Vapour Product = reactor out
Liquid Product = Purge
Reaction Set=Set-1
ReactorType = Specify Equilibrium Reactions

STREAM: Purge (Material Stream)

STREAM: D1 feed cooled (Material Stream)

UNIT OPERATION: E-102 (Cooler)

Feed Stream = D1 feed
Product Stream = D1 feed cooled
Energy Stream = cooler1
Pressure Drop = 0 kPa
Delta Temp = -200 C

STREAM: cooler1 (Energy Stream)
STREAM: DME outlet (Material Stream)
STREAM: meth feed 2 high P (Material Stream)

UNIT OPERATION: P-100 (Pump)
Feed Stream = meth feed 2
Product Stream = meth feed 2 high P
Energy Stream = Pump1
DeltaP = 690 kPa
AdiabaticEfficiency = 75 %

STREAM: Pump1 (Energy Stream)
UNIT OPERATION: RCY-1 (Recycle)
Inlet Stream = DME reflux 1
Output Stream = DME reflux

UNIT OPERATION: E-103 (Cooler)
Feed Stream = Meth Recycle
Product Stream = Cooled meth recycle
Energy Stream = Cooler3
Pressure Drop = 0 kPa
Delta Temp = -60 C

STREAM: Cooled meth recycle (Material Stream)

STREAM: Cooler3 (Energy Stream)
UNIT OPERATION: TEE-100 (Tee)
Feed Stream = CMR2
Product Stream = meth to rctr
Product Stream = meth to tower

STREAM: meth to rctr (Material Stream)
STREAM: meth to tower (Material Stream)

UNIT OPERATION: E-104 (Cooler)
Feed Stream = DME outlet
Product Stream = DME out2
Energy Stream = cooler2
Pressure Drop = 0 kPa
Delta Temp = -1 C

STREAM: DME out2 (Material Stream)

STREAM: cooler2 (Energy Stream)
UNIT OPERATION: TEE-101 (Tee)
Feed Stream = DME out3
Product Stream = DME product
Product Stream = DME reflux 1

STREAM: DME reflux (Material Stream)
Temperature = 36.9812967 C
Pressure = 860 kPa
Molar Flow = 631.577199 kgmole/h

Composition Basis (In Mole Fractions):diM-Ether = 0.999279652/ Methanol = 0.000716868145/ H2O = 3.48018063e-006/

STREAM: DME product (Material Stream)
STREAM: DME reflux 1 (Material Stream)

UNIT OPERATION: ADJ-1 (Adjust)
Target Object = DME out2
Adjusted Object = E-104
Target Variable = Vapour Fraction
AdjustedVarDescription = Delta T
StepSize = 3.5 C
Tolerance = 0.001
TargetVariable = 0

STREAM: METH reflux (Material Stream)
Temperature = 76.2885619 C
Pressure = 910 kPa
Molar Flow = 325.035811 kgmole/h
Composition Basis (In Mole Fractions):diM-Ether = 0.026406083/ Methanol = 0.81774417/ H2O = 0.155849747/

UNIT OPERATION: ADJ-2 (Adjust)
Target Object = Cooled meth recycle
Adjusted Object = E-103
Target Variable = Vapour Fraction
AdjustedVarDescription = Delta T
StepSize = 10 C
Tolerance = 0.01
TargetVariable = 0

UNIT OPERATION: RCY-2 (Recycle)
Inlet Stream = meth to tower
Output Stream = METH reflux

STREAM: meth to rctr 2 (Material Stream)
Temperature = 76.282758 C
Pressure = 910 kPa
Molar Flow = 325.012129 kgmole/h
Composition Basis (In Mole Fractions):diM-Ether = 0.0258869747/ Methanol = 0.818695161/ H2O = 0.155417864/

UNIT OPERATION: ADJ-3 (Adjust)
Target Object = meth feed 2
Adjusted Object = E-103
Target Variable = Vapour Fraction
AdjustedVarDescription = Delta T
StepSize = 10 C
Tolerance = 0.001
TargetVariable = 0

UNIT OPERATION: RCY-3 (Recycle)
Inlet Stream = meth to rctr
Output Stream = meth to rctr 2

UNIT OPERATION: ADJ-4 (Adjust)
Target Object = reactor feed
Adjusted Object = E-100

Target Variable = Temperature
AdjustedVarDescription = Delta T
StepSize = 10 C
Tolerance = 0.1 C
TargetVariable = 250 C

STREAM: Meth H₂O Pumped (Material Stream)

UNIT OPERATION: P-101 (Pump)
Feed Stream = Meth H₂O
Product Stream = Meth H₂O Pumped
Energy Stream = pumper
DeltaP = 40 kPa
AdiabaticEfficiency = 75 %

STREAM: pumper (Energy Stream)

UNIT OPERATION: P-102 (Pump)
Feed Stream = D1 feed cooled
Product Stream = D1 feed pumped
Energy Stream = pumper2
DeltaP = 40 kPa
AdiabaticEfficiency = 75 %

STREAM: D1 feed pumped (Material Stream)

STREAM: pumper2 (Energy Stream)

UNIT OPERATION: P-103 (Pump)
Feed Stream = Cooled meth recycle
Product Stream = CMR2
Energy Stream = pumper3
DeltaP = 40 kPa
AdiabaticEfficiency = 75 %

STREAM: CMR2 (Material Stream)

STREAM: pumper3 (Energy Stream)

UNIT OPERATION: P-104 (Pump)
Feed Stream = DME out2
Product Stream = DME out3
Energy Stream = pumper4
DeltaP = 40 kPa
AdiabaticEfficiency = 75 %

STREAM: pumper4 (Energy Stream)

STREAM: DME out3 (Material Stream)

UNIT OPERATION: P-105 (Pump)
Feed Stream = Waste Water
Product Stream = WWT
Energy Stream = Pumper5
DeltaP = 40 kPa
AdiabaticEfficiency = 75 %

STREAM: Pumper5 (Energy Stream)

STREAM: WWT (Material Stream)

UNIT OPERATION: TEE-102 (Tee)

Feed Stream = D1 feed pumped
Product Stream = normal op
Product Stream = turn down

STREAM: normal op (Material Stream)

STREAM: turn down (Material Stream)

FLOWSCHEET: COL1 (OWNER: T-100)

Fluid Package: Basis-1

UNIT OPERATION: Main Tower (Tower)
StageNumber = 9 (Feed)/ StageNumber = 4 (Feed)/
NumberOfColumnStages = 10
TrayActiveArea = 1.26393875 m²
WHTSpced = 1
RateHoldup = 0.0883572188
StgNumber = 0
StgNumber = 1
StgNumber = 2
StgNumber = 3
StgNumber = 4
StgNumber = 5
StgNumber = 6
StgNumber = 7
StgNumber = 8
StgNumber = 9
HasTPSAROption = True

UNIT OPERATION: Reboiler (Reboiler)
Feed Stream = To Reboiler @COL1
Vapour Product = Boilup @COL1
Liquid Product = Meth H₂O @COL1
Energy Stream = reboiler 1 @COL1
Volume = 2 m³
HeatExchanger = Duty
ViewVapourPhase = False
ViewLightLiqPhase = False
ViewHeavyLiqPhase = False

STREAM: To Reboiler (Material Stream)

STREAM: Boilup (Material Stream)

STREAM: Meth H₂O (Material Stream)

STREAM: reboiler 1 (Energy Stream)

STREAM: DME reflux (Material Stream)

STREAM: DME outlet (Material Stream)

STREAM: normal op (Material Stream)

STREAM: turn down (Material Stream)

FLOWSCHEET: COL2 (OWNER: T-101)

Fluid Package: Basis-1

UNIT OPERATION: Main Tower (Tower)

StageNumber = 6 (Feed)/ NumberOfColumnStages = 10
WhtSpeced = 1
RateHoldup = 0.0883572188
StgNumber = 0
StgNumber = 1
StgNumber = 2
StgNumber = 3
StgNumber = 4
StgNumber = 5
StgNumber = 6
StgNumber = 7
StgNumber = 8
StgNumber = 9
HasTPSAROption = True

UNIT OPERATION: Reboiler (Reboiler)

Feed Stream = To Reboiler @COL2
Vapour Product = Boilup @COL2
Liquid Product = Waste Water @COL2
Energy Stream = Reboiler 2 @COL2
Volume = 2 m3
HeatExchanger = Duty
ViewVapourPhase = False
ViewLightLiqPhase = False
ViewHeavyLiqPhase = False

STREAM: Meth Recycle (Material Stream)

STREAM: To Reboiler (Material Stream)

STREAM: Boilup (Material Stream)

STREAM: Waste Water (Material Stream)

STREAM: Reboiler 2 (Energy Stream)

STREAM: METH reflux (Material Stream)

STREAM: Meth H2O Pumped (Material Stream)

#####
OUTPUT SUMMARY
#####

OKLAHOMA STATE UNIVERSIT Case Name:
version final hopefully internals working.hsc

Bedford, MA
USA Unit Set: SI

Date/Time: Mon Mar 12 20:03:19 2018

Basis-1 (Fluid Package): Component List

Fluid Package: Basis-1

COMPONENT LIST

Component List - 1 [HYSYS Databanks]

COMPONENT	TYPE	MOLECULAR	BOILING	PT
IDEAL LIQ	CRITICAL	WEIGHT	(C)	DENSITY (kg/m3)
TEMP (C)				
diM-Ether	Pure	46.07	-24.85	670.3
Methanol	Pure	32.04	64.65	795.7
H2O	Pure	18.02	100.0	998.0
				374.1
(Continued..) Component List - 1 [HYSYS Databanks]				

COMPONENT	CRITICAL	PRES	CRITICAL	VOL
ACENTRICITY	HEAT OF FORM			
	(kPa)	(m3/kgmole)		(kJ/kgmole)
diM-Ether	5320	0.1780	0.2000	-
1.842e+005				
Methanol	7376	0.1270	0.5570	-
2.013e+005				
H2O	2.212e+004	5.710e-002	0.3440	-
2.418e+005				

Case (Simulation Case): Mass and Energy Balance, Utility
Balance, Process CO2 Emissions

Simulation Case: Case

OVERALL MASS BALANCE

In Stream	Count	Mass Flow	Out Stream	Count
Mass Flow				
	(kg/h)		(kg/h)	
Meth feed	Yes	4.000e+004	Purge	Yes 0.0000
			DME product	Yes 2.885e+004
			WWT	Yes 1.139e+004
Total In MassFlow (kg/h)	4.000e+004		Total Out MassFlow (kg/h)	4.024e+004

Mass Imbalance (kg/h) 238.1 Rel Mass Imbalance Pct (%) 0.60

OVERALL ENERGY BALANCE

InStream	Count	Energy Flow	OutStream	Count
Energy Flow				
	(kJ/h)		(kJ/h)	
heater 1	Yes	6.671e+07	Purge	Yes 0.000e-01
reboiler 1	Yes	2.707e+07	cooler1	Yes
6.679e+07				
Reboiler 2	Yes	2.339e+07	Cooler3	Yes
2.470e+07				
Meth feed	Yes	-2.998e+08	cooler2	Yes
2.364e+07				
Pump1	Yes	5.895e+04	DME product	Yes -
1.267e+08				
pumper	Yes	1.438e+03	WWT	Yes -
1.721e+08				
pumper2	Yes	3.908e+03		
pumper3	Yes	1.411e+03		
pumper4	Yes	5.257e+03		
Pumper5	Yes	6.914e+02		
Total In EnergyFlow (kJ/h)	-1.826e+008		Total Out EnergyFlow (kJ/h)	-1.836e+008

Energy Imbalance (kJ/h) -1.050e+006 Rel Energy
 Imbalance Pct (%) 0.57
OVERALL UTILITY BALANCE

Utility Name	Usage	Info	Energy Flow	Mass Flow
	Cost			

Hot Utility Summary **Cold Utility Summary**

Utility Flow ---	Utility Flow ---
Utility Cost ---	Utility Cost ---
Carbon Emiss. ---	Carbon Emiss. ---
Carbon Fees ---	Carbon Fees ---

PROCESS CO2 EMISSIONS

Inlet Stream	Count	IFPP (1995)	IFPP (2007)	EPA (2009)
	(kg/h)	(kg/h)	(kg/h)	
Meth feed	Yes	0.000e-01	0.000e-01	0.000e-01
Total from Inlets	---	---	---	
Total Carbon Fees from Inlets (Cost/hr)	---	---	---	
Outlet Stream	Count	IFPP (1995)	IFPP (2007)	EPA (2009)
	(kg/h)	(kg/h)	(kg/h)	
Purge	Yes	0.000e-01	0.000e-01	0.000e-01
DME product	Yes	0.000e-01	2.884e+04	0.000e-01
WWT	Yes	0.000e-01	1.156e-02	0.000e-01
Total from Outlets	---	2.884e+04	---	
Total Carbon Fees from Outlets (Cost/hr)	---	0.000e-01	---	

Meth feed (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Meth feed Fluid Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.
 Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 25.00 25.00
 Pressure: (kPa) 100.0 100.0
 Molar Flow (kgmole/h) 1251 1251
 Mass Flow (kg/h) 4.000e+004 4.000e+004
 Std Ideal Liq VolFlow (m3/h) 50.24 50.24
 Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
 Molar Entropy (kJ/kgmole-C) 4.664e+01 4.664e+01
 Heat Flow (kJ/h) -2.998e+08 -2.998e+08
 Liq VolFlow @Std Cond (m3/h) 50.20 50.20
COMPOSITION

Overall Phase	Vapour Fraction
0.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

	(kgmole/h)	(kg/h)	(m3/h)		
diM-Ether	0.0000	0.0000	0.0000	0.0000	0.0000
Methanol	1245	0.9950	3.989e+004	0.9972	50.13
H2O	6.256	0.0050	112.7	0.0028	0.1129
Total	1251	1.0000	4.000e+004	1.0000	50.24
1.0000					
Liquid Phase					Phase Fraction
1.000					

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

	(kgmole/h)	(kg/h)	(m3/h)		
diM-Ether	0.0000	0.0000	0.0000	0.0000	0.0000
Methanol	1245	0.9950	3.989e+004	0.9972	50.13
H2O	6.256	0.0050	112.7	0.0028	0.1129
Total	1251	1.0000	4.000e+004	1.0000	50.24
1.0000					

K VALUE

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	---	---	
Methanol	0.0000	0.0000	---
H2O	0.0000	0.0000	---

UNIT OPERATIONS

FEED TO CONNECTION	PRODUCT FROM	LOGICAL UTILITIES
Mixer: MIX-100		

(No utilities reference this stream)
PROCESS UTILITY

meth feed 3 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: meth feed 3 Fluid Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL VAPOUR PH.

Vapour / Phase Fraction	1.0000	1.0000
Temperature: (C)	135.7	135.7
Pressure: (kPa)	790.0	790.0
Molar Flow (kgmole/h)	1576	1576
Mass Flow (kg/h)	4.982e+004	4.982e+004
Std Ideal Liq VolFlow (m3/h)	62.45	62.45
Molar Enthalpy (kJ/kgmole)	-1.973e+05	-1.973e+05
Molar Entropy (kJ/kgmole-C)	1.735e+02	1.735e+02

Heat Flow (kJ/h) -3.110e+08 -3.110e+08
Liq VolFlow @Std Cond (m3/h) 62.39 62.39
COMPOSITION

Overall Phase Vapour Fraction
1.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
0.0093
Methanol 1511 0.9586 4.841e+004 0.9717 60.84
0.9743
H2O 56.77 0.0360 1023 0.0205 1.025
0.0164
Total 1576 1.0000 4.982e+004 1.0000 62.45
1.0000
Vapour Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
0.0093
Methanol 1511 0.9586 4.841e+004 0.9717 60.84
0.9743
H2O 56.77 0.0360 1023 0.0205 1.025
0.0164
Total 1576 1.0000 4.982e+004 1.0000 62.45
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether --- --- ---
Methanol --- --- ---
H2O --- --- ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Heat Exchanger: E-101 Heater: E-100
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

reactor feed (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: reactor feed Fluid Package:
Basis-1

Ideal
CONDITIONS

OVERALL VAPOUR PH.
Vapour / Phase Fraction 1.0000 1.0000

Temperature: (C) 250.0 250.0
Pressure: (kPa) 790.0 790.0
Molar Flow (kgmole/h) 1576 1576
Mass Flow (kg/h) 4.982e+004 4.982e+004
Std Ideal Liq VolFlow (m3/h) 62.45 62.45
Molar Enthalpy (kJ/kgmole) -1.909e+05 -1.909e+05
Molar Entropy (kJ/kgmole-C) 1.873e+02 1.873e+02
Heat Flow (kJ/h) -3.009e+08 -3.009e+08
Liq VolFlow @Std Cond (m3/h) 62.39 62.39
COMPOSITION

Overall Phase Vapour Fraction
1.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
0.0093
Methanol 1511 0.9586 4.841e+004 0.9717 60.84
0.9743
H2O 56.77 0.0360 1023 0.0205 1.025
0.0164
Total 1576 1.0000 4.982e+004 1.0000 62.45
1.0000
Vapour Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
0.0093
Methanol 1511 0.9586 4.841e+004 0.9717 60.84
0.9743
H2O 56.77 0.0360 1023 0.0205 1.025
0.0164
Total 1576 1.0000 4.982e+004 1.0000 62.45
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether --- --- ---
Methanol --- --- ---
H2O --- --- ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Gibbs Reactor: GBR-100 Heat Exchanger: E-101 Adjust:
ADJ-4
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

reactor out (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: reactor out
Basis-1

Ideal
CONDITIONS

OVERALL VAPOUR PH. LIQUID
PH. AQUEOUS PH.
Vapour / Phase Fraction 1.0000 1.0000 0.0000
0.0000
Temperature: (C) 367.2 367.2 367.2 367.2
Pressure: (kPa) 790.0 790.0 790.0 790.0
Molar Flow (kgmole/h) 1576 1576 0.0000
0.0000
Mass Flow (kg/h) 4.982e+004 4.982e+004 0.0000
0.0000
Std Ideal Liq VolFlow (m3/h) 66.32 66.32 0.0000
0.0000
Molar Enthalpy (kJ/kgmole) -1.909e+05 -1.909e+05 -
2.286e+05 -2.286e+05
Molar Entropy (kJ/kgmole-C) 2.008e+02 2.008e+02
1.341e+02 1.341e+02
Heat Flow (kJ/h) -3.009e+08 -3.009e+08 0.000e-01
0.000e-01
Liq VolFlow @Std Cond (m3/h) 66.51 66.51 0.0000
0.0000

COMPOSITION

Overall Phase Vapour Fraction
1.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 629.1 0.3991 2.898e+004 0.5817 43.24
0.6519
Methanol 269.6 0.1710 8637 0.1734 10.85
0.1637
H2O 677.5 0.4298 1.220e+004 0.2450 12.23
0.1844
Total 1576 1.0000 4.982e+004 1.0000 66.32
1.0000
Vapour Phase Phase Fraction
1.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 629.1 0.3991 2.898e+004 0.5817 43.24
0.6519
Methanol 269.6 0.1710 8637 0.1734 10.85
0.1637
H2O 677.5 0.4298 1.220e+004 0.2450 12.23
0.1844
Total 1576 1.0000 4.982e+004 1.0000 66.32
1.0000
Liquid Phase Phase Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

Fluid Package:

	(kgmole/h)	(kg/h)	(m3/h)		
diM-Ether	0.0000	0.2147	0.0000	0.3882	0.0000
0.4728					
Methanol	0.0000	0.1028	0.0000	0.1292	0.0000
0.1325					
H2O	0.0000	0.6825	0.0000	0.4825	0.0000
0.3947					
Total	0.0000	1.0000	0.0000	1.0000	0.0000
1.0000					
Aqueous Phase				Phase Fraction	
0.0000					

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

	(kgmole/h)	(kg/h)	(m3/h)		
--	------------	--------	--------	--	--

diM-Ether	0.0000	0.2147	0.0000	0.3882	0.0000
0.4728					

Methanol	0.0000	0.1028	0.0000	0.1292	0.0000
0.1325					

H2O	0.0000	0.6825	0.0000	0.4825	0.0000
0.3947					

Total	0.0000	1.0000	0.0000	1.0000	0.0000
1.0000					

K VALUE

COMPONENTS	MIXED	LIGHT
------------	-------	-------

HEAVY

diM-Ether	1.859	1.859
Methanol	1.665	1.665
H2O	0.6298	0.6298

UNIT OPERATIONS

FEED TO	PRODUCT FROM	LOGICAL
---------	--------------	---------

Connection		
Heat Exchanger: E-101	Gibbs Reactor: GBR-100	
UTILITIES		

(No utilities reference this stream)
PROCESS UTILITY

D1 feed (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: D1 feed Fluid Package:
Basis-1

Property Package: NRTL -

Ideal CONDITIONS

OVERALL VAPOUR PH.

Vapour / Phase Fraction	1.0000	1.0000
-------------------------	--------	--------

Temperature: (C)	273.7	273.7
------------------	-------	-------

Pressure: (kPa)	790.0	790.0
-----------------	-------	-------

Molar Flow (kgmole/h)	1576	1576
-----------------------	------	------

Mass Flow (kg/h)	4.982e+004	4.982e+004
------------------	------------	------------

Std Ideal Liq VolFlow (m3/h)	66.32	66.32
------------------------------	-------	-------

Molar Enthalpy (kJ/kgmole)	-1.973e+05	-1.973e+05
----------------------------	------------	------------

Molar Entropy (kJ/kgmole-C)	1.898e+02	1.898e+02
-----------------------------	-----------	-----------

Heat Flow (kJ/h)	-3.110e+08	-3.110e+08
------------------	------------	------------

Liq VolFlow @Std Cond (m3/h)	66.51	66.51
------------------------------	-------	-------

COMPOSITION

Overall Phase Vapour Fraction
1.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 629.1 0.3991 2.898e+004 0.5817 43.24
0.6519
Methanol 269.6 0.1710 8637 0.1734 10.85
0.1637
H2O 677.5 0.4298 1.220e+004 0.2450 12.23
0.1844
Total 1576 1.0000 4.982e+004 1.0000 66.32
1.0000
Vapour Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 629.1 0.3991 2.898e+004 0.5817 43.24
0.6519
Methanol 269.6 0.1710 8637 0.1734 10.85
0.1637
H2O 677.5 0.4298 1.220e+004 0.2450 12.23
0.1844
Total 1576 1.0000 4.982e+004 1.0000 66.32
1.0000

K VALUE

COMPONENTS	MIXED	LIGHT
HEAVY		
diM-Ether	---	---
Methanol	---	---
H2O	---	---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Cooler: E-102 Heat Exchanger: E-101
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

Meth H2O (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Meth H2O Fluid Package:
Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL AQUEOUS PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 145.4 145.4
Pressure: (kPa) 840.0 840.0

Molar Flow (kgmole/h) 954.8 954.8
Mass Flow (kg/h) 2.121e+004 2.121e+004
Std Ideal Liq VolFlow (m3/h) 23.63 23.63
Molar Enthalpy (kJ/kgmole) -2.605e+05 -2.605e+05
Molar Entropy (kJ/kgmole-C) 6.933e+01 6.933e+01
Heat Flow (kJ/h) -2.487e+08 -2.487e+08
Liq VolFlow @Std Cond (m3/h) 23.31 23.31
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.247 0.0086 379.9 0.0179 0.5668
0.0240
Methanol 269.1 0.2819 8623 0.4066 10.84
0.4585
H2O 677.5 0.7095 1.220e+004 0.5755 12.23
0.5175
Total 954.8 1.0000 2.121e+004 1.0000 23.63
1.0000
Aqueous Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.247 0.0086 379.9 0.0179 0.5668
0.0240
Methanol 269.1 0.2819 8623 0.4066 10.84
0.4585
H2O 677.5 0.7095 1.220e+004 0.5755 12.23
0.5175
Total 954.8 1.0000 2.121e+004 1.0000 23.63
1.0000
K VALUE

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	0.0000	---	0.0000
Methanol	0.0000	---	0.0000
H2O	0.0000	---	0.0000

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Pump: P-101 Reboiled Absorber: T-100
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

Meth Recycle (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Meth Recycle Fluid Package:
Basis-1

Ideal
CONDITIONS

Property Package: NRTL -

OVERALL VAPOUR PH.
 Vapour / Phase Fraction 1.0000 1.0000
 Temperature: (C) 136.3 136.3
 Pressure: (kPa) 870.0 870.0
 Molar Flow (kgmole/h) 650.0 650.0
 Mass Flow (kg/h) 1.965e+004 1.965e+004
 Std Ideal Liq VolFlow (m3/h) 24.41 24.41
 Molar Enthalpy (kJ/kgmole) -2.018e+05 -2.018e+05
 Molar Entropy (kJ/kgmole-C) 1.712e+02 1.712e+02
 Heat Flow (kJ/h) -1.312e+08 -1.312e+08
 Liq VolFlow @Std Cond (m3/h) 24.36 24.36
 COMPOSITION
 Overall Phase Vapour Fraction
 1.0000
 COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 16.83 0.0259 775.3 0.0395 1.157
 0.0474
 Methanol 532.2 0.8187 1.705e+004 0.8679 21.43
 0.8779
 H2O 101.0 0.1554 1820 0.0926 1.823
 0.0747
 Total 650.0 1.0000 1.965e+004 1.0000 24.41
 1.0000
 Vapour Phase Phase Fraction
 1.000
 COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 16.83 0.0259 775.3 0.0395 1.157
 0.0474
 Methanol 532.2 0.8187 1.705e+004 0.8679 21.43
 0.8779
 H2O 101.0 0.1554 1820 0.0926 1.823
 0.0747
 Total 650.0 1.0000 1.965e+004 1.0000 24.41
 1.0000
 K VALUE
 COMPONENTS MIXED LIGHT
 HEAVY
 diM-Ether --- --- ---
 Methanol --- --- ---
 H2O --- --- ---
 UNIT OPERATIONS
 FEED TO PRODUCT FROM LOGICAL
 CONNECTION
 Cooler: E-103 Reboiled Absorber: T-101
 UTILITIES
 (No utilities reference this stream)
 PROCESS UTILITY

 Waste Water (Material Stream): Conditions, Composition,
 K Value, Package Properties, Attachments

Material Stream: Waste Water
Basis-1

Fluid Package:

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL AQUEOUS PH.
 Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 174.1 174.1
 Pressure: (kPa) 890.0 890.0
 Molar Flow (kgmole/h) 629.8 629.8
 Mass Flow (kg/h) 1.139e+004 1.139e+004
 Std Ideal Liq VolFlow (m3/h) 11.43 11.43
 Molar Enthalpy (kJ/kgmole) -2.733e+05 -2.733e+05
 Molar Entropy (kJ/kgmole-C) 3.825e+01 3.825e+01
 Heat Flow (kJ/h) -1.721e+08 -1.721e+08
 Liq VolFlow @Std Cond (m3/h) 11.24 11.24
 COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 2.510e-004 0.0000 1.156e-002 0.0000
 1.725e-005 0.0000
 Methanol 2.733 0.0043 87.56 0.0077 0.1100
 0.0096
 H2O 627.1 0.9957 1.130e+004 0.9923 11.32
 0.9904
 Total 629.8 1.0000 1.139e+004 1.0000 11.43
 1.0000
 Aqueous Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 2.510e-004 0.0000 1.156e-002 0.0000
 1.725e-005 0.0000
 Methanol 2.733 0.0043 87.56 0.0077 0.1100
 0.0096
 H2O 627.1 0.9957 1.130e+004 0.9923 11.32
 0.9904
 Total 629.8 1.0000 1.139e+004 1.0000 11.43
 1.0000
 K VALUE

COMPONENTS MIXED LIGHT
 HEAVY
 diM-Ether 0.0000 --- 0.0000
 Methanol 0.0000 --- 0.0000
 H2O 0.0000 --- 0.0000
 UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
 CONNECTION
 Pump: P-105 Reboiled Absorber: T-101
 UTILITIES

(No utilities reference this stream)
 PROCESS UTILITY

meth feed 2 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: meth feed 2 Fluid Package:
 Basis-1

Ideal Property Package: NRTL -
 CONDITIONS

OVERALL LIQUID PH.
 Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 35.34 35.34
 Pressure: (kPa) 100.0 100.0
 Molar Flow (kgmole/h) 1576 1576
 Mass Flow (kg/h) 4.982e+004 4.982e+004
 Std Ideal Liq VolFlow (m3/h) 62.45 62.45
 Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
 Molar Entropy (kJ/kgmole-C) 5.513e+01 5.513e+01
 Heat Flow (kJ/h) -3.778e+08 -3.778e+08
 Liq VolFlow @Std Cond (m3/h) 62.39 62.39

COMPOSITION

Overall Phase Vapour Fraction
 0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
 0.0093
 Methanol 1511 0.9586 4.841e+004 0.9717 60.84
 0.9743
 H2O 56.77 0.0360 1023 0.0205 1.025
 0.0164
 Total 1576 1.0000 4.982e+004 1.0000 62.45
 1.0000
 Liquid Phase Phase Fraction
 1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
 0.0093
 Methanol 1511 0.9586 4.841e+004 0.9717 60.84
 0.9743
 H2O 56.77 0.0360 1023 0.0205 1.025
 0.0164
 Total 1576 1.0000 4.982e+004 1.0000 62.45
 1.0000
 K VALUE

COMPONENTS MIXED LIGHT
 HEAVY
 diM-Ether 0.0000 0.0000 ---
 Methanol 0.0000 0.0000 ---
 H2O 0.0000 0.0000 ---
 UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
 CONNECTION
 Pump: P-100 Mixer: MIX-100 Adjust: ADJ-3
 UTILITIES

(No utilities reference this stream)
 PROCESS UTILITY

Purge (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Purge Fluid Package:
 Basis-1

Ideal Property Package: NRTL -
 CONDITIONS

OVERALL VAPOUR PH. LIQUID
 PH. AQUEOUS PH.
 Vapour / Phase Fraction 0.0000 0.0000 0.5000
 0.5000
 Temperature: (C) 367.2 367.2 367.2 367.2
 Pressure: (kPa) 790.0 790.0 790.0 790.0
 Molar Flow (kgmole/h) 0.0000 0.0000 0.0000
 0.0000
 Mass Flow (kg/h) 0.0000 0.0000 0.0000
 0.0000
 Std Ideal Liq VolFlow (m3/h) 0.0000 0.0000 0.0000
 0.0000
 Molar Enthalpy (kJ/kgmole) -2.286e+05 -1.909e+05 -
 2.286e+05 -2.286e+05
 Molar Entropy (kJ/kgmole-C) 1.341e+02 2.008e+02
 1.341e+02 1.341e+02
 Heat Flow (kJ/h) 0.000e-01 0.000e-01 0.000e-01
 0.000e-01
 Liq VolFlow @Std Cond (m3/h) 0.0000 0.0000
 0.0000 0.0000
 COMPOSITION

Overall Phase Vapour Fraction
 0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 0.0000 0.2147 0.0000 0.3882 0.0000
 0.4728
 Methanol 0.0000 0.1028 0.0000 0.1292 0.0000
 0.1325
 H2O 0.0000 0.6825 0.0000 0.4825 0.0000
 0.3947
 Total 0.0000 1.0000 0.0000 1.0000 0.0000
 1.0000

Vapour Phase	Phase Fraction		
0.0000			
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC			
(kgmole/h)	(kg/h)	(m3/h)	
diM-Ether	0.0000	0.3991	0.0000
	0.6519		0.5817
Methanol	0.0000	0.1710	0.0000
	0.1637		0.1734
H2O	0.0000	0.4298	0.0000
	0.1844		0.2450
Total	0.0000	1.0000	0.0000
	1.0000		1.0000
Liquid Phase	Phase Fraction		
0.5000			
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC			
(kgmole/h)	(kg/h)	(m3/h)	
diM-Ether	0.0000	0.2147	0.0000
	0.4728		0.3882
Methanol	0.0000	0.1028	0.0000
	0.1325		0.1292
H2O	0.0000	0.6825	0.0000
	0.3947		0.4825
Total	0.0000	1.0000	0.0000
	1.0000		1.0000
Aqueous Phase	Phase Fraction		
0.5000			
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC			
(kgmole/h)	(kg/h)	(m3/h)	
diM-Ether	0.0000	0.2147	0.0000
	0.4728		0.3882
Methanol	0.0000	0.1028	0.0000
	0.1325		0.1292
H2O	0.0000	0.6825	0.0000
	0.3947		0.4825
Total	0.0000	1.0000	0.0000
	1.0000		1.0000
K VALUE			
COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	1.859	1.859	1.859
Methanol	1.665	1.665	1.665
H2O	0.6298	0.6298	0.6298
UNIT OPERATIONS			
FEED TO	PRODUCT FROM	LOGICAL	
CONNECTION			
	Gibbs Reactor: GBR-100		
UTILITIES			
(No utilities reference this stream)			
PROCESS UTILITY			
<hr/>			
D1 feed cooled (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments			
<hr/>			
Material Stream: D1 feed cooled	Fluid Package: Basis-1		
Property Package: NRTL -			
Ideal	CONDITIONS		
OVERALL LIQUID PH.			
Vapour / Phase Fraction	0.0000	1.0000	
Temperature: (C)	73.68	73.68	
Pressure: (kPa)	790.0	790.0	
Molar Flow (kgmole/h)	1576	1576	
Mass Flow (kg/h)	4.982e+004	4.982e+004	
Std Ideal Liq VolFlow (m3/h)	66.32	66.32	
Molar Enthalpy (kJ/kgmole)	-2.397e+05	-2.397e+05	
Molar Entropy (kJ/kgmole-C)	1.024e+02	1.024e+02	
Heat Flow (kJ/h)	-3.778e+08	-3.778e+08	
Liq VolFlow @ Std Cond (m3/h)	66.51	66.51	
COMPOSITION			
Overall Phase	Vapour Fraction		
0.0000			
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC			
(kgmole/h)	(kg/h)	(m3/h)	
diM-Ether	629.1	0.3991	2.898e+004
	0.6519		0.5817
Methanol	269.6	0.1710	8637
	0.1637		0.1734
H2O	677.5	0.4298	1.220e+004
	0.1844		0.2450
Total	1576	1.0000	4.982e+004
	1.0000		1.0000
Liquid Phase	Phase Fraction		
1.000			
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC			
(kgmole/h)	(kg/h)	(m3/h)	
diM-Ether	629.1	0.3991	2.898e+004
	0.6519		0.5817
Methanol	269.6	0.1710	8637
	0.1637		0.1734
H2O	677.5	0.4298	1.220e+004
	0.1844		0.2450
Total	1576	1.0000	4.982e+004
	1.0000		1.0000
K VALUE			
COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	0.0000	0.0000	---
Methanol	0.0000	0.0000	---
H2O	0.0000	0.0000	---
UNIT OPERATIONS			
FEED TO	PRODUCT FROM	LOGICAL	
CONNECTION			
	Pump: P-102	Cooler: E-102	
UTILITIES			

(No utilities reference this stream)
PROCESS UTILITY

DME outlet (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: DME outlet Fluid Package:
Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL VAPOUR PH.
Vapour / Phase Fraction 1.0000 1.0000
Temperature: (C) 37.94 37.94
Pressure: (kPa) 820.0 820.0
Molar Flow (kgmole/h) 1253 1253
Mass Flow (kg/h) 5.771e+004 5.771e+004
Std Ideal Liq VolFlow (m3/h) 86.08 86.08
Molar Enthalpy (kJ/kgmole) -1.833e+05 -1.833e+05
Molar Entropy (kJ/kgmole-C) 1.797e+02 1.797e+02
Heat Flow (kJ/h) -2.297e+08 -2.297e+08
Liq VolFlow @Std Cond (m3/h) 93.38 93.38
COMPOSITION

Overall Phase Vapour Fraction
1.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 1252 0.9993 5.768e+004 0.9995 86.05
0.9996
Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004
H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-005 0.0000
Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000
Vapour Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 1252 0.9993 5.768e+004 0.9995 86.05
0.9996
Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004
H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-005 0.0000
Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether --- --- ---
Methanol --- --- ---

H2O --- ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Cooler: E-104 Reboiled Absorber: T-100
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

meth feed 2 high P (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: meth feed 2 high P Fluid
Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 35.66 35.66
Pressure: (kPa) 790.0 790.0
Molar Flow (kgmole/h) 1576 1576
Mass Flow (kg/h) 4.982e+004 4.982e+004
Std Ideal Liq VolFlow (m3/h) 62.45 62.45
Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
Molar Entropy (kJ/kgmole-C) 7.194e+01 7.194e+01
Heat Flow (kJ/h) -3.777e+08 -3.777e+08
Liq VolFlow @Std Cond (m3/h) 62.39 62.39
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
0.0093
Methanol 1511 0.9586 4.841e+004 0.9717 60.84
0.9743
H2O 56.77 0.0360 1023 0.0205 1.025
0.0164
Total 1576 1.0000 4.982e+004 1.0000 62.45
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.414 0.0053 387.6 0.0078 0.5783
0.0093
Methanol 1511 0.9586 4.841e+004 0.9717 60.84
0.9743
H2O 56.77 0.0360 1023 0.0205 1.025
0.0164

Total	1576	1.0000	4.982e+004	1.0000	62.45							
1.0000						(kgmole/h)	(kg/h)	(m ³ /h)				
K VALUE						diM-Ether	16.83	0.0259	775.3	0.0395	1.157	
COMPONENTS	MIXED	LIGHT				0.0474						
HEAVY						Methanol	532.2	0.8187	1.705e+004	0.8679	21.43	
diM-Ether	0.0000	0.0000	---			0.8779						
Methanol	0.0000	0.0000	---			H2O	101.0	0.1554	1820	0.0926	1.823	
H2O	0.0000	0.0000	---			0.0747						
UNIT OPERATIONS						Total	650.0	1.0000	1.965e+004	1.0000	24.41	
FEED TO	PRODUCT FROM	LOGICAL				1.0000						
CONNECTION						K VALUE						
Heater: E-100	Pump: P-100											
UTILITIES												
(No utilities reference this stream)												
PROCESS UTILITY												

Cooled meth recycle (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments												

Material Stream: Cooled meth recycle			Fluid									
Package: Basis-1												

Property Package: NRTL -												
Ideal	CONDITIONS											
OVERALL LIQUID PH.												
Vapour / Phase Fraction	0.0000	1.0000										
Temperature: (C)	76.26	76.26										
Pressure: (kPa)	870.0	870.0										
Molar Flow (kgmole/h)	650.0	650.0										
Mass Flow (kg/h)	1.965e+004	1.965e+004										
Std Ideal Liq VolFlow (m ³ /h)	24.41	24.41										
Molar Enthalpy (kJ/kgmole)	-2.398e+05	-2.398e+05										
Molar Entropy (kJ/kgmole-C)	9.489e+01	9.489e+01										
Heat Flow (kJ/h)	-1.559e+08	-1.559e+08										
Liq VolFlow @Std Cond (m ³ /h)	24.36	24.36										
COMPOSITION												
Overall Phase	Vapour Fraction											
0.0000												
COMPONENTS MOLE FLOW MOLE FRAC MASS												
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC												
(kgmole/h)	(kg/h)	(m ³ /h)										
diM-Ether	16.83	0.0259	775.3	0.0395	1.157							
0.0474												
Methanol	532.2	0.8187	1.705e+004	0.8679	21.43							
0.8779												
H2O	101.0	0.1554	1820	0.0926	1.823							
0.0747												
Total	650.0	1.0000	1.965e+004	1.0000	24.41							
1.0000												
Liquid Phase	Phase Fraction											
1.000												
COMPONENTS MOLE FLOW MOLE FRAC MASS												
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC												
(kgmole/h)	(kg/h)	(m ³ /h)										
diM-Ether	8.415	0.0259	387.7	0.0395	0.5783							
0.0474												
Methanol	266.1	0.8187	8526	0.8679	10.71							
0.8779												
H2O	50.50	0.1554	909.8	0.0926	0.9116							
0.0747												

Total 325.0 1.0000 9823 1.0000 12.20
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.415 0.0259 387.7 0.0395 0.5783
0.0474
Methanol 266.1 0.8187 8526 0.8679 10.71
0.8779
H2O 50.50 0.1554 909.8 0.0926 0.9116
0.0747
Total 325.0 1.0000 9823 1.0000 12.20
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY

diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Recycle: RCY-3 Tee: TEE-100
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

meth to tower (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: meth to tower Fluid Package:
Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 76.28 76.28
Pressure: (kPa) 910.0 910.0
Molar Flow (kgmole/h) 325.0 325.0
Mass Flow (kg/h) 9823 9823
Std Ideal Liq VolFlow (m3/h) 12.20 12.20
Molar Enthalpy (kJ/kgmole) -2.398e+05 -2.398e+05
Molar Entropy (kJ/kgmole-C) 9.521e+01 9.521e+01
Heat Flow (kJ/h) -7.794e+07 -7.794e+07
Liq VolFlow @Std Cond (m3/h) 12.18 12.18
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.415 0.0259 387.7 0.0395 0.5783

0.0474
Methanol 266.1 0.8187 8526 0.8679 10.71
0.8779

H2O 50.50 0.1554 909.8 0.0926 0.9116
0.0747

Total 325.0 1.0000 9823 1.0000 12.20

1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.415 0.0259 387.7 0.0395 0.5783

0.0474
Methanol 266.1 0.8187 8526 0.8679 10.71
0.8779

H2O 50.50 0.1554 909.8 0.0926 0.9116
0.0747

Total 325.0 1.0000 9823 1.0000 12.20

1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY

diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Recycle: RCY-2 Tee: TEE-100
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

DME out2 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: DME out2 Fluid Package:
Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 36.94 36.94
Pressure: (kPa) 820.0 820.0
Molar Flow (kgmole/h) 1253 1253
Mass Flow (kg/h) 5.771e+004 5.771e+004
Std Ideal Liq VolFlow (m3/h) 86.08 86.08
Molar Enthalpy (kJ/kgmole) -2.022e+05 -2.022e+05
Molar Entropy (kJ/kgmole-C) 1.536e+02 1.536e+02
Heat Flow (kJ/h) -2.533e+08 -2.533e+08
Liq VolFlow @Std Cond (m3/h) 93.38 93.38

COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 1252 0.9993 5.768e+004 0.9995 86.05
0.9996
Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004
H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-
005 0.0000
Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 1252 0.9993 5.768e+004 0.9995 86.05
0.9996
Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004
H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-
005 0.0000
Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000

K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Pump: P-104 Cooler: E-104 Adjust: ADJ-1
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

DME reflux (Material Stream): Conditions, Composition,
K Value, Package Properties, Attachments

Material Stream: DME reflux Fluid Package:
Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 36.98 36.98
Pressure: (kPa) 860.0 860.0

Molar Flow (kgmole/h) 631.6 631.6
Mass Flow (kg/h) 2.909e+004 2.909e+004
Std Ideal Liq VolFlow (m3/h) 43.39 43.39
Molar Enthalpy (kJ/kgmole) -2.022e+05 -2.022e+05
Molar Entropy (kJ/kgmole-C) 1.540e+02 1.540e+02
Heat Flow (kJ/h) -1.277e+08 -1.277e+08
Liq VolFlow @Std Cond (m3/h) 47.07 47.07
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 631.1 0.9993 2.908e+004 0.9995 43.38
0.9996
Methanol 0.4528 0.0007 14.51 0.0005 1.823e-002
0.0004
H2O 2.198e-003 0.0000 3.960e-002 0.0000 3.968e-
005 0.0000
Total 631.6 1.0000 2.909e+004 1.0000 43.39
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 631.1 0.9993 2.908e+004 0.9995 43.38
0.9996
Methanol 0.4528 0.0007 14.51 0.0005 1.823e-002
0.0004
H2O 2.198e-003 0.0000 3.960e-002 0.0000 3.968e-
005 0.0000
Total 631.6 1.0000 2.909e+004 1.0000 43.39
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Reboiled Absorber: T-100 Recycle: RCY-1
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

DME product (Material Stream): Conditions, Composition,
K Value, Package Properties, Attachments

Material Stream: DME product Fluid Package:
Basis-1

Ideal
CONDITIONS

Property Package: NRTL -

OVERALL LIQUID PH.
 Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 36.98 36.98
 Pressure: (kPa) 860.0 860.0
 Molar Flow (kgmole/h) 626.4 626.4
 Mass Flow (kg/h) 2.885e+004 2.885e+004
 Std Ideal Liq VolFlow (m3/h) 43.04 43.04
 Molar Enthalpy (kJ/kgmole) -2.022e+05 -2.022e+05
 Molar Entropy (kJ/kgmole-C) 1.540e+02 1.540e+02
 Heat Flow (kJ/h) -1.267e+08 -1.267e+08
 Liq VolFlow @Std Cond (m3/h) 46.69 46.69
 COMPOSITION
 Overall Phase Vapour Fraction
 0.0000
 COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 626.0 0.9993 2.884e+004 0.9995 43.02
 0.9996
 Methanol 0.4490 0.0007 14.39 0.0005 1.808e-002
 0.0004
 H2O 2.143e-003 0.0000 3.861e-002 0.0000 3.869e-
 005 0.0000
 Total 626.4 1.0000 2.885e+004 1.0000 43.04
 1.0000
 Liquid Phase Phase Fraction
 1.000
 COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 626.0 0.9993 2.884e+004 0.9995 43.02
 0.9996
 Methanol 0.4490 0.0007 14.39 0.0005 1.808e-002
 0.0004
 H2O 2.143e-003 0.0000 3.861e-002 0.0000 3.869e-
 005 0.0000
 Total 626.4 1.0000 2.885e+004 1.0000 43.04
 1.0000
 K VALUE
 COMPONENTS MIXED LIGHT
 HEAVY
 diM-Ether 0.0000 0.0000 ---
 Methanol 0.0000 0.0000 ---
 H2O 0.0000 0.0000 ---
 UNIT OPERATIONS
 FEED TO PRODUCT FROM LOGICAL
 CONNECTION
 Tee: TEE-101
 UTILITIES
 (No utilities reference this stream)
 PROCESS UTILITY

DME reflux 1 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: DME reflux 1
Basis-1

Fluid Package:

Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 36.98 36.98
 Pressure: (kPa) 860.0 860.0
 Molar Flow (kgmole/h) 626.4 626.4
 Mass Flow (kg/h) 2.885e+004 2.885e+004
 Std Ideal Liq VolFlow (m3/h) 43.04 43.04
 Molar Enthalpy (kJ/kgmole) -2.022e+05 -2.022e+05
 Molar Entropy (kJ/kgmole-C) 1.540e+02 1.540e+02
 Heat Flow (kJ/h) -1.267e+08 -1.267e+08
 Liq VolFlow @Std Cond (m3/h) 46.69 46.69
 COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 626.0 0.9993 2.884e+004 0.9995 43.02
 0.9996
 Methanol 0.4490 0.0007 14.39 0.0005 1.808e-002
 0.0004
 H2O 2.143e-003 0.0000 3.861e-002 0.0000 3.869e-
 005 0.0000
 Total 626.4 1.0000 2.885e+004 1.0000 43.04
 1.0000
 Liquid Phase Phase Fraction
 1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 626.0 0.9993 2.884e+004 0.9995 43.02
 0.9996
 Methanol 0.4490 0.0007 14.39 0.0005 1.808e-002
 0.0004
 H2O 2.143e-003 0.0000 3.861e-002 0.0000 3.869e-
 005 0.0000
 Total 626.4 1.0000 2.885e+004 1.0000 43.04
 1.0000
 K VALUE

COMPONENTS MIXED LIGHT

HEAVY
 diM-Ether 0.0000 0.0000 ---
 Methanol 0.0000 0.0000 ---
 H2O 0.0000 0.0000 ---
 UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
 CONNECTION Recycle: RCY-1 Tee: TEE-101
 UTILITIES

(No utilities reference this stream)
 PROCESS UTILITY

METH reflux (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: METH reflux Fluid Package:
 Basis-1

Ideal Property Package: NRTL -
 CONDITIONS

OVERALL LIQUID PH.
 Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 76.29 76.29
 Pressure: (kPa) 910.0 910.0
 Molar Flow (kgmole/h) 325.0 325.0
 Mass Flow (kg/h) 9825 9825
 Std Ideal Liq VolFlow (m3/h) 12.21 12.21
 Molar Enthalpy (kJ/kgmole) -2.398e+05 -2.398e+05
 Molar Entropy (kJ/kgmole-C) 9.524e+01 9.524e+01
 Heat Flow (kJ/h) -7.795e+07 -7.795e+07
 Liq VolFlow @Std Cond (m3/h) 12.18 12.18

COMPOSITION

Overall Phase Vapour Fraction
 0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 8.583 0.0264 395.4 0.0402 0.5899
 0.0483
 Methanol 265.8 0.8177 8517 0.8669 10.70
 0.8768
 H2O 50.66 0.1558 912.6 0.0929 0.9144
 0.0749
 Total 325.0 1.0000 9825 1.0000 12.21
 1.0000
 Liquid Phase Phase Fraction
 1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 8.583 0.0264 395.4 0.0402 0.5899
 0.0483
 Methanol 265.8 0.8177 8517 0.8669 10.70
 0.8768
 H2O 50.66 0.1558 912.6 0.0929 0.9144
 0.0749
 Total 325.0 1.0000 9825 1.0000 12.21
 1.0000
 K VALUE

COMPONENTS MIXED LIGHT
 HEAVY
 diM-Ether 0.0000 0.0000 ---
 Methanol 0.0000 0.0000 ---
 H2O 0.0000 0.0000 ---
 UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
 CONNECTION Reboiled Absorber: T-101 Recycle: RCY-2
 UTILITIES

(No utilities reference this stream)
 PROCESS UTILITY

meth to rctr 2 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: meth to rctr 2 Fluid Package:
 Basis-1

Ideal Property Package: NRTL -
 CONDITIONS

OVERALL LIQUID PH.
 Vapour / Phase Fraction 0.0000 1.0000
 Temperature: (C) 76.28 76.28
 Pressure: (kPa) 910.0 910.0
 Molar Flow (kgmole/h) 325.0 325.0
 Mass Flow (kg/h) 9823 9823
 Std Ideal Liq VolFlow (m3/h) 12.20 12.20
 Molar Enthalpy (kJ/kgmole) -2.398e+05 -2.398e+05
 Molar Entropy (kJ/kgmole-C) 9.521e+01 9.521e+01
 Heat Flow (kJ/h) -7.795e+07 -7.795e+07
 Liq VolFlow @Std Cond (m3/h) 12.18 12.18

COMPOSITION

Overall Phase Vapour Fraction
 0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 8.414 0.0259 387.6 0.0395 0.5783
 0.0474
 Methanol 266.1 0.8187 8526 0.8679 10.71
 0.8779
 H2O 50.51 0.1554 910.0 0.0926 0.9118
 0.0747
 Total 325.0 1.0000 9823 1.0000 12.20
 1.0000
 Liquid Phase Phase Fraction
 1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m3/h)
 diM-Ether 8.414 0.0259 387.6 0.0395 0.5783
 0.0474

Methanol 266.1 0.8187 8526 0.8679 10.71
0.8779
H2O 50.51 0.1554 910.0 0.0926 0.9118
0.0747
Total 325.0 1.0000 9823 1.0000 12.20
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Mixer: MIX-100 Recycle: RCY-3
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

Meth H2O Pumped (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: Meth H2O Pumped Fluid
Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL AQUEOUS PH.

Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 145.4 145.4
Pressure: (kPa) 880.0 880.0
Molar Flow (kgmole/h) 954.8 954.8
Mass Flow (kg/h) 2.121e+004 2.121e+004
Std Ideal Liq VolFlow (m3/h) 23.63 23.63
Molar Enthalpy (kJ/kgmole) -2.605e+05 -2.605e+05
Molar Entropy (kJ/kgmole-C) 6.944e+01 6.944e+01
Heat Flow (kJ/h) -2.487e+08 -2.487e+08
Liq VolFlow @Std Cond (m3/h) 23.31 23.31
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.247 0.0086 379.9 0.0179 0.5668
0.0240
Methanol 269.1 0.2819 8623 0.4066 10.84
0.4585
H2O 677.5 0.7095 1.220e+004 0.5755 12.23
0.5175
Total 954.8 1.0000 2.121e+004 1.0000 23.63
1.0000

Aqueous Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 8.247 0.0086 379.9 0.0179 0.5668
0.0240
Methanol 269.1 0.2819 8623 0.4066 10.84
0.4585
H2O 677.5 0.7095 1.220e+004 0.5755 12.23
0.5175
Total 954.8 1.0000 2.121e+004 1.0000 23.63
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether 0.0000 --- 0.0000
Methanol 0.0000 --- 0.0000
H2O 0.0000 --- 0.0000
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Reboiled Absorber: T-101 Pump: P-101
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

D1 feed pumped (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: D1 feed pumped Fluid
Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 73.70 73.70
Pressure: (kPa) 830.0 830.0
Molar Flow (kgmole/h) 1576 1576
Mass Flow (kg/h) 4.982e+004 4.982e+004
Std Ideal Liq VolFlow (m3/h) 66.32 66.32
Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
Molar Entropy (kJ/kgmole-C) 1.026e+02 1.026e+02
Heat Flow (kJ/h) -3.778e+08 -3.778e+08
Liq VolFlow @Std Cond (m3/h) 66.51 66.51
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 629.1 0.3991 2.898e+004 0.5817 43.24
0.6519

Methanol 269.6 0.1710 8637 0.1734 10.85

0.1637

H2O 677.5 0.4298 1.220e+004 0.2450 12.23

0.1844

Total 1576 1.0000 4.982e+004 1.0000 66.32

1.0000

Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 629.1 0.3991 2.898e+004 0.5817 43.24

0.6519

Methanol 269.6 0.1710 8637 0.1734 10.85

0.1637

H2O 677.5 0.4298 1.220e+004 0.2450 12.23

0.1844

Total 1576 1.0000 4.982e+004 1.0000 66.32

1.0000

K VALUE

COMPONENTS MIXED LIGHT

HEAVY

diM-Ether 0.0000 0.0000 ---

Methanol 0.0000 0.0000 ---

H2O 0.0000 0.0000 ---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION

Tee: TEE-102 Pump: P-102

UTILITIES

(No utilities reference this stream)

PROCESS UTILITY

CMR2 (Material Stream): Conditions, Composition, K
Value, Package Properties, Attachments

Material Stream: CMR2 Fluid Package:
Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction 0.0000 1.0000

Temperature: (C) 76.28 76.28

Pressure: (kPa) 910.0 910.0

Molar Flow (kgmole/h) 650.0 650.0

Mass Flow (kg/h) 1.965e+004 1.965e+004

Std Ideal Liq VolFlow (m3/h) 24.41 24.41

Molar Enthalpy (kJ/kgmole) -2.398e+05 -2.398e+05

Molar Entropy (kJ/kgmole-C) 9.521e+01 9.521e+01

Heat Flow (kJ/h) -1.559e+08 -1.559e+08

Liq VolFlow @Std Cond (m3/h) 24.36 24.36

COMPOSITION

Overall Phase Vapour Fraction

0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 16.83 0.0259 775.3 0.0395 1.157

0.0474

Methanol 532.2 0.8187 1.705e+004 0.8679 21.43

0.8779

H2O 101.0 0.1554 1820 0.0926 1.823

0.0747

Total 650.0 1.0000 1.965e+004 1.0000 24.41

1.0000

Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 16.83 0.0259 775.3 0.0395 1.157

0.0474

Methanol 532.2 0.8187 1.705e+004 0.8679 21.43

0.8779

H2O 101.0 0.1554 1820 0.0926 1.823

0.0747

Total 650.0 1.0000 1.965e+004 1.0000 24.41

1.0000

K VALUE

COMPONENTS MIXED LIGHT

HEAVY

diM-Ether 0.0000 0.0000 ---

Methanol 0.0000 0.0000 ---

H2O 0.0000 0.0000 ---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION

Tee: TEE-100 Pump: P-103

UTILITIES

(No utilities reference this stream)

PROCESS UTILITY

DME out3 (Material Stream): Conditions, Composition, K
Value, Package Properties, Attachments

Material Stream: DME out3 Fluid Package:
Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction 0.0000 1.0000

Temperature: (C) 36.98 36.98

Pressure: (kPa) 860.0 860.0

Molar Flow (kgmole/h) 1253 1253

Mass Flow (kg/h) 5.771e+004 5.771e+004

Std Ideal Liq VolFlow (m3/h) 86.08 86.08

Molar Enthalpy (kJ/kgmole) -2.022e+05 -2.022e+05

Molar Entropy (kJ/kgmole-C) 1.540e+02 1.540e+02

Heat Flow (kJ/h) -2.533e+08 -2.533e+08

Liq VolFlow @Std Cond (m3/h) 93.38 93.38

COMPOSITION

Overall Phase	Vapour Fraction
0.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 1252 0.9993 5.768e+004 0.9995 86.05

0.9996

Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004

H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-
005 0.0000

Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000

Liquid Phase	Phase Fraction
1.000	

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 1252 0.9993 5.768e+004 0.9995 86.05
0.9996

Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004

H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-
005 0.0000

Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000

K VALUE

COMPONENTS MIXED LIGHT

HEAVY

diM-Ether 0.0000 0.0000 ---

Methanol 0.0000 0.0000 ---

H2O 0.0000 0.0000 ---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION

Tee: TEE-101 Pump: P-104

UTILITIES

(No utilities reference this stream)

PROCESS UTILITY

WWT (Material Stream): Conditions, Composition, K
Value, Package Properties, Attachments

Material Stream: WWT Fluid Package:
Basis-1

Property Package: NRTL -
Ideal

CONDITIONS

OVERALL AQUEOUS PH.

Vapour / Phase Fraction 0.0000 1.0000

Temperature: (C) 174.1 174.1

Pressure: (kPa) 930.0 930.0

Molar Flow (kgmole/h) 629.8 629.8

Mass Flow (kg/h) 1.139e+004 1.139e+004

Std Ideal Liq VolFlow (m3/h) 11.43 11.43

Molar Enthalpy (kJ/kgmole) -2.733e+05 -2.733e+05

Molar Entropy (kJ/kgmole-C) 3.825e+01 3.825e+01

Heat Flow (kJ/h) -1.721e+08 -1.721e+08

Liq VolFlow @Std Cond (m3/h) 11.24 11.24

COMPOSITION

Overall Phase	Vapour Fraction
0.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 2.510e-004 0.0000 1.156e-002 0.0000
1.725e-005 0.0000

Methanol 2.733 0.0043 87.56 0.0077 0.1100
0.0096

H2O 627.1 0.9957 1.130e+004 0.9923 11.32
0.9904

Total 629.8 1.0000 1.139e+004 1.0000 11.43
1.0000

Aqueous Phase	Phase Fraction
1.000	

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether 2.510e-004 0.0000 1.156e-002 0.0000
1.725e-005 0.0000

Methanol 2.733 0.0043 87.56 0.0077 0.1100
0.0096

H2O 627.1 0.9957 1.130e+004 0.9923 11.32
0.9904

Total 629.8 1.0000 1.139e+004 1.0000 11.43
1.0000

K VALUE

COMPONENTS MIXED LIGHT

HEAVY

diM-Ether 0.0000 --- 0.0000

Methanol 0.0000 --- 0.0000

H2O 0.0000 --- 0.0000

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL

CONNECTION Pump: P-105

UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

normal op (Material Stream): Conditions, Composition, K
Value, Package Properties, Attachments

Material Stream: normal op
Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 73.70 73.70
Pressure: (kPa) 830.0 830.0
Molar Flow (kgmole/h) 788.1 788.1
Mass Flow (kg/h) 2.491e+004 2.491e+004
Std Ideal Liq VolFlow (m3/h) 33.16 33.16
Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
Molar Entropy (kJ/kgmole-C) 1.026e+02 1.026e+02
Heat Flow (kJ/h) -1.889e+08 -1.889e+08
Liq VolFlow @Std Cond (m3/h) 33.26 33.26
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 314.6 0.3991 1.449e+004 0.5817 21.62
0.6519
Methanol 134.8 0.1710 4319 0.1734 5.427
0.1637
H2O 338.7 0.4298 6102 0.2450 6.115
0.1844
Total 788.1 1.0000 2.491e+004 1.0000 33.16
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 314.6 0.3991 1.449e+004 0.5817 21.62
0.6519
Methanol 134.8 0.1710 4319 0.1734 5.427
0.1637
H2O 338.7 0.4298 6102 0.2450 6.115
0.1844
Total 788.1 1.0000 2.491e+004 1.0000 33.16
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Reboiled Absorber: T-100 Tee: TEE-102
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

turn down (Material Stream): Conditions, Composition, K
Value, Package Properties, Attachments

Material Stream: turn down Fluid Package:
Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 73.70 73.70
Pressure: (kPa) 830.0 830.0
Molar Flow (kgmole/h) 788.1 788.1
Mass Flow (kg/h) 2.491e+004 2.491e+004
Std Ideal Liq VolFlow (m3/h) 33.16 33.16
Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
Molar Entropy (kJ/kgmole-C) 1.026e+02 1.026e+02
Heat Flow (kJ/h) -1.889e+08 -1.889e+08
Liq VolFlow @Std Cond (m3/h) 33.26 33.26
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 314.6 0.3991 1.449e+004 0.5817 21.62
0.6519
Methanol 134.8 0.1710 4319 0.1734 5.427
0.1637
H2O 338.7 0.4298 6102 0.2450 6.115
0.1844
Total 788.1 1.0000 2.491e+004 1.0000 33.16
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 314.6 0.3991 1.449e+004 0.5817 21.62
0.6519
Methanol 134.8 0.1710 4319 0.1734 5.427
0.1637
H2O 338.7 0.4298 6102 0.2450 6.115
0.1844
Total 788.1 1.0000 2.491e+004 1.0000 33.16
1.0000
K VALUE

COMPONENTS	MIXED	LIGHT	Temperature (C)	Pressure (kPa)	Heat Flow (kJ/h)	Enthalpy (kJ/kgmole)
HEAVY			35.66	790.00	0.00	-239657.87
diM-Ether	0.0000	0.0000	---			
Methanol	0.0000	0.0000	---			
H2O	0.0000	0.0000	---			
UNIT OPERATIONS			55.66	790.00	3663562.60	-237333.44
FEED TO CONNECTION	PRODUCT FROM	LOGICAL	65.66	790.00	5525463.73	-236152.12
Reboiled Absorber: T-100 Tee: TEE-102			75.66	790.00	7410938.23	-234955.84
UTILITIES			85.66	790.00	9323138.06	-233742.61
(No utilities reference this stream)			95.66	790.00	11265774.73	-232510.06
PROCESS UTILITY			105.66	790.00	13243344.37	-231255.35
E-100 (Heater): Design, Rating, Profiles, Tables			115.66	790.00	15261719.39	-229974.75
Heater: E-100			125.66	790.00	17332646.11	-228660.81
CONNECTIONS			135.66	790.00	66709614.10	-197332.55
Inlet Stream			Vapour Fraction	Vap Phase Mass Frac	Heat of Vap (kJ/kgmole)	
STREAM NAME	meth feed 2 high P	FROM UNIT OPERATION	0.0000	0.0000	---	
		P-100 Pump	0.0000	0.0000	---	
Outlet Stream			0.0000	0.0000	---	
STREAM NAME	meth feed 3	TO UNIT OPERATION	0.0000	0.0000	---	
		E-101 Heat Exchanger	0.0000	0.0000	---	
Energy Stream			1.0000	1.0000	---	
STREAM NAME	heater 1	FROM UNIT OPERATION	Vapour Phase			
PARAMETERS						
Pressure Drop: 0.0000 kPa	Duty: 6.671e+007 kJ/h		Mass Flow (kg/h)	Molecular Wt (kg/m3)	Density (kJ/kg-C)	Mass Sp Heat (W/m-K)
Volume: 0.1000 m3			---	---	---	---
Function: Not Selected	Zones: 1		---	---	---	---
User Variables			---	---	---	---
RATING			---	---	---	---
NOZZLE PARAMETERS			49823.49	31.61	7.35	1.65
Base Elevation Relative to Ground Level	0.0000 m		0.01	0.02		
meth feed 2 high P	meth feed 3		Std Gas Flow Z Factor	Pseudo Pc	Pseudo Tc	Pseudo Omega
Diameter (m)	5.000e-002	5.000e-002	(STD_m3/h)	(kPa)	(C)	
Elevation (Base) (m)	0.0000	0.0000	---	---	---	---
Elevation (Ground) (m)	0.0000	0.0000	---	---	---	---
PERFORMANCE PROFILES			---	---	---	---
Zone	Pressure	Temperature	Vapour Fraction	---	---	---
Enthalpy	(kPa)	(C)	(kJ/kgmole)	---	---	---
Inlet	790.00	35.66	0.0000	-239657.87		
0	790.00	135.66	1.0000	-197332.55		
PERFORMANCE TABLE			37266.37	1.00	7896.50	243.70
Overall Phase			Light Liquid Phase	0.25	0.55	
			Mass Flow (kg/h)	Density (kg/m3)	Mass Sp Heat (kJ/kg-C)	Viscosity (cP)
			Cond Surface Tens (dyne/cm)	Tens (W/m-K)		

49823.49	777.61	3.64	0.47	0.19	29.32
49823.49	766.97	3.68	0.41	0.18	27.74
49823.49	756.10	3.72	0.37	0.18	26.17
49823.49	744.98	3.76	0.33	0.17	24.61
49823.49	733.56	3.81	0.29	0.17	23.06
49823.49	721.82	3.87	0.26	0.16	21.52
49823.49	709.71	3.93	0.23	0.16	20.00
49823.49	697.17	4.01	0.21	0.15	18.50
49823.49	684.12	4.10	0.19	0.15	17.01
49823.49	670.49	4.24	0.17	0.14	15.54

Molecular Zc	Wt Pseudo	Sp Omega	Gravity	Pseudo	Pc	Pseudo	Tc	Pseudo
(kPa)	(C)							
31.61	0.78		7896.50	243.70	0.25	0.55		
31.61	0.77		7896.50	243.70	0.25	0.55		
31.61	0.76		7896.50	243.70	0.25	0.55		
31.61	0.74		7896.50	243.70	0.25	0.55		
31.61	0.73		7896.50	243.70	0.25	0.55		
31.61	0.72		7896.50	243.70	0.25	0.55		
31.61	0.71		7896.50	243.70	0.25	0.55		
31.61	0.70		7896.50	243.70	0.25	0.55		
31.61	0.68		7896.50	243.70	0.25	0.55		
31.61	0.67		7896.50	243.70	0.25	0.55		

Heavy Liquid Phase

Mass Flow Cond	Density Surface	Mass Tens	Sp	Heat	Viscosity	Thermal
(kg/h)	(kg/m ³)	(N/m)	(kJ/kg-C)	(cP)	(W/m-K)	
(dyne/cm)						
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---

Molecular Zc	Wt Pseudo	Sp Omega	Gravity	Pseudo	Pc	Pseudo	Tc	Pseudo
(kPa)	(C)							
---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---

Mixed Liquid Phase

Mass Flow Cond	Density Surface	Mass Tens	Sp	Heat	Viscosity	Thermal
(kg/h)	(kg/m ³)	(N/m)	(kJ/kg-C)	(cP)	(W/m-K)	
(dyne/cm)						
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---
---	---	---	---	---	---	---

49823.49	777.61	3.64	0.47	0.19	29.32
49823.49	766.97	3.68	0.41	0.18	27.74
49823.49	756.10	3.72	0.37	0.18	26.17
49823.49	744.98	3.76	0.33	0.17	24.61
49823.49	733.56	3.81	0.29	0.17	23.06
49823.49	721.82	3.87	0.26	0.16	21.52
49823.49	709.71	3.93	0.23	0.16	20.00
49823.49	697.17	4.01	0.21	0.15	18.50
49823.49	684.12	4.10	0.19	0.15	17.01
49823.49	670.49	4.24	0.17	0.14	15.54

Molecular Zc	Wt Pseudo	Sp Omega	Gravity	Pseudo	Pc	Pseudo	Tc	Pseudo
(kPa)	(C)							
31.61	0.78		7896.50	243.70	0.25	0.55		
31.61	0.77		7896.50	243.70	0.25	0.55		
31.61	0.76		7896.50	243.70	0.25	0.55		
31.61	0.74		7896.50	243.70	0.25	0.55		
31.61	0.73		7896.50	243.70	0.25	0.55		
31.61	0.72		7896.50	243.70	0.25	0.55		
31.61	0.71		7896.50	243.70	0.25	0.55		
31.61	0.70		7896.50	243.70	0.25	0.55		
31.61	0.68		7896.50	243.70	0.25	0.55		
31.61	0.67		7896.50	243.70	0.25	0.55		

E-101 (Heat Exchanger): Design, Rating, Details, Tables, HTFS Results, Exchanger Design and Rating

Heat Exchanger: E-101

CONNECTIONS

Tube Side Shell Side

Inlet Name	Outlet Name	Inlet Name	Outlet Name
meth feed 3	reactor feed	reactor out	
Name D1 feed			
From Op. E-100	To Op. GBR-100	From Op. GBR-100	To Op. E-102
Op. Type Heater	Op. Type Gibbs Reactor	Op. Type Gibbs Reactor	Op. Type Cooler
Temp 135.66 C	Temp 250.00 C	Temp 367.22 C	
Temp 273.68 C			

PARAMETERS

Heat Exchanger Model: Simple End Point

Tube Side DeltaP: 0.0000 kPa Shell Side DeltaP: 0.0000 kPa Passes: --- UA: 7.969e+004 kJ/C-h Tolerance: 1.0000e-04 Tube Side Data Shell Side Data Heat Transfer Coeff --- Heat Transfer Coeff --- Tube Pressure Drop 0.00 kPa Shell Pressure Drop 0.00 kPa Fouling 0.00000 C-h-m²/kJ Fouling 0.00000 C-h-m²/kJ Tube Length 6.00 m Shell Passes 2 Tube O.D. 20.00 mm Shell Series 1

Tube Thickness 2.0000 mm Shell Parallel 1
 Tube Pitch 50.0000 mm Baffle Type Single
 Orientation Horizontal Baffle Cut(% Area) 20.00
 Passes Per Shell 2 Baffle Orientation Horizontal
 Tubes Per Shell 160 Spacing 800.0000
 mm
 Layout Angle Triangular (30 degrees) Diameter
 739.0488 mm
 TEMA Type A F L Area 60.32 m²
 SPECS

Spec	Value	Curr Value	Rel Error	Active Estimate
E-101 Heat Balance	0.0000 kJ/h	1.637e-009 kJ/h	1.613e-016	On Off
E-101 UA	---	7.969e+004 kJ/C-h	---	On Off

Detailed Specifications

E-101 Heat Balance
 Type: Duty Pass: Error Spec Value: 0.0000
 kJ/h
 E-101 UA
 Type: UA Pass: Overall Spec Value: ---
 User Variables

RATING

Sizing

Overall Data
 Configuration
 # of Shells in Series 1 Tube Passes per Shell 2 Elevation
 (Base) 0.0000 m
 # of Shells in Parallel 1 Exchange Orientation Horizontal
 First Tube Pass Flow Direction Counter
 TEMA Type: A F L
 Calculated Information
 Shell HT Coeff --- Tube HT Coeff ---
 Overall U 1321 kJ/h-m²-C Overall UA 7.969e+004
 kJ/C-h
 Shell DP 0.0000 kPa Tube DP 0.0000 kPa
 Shell Vol per Shell 2.272 m³ Tube Vol per Shell
 0.1930 m³

HT Area per Shell 60.32 m²

Shell Data

Shell and Tube Bundle
 Shell Diameter 739.0 Tube Pitch 50.00 Shell Fouling
 0.0000
 (mm) (mm) (C-h-m²/kJ)
 # of Tubes per Shell 160 Tube Layout Angle Triangular (30
 degrees)
 Shell Baffles
 Shell Baffle Type Single Shell Baffle Orientation
 Horizontal
 Baffle Cut (% Area) 20.00 Baffle Spacing 800.0 mm
 Tube Data
 Dimensions
 OD 20.00 ID 16.00 Tube Thickness 2.000 Tube
 Length 6.000
 (mm) (mm) (mm) (m)
 Tube Properties

Tube Fouling 0.0000 Thermal Cond. 45.00 Wall Cp ---
 Wall Density ---
 (C-h-m²/kJ) (W/m-K) (kJ/kg-C) (kg/m³)
 Nozzle Parameters

Base Elevation Relative to Ground Level 0.0000 m			
meth feed 3	reactor out	reactor feed	
Diameter (m)	5.000e-002	5.000e-002	5.000e-002
Elevation (Base) (m)	0.0000	0.0000	0.0000
Elevation (Ground) (m)	0.0000	0.0000	0.0000
Elevation (% of Height) (%)	0.00	0.00	0.00
D1 feed			
Diameter (m)	5.000e-002		
Elevation (Base) (m)	0.0000		
Elevation (Ground) (m)	0.0000		
Elevation (% of Height) (%)	0.00		

DETAILS

Overall/Detailed Performance

Duty: 1.015e+07 kJ/h	UA Curv. Error: 0.00e-01
kJ/C-h	
Heat Leak: 0.000e-01 kJ/h	Hot Pinch Temp: 367.2 C
Heat Loss: 0.000e-01 kJ/h	Cold Pinch Temp: 250.0 C
UA: 7.969e+04 kJ/C-h	Ft Factor: ---
Min. Approach: 117.2 C	Uncorrected Lmtd: 127.3
C	
Lmtd: 127.3 C	

TABLES

Shell Side - Overall Phase

Temperature (C)	Pressure (kPa)	Heat Flow (kJ/h)	Enthalpy (kJ/kgmole)
273.68	790.00	0.00	-197332.55
367.22	790.00	10147733.23	-190894.10
UA	Molar Vap Frac	Mass Vap Frac	Heat of Vap.
(kJ/C-h)			(kJ/kgmole)
0.00	1.0000	1.0000	---
0.00	1.0000	1.0000	---

Shell Side - Vapour Phase

Mass Flow Viscosity (kg/h)	Molecular Wt (kg/m ³)	Density (kJ/kg-C)	Mass Sp Heat (cP)	Thermal Cond (W/m-K)
----------------------------	-----------------------------------	-------------------	-------------------	----------------------

49823.68	31.61	5.49	2.09	0.02	0.04
49823.68	31.61	4.69	2.27	0.02	0.05

Std Gas Flow Z Factor	Pseudo Pc	Pseudo Tc	Pseudo Zc	Pseudo Omega
-----------------------	-----------	-----------	-----------	--------------

(STD_m ³ /h)	(kPa)	(C)		
-------------------------	-------	-----	--	--

37266.37	1.00	12892.78	252.40	0.26	0.32
----------	------	----------	--------	------	------

37266.37	1.00	12892.78	252.40	0.26	0.32
----------	------	----------	--------	------	------

Shell Side - Light Liquid Phase

Mass Flow Density (kg/h)	Mass Sp Heat (kg/m ³)	Viscosity (kJ/kg-C)	Thermal Cond (cP)	Surface Tens (W/m-K)
--------------------------	-----------------------------------	---------------------	-------------------	----------------------

(dyne/cm)				
-----------	--	--	--	--

---	---	---	---	---
-----	-----	-----	-----	-----

0.00	1415.59	8.62	0.14	0.18
------	---------	------	------	------

				0.56
--	--	--	--	------

Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(kPa) (C)
--- --- --- --- --- ---
25.48 1.42 16997.50 307.20 0.26 0.33
Shell Side - Heavy Liquid Phase

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m3) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)
--- --- --- --- ---
0.00 1415.59 8.62 0.14 0.18 0.56
Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(kPa) (C)
--- --- --- --- --- ---
25.48 1.42 16997.50 307.20 0.26 0.33
Shell Side - Mixed Liquid

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m3) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)
--- --- --- --- ---
0.00 1415.59 8.62 0.14 0.18 ---
Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(kPa) (C)
--- --- --- --- --- ---
25.48 1.42 16997.50 307.20 0.26 0.33
Tube Side - Overall Phase

Temperature	Pressure	Heat Flow	Enthalpy
(C)	(kPa)	(kJ/h)	(kJ/kgmole)
135.66	790.00	0.00	-197332.55
250.00	790.00	10147733.23	-190894.10
UA	Molar Vap Frac	Mass Vap Frac	Heat of Vap.
(kJ/C-h)			(kJ/kgmole)
0.00	1.0000	1.0000	---
0.00	1.0000	1.0000	---

Tube Side - Vapour Phase

Mass Flow Molecular Wt Density Mass Sp Heat
Viscosity Thermal Cond
(kg/h) (kg/m3) (kJ/kg-C) (cP) (W/m-K)
49823.49 31.61 7.35 1.65 0.01 0.02
49823.49 31.61 5.74 1.91 0.01 0.03
Std Gas Flow Z Factor Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(STD_m3/h) (kPa) (C)
37266.37 1.00 7896.50 243.70 0.25 0.55
37266.37 1.00 7896.50 243.70 0.25 0.55
Tube Side - Light Liquid Phase

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m3) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)
--- --- --- --- --- ---
--- --- --- --- --- ---

Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(kPa) (C)
--- --- --- --- --- ---
--- --- --- --- --- ---
Tube Side - Heavy Liquid Phase

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m3) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)
--- --- --- --- --- ---
--- --- --- --- --- ---
Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(kPa) (C)
--- --- --- --- --- ---
--- --- --- --- --- ---
Tube Side - Mixed Liquid

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m3) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)
--- --- --- --- --- ---
--- --- --- --- --- ---
Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega
(kPa) (C)
--- --- --- --- --- ---
--- --- --- --- --- ---
HTFS

Exchanger Design and Rating

T-100 (Reboiled Absorber): Design, Parameters, Side Ops, Internals, Rating, Performance, Flowsheet, Tray Tables

Reboiled Absorber: T-100

CONNECTIONS

STREAM NAME	Stage	FROM UNIT
OPERATION		
reboiler 1	Reboiler	
DME reflux	1__Main Tower	RCY-1 Recycle
normal op	4__Main Tower	TEE-102 Tee
turn down	9__Main Tower	TEE-102 Tee
Outlet Stream		
STREAM NAME	Stage	TO UNIT
OPERATION		
Meth H2O	Reboiler	P-101 Pump
DME outlet	1__Main Tower	E-104 Cooler
MONITOR		

Specifications Summary

Specified Value	Current Value	Wt. Error
Btms Prod Rate	---	954.8 kgmole/h ---
Boilup Ratio	10.00	0.8359 9.164

Comp Fraction 0.9995 0.9995 -6.811e-005
 Wt. Tol. Abs. Tol. Active Estimate
 Used
 Btms Prod Rate 1.000e-002 1.000 kgmole/h Off On
 Off
 Boilup Ratio 1.000e-002 1.000e-002 Off On
 Off
 Comp Fraction 1.000e-002 1.000e-003 On On
 On
 SPECS

Column Specification Parameters
 Btms Prod Rate

Fix/Rang: Fixed Prim/Alter: Primary Lower Bnd: ---
 Upper Bnd: ---
 Stream: Meth H2O @COL1 Flow Basis: Molar
 Boilup Ratio

Fix/Rang: Fixed Prim/Alter: Primary Lower Bnd: ---
 Upper Bnd: ---
 Stage: Reboiler Basis: Molar
 Comp Fraction

Fix/Rang: Fixed Prim/Alter: Primary Lower Bnd: ---
 Upper Bnd: ---
 Stage: Flow Basis: Mass Fraction Phase: Liquid
 Components: diM-Ether
 SUBCOOLING

Degrees of Subcooling
 Subcool to
 User Variables

PROFILES

General Parameters

Sub-Flow Sheet: T-100 (COL1) Number of Stages: 10
 Profile Estimates

	Temperature (C)	Net Liquid (kgmole/h)	Net Vapour (kgmole/h)
1_Main Tower	58.00	593.6	1253
2_Main Tower	45.03	444.8	1215
3_Main Tower	70.77	320.4	1066
4_Main Tower	94.16	1058	941.7
5_Main Tower	108.8	1041	891.7
6_Main Tower	115.7	1037	874.1
7_Main Tower	118.5	1035	869.9
8_Main Tower	119.8	1030	867.9
9_Main Tower	121.3	1785	863.7
10_Main Tower	135.2	1753	830.3
Reboiler	114.0	954.8	798.2

EFFICIENCIES

Stage Efficiencies

Stages	Overall	diM-Ether	Methanol	H2O
1_Main Tower	1.000	1.000	1.000	1.000
2_Main Tower	1.000	1.000	1.000	1.000
3_Main Tower	1.000	1.000	1.000	1.000
4_Main Tower	1.000	1.000	1.000	1.000
5_Main Tower	1.000	1.000	1.000	1.000

6_Main Tower	1.000	1.000	1.000	1.000
7_Main Tower	1.000	1.000	1.000	1.000
8_Main Tower	1.000	1.000	1.000	1.000
9_Main Tower	1.000	1.000	1.000	1.000
10_Main Tower	1.000	1.000	1.000	1.000
Reboiler	1.000	1.000	1.000	1.000

SOLVER

Column Solving Algorithm: HYSIM Inside-Out
 Solving Options Acceleration Parameters
 Maximum Iterations: 10000 Accelerate K Value & H
 Model Parameters: Off
 Equilibrium Error Tolerance: 1.000e-05
 Heat/Spec Error Tolerance: 5.000e-004
 Save Solutions as Initial Estimate: On
 Super Critical Handling Model: Simple K
 Trace Level: Low
 Init from Ideal K's: Off Damping Parameters
 Initial Estimate Generator Parameters Azeotrope Check: Off
 Iterative IEG (Good for Chemicals): Off Fixed Damping Factor: 1

SIDE STRIPPERS

SIDE RECTIFIERS

PUMP AROUNDS

VAP BYPASSES

ACTIVE INTERNAL OPTION: Internals-1@Main Tower@COL1

Tray / Packing Number	Packing	Packing								
Packing	Tray Spacing /	Name	Start	Stage	End	Stage	Mode	Internals	Type	of
Diameter		Vendor	Material	Dimension	Section	Packed	Height			
CS-1	1_Main Tower	8_Main Tower	Interactive	Sizing						
	Trayed Sieve 1	---	---	---	0.6096	1.550				
CS-2	9_Main Tower	10_Main Tower	Interactive	Sizing						
	Trayed Bubble Cap 1	---	---	---	0.6096	1.550				
	SETUP									

Section Name	CS-1	CS-2
Section Start	1_Main Tower	9_Main Tower
Section End	8_Main Tower	10_Main Tower
Internals	Trayed	Trayed
Internals Type	Sieve	Bubble Cap
Diameter (m)	1.550	1.550
Tray Spacing / Section Packed Height (m)	0.6096	0.6096
Number Of Passes	1	1
Maximum Acceptable Pressure Drop (kPa)	2.500	2.500
Maximum Percent Downcomer Backup %	100.00 %	100.00 %
Maximum Percent Jet Flood %	100.00 %	100.00 %
Percent Jet Flood For Design %	80.00 %	80.00 %
Maximum Percent Liquid Entrainment %	10.00 %	10.00 %
Minimum Weir Loading (m ³ /h-m)	4.471	4.471

Maximum Weir Loading (m ³ /h-m)	117.4	117.4		Downcomer Width - Top (mm)	---	---
Minimum Downcomer Area / Total Tray Area	0.1000			Downcomer Width - Bottom (mm)	---	---
0.1000				Downcomer Loading Top (m ³ /h-m ²)	---	---
Override Downcomer Froth Density	No	No		Weir Loading (m ³ /h-m)	---	---
Froth Density	---	---		Downcomer Area - Top (m ²)	---	---
Weep Method	Hsieh	Hsieh		Downcomer Area - Bottom (m ²)	---	---
Default Jet Flood Calculation Method	GLITSCH6			Picketing Fraction	---	---
GLITSCH6				Off Center Weir Height (mm)	---	---
Maximum Downcomer Loading Method	Glitsch	Glitsch		Inside Weir Length (m)	---	---
% Approach to Maximum Capacity	---	---		Outside Weir Length (m)	---	---
Design Capacity Factor	---	---		Downcomer Clearance (mm)	---	---
Capacity Factor at Flooding	---	---		Downcomer Width - Top (mm)	---	---
System Foaming Factor	1.000	1.000		Downcomer Width - Bottom (mm)	---	---
Aeration Factor Multipler	1.000	1.000		Downcomer Loading Top (m ³ /h-m ²)	---	---
Minimum Liquid Flow Rate	---	---		Maximum Outside Weir Loading (m ³ /h-m)	---	-
Pressure Drop at Flood per Unit Packed Height	---	---		Maximum Inside Weir Loading (m ³ /h-m)	---	---
Allowable Pressure Drop per Unit Packed Height	---	---		Downcomer Area - Top (m ²)	---	---
Minimum Pressure Drop per Unit Packed Height	---	---		Downcomer Area - Bottom (m ²)	---	---
Number of Curves	---	---		Inside Picketing Fraction	---	---
Warning Status (% to Limit)	10.00 %	10.00 %		Outside Picketing Fraction	---	---
Pressure Drop Calculation Method	---	---		Off-Center Downcomer Location (m)	---	---
Mode	Interactive Sizing	Interactive Sizing		Swept Back Weir Geometry	CS-1	CS-2
Status	Needs Calculating	Needs Calculating		Compatibility	KG Tower	KG Tower
GEOMETRY DETAILS						
Common Geometry	CS-1	CS-2		A	---	---
Section Start	1_Main Tower	9_Main Tower		B/Parallel Chord Segment	---	---
Section End	8_Main Tower	10_Main Tower		S/Swept-Back Weir	---	---
Internals	Sieve	Bubble Cap		Swept-Back Weir Chord	---	---
Section Diameter (m)	1.550	1.550		Angled Chord Segment	---	---
Foaming Factor	1.000	1.000		Tray With Maximum Weir Loading	4	9
Over-Design Factor	1.000	1.000		Maximum Weir Loading (m ³ /h-m)	41.14	58.24
Common Tray Geometry	CS-1	CS-2		Maximum Allowable Weir Loading in Section (m ³ /h-m)	117.4	
Number of Passes	1	1		Actual Side Weir Length (m)	1.126	1.126
Tray Spacing (m)	0.6096	0.6096		Effective Side Weir Length (m)	1.126	1.126
Picket Fence Weirs	No	No		Lost Area (%)	0.00	0.00
Swept Back Weirs	No	No		Sieve Geometry	CS-1	CS-2
Active Area Under Downcomer	No	No		Hole Diameter (mm)	12.70	---
Deck Thickness	10 Gauge	10 Gauge		Number of Holes	1191	---
Deck Thickness Value (mm)	3.404	3.404		Hole Area to Active Area	0.1000	---
Balance Downcomers Based On Maximum Downcomer				Bubble Cap Geometry	CS-1	CS-2
Loading Maximum Downcomer Loading				Cap Diameter	---	3 in (76.2 mm)
Weir Modifications	None	None		Skirt Height	---	1.0 in (25.4 mm)
Net Area (m ²)	1.698	1.698		Number of Caps	---	75
Cross-Sectional Area (m ²)	1.887	1.887		Number of Caps Per Active Area	---	50.00
Active Area (m ²)	1.510	1.510		Valve Geometry	CS-1	CS-2
Downcomer Geometry	CS-1	CS-2		Tray Type	---	---
Side Weir Height (mm)	50.80	50.80		Valve Type	---	---
Weir Length (m)	---	---		Valve Material	---	---
Downcomer Clearance (mm)	38.10	38.10		Leg Length	---	---
Downcomer Width - Top (mm)	242.5	242.5		Valve Thickness	---	---
Downcomer Width - Bottom (mm)	242.5	242.5		Number of Valves	---	---
Downcomer Loading Top (m ³ /h-m ²)	245.6	347.6		Number of Valves per Active Area	---	---
Weir Loading (m ³ /h-m)	41.14	58.24		Packing Geometry	CS-1	CS-2
Downcomer Area - Top (m ²)	0.1887	0.1887		HETP (m)	---	---
Downcomer Area - Bottom (m ²)	0.1887	0.1887		Section Packed Height (m)	---	---
Picketing Fraction	---	---		Packing Type	---	---
Center Weir Height (mm)	---	---		Packing Vendor	---	---
Weir Length (m)	---	---		Packing Material	---	---
Downcomer Clearance (mm)	---	---		Packing Dimension	---	---

1st Stichlmair Constant --- ---
 2nd Stichlmair Constant --- ---
 3rd Stichlmair Constant --- ---
 Void Fraction --- ---
RESULTS SUMMARY

Section Name	CS-1	CS-2
Section Start	1_Main Tower	9_Main Tower
Section End	8_Main Tower	10_Main Tower
Internals	Trayed	Trayed
Diameter (m)	1.550	1.550
Number of Passes	1	1
Tray Spacing / Section Packed Height (m)	0.6096	0.6096
Total Height (m)	4.877	1.219
Total Pressure Drop (kPa)	57.03	23.78
Total Pressure Drop (Head Loss) (m)	879.6	331.1
Trays With Weeping	None	None
Maximum Percent Jet Flood (%)	92.91	59.70
Tray With Maximum Jet Flood	1_Main Tower	9_Main Tower
Maximum Percent Downcomer Backup (%)	46.67	70.66
Tray With Maximum Downcomer Backup	1_Main Tower	9_Main Tower
Maximum Downcomer Loading (m ³ /h-m ²)	245.6	347.6
Tray With Maximum Downcomer Loading	4_Main Tower	9_Main Tower
Maximum Downcomer Loading Location	Side	Side
Maximum Weir Loading (m ³ /h-m)	41.14	58.24
Tray With Maximum Weir Loading	4_Main Tower	9_Main Tower
Maximum Weir Loading Location	Side	Side
Maximum Aerated Height Over Weir (mm)	141.6	114.0
Tray With Maximum Aerated Height Over Weir	1_Main Tower	9_Main Tower
Maximum % Approach To System Limit (%)	69.41	30.13
Tray With Maximum % Approach To System Limit	1_Main Tower	9_Main Tower
Maximum Cs Based On Bubbling Area (%)	0.1136	6.450e-002
Tray With Maximum Cs Based On Bubbling Area	1_Main Tower	9_Main Tower
Maximum % Capacity (Constant L/V)	92.91	59.70
Maximum Capacity Factor	---	---
Section Pressure Drop (kPa)	57.03	23.78
Average Pressure Drop Per Height (kPa/m)	---	---
Average Pressure Drop Per Height (Frictional) (mbar/m)	---	---
Maximum Stage Liquid Holdup (m ³)	---	---
Maximum Liquid Superficial Velocity (m/s)	---	---
Surface Area (m ² /m ³)	---	---
Void Fraction	---	---
1st Stichlmair Constant	---	---
2nd Stichlmair Constant	---	---
3rd Stichlmair Constant	---	---

STAGE BY STAGE RESULTS: CS-1

State Conditions

Stages	Liquid Temperature	Vapor Temperature	Liquid Mass Flow	Vapor Mass Flow	Liquid Volume Flow	Vapor Volume Flow
(C)	(C)	(kg/h)	(kg/h)	(m ³ /s)	(m ³ /s)	

1_Main Tower	37.94	45.03	2.719e+004	5.580e+004
1.287e-002	1.086			
2_Main Tower	45.03	70.77	1.924e+004	4.786e+004
8.851e-003	1.027			
3_Main Tower	70.77	94.16	1.163e+004	4.024e+004
4.994e-003	0.9664			
4_Main Tower	94.16	108.8	3.190e+004	3.561e+004
1.287e-002	0.9490			
5_Main Tower	108.8	115.7	2.961e+004	3.332e+004
1.171e-002	0.9446			
6_Main Tower	115.7	118.5	2.876e+004	3.247e+004
1.128e-002	0.9442			
7_Main Tower	118.5	119.8	2.840e+004	3.210e+004
1.109e-002	0.9427			
8_Main Tower	119.8	121.3	2.801e+004	3.171e+004
1.089e-002	0.9392			
Physical Conditions				
Stages	Liquid Molecular Weight	Vapor Molecular Weight	Liquid Mass Density	Vapor Mass Density
Vapor Viscosity	Surface Tension	(kg/m ³)	(kg/m ³)	(cP)
(dyne/cm)				
1_Main Tower	45.80	45.93	586.8	14.28
8.172e-002	9.582e-003	10.32		
2_Main Tower	43.25	44.89	603.8	12.94
1.010e-002	12.90			0.1009
3_Main Tower	36.29	42.73	646.7	11.57
1.044e-002	20.64			0.1475
4_Main Tower	30.14	39.93	688.4	10.42
1.030e-002	30.71			0.1623
5_Main Tower	28.45	38.12	702.5	9.798
1.014e-002	30.93			0.1668
6_Main Tower	27.75	37.32	708.6	9.552
1.007e-002	30.86			0.1659
7_Main Tower	27.45	36.99	711.3	9.459
1.007e-002	30.91			0.1653
8_Main Tower	27.18	36.72	714.1	9.379
1.013e-002	31.33			0.1646
Hydraulic Results				
Stages	Percent Jet Flood	Dry Pressure Drop	Total Pressure Drop	Dry Pressure Drop (Head Loss)
			Total Pressure Drop (Head Loss)	
(%)	(mbar)	(mbar)	(mm)	(mm)
1_Main Tower	92.91	6.811	9.173	118.4
159.4				
2_Main Tower	80.34	5.525	7.834	93.31
132.3				
3_Main Tower	66.91	4.372	6.724	68.93
106.0				
4_Main Tower	66.10	3.798	6.935	56.26
102.7				
5_Main Tower	62.63	3.538	6.686	51.35
97.06				
6_Main Tower	61.34	3.446	6.599	49.59
94.97				
7_Main Tower	60.75	3.402	6.560	48.77
94.04				
8_Main Tower	60.07	3.348	6.516	47.80
93.05				
Stages				
Downcomer Backup (Aerated)	Downcomer Backup (Unaerated)	Percent Downcomer Backup (Aerated)	Percent Downcomer Backup (Unaerated)	

	(m)	(m)	(%)	(%)	
1_Main Tower	0.3082	0.1827	46.67	27.66	
2_Main Tower	0.2497	0.1488	37.81	22.53	
3_Main Tower	0.1980	0.1191	29.99	18.04	
4_Main Tower	0.2317	0.1401	35.09	21.21	
5_Main Tower	0.2191	0.1326	33.18	20.08	
6_Main Tower	0.2145	0.1299	32.49	19.67	
7_Main Tower	0.2126	0.1287	32.19	19.49	
8_Main Tower	0.2105	0.1275	31.87	19.30	
Stages	Mass Rate / Column Area Volume Rate / Column Area Fs (Net Area) Fs (Bubble Area) Cs (Net Area)				
	(kg/s-m2)	(m3/h-m2)	(sqrt(Pa))	(sqrt(Pa))	
(m/s)					
1_Main Tower	4.002	24.56	2.416	2.718	
0.1010					
2_Main Tower	2.832	16.89	2.176	2.448	
8.951e-002					
3_Main Tower	1.712	9.528	1.935	2.177	
7.680e-002					
4_Main Tower	4.696	24.56	1.804	2.030	
6.928e-002					
5_Main Tower	4.359	22.34	1.741	1.959	
6.615e-002					
6_Main Tower	4.234	21.51	1.718	1.933	
6.499e-002					
7_Main Tower	4.180	21.16	1.707	1.921	
6.444e-002					
8_Main Tower	4.123	20.78	1.694	1.905	
6.380e-002					
Stages	Cs (Bubble Area) Approach to System Limit Height Over Weir (Aerated) Height Over Weir (Unaerated)				
	(m/s)	(%)	(m)	(m)	
1_Main Tower	0.1136	69.41	0.1416		
2.528e-002					
2_Main Tower	0.1007	58.14	9.324e-002		
1.748e-002					
3_Main Tower	8.640e-002	44.67	5.686e-002		
1.137e-002					
4_Main Tower	7.794e-002	36.94	0.1186		
2.477e-002					
5_Main Tower	7.442e-002	35.27	0.1062		
2.268e-002					
6_Main Tower	7.312e-002	34.69	0.1019		
2.195e-002					
7_Main Tower	7.250e-002	34.40	0.1000		
2.164e-002					
8_Main Tower	7.177e-002	33.96	9.802e-002		
2.133e-002					
Side Downcomer Results					
Stages	Volume Residence Time Velocity From Top Velocity from Bottom Exit Velocity				
	(m3)	(seconds)	(m/s)	(m/s)	
1_Main Tower	3.447e-002	2.678	6.821e-002	6.821e-002	
0.3000					
2_Main Tower	2.808e-002	3.173	4.691e-002	4.691e-002	
0.2063					
3_Main Tower	2.248e-002	4.501	2.647e-002	2.647e-002	
0.1164					
4_Main Tower	2.643e-002	2.054	6.822e-002	6.822e-002	
0.3000					
5_Main Tower	2.502e-002	2.137	6.206e-002	6.206e-002	
0.2729					

6_Main Tower	2.451e-002	2.174	5.976e-002	5.976e-002
0.2628				
7_Main Tower	2.429e-002	2.190	5.877e-002	5.877e-002
0.2584				
STAGE BY STAGE RESULTS: CS-2				

State Conditions					
Stages	Liquid	Temperature	Vapor	Temperature	Liquid
Area Fs (Net Area)	Mass Flow	Vapor	Mass Flow	Liquid	Volume Flow
Area Fs (Bubble Area)	Vapor	Mass Density	Vapor	Mass Density	Liquid
Cs (Net Area)	Volume	Weight	Viscosity	Surface Tension	Vapor
(kg/s-m2)	(m3/h-m2)	(sqrt(Pa))	(sqrt(Pa))	(kg/m3)	(kg/m3)
(C)	(C)	(kg/h)	(kg/h)	(m3/s)	(m3/s)
9_Main Tower	121.3	135.2	4.735e+004	2.615e+004	
1.822e-002	0.9322				
10_Main Tower	135.2	145.4	4.326e+004	2.205e+004	
1.614e-002	0.9184				
Physical Conditions					
Stages	Liquid	Molecular Weight	Vapor	Molecular Weight	Liquid
Weight	Liquid	Mass Density	Vapor	Mass Density	Liquid
Viscosity	Vapor	Surface Tension			
(kg/m3)	(kg/m3)	(cP)	(cP)		
(dyne/cm)					
9_Main Tower	26.53	31.49	721.9	7.790	0.1630
9.674e-003	32.85				
10_Main Tower	24.68	27.63	744.7	6.670	
0.1595	9.732e-003	34.10			
Hydraulic Results					
Stages	Percent Jet Flood Dry Pressure Drop Total Pressure Drop Dry Pressure Drop (Head Loss) Total Pressure Drop (Head Loss)				
	(%)	(mbar)	(mbar)	(mm)	(mm)
9_Main Tower	59.70	7.914	12.49	111.8	
176.5					
10_Main Tower	53.27	6.954	11.29	95.22	
154.6					
Stages	Downcomer Backup (Aerated) Downcomer Backup (Unaerated) Percent Downcomer Backup (Aerated) Percent Downcomer Backup (Unaerated)				
	(m)	(m)	(%)	(%)	
9_Main Tower	0.4667	0.2828	70.66	42.82	
10_Main Tower	0.4151	0.2518	62.86		
38.13					
Stages	Mass Rate / Column Area Volume Rate / Column Area Fs (Net Area)				
Area Fs (Bubble Area)	Cs (Net Area)				
(kg/s-m2)	(m3/h-m2)	(sqrt(Pa))	(sqrt(Pa))		
(m/s)					
9_Main Tower	6.971	34.76	1.532	1.724	
5.734e-002					
10_Main Tower	6.369	30.78	1.397	1.571	
5.141e-002					
Stages	Cs (Bubble Area) Approach to System Limit Height Over Weir (Aerated) Height Over Weir (Unaerated)				
	(m/s)	(%)	(m)	(m)	
9_Main Tower	6.450e-002	30.13	0.1140		
3.510e-002					
10_Main Tower	5.784e-002	26.80	9.561e-002		
3.172e-002					
Side Downcomer Results					
Stages	Volume Residence Time Velocity From Top Velocity from Bottom Exit Velocity				
	(m3)	(seconds)	(m/s)	(m/s)	

9_Main Tower 5.336e-002 2.928 9.657e-002 9.657e-002 0.4246
 10_Main Tower 4.752e-002 2.945 8.551e-002 8.551e-002 0.3760
 RATING

Tray Sections
 Tray Section Main Tower @COL1
 Tray Diameter (m) 1.500
 Weir Height (m) 5.000e-002
 Weir Length (m) 1.200
 Tray Space (m) 0.5000
 Tray Volume (m³) 0.8836
 Disable Heat Loss Calculations No
 Heat Model None
 Rating Calculations No
 Tray Hold Up (m³) 8.836e-002
Vessels
 Vessel Reboiler @COL1
 Diameter (m) 1.193
 Length (m) 1.789
 Volume (m³) 2.000
 Orientation Horizontal
 Vessel has a Boot No
 Boot Diameter (m) ---
 Boot Length (m) ---
 Hold Up (m³) 1.000
 Other Equipment In Column Flowsheet

Pressure Profile
 Pressure (kPa) Pressure Drop (kPa)
 1_Main Tower 820.0 kPa 2.222 kPa
 2_Main Tower 822.2 kPa 2.222 kPa
 3_Main Tower 824.4 kPa 2.222 kPa
 4_Main Tower 826.7 kPa 2.222 kPa
 5_Main Tower 828.9 kPa 2.222 kPa
 6_Main Tower 831.1 kPa 2.222 kPa
 7_Main Tower 833.3 kPa 2.222 kPa
 8_Main Tower 835.6 kPa 2.222 kPa
 9_Main Tower 837.8 kPa 2.222 kPa
 10_Main Tower 840.0 kPa ---
 Reboiler 840.0 kPa 0.0000 kPa
Pressure Solving Options
 Pressure Tolerance 1.000e-004 Pressure Drop
 Tolerance 1.000e-004
 Damping Factor 1.000 Max Press Iterations 100
SUMMARY
 Flow Basis: Molar The composition option is selected
 Feed Composition
 DME reflux normal op turn down
 Flow Rate (kgmole/h) 631.5772 788.0580
 788.0580
 --- --- ---
 diM-Ether 0.9993 0.3991 0.3991
 Methanol 0.0007 0.1710 0.1710

H2O 0.0000 0.4298 0.4298
 Flow Basis: Molar The composition option is selected
 Feed Flows
 DME reflux normal op turn down
 Flow Rate (kgmole/h) 631.5772 788.0580
 788.0580
 --- --- ---
 diM-Ether (kgmole/h) 631.1222 314.5502
 314.5502
 Methanol (kgmole/h) 0.4528 134.7802
 134.7802
 H2O (kgmole/h) 0.0022 338.7276 338.7276
 Products
 Flow Basis: Molar The composition option is selected
 Product Compositions
 DME outlet Meth H2O
 Flow Rate (kgmole/h) 1.252878e+03 954.8151
 --- --- ---
 diM-Ether 0.9993 0.0086
 Methanol 0.0007 0.2819
 H2O 0.0000 0.7095
 Flow Basis: Molar The composition option is selected
 Product Flows
 DME outlet Meth H2O
 Flow Rate (kgmole/h) 1.252878e+03 954.8151
 --- --- ---
 diM-Ether (kgmole/h) 1.251976e+03 8.2470
 Methanol (kgmole/h) 0.8981 269.1150
 H2O (kgmole/h) 0.0043 677.4530
 Flow Basis: Molar The composition option is selected
 Product Recoveries
 DME outlet Meth H2O
 Flow Rate (kgmole/h) 1.252878e+03 954.8151
 --- --- ---
 diM-Ether (%) 99.3456 0.6544
 Methanol (%) 0.3326 99.6674
 H2O (%) 0.0006 99.9994
COLUMN PROFILES
 Reflux Ratio: 0.4738 Reboil Ratio: 0.8359 The Flows Option is Selected Flow Basis: Molar Column Profiles Flows
 Temp Pres Net Liq Net Vap Net Feed Net Draws Duty
 (C) (kPa) (kgmole/h) (kgmole/h) (kgmole/h) (kgmole/h) (kJ/h)
 1_Main Tower 37.9 820.0 593.6 --- 631.6 1253

 2_Main Tower 45.0 822.2 444.8 1215 --- ---

 3_Main Tower 70.8 824.4 320.4 1066 --- ---

 4_Main Tower 94.2 826.7 1058 941.7 788.1 ---

 5_Main Tower 108.8 828.9 1041 891.7 --- ---

 6_Main Tower 115.7 831.1 1037 874.1 --- ---

7	Main Tower	118.5	833.3	1035	869.9	---	---

8	Main Tower	119.8	835.6	1030	867.9	---	---

9	Main Tower	121.3	837.8	1785	863.7	788.1	---

10	Main Tower	135.2	840.0	1753	830.3	---	---

Reboiler		145.4	840.0	---	798.2	---	954.8
		2.71e+007					
Column Profiles Energy							
	Temperature	Liq Enthalpy	Vap Enthalpy	Heat Loss	(C)	(kJ/kgmole)	(kJ/kgmole)
1	Main Tower	37.94	-2.028e+005	-1.833e+005	-		
2	Main Tower	45.03	-2.086e+005	-1.830e+005	-		
3	Main Tower	70.77	-2.246e+005	-1.827e+005	-		
4	Main Tower	94.16	-2.408e+005	-1.847e+005	-		
5	Main Tower	108.8	-2.438e+005	-1.883e+005	-		
6	Main Tower	115.7	-2.450e+005	-1.909e+005	-		
7	Main Tower	118.5	-2.456e+005	-1.921e+005	-		
8	Main Tower	119.8	-2.463e+005	-1.926e+005	-		
9	Main Tower	121.3	-2.484e+005	-1.932e+005	-		
10	Main Tower	135.2	-2.529e+005	-2.019e+005	-		
Reboiler		145.4	-2.605e+005	-2.099e+005	---		

FEEDS / PRODUCTS

Flow Basis: Molar							
Stream	Type	Duty	State	Flows	Enthalpy		
Temp		(kJ/h)		(kgmole/h)	(kJ/kgmole)		
(C)							
1	Main Tower DME reflux Feed	---	Liquid	632			
-2.0e+005	36.98						
1.8e+005	37.94						
2	Main Tower						
3	Main Tower						
4	Main Tower normal op Feed	---	Liquid	788			
-2.4e+005	73.70						
5	Main Tower						
6	Main Tower						
7	Main Tower						
8	Main Tower						
9	Main Tower turn down Feed	---	Liquid	788			
-2.4e+005	73.70						
10	Main Tower						
Reboiler	reboiler 1 Energy	2.7e+007	---	---			
---	Meth H2O Draw	---	Liquid	955	-		
2.6e+005	145.35						

PERFORMANCE SUMMARY FOR INTERNAL OPTION: Internals-1@Main Tower@COL1

Number Of Stages	10				
Total Height (m)	6.096				
Total Head Loss (mm)	1211				
Total Pressure Drop (mbar)	80.81				
Number Of Sections	2				
Number Of Diameters	1				
Pressure Drop Across Sump (kPa)	---				
Section Start End Height Diameter Internals Tray or Packing Section Pressure Drop Approach To Flood Limiting	(m) (m) Type Type (mbar) (%) Stage				
CS-1 1	Main Tower 8	Main Tower	0.6096	1.550	
Trayed Sieve	57.03		92.91		
CS-2 9	Main Tower 10	Main Tower	0.6096	1.550	
Trayed Bubble Cap	23.78		59.70		
SETUP					

Sub-Flowsheet

Internal Feed Stream	External Feed Stream	Transfer Basis
reboiler 1	reboiler 1	None Req'd
DME reflux	DME reflux	P-H Flash
normal op	normal op	P-H Flash
turn down	turn down	P-H Flash
Internal Prod Stream	External Prod Stream	Transfer Basis
Meth H2O	Meth H2O	P-H Flash
DME outlet	DME outlet	P-H Flash

VARIABLES

Column Flowsheet Vars Available as Parameters		
Data Source	Variable	Component
Description		

COMPONENT MAPS

Feed Streams		
Feed Name	In to SubFlowSheet	Out of
SubFlowSheet		
reboiler 1		
DME reflux		
normal op		

Product Stream		
Product Name	In to SubFlowSheet	Out of
SubFlowSheet		
Meth H2O		

TRAY by TRAY PROPERTIES TABLES

Column Temperature / Pressure Profile

Column Stage	Temperature	Pressure
(C)	(kPa)	
1 Main Tower	37.94	820.0
2 Main Tower	45.03	822.2
3 Main Tower	70.77	824.4
4 Main Tower	94.16	826.7

5_Main Tower	108.8	828.9
6_Main Tower	115.7	831.1
7_Main Tower	118.5	833.3
8_Main Tower	119.8	835.6
9_Main Tower	121.3	837.8
10_Main Tower	135.2	840.0
Reboiler	145.4	840.0

Column Flow Profile

Options Selected

Molar flow is selected Net is selected as flow basis

Tray Number	Vapour (kgmole/h)	Bulk Liquid (kgmole/h)
-------------	----------------------	---------------------------

1_Main Tower	1253	593.6
2_Main Tower	1215	444.8
3_Main Tower	1066	320.4
4_Main Tower	941.7	1058
5_Main Tower	891.7	1041
6_Main Tower	874.1	1037
7_Main Tower	869.9	1035
8_Main Tower	867.9	1030
9_Main Tower	863.7	1785
10_Main Tower	830.3	1753

Reboiler 798.2 954.8
Column Properties Profile

Options Selected

Mass basis is selected

Stage	Surf Tens	Mol Wt	Dens	Visc	Therm Con
-------	-----------	--------	------	------	-----------

Heat Cap	L-Liq (kJ/kg-C)	L-Liq (dyne/cm)	L-Liq (kg/m3)	L-Liq (cP)	L-Liq (W/m-K)
----------	--------------------	--------------------	------------------	---------------	------------------

1_Main Tower	10.3 2.53	45.8	587	8.17e-002	0.126
2_Main Tower	12.9 2.73	43.3	604	0.101	0.132
3_Main Tower	20.6 3.31	36.3	647	0.147	0.169
4_Main Tower	30.7 3.78	30.1	688	0.162	0.265
5_Main Tower	30.9 4.10	28.5	702	0.167	0.279
6_Main Tower	30.9 4.29	27.7	709	0.166	0.285
7_Main Tower	30.9 4.38	27.4	711	0.165	0.289
8_Main Tower	31.3 4.44	27.2	714	0.165	0.295
9_Main Tower	32.9 4.54	26.5	722	0.163	0.317
10_Main Tower	34.1 4.14	24.7	745	0.159	0.360
Reboiler	38.4	22.2	786	0.150	0.458
					4.31

Column Composition Profile

Options Selected

Fraction is selected as the composition basis Net is selected as flow basis

Molar basis is selected

Stage diM-Ether Methanol H2O

	L-Liq	L-Liq	L-Liq
1_Main Tower	0.9814	0.0182	0.0004
2_Main Tower	0.8151	0.1690	0.0159
3_Main Tower	0.4351	0.4325	0.1324
4_Main Tower	0.2534	0.3576	0.3890
5_Main Tower	0.1586	0.4268	0.4146
6_Main Tower	0.1191	0.4554	0.4254
7_Main Tower	0.1048	0.4627	0.4325
8_Main Tower	0.0996	0.4541	0.4463
9_Main Tower	0.0967	0.4134	0.4899
10_Main Tower	0.0328	0.4094	0.5578
Reboiler	0.0086	0.2819	0.7095

Heavy/Light Key Component Ratios

Options Selected

Molar basis is selected

Key Components

Light Key	Chosen	Heavy Key	Chosen
diM-Ether	On	diM-Ether	Off
Methanol	On	Methanol	Off
H2O	On	H2O	Off
Stage	Light Liq		
1_Main Tower	---		
2_Main Tower	---		
3_Main Tower	---		
4_Main Tower	---		
5_Main Tower	---		
6_Main Tower	---		
7_Main Tower	---		
8_Main Tower	---		
9_Main Tower	---		
10_Main Tower	---		
Reboiler	---		

Column K-Values Profile

Tray Number	diM-Ether	Methanol	H2O
1_Main Tower	1.018	3.934e-002	8.161e-003
2_Main Tower	1.215	5.484e-002	1.302e-002
3_Main Tower	2.120	0.1640	5.001e-002
4_Main Tower	3.186	0.4129	0.1158
5_Main Tower	4.061	0.6415	0.1976
6_Main Tower	4.527	0.7784	0.2494
7_Main Tower	4.715	0.8392	0.2719
8_Main Tower	4.798	0.8740	0.2807
9_Main Tower	4.898	0.9342	0.2863
10_Main Tower	6.029	1.379	0.4256
Reboiler	7.150	1.994	0.5304

T-101 (Reboiled Absorber): Design, Parameters, Side Ops, Internals, Rating, Performance, Flowsheet, Tray Tables

Reboiled Absorber: T-101

CONNECTIONS

Inlet Stream	STREAM NAME	Stage	FROM UNIT
OPERATION			
Reboiler 2	Reboiler		
METH reflux	1_Main Tower		RCY-2 Recycle

Meth H₂O Pumped 6_Main Tower P-101 Pump
 Outlet Stream
 STREAM NAME Stage TO UNIT
 OPERATION
 Meth Recycle 1_Main Tower E-103 Cooler
 Waste Water Reboiler P-105 Pump
 MONITOR

Specifications Summary
 Specified Value Current Value Wt. Error
 Ovhd Prod Rate 650.0 kgmole/h 650.0 kgmole/h
 1.080e-005
 Btms Prod Rate --- 629.8 kgmole/h ---
 Boilup Ratio 4.000 1.013 2.987
 Wt. Tol. Abs. Tol. Active Estimate
 Used
 Ovhd Prod Rate 1.000e-002 1.000 kgmole/h On On
 On
 Btms Prod Rate 1.000e-002 1.000 kgmole/h Off On
 Off
 Boilup Ratio 1.000e-002 1.000e-002 Off On
 Off
 SPECS

Column Specification Parameters
 Ovhd Prod Rate

Fix/Rang: Fixed Prim/Alter: Primary Lower Bnd: ---
 Upper Bnd: ---
 Stream: Meth Recycle @COL2 Flow Basis: Molar
 Btms Prod Rate

Fix/Rang: Fixed Prim/Alter: Primary Lower Bnd: ---
 Upper Bnd: ---
 Stream: Waste Water @COL2 Flow Basis: Molar
 Boilup Ratio

Fix/Rang: Fixed Prim/Alter: Primary Lower Bnd: ---
 Upper Bnd: ---
 Stage: Reboiler Basis: Molar
 SUBCOOLING

Degrees of Subcooling
 Subcool to
 User Variables

PROFILES

General Parameters

Sub-Flow Sheet: T-101 (COL2) Number of Stages: 10
 Profile Estimates

	Temperature (C)	Net Liquid (kgmole/h)	Net Vapour (kgmole/h)
1_Main Tower	120.0	375.2	650.0
2_Main Tower	140.5	359.9	700.2
3_Main Tower	144.8	348.0	684.9
4_Main Tower	148.5	341.1	673.0
5_Main Tower	150.9	338.0	666.1
6_Main Tower	152.1	1286	662.9
7_Main Tower	157.5	1273	655.9
8_Main Tower	163.9	1267	643.3
9_Main Tower	169.4	1267	637.0

10_Main Tower 172.7 1268 636.7
 Reboiler 160.0 629.8 638.0
 EFFICIENCIES

Stage Efficiencies
 Stages Overall diM-Ether Methanol H₂O
 1_Main Tower 1.000 1.000 1.000 1.000
 2_Main Tower 1.000 1.000 1.000 1.000
 3_Main Tower 1.000 1.000 1.000 1.000
 4_Main Tower 1.000 1.000 1.000 1.000
 5_Main Tower 1.000 1.000 1.000 1.000
 6_Main Tower 1.000 1.000 1.000 1.000
 7_Main Tower 1.000 1.000 1.000 1.000
 8_Main Tower 1.000 1.000 1.000 1.000
 9_Main Tower 1.000 1.000 1.000 1.000
 10_Main Tower 1.000 1.000 1.000 1.000
 Reboiler 1.000 1.000 1.000 1.000
 SOLVER

Column Solving Algorithm: HYSIM Inside-Out
 Solving Options Acceleration Parameters
 Maximum Iterations: 10000 Accelerate K Value & H
 Model Parameters: Off
 Equilibrium Error Tolerance: 1.000e-05
 Heat/Spec Error Tolerance: 5.000e-004
 Save Solutions as Initial Estimate: On
 Super Critical Handling Model: Simple K
 Trace Level: Low
 Init from Ideal K's: Off Damping Parameters
 Initial Estimate Generator Parameters Azeotrope Check:
 Off
 Iterative IEG (Good for Chemicals): Off Fixed Damping
 Factor: 1

SIDE STRIPPERS

SIDE RECTIFIERS

PUMP AROUNDS

VAP BYPASSES

ACTIVE INTERNAL OPTION: Internals-1@Main
 Tower@COL2

Tray / Packing Number Packing Packing
 Packing Tray Spacing /
 Name Start Stage End Stage Mode Internals Type of
 Vendor Material Dimension Section Packed Height
 Diameter

	Passes	(m)	(m)
CS-1 1_Main Tower	10__Main Tower	Interactive Sizing	
Trayed Sieve 1	---	0.6096	1.300

SETUP

Section Name CS-1
 Section Start 1_Main Tower
 Section End 10_Main Tower
 Internals Trayed
 Internals Type Sieve
 Diameter (m) 1.300
 Tray Spacing / Section Packed Height (m) 0.6096

Number Of Passes	1	Center Weir Height (mm)	---
Maximum Acceptable Pressure Drop (kPa)	2.500	Weir Length (m)	---
Maximum Percent Downcomer Backup	100.00 %	Downcomer Clearance (mm)	---
Maximum Percent Jet Flood	100.00 %	Downcomer Width - Top (mm)	---
Percent Jet Flood For Design	80.00 %	Downcomer Width - Bottom (mm)	---
Maximum Percent Liquid Entrainment	10.00 %	Downcomer Loading Top (m ³ /h-m ²)	---
Minimum Weir Loading (m ³ /h-m)	4.471	Weir Loading (m ³ /h-m)	---
Maximum Weir Loading (m ³ /h-m)	117.4	Downcomer Area - Top (m ²)	---
Minimum Downcomer Area / Total Tray Area	0.1000	Downcomer Area - Bottom (m ²)	---
Override Downcomer Froth Density	No	Picketing Fraction	---
Froth Density	---	Off Center Weir Height (mm)	---
Weep Method	Hsieh	Inside Weir Length (m)	---
Default Jet Flood Calculation Method	GLITSCH6	Outside Weir Length (m)	---
Maximum Downcomer Loading Method	Glitsch	Downcomer Clearance (mm)	---
% Approach to Maximum Capacity	---	Downcomer Width - Top (mm)	---
Design Capacity Factor	---	Downcomer Width - Bottom (mm)	---
Capacity Factor at Flooding	---	Downcomer Loading Top (m ³ /h-m ²)	---
System Foaming Factor	1.000	Maximum Outside Weir Loading (m ³ /h-m)	---
Aeration Factor Multipler	1.000	Maximum Inside Weir Loading (m ³ /h-m)	---
Minimum Liquid Flow Rate	---	Downcomer Area - Top (m ²)	---
Pressure Drop at Flood per Unit Packed Height	---	Downcomer Area - Bottom (m ²)	---
Allowable Pressure Drop per Unit Packed Height	---	Inside Picketing Fraction	---
Minimum Pressure Drop per Unit Packed Height	---	Outside Picketing Fraction	---
Number of Curves	---	Off-Center Downcomer Location (m)	---
Warning Status (% to Limit)	10.00 %	Swept Back Weir Geometry	CS-1
Pressure Drop Calculation Method	---	Compatibility	KG Tower
Mode	Interactive Sizing	A	---
Status	Needs Calculating	B/Parallel Chord Segment	---
GEOOMETRY DETAILS		S/Swept-Back Weir	---
Common Geometry	CS-1	Swept-Back Weir Chord	---
Section Start	1_Main Tower	Angled Chord Segment	---
Section End	10_Main Tower	Tray With Maximum Weir Loading	6
Internals	Sieve	Maximum Weir Loading (m ³ /h-m)	35.75
Section Diameter (m)	1.300	Maximum Allowable Weir Loading in Section (m ³ /h-m)	117.4
Foaming Factor	1.000	Actual Side Weir Length (m)	0.9446
Over-Design Factor	1.000	Effective Side Weir Length (m)	0.9446
Common Tray Geometry	CS-1	Lost Area (%)	0.00
Number of Passes	1	Sieve Geometry	CS-1
Tray Spacing (m)	0.6096	Hole Diameter (mm)	12.70
Picket Fence Weirs	No	Number of Holes	838
Swept Back Weirs	No	Hole Area to Active Area	0.1000
Active Area Under Downcomer	No	Bubble Cap Geometry	CS-1
Deck Thickness	10 Gauge	Cap Diameter	---
Deck Thickness Value (mm)	3.404	Skirt Height	---
Balance Downcomers Based On Maximum Downcomer		Number of Caps	---
Loading		Number of Caps Per Active Area	---
Weir Modifications	None	Valve Geometry	CS-1
Net Area (m ²)	1.195	Tray Type	---
Cross-Sectional Area (m ²)	1.327	Valve Type	---
Active Area (m ²)	1.062	Valve Material	---
Downcomer Geometry	CS-1	Leg Length	---
Side Weir Height (mm)	50.80	Valve Thickness	---
Weir Length (m)	---	Number of Valves	---
Downcomer Clearance (mm)	38.10	Number of Valves per Active Area	---
Downcomer Width - Top (mm)	203.4	Packing Geometry	CS-1
Downcomer Width - Bottom (mm)	203.4	HETP (m)	---
Downcomer Loading Top (m ³ /h-m ²)	111.9	Section Packed Height (m)	---
Weir Loading (m ³ /h-m)	35.75	Packing Type	---
Downcomer Area - Top (m ²)	0.1327	Packing Vendor	---
Downcomer Area - Bottom (m ²)	0.1327	Packing Material	---
Picketing Fraction	---	Packing Dimension	---

Packing Factor (m ² /m ³) ---						
Packing Surface Area (m ² /m ³) ---						
1st Stichlmair Constant ---						
2nd Stichlmair Constant ---						
3rd Stichlmair Constant ---						
Void Fraction ---						
RESULTS SUMMARY						
Section Name CS-1						
Section Start 1_Main Tower						
Section End 10_Main Tower						
Internals Trayed						
Diameter (m) 1.300						
Number of Passes 1						
Tray Spacing / Section Packed Height (m) 0.6096						
Total Height (m) 6.096						
Total Pressure Drop (kPa) 59.42						
Total Pressure Drop (Head Loss) (m) 760.0						
Trays With Weeping None						
Maximum Percent Jet Flood (%) 57.46						
Tray With Maximum Jet Flood 1_Main Tower						
Maximum Percent Downcomer Backup (%) 30.61						
Tray With Maximum Downcomer Backup 6_Main Tower						
Maximum Downcomer Loading (m ³ /h-m ²) 254.4						
Tray With Maximum Downcomer Loading 6_Main Tower						
Maximum Downcomer Loading Location Side						
Maximum Weir Loading (m ³ /h-m) 35.75						
Tray With Maximum Weir Loading 6_Main Tower						
Maximum Weir Loading Location Side						
Maximum Aerated Height Over Weir (mm) 99.71						
Tray With Maximum Aerated Height Over Weir 6_Main Tower						
Maximum % Approach To System Limit (%) 36.75						
Tray With Maximum % Approach To System Limit 1_Main Tower						
Maximum Cs Based On Bubbling Area (%) 7.425e-002						
Tray With Maximum Cs Based On Bubbling Area 1_Main Tower						
Maximum % Capacity (Constant L/V) 57.46						
Maximum Capacity Factor ---						
Section Pressure Drop (kPa) 59.42						
Average Pressure Drop Per Height (kPa/m) ---						
Average Pressure Drop Per Height (Frictional) (mbar/m) ---						
Maximum Stage Liquid Holdup (m ³) ---						
Maximum Liquid Superficial Velocity (m/s) ---						
Surface Area (m ² /m ³) ---						
Void Fraction ---						
1st Stichlmair Constant ---						
2nd Stichlmair Constant ---						
3rd Stichlmair Constant ---						
STAGE BY STAGE RESULTS: CS-1						
State Conditions						
Stages Liquid Temperature Vapor Temperature Liquid						
Mass Flow Vapor Mass Flow Liquid Volume Flow Vapor						
Volume Flow						
(C) (C) (kg/h) (kg/h) (m ³ /s) (m ³ /s)						
1_Main Tower 136.3 140.5 1.041e+004 2.023e+004						
4.127e-003 0.7669						
2_Main Tower 140.5 144.8 9163 1.898e+004						
3.487e-003 0.7560						
3_Main Tower 144.8 148.5 8166 1.799e+004						
2.980e-003 0.7475						
4_Main Tower 148.5 150.9 7554 1.738e+004						
2.672e-003 0.7422						
5_Main Tower 150.9 152.1 7253 1.708e+004						
2.521e-003 0.7390						
6_Main Tower 152.1 157.5 2.720e+004 1.582e+004						
9.381e-003 0.7385						
7_Main Tower 157.5 163.9 2.556e+004 1.417e+004						
8.561e-003 0.7333						
8_Main Tower 163.9 169.4 2.420e+004 1.281e+004						
7.884e-003 0.7334						
9_Main Tower 169.4 172.7 2.342e+004 1.204e+004						
7.498e-003 0.7366						
10_Main Tower 172.7 174.1 2.307e+004 1.169e+004						
7.325e-003 0.7405						
Physical Conditions						
Stages Liquid Molecular Weight Vapor Molecular						
Weight Liquid Mass Density Vapor Mass Density Liquid						
Viscosity Vapor Viscosity Surface Tension						
(kg/m ³) (kg/m ³) (cP) (cP)						
(dyne/cm)						
1_Main Tower 27.75 28.90 700.7 7.329 0.1622						
9.159e-003 24.67						
2_Main Tower 25.46 27.72 730.0 6.976 0.1600						
9.432e-003 30.24						
3_Main Tower 23.47 26.73 761.3 6.685 0.1547						
9.673e-003 34.94						
4_Main Tower 22.15 26.09 785.4 6.503 0.1480						
9.832e-003 37.85						
5_Main Tower 21.46 25.76 799.1 6.418 0.1429						
9.916e-003 39.24						
6_Main Tower 21.15 24.11 805.4 5.949 0.1401						
1.024e-002 39.82						
7_Main Tower 20.08 22.03 829.3 5.369 0.1298						
1.070e-002 41.63						
8_Main Tower 19.10 20.12 852.6 4.853						
8.994e-002 1.108e-002 42.89						
9_Main Tower 18.49 18.91 867.7 4.539						
9.042e-002 1.128e-002 43.33						
10_Main Tower 18.20 18.32 875.1 4.385						
9.027e-002 1.135e-002 43.39						
Hydraulic Results						
Stages Percent Jet Flood Dry Pressure Drop Total						
Pressure Drop Dry Pressure Drop (Head Loss) Total						
Pressure Drop (Head Loss)						
(%) (mbar) (mbar) (mm) (mm)						
1_Main Tower 57.46 3.525 5.984 51.30						
87.09						
2_Main Tower 53.75 3.260 5.838 45.54						
81.54						
3_Main Tower 50.62 3.055 5.752 40.92						
77.04						
4_Main Tower 48.61 2.930 5.717 38.04						
74.22						
5_Main Tower 47.58 2.867 5.704 36.58						
72.79						
6_Main Tower 51.32 2.653 6.322 33.59						
80.05						
7_Main Tower 47.50 2.361 6.147 29.04						
75.58						

8_Main Tower	44.36	2.135	6.029	25.53	6_Main Tower	5.999e-002	27.08	9.971e-002
72.11					2.350e-002			
9_Main Tower	42.60	2.014	5.975	23.67	7_Main Tower	5.575e-002	24.97	8.796e-002
70.21					2.162e-002			
10_Main Tower	41.86	1.967	5.955	22.92	8_Main Tower	5.226e-002	23.31	7.932e-002
69.39					2.022e-002			
Stages	Downcomer Backup (Aerated)	Downcomer Backup (Unaerated)	Percent Downcomer Backup (Aerated)	Percent Downcomer Backup (Unaerated)	9_Main Tower	5.030e-002	22.43	7.473e-002
		(m)	(%)	(%)	10_Main Tower	4.949e-002	22.08	7.278e-002
1_Main Tower	0.1778	0.1076	26.92	16.29	1.912e-002			
2_Main Tower	0.1686	0.1022	25.52	15.47	Side Downcomer Results			
3_Main Tower	0.1614	9.797e-002	24.44	14.83	Stages	Volume	Residence Time	Velocity From Top
						(m3)	(seconds)	Velocity From Bottom Exit Velocity
4_Main Tower	0.1571	9.541e-002	23.79	14.45	1_Main Tower	1.428e-002	3.460	(m/s) (m/s)
5_Main Tower	0.1549	9.414e-002	23.46	14.25	2_Main Tower	1.356e-002	3.890	3.109e-002 3.109e-002
6_Main Tower	0.2021	0.1228	30.61	18.60	3_Main Tower	1.300e-002	4.364	2.627e-002 2.627e-002
7_Main Tower	0.1935	0.1176	29.30	17.81	4_Main Tower	1.266e-002	4.740	2.245e-002 2.245e-002
8_Main Tower	0.1870	0.1137	28.32	17.21	5_Main Tower	1.249e-002	4.956	2.013e-002 2.013e-002
9_Main Tower	0.1835	0.1116	27.79	16.90	6_Main Tower	1.630e-002	1.738	1.900e-002 1.900e-002
10_Main Tower	0.1820	0.1107	27.56	16.76	7_Main Tower	1.561e-002	1.823	7.068e-002 7.068e-002
Stages	Mass Rate / Column Area	Volume Rate / Column Area	Fs (Net Area)	Fs (Bubble Area)	8_Main Tower	1.509e-002	1.914	5.940e-002 5.940e-002
	(kg/s-m2)	(m3/h-m2)	(sqrt(Pa))	(sqrt(Pa))	9_Main Tower	1.481e-002	1.975	0.2191 0.2083
(m/s)					10_Main Tower	1.469e-002	2.006	5.518e-002 5.518e-002
1_Main Tower	2.179	11.19	1.738	1.955	RATING			
6.600e-002					Tray Sections			
2_Main Tower	1.917	9.456	1.671	1.880	Tray Section	Main Tower @COL2		
6.216e-002					Tray Diameter (m)	1.500		
3_Main Tower	1.709	8.082	1.618	1.820	Weir Height (m)	5.000e-002		
5.890e-002					Weir Length (m)	1.200		
4_Main Tower	1.581	7.246	1.584	1.782	Tray Space (m)	0.5000		
5.677e-002					Tray Volume (m3)	0.8836		
5_Main Tower	1.518	6.838	1.567	1.763	Disable Heat Loss Calculations	No		
5.567e-002					Heat Model	None		
6_Main Tower	5.692	25.44	1.508	1.696	Rating Calculations	No		
5.333e-002					Tray Hold Up (m3)	8.836e-002		
7_Main Tower	5.349	23.22	1.422	1.600	Vessels			
4.955e-002					Vessel	Reboiler @COL2		
8_Main Tower	5.064	21.38	1.352	1.522	Diameter (m)	1.193		
4.645e-002					Length (m)	1.789		
9_Main Tower	4.902	20.34	1.314	1.478	Volume (m3)	2.000		
4.472e-002					Orientation	Horizontal		
10_Main Tower	4.829	19.87	1.298	1.460	Vessel has a Boot	No		
4.399e-002					Boot Diameter (m)	---		
Stages	Cs (Bubble Area)	Approach to System Limit			Boot Length (m)	---		
		Height Over Weir (Aerated)	Height Over Weir (Unaerated)		Hold Up (m3)	1.000		
(m/s)	(%)	(m)	(m)		Other Equipment In Column Flowsheet			
1_Main Tower	7.425e-002	36.75	5.461e-002					
1.168e-002								
2_Main Tower	6.993e-002	33.13	4.724e-002					
1.037e-002								
3_Main Tower	6.626e-002	30.50	4.145e-002					
9.301e-003								
4_Main Tower	6.387e-002	28.99	3.792e-002					
8.633e-003								
5_Main Tower	6.263e-002	28.27	3.618e-002					
8.300e-003								
Pressure Profile								

	Pressure (kPa)	Pressure Drop (kPa)				
1_Main Tower	870.0 kPa	2.222 kPa	diM-Ether (%)	99.9985	0.0015	
2_Main Tower	872.2 kPa	2.222 kPa	Methanol (%)	99.4891	0.5109	
3_Main Tower	874.4 kPa	2.222 kPa	H2O (%)	13.8714	86.1286	
4_Main Tower	876.7 kPa	2.222 kPa	COLUMN PROFILES			
5_Main Tower	878.9 kPa	2.222 kPa	Reflux Ratio: 0.5772	Reboil Ratio: 1.013	The Flows	
6_Main Tower	881.1 kPa	2.222 kPa	Option is Selected Flow Basis: Molar			
7_Main Tower	883.3 kPa	2.222 kPa	Column Profiles Flows			
8_Main Tower	885.6 kPa	2.222 kPa	Temp	Pres	Net Liq	Net Vap
9_Main Tower	887.8 kPa	2.222 kPa	Net Feed	Net	Draws	Duty
10_Main Tower	890.0 kPa	---	(C)	(kPa)	(kgmole/h)	(kgmole/h)
Reboiler	890.0 kPa	0.0000 kPa	(kgmole/h)	(kJ/h)		
Pressure Solving Options						
Pressure Tolerance	1.000e-004	Pressure Drop	1_Main Tower	136.3	870.0	375.2
Tolerance	1.000e-004		---	---	325.0	650.0
Damping Factor	1.000	Max Press Iterations	2_Main Tower	140.5	872.2	359.9
SUMMARY			---	700.2	---	---
Flow Basis: Molar		The composition option is selected	3_Main Tower	144.8	874.4	348.0
Feed Composition			---	684.9	---	---
METH reflux		Meth H2O Pumped	4_Main Tower	148.5	876.7	341.1
Flow Rate (kgmole/h)	325.0358	954.8151	---	673.0	---	---
---	---		5_Main Tower	150.9	878.9	338.0
diM-Ether	0.0264	0.0086	---	666.1	---	---
Methanol	0.8177	0.2819	---	662.9	954.8	---
H2O	0.1558	0.7095	6_Main Tower	152.1	881.1	1286
Flow Basis: Molar		The composition option is selected	---	655.9	---	---
Feed Flows			7_Main Tower	157.5	883.3	1273
METH reflux		Meth H2O Pumped	---	643.3	---	---
Flow Rate (kgmole/h)	325.0358	954.8151	8_Main Tower	163.9	885.6	1267
---	---		---	637.0	---	---
diM-Ether (kgmole/h)	8.5829	8.2470	9_Main Tower	169.4	887.8	1267
Methanol (kgmole/h)	265.7961	269.1150	---	636.7	---	---
H2O (kgmole/h)	50.6567	677.4530	10_Main Tower	172.7	890.0	1268
Products			---	629.8		
Flow Basis: Molar		The composition option is selected	Reboiler	174.1	890.0	---
Product Compositions			2.34e+007	638.0	---	629.8
Meth Recycle		Waste Water	Column Profiles Energy			
Flow Rate (kgmole/h)	650.0070	629.8439	Temperature	Liq Enthalpy	Vap Enthalpy	Heat Loss
---	---		(C)	(kJ/kgmole)	(kJ/kgmole)	(kJ/h)
diM-Ether	0.0259	0.0000	1_Main Tower	136.3	-2.413e+005	-2.018e+005
Methanol	0.8187	0.0043	---	---	---	---
H2O	0.1554	0.9957	2_Main Tower	140.5	-2.491e+005	-2.053e+005
Flow Basis: Molar		The composition option is selected	---	---	---	---
Product Flows			3_Main Tower	144.8	-2.559e+005	-2.086e+005
Meth Recycle		Waste Water	---	---	---	---
Flow Rate (kgmole/h)	650.0070	629.8439	4_Main Tower	148.5	-2.603e+005	-2.114e+005
---	---		---	---	---	---
diM-Ether (kgmole/h)	16.8297	0.0003	5_Main Tower	150.9	-2.626e+005	-2.133e+005
Methanol (kgmole/h)	532.1784	2.7328	---	---	---	---
H2O (kgmole/h)	100.9990	627.1108	6_Main Tower	152.1	-2.636e+005	-2.142e+005
Flow Basis: Molar		The composition option is selected	---	---	---	---
Product Recoveries			7_Main Tower	157.5	-2.671e+005	-2.188e+005
Meth Recycle		Waste Water	---	---	---	---
Flow Rate (kgmole/h)	650.0070	629.8439	8_Main Tower	163.9	-2.702e+005	-2.248e+005
---	---		---	---	---	---
diM-Ether (kgmole/h)	532.1784	2.7328	9_Main Tower	169.4	-2.721e+005	-2.305e+005
Methanol (kgmole/h)	100.9990	627.1108	---	---	---	---
Flow Basis: Molar		The composition option is selected	10_Main Tower	172.7	-2.729e+005	-2.341e+005
FEEDS / PRODUCTS			---	---	---	---
Reboiler	174.1	-2.733e+005	-2.359e+005	---		

Flow Basis: Molar

Stream	Type	Duty	State	Flows	Enthalpy
Temp		(kJ/h)		(kgmole/h)	(kJ/kgmole)
(C)					
1_Main Tower	METH reflux Feed	---	Liquid	325	
-2.4e+005	76.29				
Meth Recycle Draw	---	Vapour	650	-	
2.0e+005	136.26				
2_Main Tower					
3_Main Tower					
4_Main Tower					
5_Main Tower					
6_Main Tower	Meth H2O Pumped Feed	---	Liquid		
955	-2.6e+005	145.36			
7_Main Tower					
8_Main Tower					
9_Main Tower					
10_Main Tower					
Reboiler	Reboiler 2 Energy	2.3e+007	---	---	

Waste Water Draw	---	Liquid	630	-	
2.7e+005	174.14				

PERFORMANCE SUMMARY FOR INTERNAL
OPTION: Internals-1@Main Tower@COL2

Number Of Stages	10
Total Height (m)	6.096
Total Head Loss (mm)	760.0
Total Pressure Drop (mbar)	59.42
Number Of Sections	1
Number Of Diameters	1
Pressure Drop Across Sump (kPa)	---
Section Start End Height Diameter Internals Tray or Packing Section Pressure Drop Approach To Flood	
Limiting	
(m) (m) Type Type (mbar) (%) Stage	
CS-1 1_Main Tower 10_Main Tower 0.6096 1.300	
Trayed Sieve 59.42 57.46	
SETUP	

Sub-Flowsheet

Internal Feed Stream	External Feed Stream	Transfer
Basis		
Reboiler 2	Reboiler 2	None Req'd
METH reflux	METH reflux	P-H Flash
Meth H2O Pumped	Meth H2O Pumped	P-H Flash
Internal Prod Stream	External Prod Stream	Transfer
Basis		
Meth Recycle	Meth Recycle	P-H Flash
Waste Water	Waste Water	P-H Flash

VARIABLES

Column Flowsheet Vars Available as Parameters

Data Source	Variable	Component
Description		

COMPONENT MAPS

Feed Streams

Feed Name	In to SubFlowSheet	Out of
SubFlowSheet		
Reboiler 2		
METH reflux		

Product Stream	In to SubFlowSheet	Out of
Product Name		
SubFlowSheet		
Meth Recycle		

TRAY by TRAY PROPERTIES TABLES

Column Temperature / Pressure Profile

Column Stage	Temperature (C)	Pressure (kPa)
1_Main Tower	136.3	870.0
2_Main Tower	140.5	872.2
3_Main Tower	144.8	874.4
4_Main Tower	148.5	876.7
5_Main Tower	150.9	878.9
6_Main Tower	152.1	881.1
7_Main Tower	157.5	883.3
8_Main Tower	163.9	885.6
9_Main Tower	169.4	887.8
10_Main Tower	172.7	890.0
Reboiler	174.1	890.0

Column Flow Profile

Options Selected

Molar flow is selected Net is selected as flow basis

Tray Number	Vapour	Bulk Liquid
	(kgmole/h)	(kgmole/h)

1_Main Tower	650.0	375.2
2_Main Tower	700.2	359.9
3_Main Tower	684.9	348.0
4_Main Tower	673.0	341.1
5_Main Tower	666.1	338.0
6_Main Tower	662.9	1286
7_Main Tower	655.9	1273
8_Main Tower	643.3	1267
9_Main Tower	637.0	1267
10_Main Tower	636.7	1268
Reboiler	638.0	629.8

Column Properties Profile

Options Selected

Mass basis is selected

Stage	Surf Tens	Mol Wt	Dens	Visc	Therm Con
Heat Cap					

	L-Liq (dyne/cm)	L-Liq (kg/m3)	L-Liq (cP)	L-Liq (W/m-K)	L-Liq (kJ/kg-C)
1_Main Tower	24.7	27.7	701	0.162	0.241
4.28					
2_Main Tower	30.2	25.5	730	0.160	0.318
4.32					
3_Main Tower	34.9	23.5	761	0.155	0.397
4.35					
4_Main Tower	37.8	22.1	785	0.148	0.457
4.36					

5_Main Tower	39.2 4.37	21.5	799	0.143	0.490
6_Main Tower	39.8 4.38	21.2	805	0.140	0.506
7_Main Tower	41.6 4.40	20.1	829	0.130	0.562
8_Main Tower	42.9 4.41	19.1	853	8.99e-002	0.617
9_Main Tower	43.3 4.41	18.5	868	9.04e-002	0.653
10_Main Tower	43.4 4.40	18.2	875	9.03e-002	0.671
Reboiler	43.4	18.1	878	9.01e-002	0.679
					4.40

Column Composition Profile

Options Selected

Fraction is selected as the composition basis Net is selected as flow basis

Molar basis is selected

Stage	diM-Ether	Methanol	H2O
	L-Liq	L-Liq	L-Liq
1_Main Tower	0.0043	0.6853	0.3105
2_Main Tower	0.0022	0.5260	0.4718
3_Main Tower	0.0020	0.3846	0.6134
4_Main Tower	0.0019	0.2907	0.7074
5_Main Tower	0.0018	0.2421	0.7561
6_Main Tower	0.0017	0.2204	0.7779
7_Main Tower	0.0004	0.1461	0.8535
8_Main Tower	0.0001	0.0773	0.9226
9_Main Tower	0.0000	0.0341	0.9659
10_Main Tower	0.0000	0.0132	0.9868
Reboiler	0.0000	0.0043	0.9957

Heavy/Light Key Component Ratios

Options Selected

Molar basis is selected

Key Components

Light Key	Chosen	Heavy Key	Chosen
diM-Ether	On	diM-Ether	Off
Methanol	On	Methanol	Off
H2O	On	H2O	Off

Stage Light Liq

1_Main Tower	---
2_Main Tower	---
3_Main Tower	---
4_Main Tower	---
5_Main Tower	---
6_Main Tower	---
7_Main Tower	---
8_Main Tower	---
9_Main Tower	---
10_Main Tower	---
Reboiler	---

Column K-Values Profile

Tray Number	diM-Ether	Methanol	H2O
1_Main Tower	6.088	1.195	0.5005
2_Main Tower	6.280	1.422	0.5050
3_Main Tower	6.681	1.730	0.5240
4_Main Tower	7.159	2.045	0.5542

5_Main Tower	7.507	2.267	0.5791
6_Main Tower	7.688	2.384	0.5931
7_Main Tower	8.561	2.928	0.6664
8_Main Tower	9.739	3.685	0.7743
9_Main Tower	10.79	4.387	0.8804
10_Main Tower	11.42	4.826	0.9490
Reboiler	11.73	5.037	0.9824

MIX-100 (Mixer): Design, Rating

Mixer: MIX-100

CONNECTIONS

Inlet Stream

STREAM NAME	FROM UNIT OPERATION
Meth feed	
meth to rctr 2	RCY-3 Recycle

STREAM NAME	TO UNIT OPERATION
meth feed 2	P-100 Pump

PARAMETERS

User Variables

NOZZLE PARAMETERS

Base Elevation Relative to Ground Level 0.0000 m		
Meth feed	meth to rctr 2	meth feed 2
Diameter (m)	5.000e-002	5.000e-002
Elevation (Base) (m)	0.0000	0.0000
Elevation (Ground) (m)	0.0000	0.0000

GBR-100 (Gibbs Reactor): Design, Reactions, Rating

Gibbs Reactor: GBR-100

CONNECTIONS

Inlet Stream Connections

Stream Name	From Unit Operation
reactor feed	E-101 Heat Exchanger
Outlet Stream Connections	

Stream Name	To Unit Operation
reactor out	Heat Exchanger: E-101

Purge

Energy Stream Connections

Stream Name	From Unit Operation

PARAMETERS

Physical Parameters	Optional Heat Transfer

Delta P Stream	Vessel Volume	Duty	Energy	Inlet Stream
0.0000 kPa	---	0.0000 kJ/h		STREAM NAME FROM UNIT OPERATION
User Variables				D1 feed E-101 Heat Exchanger
REACTIONS OVERALL				Outlet Stream
REACTIONS SUMMARY: Set-1				
Name Est. Extent	% Conversion	Base	Equilibrium Rxn Extent	STREAM NAME TO UNIT OPERATION
Rxn-1 ---	Component	Constant		D1 feed cooled P-102 Pump
	Methanol	---	---	Energy Stream
REACTOR COMPONENT SUMMARY				STREAM NAME TO UNIT OPERATION
Components	Total Inflow	Total Reaction	Total Outflow	cooler1
	---	---	---	PARAMETERS
	---	---	---	
	---	---	---	
REACTION DETAILS				Pressure Drop: 0.0000 kPa Duty: 6.679e+007 kJ/h
MOLE FLOW SPECIFICATIONS				Volume: 0.1000 m ³
Components Fixed Spec	Total Feed (kgmole/h)	Total Prod (kgmole/h)	Inerts (kgmole/h)	Function: Not Selected Zones: 1
diM-Ether	8.414	629.1	No	User Variables
Methanol	1511	269.6	No	
H2O	56.77	677.5	No	
ATOM MATRIX DATA				
	C	H	O	
diM-Ether	2.000	6.000	1.000	
Methanol	1.000	4.000	1.000	
H2O	0.0000	2.000	1.000	
RATING				
Sizing				
Cylinder	Vertical	Reactor has a Boot:		
No				
Volume ---	Diameter ---	Height ---		
Nozzles				
Base Elevation Relative to Ground Level 0.0000 m				
Diameter ---	Height ---			
	reactor feed	reactor out	Purge	
Diameter (m)	5.000e-002	5.000e-002	5.000e-002	
Elevation (Base) (m)	0.0000	0.0000	0.0000	
Elevation (Ground) (m)	0.0000	0.0000	0.0000	
Elevation (% of Height) (%) ---	---	---	---	
<hr/> E-102 (Cooler): Design, Rating, Profiles, Tables <hr/>				
Cooler: E-102				
CONNECTIONS				

0.0000	0.0000	---	Heavy Liquid Phase											
Vapour Phase														
Mass Flow Molecular Wt Density Mass Sp Heat														
Viscosity Thermal Cond		Cond Surface Tens		Mass Sp Heat		Viscosity		Thermal						
(kg/h)	(kg/m3)	(kJ/kg-C)	(cP)	(W/m-K)	(kg/h)	(kg/m3)	(kJ/kg-C)	(W/m-K)						
49823.68	31.61	5.49	2.09	0.02	0.04	---	---	---						
49823.68	31.61	5.70	2.05	0.01	0.04	---	---	---						
49823.68	31.61	5.93	2.01	0.01	0.04	---	---	---						
49823.68	31.61	6.17	1.98	0.01	0.03	---	---	---						
49823.68	31.61	6.43	1.95	0.01	0.03	---	---	---						
49823.68	31.61	6.72	1.92	0.01	0.03	---	---	---						
49823.68	31.61	7.04	1.91	0.01	0.03	---	---	---						
42541.05	34.41	8.04	1.83	0.01	0.03	7282.63	807.87	3.92						
29465.49	39.60	9.73	1.71	0.01	0.02	20358.19	756.59	4.29						
16872.06	43.04	11.15	1.64	0.01	0.02	32951.62	714.98	3.79						
---	---	---	---	---	---	---	---	---						
Std Gas Flow Z Factor Pseudo Pc Pseudo Tc Pseudo	Zc Pseudo Omega	Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo												
(STD_m3/h)	(kPa)	(C)	(kPa)	(C)	(kPa)	(C)	(kPa)	(C)						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
37266.37	1.00	12892.78	252.40	0.26	0.32	---	---	---						
29227.76	1.00	11090.89	227.48	0.27	0.31	21.42	0.81	19444.33						
17592.10	1.00	8123.26	181.99	0.27	0.28	24.47	0.76	17157.53						
9269.16	1.00	6528.65	152.51	0.27	0.24	27.83	0.71	14999.78						
---	---	---	---	---	---	---	---	---						
Light Liquid Phase														
Mass Flow Density Mass Sp Heat Viscosity Thermal														
Cond Surface Tens		Cond Surface Tens		Viscosity		Thermal								
(kg/h)	(kg/m3)	(kJ/kg-C)	(cP)	(W/m-K)	(kg/h)	(kg/m3)	(kJ/kg-C)	(W/m-K)						
(dyne/cm)					(dyne/cm)									
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
49823.68	680.04	3.39	0.15	0.28	33.17	7282.63	807.87	3.92						
Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo	Zc Pseudo Omega	Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo												
(kPa)	(C)	(kPa)	(C)	(kPa)	(C)	(kPa)	(C)							
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
---	---	---	---	---	---	---	---	---						
21.42	0.81	19444.33	343.02	0.26	0.36									
24.47	0.76	17157.53	315.37	0.26	0.36									
27.83	0.71	14999.78	285.48	0.26	0.35									
31.61	0.68	12892.78	252.40	0.26	0.32									

E-103 (Cooler): Design, Rating, Profiles, Tables	0.0000	0.0000	---	
Cooler: E-103	0.0000	0.0000	---	
CONNECTIONS	0.0000	0.0000	---	
Inlet Stream	0.0000	0.0000	---	
STREAM NAME	FROM UNIT OPERATION			
Meth Recycle	T-101 Reboiled Absorber			
Outlet Stream	---			
STREAM NAME	TO UNIT OPERATION			
Cooled meth recycle	P-103 Pump			
Energy Stream	---			
STREAM NAME	TO UNIT OPERATION			
Cooler3	---			
PARAMETERS	---			
Pressure Drop: 0.0000 kPa	Duty: 2.470e+007 kJ/h	---		
Volume: 0.1000 m3	---			
Function: Not Selected	Zones: 1	---		
User Variables	---			
NOZZLE PARAMETERS	---			
Base Elevation Relative to Ground Level 0.0000 m	---			
Meth Recycle Cooled meth recycle	---			
Diameter (m)	5.000e-002	5.000e-002	---	
Elevation (Base) (m)	0.0000	0.0000	---	
Elevation (Ground) (m)	0.0000	0.0000	---	
PERFORMANCE PROFILES	---			
Zone Pressure Temperature Vapour Fraction	---			
Enthalpy (kPa) (C) (kJ/kgmole)	---			
Inlet 870.00 136.26 1.0000 -201833.38	---			
0 870.00 76.26 0.0000 -239827.88	---			
PERFORMANCE TABLE	Light Liquid Phase			
Overall Phase	---			
Temperature Pressure Heat Flow Enthalpy	---			
(C) (kPa) (kJ/h) (kJ/kgmole)	---			
136.26 870.00 0.00 -201833.38	---			
130.26 870.00 -19288457.75 -231507.61	18293.94 677.79 4.17 0.16 0.18 19.57			
124.26 870.00 -20927755.57 -234029.58	19646.84 683.26 4.35 0.17 0.18 20.17			
118.26 870.00 -21427800.51 -234798.87	19646.84 691.29 4.17 0.18 0.19 21.08			
112.26 870.00 -21914380.61 -235547.45	19646.84 699.11 4.09 0.20 0.19 21.99			
106.26 870.00 -22392444.87 -236282.92	19646.84 706.72 4.02 0.21 0.19 22.91			
100.26 870.00 -22863705.28 -237007.93	19646.84 714.16 3.97 0.22 0.19 23.84			
94.26 870.00 -23329143.12 -237723.98	19646.84 721.43 3.93 0.24 0.20 24.77			
88.26 870.00 -23789446.27 -238432.13	19646.84 728.55 3.88 0.25 0.20 25.70			
82.26 870.00 -24245149.01 -239133.21	19646.84 735.53 3.85 0.27 0.20 26.63			
76.26 870.00 -24696690.78 -239827.88	19646.84 742.38 3.81 0.29 0.21 27.57			
Vapour Fraction Vap Phase Mass Frac Heat of Vap	Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo Zc Pseudo Omega			
(kJ/kgmole)	(kPa) (C)			
1.0000 1.0000 ---	30.06 0.68 9707.13 258.89 0.25 0.52			
0.0638 0.0689 ---	30.23 0.68 9614.08 257.46 0.25 0.51			

30.23	0.69	9614.08	257.46	0.25	0.51
30.23	0.70	9614.08	257.46	0.25	0.51
30.23	0.71	9614.08	257.46	0.25	0.51
30.23	0.71	9614.08	257.46	0.25	0.51
30.23	0.72	9614.08	257.46	0.25	0.51
30.23	0.73	9614.08	257.46	0.25	0.51
30.23	0.74	9614.08	257.46	0.25	0.51
30.23	0.74	9614.08	257.46	0.25	0.51

Heavy Liquid Phase

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m³) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)

---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---

Molecular Wt Sp Gravity Pseudo Pc Pseudo Tc Pseudo
Zc Pseudo Omega

---	---	(kPa)	(C)	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---

Mixed Liquid Phase

Mass Flow Density Mass Sp Heat Viscosity Thermal
Cond Surface Tens
(kg/h) (kg/m³) (kJ/kg-C) (cP) (W/m-K)
(dyne/cm)

18293.94	677.79	4.17	0.16	0.18	19.57
19646.84	683.26	4.35	0.17	0.18	20.17
19646.84	691.29	4.17	0.18	0.19	21.08
19646.84	699.11	4.09	0.20	0.19	21.99
19646.84	706.72	4.02	0.21	0.19	22.91
19646.84	714.16	3.97	0.22	0.19	23.84
19646.84	721.43	3.93	0.24	0.20	24.77
19646.84	728.55	3.88	0.25	0.20	25.70
19646.84	735.53	3.85	0.27	0.20	26.63
19646.84	742.38	3.81	0.29	0.21	27.57
Molecular Wt	Sp Gravity	Pseudo Pc	Pseudo Tc	Pseudo	
Zc	Pseudo Omega				
---	---	(kPa)	(C)	---	---

30.06	0.68	9707.13	258.89	0.25	0.52
30.23	0.68	9614.08	257.46	0.25	0.51

30.23	0.69	9614.08	257.46	0.25	0.51
30.23	0.70	9614.08	257.46	0.25	0.51
30.23	0.71	9614.08	257.46	0.25	0.51
30.23	0.71	9614.08	257.46	0.25	0.51
30.23	0.72	9614.08	257.46	0.25	0.51
30.23	0.73	9614.08	257.46	0.25	0.51
30.23	0.74	9614.08	257.46	0.25	0.51
30.23	0.74	9614.08	257.46	0.25	0.51

E-104 (Cooler): Design, Rating, Profiles, Tables

Cooler: E-104

CONNECTIONS

Inlet Stream

STREAM NAME FROM UNIT OPERATION
DME outlet T-100 Reboiled Absorber
Outlet Stream

STREAM NAME TO UNIT OPERATION
DME out2 P-104 Pump
Energy Stream

STREAM NAME TO UNIT OPERATION
cooler2
PARAMETERS

Pressure Drop: 0.0000 kPa Duty: 2.364e+007 kJ/h
Volume: 0.1000 m³
Function: Not Selected Zones: 1
User Variables

NOZZLE PARAMETERS

Base Elevation Relative to Ground Level 0.0000 m
DME outlet DME out2
Diameter (m) 5.000e-002 5.000e-002
Elevation (Base) (m) 0.0000 0.0000
Elevation (Ground) (m) 0.0000 0.0000
PERFORMANCE PROFILES

Zone	Pressure	Temperature	Vapour Fraction
Enthalpy	(kPa)	(C)	(kJ/kgmole)
Inlet	820.00	37.94	1.0000 -183339.13
0	820.00	36.94	0.0000 -202207.96

PERFORMANCE TABLE

Overall Phase

Temperature	Pressure	Heat Flow	Enthalpy
(C)	(kPa)	(kJ/h)	(kJ/kgmole)
37.94	820.00	0.00	-183339.13
37.84	820.00	-167637.55	-183472.93
37.74	820.00	-403347.75	-183661.06
37.64	820.00	-755150.17	-183941.86
37.54	820.00	-1341529.14	-184409.88
37.44	820.00	-2533470.21	-185361.25

37.34	820.00	-6369657.75	-188423.15		57706.12	585.16	2.51	0.08	0.13	10.09
37.24	820.00	-23596837.39	-202173.23		57706.12	585.31	2.51	0.08	0.13	10.11
37.14	820.00	-23611347.29	-202184.81		57706.12	585.47	2.51	0.08	0.13	10.12
37.04	820.00	-23625852.71	-202196.39	Molecular Weight	Sp Grav	Pseudo	Pc	Pseudo	Tc	Pseudo
36.94	820.00	-23640353.63	-202207.96	Zc	Pseudo Omega					
Vapour Fraction	Vap Phase Mass Frac (kJ/kgmole)	Heat of Vap			(kPa)	(C)				
1.0000	1.0000	---			45.84	0.59	5356.26	128.68	0.27	0.21
0.9933	0.9934	---			45.88	0.59	5349.39	128.36	0.27	0.20
0.9838	0.9838	---			45.92	0.59	5343.07	128.05	0.27	0.20
0.9693	0.9694	---			45.96	0.59	5337.00	127.74	0.27	0.20
0.9448	0.9449	---			46.00	0.59	5331.06	127.43	0.27	0.20
0.8946	0.8947	---			46.03	0.59	5325.19	127.13	0.27	0.20
0.7319	0.7321	---			46.06	0.59	5321.53	126.93	0.27	0.20
0.0000	0.0000	---			46.06	0.59	5321.53	126.93	0.27	0.20
0.0000	0.0000	---			46.06	0.59	5321.53	126.93	0.27	0.20
0.0000	0.0000	---			46.06	0.59	5321.53	126.93	0.27	0.20
0.0000	0.0000	---			Heavy Liquid Phase					

Vapour Phase

Mass Flow	Molecular Wt	Density	Mass Sp	Heat	
Viscosity	Thermal Cond				
(kg/h)	(kg/m3)	(kJ/kg-C)	(cP)	(W/m-K)	
57706.12	46.06	14.60	1.47	0.01	0.02
57322.93	46.06	14.61	1.47	0.01	0.02
56772.83	46.06	14.61	1.47	0.01	0.02
55937.86	46.06	14.62	1.47	0.01	0.02
54527.23	46.06	14.62	1.47	0.01	0.02
51630.51	46.07	14.63	1.47	0.01	0.02
42244.73	46.07	14.63	1.47	0.01	0.02
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
Std Gas Flow	Z Factor	Pseudo Pc	Pseudo Tc	Pseudo	
Zc	Pseudo Omega				
(STD_m3/h)	(kPa)	(C)			
29623.60	1.00	5321.53	126.93	0.27	0.20
29425.95	1.00	5321.30	126.92	0.27	0.20
29142.63	1.00	5321.07	126.91	0.27	0.20
28713.10	1.00	5320.85	126.90	0.27	0.20
27988.11	1.00	5320.63	126.88	0.27	0.20
26500.42	1.00	5320.41	126.87	0.27	0.20
21682.28	1.00	5320.19	126.86	0.27	0.20
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---
---	---	---	---	---	---

Light Liquid Phase

Mass Flow	Density	Mass Sp	Heat	Viscosity	Thermal
Cond	Surface	Tens			
(kg/h)	(kg/m3)	(kJ/kg-C)	(cP)	(W/m-K)	
(dyne/cm)					
---	---	---	---	---	---
383.19	586.48	2.53	0.08	0.13	10.28
933.29	586.21	2.53	0.08	0.13	10.24
1768.26	585.94	2.53	0.08	0.13	10.20
3178.89	585.66	2.52	0.08	0.13	10.17
6075.62	585.39	2.52	0.08	0.13	10.13
15461.39	585.12	2.52	0.08	0.13	10.10
57706.12	585.00	2.51	0.08	0.13	10.08

	Mass Flow	Density	Mass Sp	Heat	Viscosity	Thermal
Cond	Surface	Tens				
(kg/h)	(kg/m3)	(kJ/kg-C)	(cP)	(W/m-K)		
(dyne/cm)						
---	---	---	---	---	---	---
383.19	586.48	2.53	0.08	0.13	10.28	
933.29	586.21	2.53	0.08	0.13	10.24	
1768.26	585.94	2.53	0.08	0.13	10.20	
3178.89	585.66	2.52	0.08	0.13	10.17	
6075.62	585.39	2.52	0.08	0.13	10.13	
15461.39	585.12	2.52	0.08	0.13	10.10	
57706.12	585.00	2.51	0.08	0.13	10.08	

Mixed Liquid Phase

Mass Flow	Density	Mass Sp	Heat	Viscosity	Thermal
Cond	Surface	Tens			
(kg/h)	(kg/m3)	(kJ/kg-C)	(cP)	(W/m-K)	
(dyne/cm)					
---	---	---	---	---	---
383.19	586.48	2.53	0.08	0.13	10.28
933.29	586.21	2.53	0.08	0.13	10.24
1768.26	585.94	2.53	0.08	0.13	10.20
3178.89	585.66	2.52	0.08	0.13	10.17
6075.62	585.39	2.52	0.08	0.13	10.13
15461.39	585.12	2.52	0.08	0.13	10.10
57706.12	585.00	2.51	0.08	0.13	10.08

Molecular Wt	Sp Gravity	Pseudo Pc	Pseudo Tc	Pseudo Zc	Pseudo Omega
(kPa)	(C)				
45.84	0.59	5356.26	128.68	0.27	0.21
45.88	0.59	5349.39	128.36	0.27	0.20
45.92	0.59	5343.07	128.05	0.27	0.20
45.96	0.59	5337.00	127.74	0.27	0.20
46.00	0.59	5331.06	127.43	0.27	0.20
46.03	0.59	5325.19	127.13	0.27	0.20
46.06	0.59	5321.53	126.93	0.27	0.20
46.06	0.59	5321.53	126.93	0.27	0.20
46.06	0.59	5321.53	126.93	0.27	0.20
46.06	0.59	5321.53	126.93	0.27	0.20

P-100 (Pump): Design, Rating, Performance

Pump: P-100

CONNECTIONS

Inlet Stream

Stream Name From Unit Operation
meth feed 2 MIX-100 Mixer

Stream Name To Unit Operation
meth feed 2 high P E-100 Heater

Stream Name From Unit Operation
Pump1

PARAMETERS

Adiabatic Efficiency (%): 75.00 Delta P: 690.0 kPa

Duty: 16.38 kW

CURVES

Delta P: 690.0 kPa Duty: 16.38 kW
Coefficient A: 0.0000 Coefficient B: 0.0000 Coefficient C: 0.0000

Parameter Preferences Units for Delta P: m Flow Basis

ActVolFlow Units for Flow: m3/h

User Variables

RATING

Head Offset: --- Efficiency Offset: ---
Characteristic Curves

Speed:
Flow Head Efficiency (%)
NPSH

NPSH Required --- NPSH Available 13.14 m Enable
NPSH Curves: No
NPSH Curves

Nozzle Parameters

Base Elevation Relative to Ground Level 0.0000 m

meth feed 2 meth feed 2 high P

Diameter (m) 5.000e-002 5.000e-002

Elevation (Base) (m) 0.0000 0.0000

Elevation (Ground) (m) 0.0000 0.0000

Inertia

Rotational inertia (kg-m²) 0.5000 Radius of gyration (m)

0.1000 Mass (kg) 50.00 Friction loss factor (kg-m²/s)

5.000e-002

Start Up

Design Flow Typical Operating Capacity 10.00 m³/h

PERFORMANCE

Results

Total Head --- Velocity Head -7.869e-004 m

Total Fluid Head ---

Pressure Head 90.49 m Delta P excluding Static

Head Results ---

P-101 (Pump): Design, Rating, Performance

Pump: P-101

CONNECTIONS

Inlet Stream

Stream Name From Unit Operation
Meth H2O T-100 Reboiled Absorber

Stream Name To Unit Operation
Meth H2O Pumped T-101 Reboiled Absorber

Stream Name From Unit Operation
pumper

PARAMETERS

Adiabatic Efficiency (%): 75.00 Delta P: 40.00 kPa

Duty: 0.3996 kW

CURVES

Delta P: 40.00 kPa Duty: 0.3996 kW
Coefficient A: 0.0000 Coefficient B: 0.0000 Coefficient C: 0.0000

Parameter Preferences Units for Delta P: m Flow Basis

ActVolFlow Units for Flow: m3/h

User Variables

RATING

Head Offset: --- Efficiency Offset: ---
Characteristic Curves

Flow NPSH	Speed: Head	Efficiency (%)
--------------	----------------	----------------

NPSH Required --- NPSH Available 0.7431 m Enable
 NPSH Curves: No
 NPSH Curves

Nozzle Paramaters

Base Elevation Relative to Ground Level 0.0000 m

Meth H₂O Meth H₂O Pumped

Diameter (m) 5.000e-002 5.000e-002

Elevation (Base) (m) 0.0000 0.0000

Elevation (Ground) (m) 0.0000 0.0000

Inertia

Rotational inertia (kg-m²) 0.5000 Radius of gyration (m)

0.1000 Mass (kg) 50.00 Friction loss factor (kg-m²/s)

5.000e-002

Start Up

Design Flow Typical Operating Capacity 10.00 m³/h

PERFORMANCE

Results

Total Head --- Velocity Head -5.837e-005 m

Total Fluid Head ---

Pressure Head 5.187 m Delta P excluding Static

Head Results ---

P-102 (Pump): Design, Rating, Performance

Pump: P-102

CONNECTIONS

Inlet Stream

Stream Name From Unit Operation
 D1 feed cooled E-102 Cooler
 Outlet Stream

Stream Name To Unit Operation
 D1 feed pumped TEE-102 Tee
 Energy Stream

Stream Name From Unit Operation
 pumper2
 PARAMEETERS

Adiabatic Efficiency (%): 75.00 Delta P: 40.00 kPa

Duty: 1.085 kW

CURVES

Delta P: 40.00 kPa Duty: 1.085 kW
 Coefficient A: 0.0000 Coefficient B: 0.0000 Coefficient
 C: 0.0000

Parameter Preferences Units for Delta P: m Flow Basis

ActVolFlow Units for Flow: m³/h

User Variables

RATING

Head Offset: --- Efficiency Offset: ---

Characteristic Curves

Speed: Flow NPSH	Head	Efficiency (%)
------------------------	------	----------------

NPSH Required --- NPSH Available 7.521 m Enable
 NPSH Curves: No
 NPSH Curves

Nozzle Paramaters

Base Elevation Relative to Ground Level 0.0000 m

D1 feed cooled D1 feed pumped

Diameter (m) 5.000e-002 5.000e-002

Elevation (Base) (m) 0.0000 0.0000

Elevation (Ground) (m) 0.0000 0.0000

Inertia

Rotational inertia (kg-m²) 0.5000 Radius of gyration (m)

0.1000 Mass (kg) 50.00 Friction loss factor (kg-m²/s)

5.000e-002

Start Up

Design Flow Typical Operating Capacity 10.00 m³/h

PERFORMANCE

Results

Total Head --- Velocity Head 1.659e-004 m

Total Fluid Head ---

Pressure Head 5.998 m Delta P excluding Static

Head Results ---

P-103 (Pump): Design, Rating, Performance

Pump: P-103

CONNECTIONS

Inlet Stream

Stream Name From Unit Operation
 Cooled meth recycle E-103 Cooler
 Outlet Stream

Stream Name To Unit Operation
 CMR2 TEE-100 Tee
 Energy Stream

Stream Name From Unit Operation
 pumper3
 PARAMEETERS

Adiabatic Efficiency (%): 75.00 Delta P: 40.00 kPa

Duty: 0.3921 kW

CURVES

Delta P: 40.00 kPa Duty: 0.3921 kW
Coefficient A: 0.0000 Coefficient B: 0.0000 Coefficient C: 0.0000
Parameter Preferences Units for Delta P: m Flow Basis
ActVolFlow Units for Flow: m³/h
User Variables

RATING

Head Offset: --- Efficiency Offset: ---
Characteristic Curves

Speed:
Flow Head Efficiency (%)
NPSH

NPSH Required --- NPSH Available 94.13 m Enable
NPSH Curves: No
NPSH Curves

Nozzle Paramaters

Base Elevation Relative to Ground Level 0.0000 m
Cooled meth recycle CMR2
Diameter (m) 5.000e-002 5.000e-002
Elevation (Base) (m) 0.0000 0.0000
Elevation (Ground) (m) 0.0000 0.0000
Inertia

Rotational inertia (kg-m²) 0.5000 Radius of gyration (m)
0.1000 Mass (kg) 50.00 Friction loss factor (kg-m²/s)
5.000e-002
Start Up

Design Flow Typical Operating Capacity 10.00 m³/h
PERFORMANCE

Results

Total Head --- Velocity Head -4.134e-005 m
Total Fluid Head ---
Pressure Head 5.494 m Delta P excluding Static
Head Results ---

P-104 (Pump): Design, Rating, Performance

Pump: P-104

CONNECTIONS

Inlet Stream

Stream Name From Unit Operation
DME out2 E-104 Cooler
Outlet Stream

Stream Name To Unit Operation
DME out3 TEE-101 Tee
Energy Stream

Stream Name From Unit Operation
pumper4
PARAMETERS

Adiabatic Efficiency (%): 75.00 Delta P: 40.00 kPa
Duty: 1.460 kW
CURVES

Delta P: 40.00 kPa Duty: 1.460 kW
Coefficient A: 0.0000 Coefficient B: 0.0000 Coefficient C: 0.0000
Parameter Preferences Units for Delta P: m Flow Basis
ActVolFlow Units for Flow: m³/h
User Variables

RATING

Head Offset: --- Efficiency Offset: ---
Characteristic Curves

Speed:
Flow Head Efficiency (%)
NPSH

NPSH Required --- NPSH Available 11.18 m Enable
NPSH Curves: No
NPSH Curves

Nozzle Paramaters

Base Elevation Relative to Ground Level 0.0000 m
DME out2 DME out3
Diameter (m) 5.000e-002 5.000e-002
Elevation (Base) (m) 0.0000 0.0000
Elevation (Ground) (m) 0.0000 0.0000
Inertia

Rotational inertia (kg-m²) 0.5000 Radius of gyration (m)
0.1000 Mass (kg) 50.00 Friction loss factor (kg-m²/s)
5.000e-002
Start Up

Design Flow Typical Operating Capacity 10.00 m³/h
PERFORMANCE

Results

Total Head --- Velocity Head -7.647e-004 m
Total Fluid Head ---
Pressure Head 6.967 m Delta P excluding Static
Head Results ---

P-105 (Pump): Design, Rating, Performance

Pump: P-105

CONNECTIONS

Inlet Stream

Stream Name	From Unit Operation	-----
Waste Water Outlet Stream	T-101 Reboiled Absorber	Recycle: RCY-1
Stream Name	To Unit Operation	CONNECTIONS
WWT Energy Stream		Inlet Stream
Stream Name	From Unit Operation	Stream Name From Unit Operation
Pumper5		DME reflux 1 TEE-101 Tee
PARAMETERS		Outlet Stream
Adiabatic Efficiency (%): 75.00	Delta P: 40.00 kPa	Stream Name To Unit Operation
Duty: 0.1921 kW		DME reflux T-100 Reboiled Absorber
CURVES		TOLERANCE
Delta P: 40.00 kPa	Duty: 0.1921 kW	Vapour Fraction: 10.00 Temperature: 10.00 Pressure:
Coefficient A: 0.0000	Coefficient B: 0.0000	10.00
C: 0.0000		Flow: 10.00 Enthalpy: 10.00 Composition:
Parameter Preferences Units for Delta P: m	Flow Basis	10.00
ActVolFlow Units for Flow: m3/h		NUMERICAL
User Variables		Acceleration Type: Wegstein Iteration Type: Nested
RATING		Maximum Iterations: 10 Iteration Count: 0
Head Offset: ---	Efficiency Offset: ---	Wegstein Count: 3 Q Minimum: -20.00 Q
Characteristic Curves		Maximum: 0.0000
Speed:		Iteration History
Flow Head NPSH	Efficiency (%)	Iteration Variable Outlet Value Inlet Value
NPSH Required ---	NPSH Available 0.1708 m	0 Converged --- ---
NPSH Curves: No	Enable	User Variables
NPSH Curves		-----
Nozzle Parameters		RCY-2 (Recycle): Design
Base Elevation Relative to Ground Level 0.0000 m		-----
Waste Water WWT		Recycle: RCY-2
Diameter (m)	5.000e-002	CONNECTIONS
Elevation (Base) (m)	0.0000	Inlet Stream
Elevation (Ground) (m)	0.0000	Stream Name From Unit Operation
Inertia		meth to tower TEE-100 Tee
Rotational inertia (kg-m ²)	0.5000	Outlet Stream
Radius of gyration (m)		Stream Name To Unit Operation
0.1000 Mass (kg)	50.00	METH reflux T-101 Reboiled Absorber
Friction loss factor (kg-m ² /s)		TOLERANCE
5.000e-002		Vapour Fraction: 10.00 Temperature: 10.00 Pressure:
Start Up		10.00
Design Flow Typical Operating Capacity 10.00 m ³ /h		Flow: 10.00 Enthalpy: 10.00 Composition:
PERFORMANCE		10.00
Results		NUMERICAL
Total Head ---	Velocity Head -8.764e-006 m	Acceleration Type: Wegstein Iteration Type: Nested
Total Fluid Head ---		Maximum Iterations: 10 Iteration Count: 0
Pressure Head 4.644 m	Delta P excluding Static	Wegstein Count: 3 Q Minimum: -20.00 Q
Head Results ---		Maximum: 0.0000
RCY-1 (Recycle): Design		Iteration History
-----		Iteration Variable Outlet Value Inlet Value
		4 Converged --- ---

User Variables

RCY-3 (Recycle): Design

Recycle: RCY-3

CONNECTIONS

Inlet Stream

Stream Name meth to rctr	From Unit Operation
Outlet Stream	TEE-100 Tee

Stream Name meth to rctr 2	To Unit Operation
TOLERANCE	MIX-100 Mixer

Vapour Fraction: 10.00 Temperature: 10.00 Pressure:
10.00

Flow: 10.00 Enthalpy: 10.00 Composition:
10.00

NUMERICAL

Acceleration Type: Wegstein Iteration Type: Nested

Maximum Iterations: 10 Iteration Count: 0

Wegstein Count: 3 Q Minimum: -20.00 Q

Maximum: 0.0000

Iteration History

Iteration Variable 5 Converged	Outlet Value ---	Inlet Value ---
-----------------------------------	---------------------	--------------------

TEE-100 (Tee): Design, Rating, Dynamcis

Tee: TEE-100

CONNECTIONS

Inlet Stream

STREAM NAME CMR2	FROM UNIT OPERATION
	P-103 Pump
Outlet Stream	

STREAM NAME meth to rctr	TO UNIT OPERATION
	RCY-3 Recycle
meth to tower	RCY-2 Recycle
PARAMETERS	

Flow Ratios Openings	Dynamic Valve
meth to rctr 0.5000	50.00
meth to tower 0.5000	50.00

Valve Control: Multiple Stream

User Variables

RATING

Nozzle Parameters

Base Elevation Relative to Ground Level 0.0000 m
CMR2 meth to rctr meth to tower
Diameter (m) 5.000e-002 5.000e-002 5.000e-002
Elevation (Base) (m) 0.0000 0.0000 0.0000
Elevation (Ground) (m) 0.0000 0.0000 0.0000
DYNAMICS

Holdup Details

Phase	Accumulation (kgmole/h)	Moles (kgmole)	Volume (m ³)
Vapour	0.0000	0.0000	0.0000
Liquid	0.0000	0.0000	0.0000
Aqueous	0.0000	0.0000	0.0000
Total	0.0000	0.0000	0.0000

TEE-101 (Tee): Design, Rating, Dynamcis

Tee: TEE-101

CONNECTIONS

Inlet Stream

STREAM NAME DME out3	FROM UNIT OPERATION
	P-104 Pump
Outlet Stream	

STREAM NAME DME product	TO UNIT OPERATION
DME reflux 1	RCY-1 Recycle
PARAMETERS	

Flow Ratios Openings	Dynamic Valve
DME product 0.5000	50.00
DME reflux 1 0.5000	50.00

Valve Control: Multiple Stream

User Variables

RATING

Nozzle Parameters

Base Elevation Relative to Ground Level 0.0000 m
DME out3 DME product DME
reflux 1
Diameter (m) 5.000e-002 5.000e-002 5.000e-002
Elevation (Base) (m) 0.0000 0.0000 0.0000
Elevation (Ground) (m) 0.0000 0.0000 0.0000
DYNAMICS

Holdup Details

Phase	Accumulation	Moles	Volume
-------	--------------	-------	--------

	(kgmole/h)	(kgmole)	(m3)
Vapour	0.0000	0.0000	0.0000
Liquid	0.0000	0.0000	0.0000
Aqueous	0.0000	0.0000	0.0000
Total	0.0000	0.0000	0.0000

TEE-102 (Tee): Design, Rating, Dynamcis

Tee: TEE-102

CONNECTIONS

Inlet Stream

STREAM NAME	FROM UNIT OPERATION
D1 feed pumped	P-102 Pump
Outlet Stream	

STREAM NAME	TO UNIT OPERATION
normal op	T-100 Reboiled Absorber
turn down	T-100 Reboiled Absorber

PARAMETERS

Openings	Flow Ratios	Dynamic Valve
normal op	0.5000	50.00
turn down	0.5000	50.00

Valve Control: Multiple Stream

User Variables

RATING

Nozzle Parameters

Base Elevation Relative to Ground Level 0.0000 m			
	D1 feed pumped	normal op	turn down
Diameter (m)	5.000e-002	5.000e-002	5.000e-002
Elevation (Base) (m)	0.0000	0.0000	0.0000
Elevation (Ground) (m)	0.0000	0.0000	0.0000

DYNAMICS

Holdup Details

Phase	Accumulation	Moles	Volume
	(kgmole/h)	(kgmole)	(m3)
Vapour	0.0000	0.0000	0.0000
Liquid	0.0000	0.0000	0.0000
Aqueous	0.0000	0.0000	0.0000
Total	0.0000	0.0000	0.0000

ADJ-1 (Adjust): Design

Adjust: ADJ-1

Adjusted Variable Measured Variable

OBJECT VARIABLE	VARIABLE	OBJECT
E-104	Delta T	DME out2
Fraction		Vapour
Solving Parameters		

Source for Target Value: User Supplied Target Value:
0.0000
Solving Method: Secant Tolerance: 0.0010 Maximum
Iterations: 10
Step Size: 3.500 C Minimum: --- Maximum: ---
User Variables

ADJ-2 (Adjust): Design

Adjust: ADJ-2

Adjusted Variable	Measured Variable	
OBJECT VARIABLE	OBJECT	
E-103	Delta T	Cooled meth recycle
Fraction		Vapour
Solving Parameters		

Source for Target Value: User Supplied Target Value:
0.0000
Solving Method: Secant Tolerance: 0.0100 Maximum
Iterations: 10
Step Size: 10.00 C Minimum: --- Maximum: ---
User Variables

ADJ-3 (Adjust): Design

Adjust: ADJ-3

Adjusted Variable	Measured Variable	
OBJECT VARIABLE	OBJECT	
E-103	Delta T	meth feed 2
Fraction		Vapour
Solving Parameters		

Source for Target Value: User Supplied Target Value:
0.0000
Solving Method: Secant Tolerance: 0.0010 Maximum
Iterations: 10
Step Size: 10.00 C Minimum: --- Maximum: ---
User Variables

ADJ-4 (Adjust): Design

Adjust: ADJ-4

Adjusted Variable Measured Variable

OBJECT VARIABLE OBJECT
VARIABLE
E-100 Delta T reactor feed Temperature
Solving Parameters
Source for Target Value: User Supplied Target Value:
250.0 C
Solving Method: Secant Tolerance: 0.1000 C Maximum Iterations: 10
Step Size: 10.00 C Minimum: --- Maximum: ---
User Variables

To Reboiler @COL1 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: To Reboiler @COL1 Fluid
Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

	OVERALL	VAPOUR	PH.	LIQUID
PH.				
Vapour / Phase Fraction	0.0000	0.0000	1.0000	
Temperature: (C)	135.2	135.2	135.2	
Pressure: (kPa)	840.0	840.0	840.0	
Molar Flow (kgmole/h)	1753	0.0000	1753	
Mass Flow (kg/h)	4.326e+004	0.0000	4.326e+004	
Std Ideal Liq VolFlow (m3/h)	50.50	0.0000	50.50	
Molar Enthalpy (kJ/kgmole)	-2.529e+05	-2.019e+05	-2.529e+05	
Molar Entropy (kJ/kgmole-C)	8.519e+01	1.757e+02	8.519e+01	
Heat Flow (kJ/h)	-4.434e+08	0.000e-01	-4.434e+08	
Liq VolFlow @Std Cond (m3/h)	49.94	0.0000	49.94	
COMPOSITION				
Overall Phase		Vapour Fraction		
0.0000				

	COMPONENTS	MOLE FLOW	MOLE FRAC	MASS FLOW	MASS FRAC	LIQVOL FLOW	LIQVOL FRAC
	(kgmole/h)	(kg/h)	(m3/h)				
diM-Ether	57.54	0.0328	2651	0.0613	3.955		
0.0783							
Methanol	717.6	0.4094	2.299e+004	0.5315	28.90		
0.5722							
H2O	977.8	0.5578	1.762e+004	0.4072	17.65		
0.3495							
Total	1753	1.0000	4.326e+004	1.0000	50.50		
1.0000							
Vapour Phase		Phase Fraction					
0.0000							

	COMPONENTS	MOLE FLOW	MOLE FRAC	MASS FLOW	MASS FRAC	LIQVOL FLOW	LIQVOL FRAC
	(kgmole/h)	(kg/h)	(m3/h)				
diM-Ether	0.0000	0.1979	0.0000	0.2896	0.0000		
0.3348							

Methanol	0.0000	0.5647	0.0000	0.5746	0.0000
0.5597					
H2O	0.0000	0.2374	0.0000	0.1358	0.0000
0.1055					
Total	0.0000	1.0000	0.0000	1.0000	0.0000
1.0000					
Liquid Phase					Phase Fraction
1.000					

COMPONENTS	MOLE FLOW	MOLE FRAC	MASS FLOW	MASS FRAC	LIQVOL FLOW	LIQVOL FRAC
(kgmole/h)	(kg/h)	(m3/h)				
diM-Ether	57.54	0.0328	2651	0.0613	3.955	
0.0783						
Methanol	717.6	0.4094	2.299e+004	0.5315	28.90	
0.5722						
H2O	977.8	0.5578	1.762e+004	0.4072	17.65	
0.3495						
Total	1753	1.0000	4.326e+004	1.0000	50.50	
1.0000						
K VALUE						

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	6.029	6.029	---
Methanol	1.379	1.379	---
H2O	0.4256	0.4256	---

UNIT OPERATIONS

FEED TO	PRODUCT FROM	LOGICAL CONNECTION
Reboiler: Reboiler @COL1	Tower: Main Tower @COL1	
UTILITIES		

(No utilities reference this stream)
PROCESS UTILITY

Boilup @COL1 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Boilup @COL1 Fluid
Package: Basis-1

PROPERTY PACKAGE:	NRTL -
Ideal	CONDITIONS

OVERALL	VAPOUR	PH.
Vapour / Phase Fraction	1.0000	1.0000
Temperature: (C)	145.4	145.4
Pressure: (kPa)	840.0	840.0
Molar Flow (kgmole/h)	798.2	798.2
Mass Flow (kg/h)	2.205e+004	2.205e+004
Std Ideal Liq VolFlow (m3/h)	26.87	26.87
Molar Enthalpy (kJ/kgmole)	-2.099e+05	-2.099e+05
Molar Entropy (kJ/kgmole-C)	1.647e+02	1.647e+02
Heat Flow (kJ/h)	-1.676e+08	-1.676e+08
Liq VolFlow @Std Cond (m3/h)	26.70	26.70
COMPOSITION		

Overall Phase	Vapour Fraction	Mass Flow (kg/h)	2.121e+004	0.0000	2.121e+004
1.0000		Std Ideal Liq VolFlow (m3/h)	23.63	0.0000	23.63
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	49.29	0.0618	2271	0.1030	3.388
0.1261					
Methanol	448.5	0.5619	1.437e+004	0.6517	18.06
0.6722					
H2O	300.3	0.3763	5411	0.2453	5.422
0.2018					
Total	798.2	1.0000	2.205e+004	1.0000	26.87
1.0000					
Vapour Phase	Phase Fraction	Overall Phase	Vapour Fraction		
1.000		0.0000			
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	49.29	0.0618	2271	0.1030	3.388
0.1261					
Methanol	448.5	0.5619	1.437e+004	0.6517	18.06
0.6722					
H2O	300.3	0.3763	5411	0.2453	5.422
0.2018					
Total	798.2	1.0000	2.205e+004	1.0000	26.87
1.0000					
K VALUE					
COMPONENTS	MIXED	LIGHT	COMPONENTS	MIXED	LIGHT
HEAVY			HEAVY		
diM-Ether	---	---	diM-Ether	0.0000	0.0618
Methanol	---	---	Methanol	0.0000	0.5619
H2O	---	---	H2O	0.0000	0.3763
UNIT OPERATIONS					
FEED TO	PRODUCT FROM	LOGICAL CONNECTION	FEED TO	PRODUCT FROM	LOGICAL CONNECTION
Tower: Main Tower @COL1	Reboiler: Reboiler @COL1		Tower: Main Tower @COL1	Reboiler: Reboiler @COL1	
UTILITIES					
(No utilities reference this stream)					
PROCESS UTILITY					

Meth H2O @COL1 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments					

Material Stream: Meth H2O @COL1 Fluid					
Package: Basis-1					
Property Package: NRTL -					
Ideal			COMPONENTS	MIXED	LIGHT
CONDITIONS			HEAVY		
OVERALL VAPOUR PH. LIQUID					
PH.			diM-Ether	7.150	7.150
Vapour / Phase Fraction	0.0000	0.0000	Methanol	1.994	1.994
Temperature: (C)	145.4	145.4	H2O	0.5304	0.5304
Pressure: (kPa)	840.0	840.0	UNIT OPERATIONS		
Molar Flow (kgmole/h)	954.8	0.0000			

FEED TO PRODUCT FROM LOGICAL
CONNECTION

Material Stream: Meth H2O Reboiler: Reboiler @COL1
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

DME reflux @COL1 (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: DME reflux @COL1 Fluid
Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL LIQUID PH.

Vapour / Phase Fraction	0.0000	1.0000
Temperature: (C)	36.98	36.98
Pressure: (kPa)	860.0	860.0
Molar Flow (kgmole/h)	631.6	631.6
Mass Flow (kg/h)	2.909e+004	2.909e+004
Std Ideal Liq VolFlow (m3/h)	43.39	43.39
Molar Enthalpy (kJ/kgmole)	-2.022e+05	-2.022e+05
Molar Entropy (kJ/kgmole-C)	1.540e+02	1.540e+02
Heat Flow (kJ/h)	-1.277e+08	-1.277e+08
Liq VolFlow @Std Cond (m3/h)	47.07	47.07

COMPOSITION

Overall Phase	Vapour Fraction
0.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	631.1	0.9993	2.908e+004	0.9995	43.38
0.9996					
Methanol	0.4528	0.0007	14.51	0.0005	1.823e-002
0.0004					
H2O	2.198e-003	0.0000	3.960e-002	0.0000	3.968e-005
0.0000					
Total	631.6	1.0000	2.909e+004	1.0000	43.39
1.0000					
Liquid Phase	Vapour Fraction				
1.000					

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	631.1	0.9993	2.908e+004	0.9995	43.38
0.9996					
Methanol	0.4528	0.0007	14.51	0.0005	1.823e-002
0.0004					
H2O	2.198e-003	0.0000	3.960e-002	0.0000	3.968e-005
0.0000					
Total	631.6	1.0000	2.909e+004	1.0000	43.39
1.0000					
K VALUE					

COMPONENTS MIXED LIGHT

HEAVY			
diM-Ether	0.0000	0.0000	---
Methanol	0.0000	0.0000	---
H2O	0.0000	0.0000	---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION

Tower: Main Tower @COL1 Material Stream: DME reflux
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

DME outlet @COL1 (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: DME outlet @COL1 Fluid
Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL VAPOUR PH.

Vapour / Phase Fraction	1.0000	1.0000
Temperature: (C)	37.94	37.94
Pressure: (kPa)	820.0	820.0
Molar Flow (kgmole/h)	1253	1253
Mass Flow (kg/h)	5.771e+004	5.771e+004
Std Ideal Liq VolFlow (m3/h)	86.08	86.08
Molar Enthalpy (kJ/kgmole)	-1.833e+05	-1.833e+05
Molar Entropy (kJ/kgmole-C)	1.797e+02	1.797e+02
Heat Flow (kJ/h)	-2.297e+08	-2.297e+08
Liq VolFlow @Std Cond (m3/h)	93.38	93.38

COMPOSITION

Overall Phase	Vapour Fraction
1.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	1252	0.9993	5.768e+004	0.9995	86.05
0.9996					
Methanol	0.8981	0.0007	28.78	0.0005	3.616e-002
0.0004					

H2O	4.286e-003	0.0000	7.722e-002	0.0000	7.737e-005
0.0000					
Total	1253	1.0000	5.771e+004	1.0000	86.08

1.0000					
Vapour Phase	Phase Fraction				
1.000					

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	1252	0.9993	5.768e+004	0.9995	86.05
0.9996					

Methanol 0.8981 0.0007 28.78 0.0005 3.616e-002
0.0004
H2O 4.286e-003 0.0000 7.722e-002 0.0000 7.737e-
005 0.0000
Total 1253 1.0000 5.771e+004 1.0000 86.08
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether --- --- ---
Methanol --- --- ---
H2O --- --- ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Material Stream: DME outlet Tower: Main Tower @COL1
UTILITIES
(No utilities reference this stream)
PROCESS UTILITY

normal op @COL1 (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: normal op @COL1 Fluid
Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 73.70 73.70
Pressure: (kPa) 830.0 830.0
Molar Flow (kgmole/h) 788.1 788.1
Mass Flow (kg/h) 2.491e+004 2.491e+004
Std Ideal Liq VolFlow (m3/h) 33.16 33.16
Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
Molar Entropy (kJ/kgmole-C) 1.026e+02 1.026e+02
Heat Flow (kJ/h) -1.889e+08 -1.889e+08
Liq VolFlow @Std Cond (m3/h) 33.26 33.26
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 314.6 0.3991 1.449e+004 0.5817 21.62
0.6519
Methanol 134.8 0.1710 4319 0.1734 5.427
0.1637
H2O 338.7 0.4298 6102 0.2450 6.115
0.1844
Total 788.1 1.0000 2.491e+004 1.0000 33.16
1.0000

Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 314.6 0.3991 1.449e+004 0.5817 21.62
0.6519
Methanol 134.8 0.1710 4319 0.1734 5.427
0.1637
H2O 338.7 0.4298 6102 0.2450 6.115
0.1844
Total 788.1 1.0000 2.491e+004 1.0000 33.16
1.0000
K VALUE

COMPONENTS MIXED LIGHT
HEAVY
diM-Ether 0.0000 0.0000 ---
Methanol 0.0000 0.0000 ---
H2O 0.0000 0.0000 ---
UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Tower: Main Tower @COL1 Material Stream: normal op
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

turn down @COL1 (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: turn down @COL1 Fluid
Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 73.70 73.70
Pressure: (kPa) 830.0 830.0
Molar Flow (kgmole/h) 788.1 788.1
Mass Flow (kg/h) 2.491e+004 2.491e+004
Std Ideal Liq VolFlow (m3/h) 33.16 33.16
Molar Enthalpy (kJ/kgmole) -2.397e+05 -2.397e+05
Molar Entropy (kJ/kgmole-C) 1.026e+02 1.026e+02
Heat Flow (kJ/h) -1.889e+08 -1.889e+08
Liq VolFlow @Std Cond (m3/h) 33.26 33.26
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)

diM-Ether	314.6	0.3991	1.449e+004	0.5817	21.62
	0.6519				
Methanol	134.8	0.1710	4319	0.1734	5.427
	0.1637				
H2O	338.7	0.4298	6102	0.2450	6.115
	0.1844				
Total	788.1	1.0000	2.491e+004	1.0000	33.16
	1.0000				
Liquid Phase			Phase Fraction		
	1.000				

COMPONENTS MOLE FLOW MOLE FRAC MASS
 FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
 (kgmole/h) (kg/h) (m³/h)

diM-Ether	314.6	0.3991	1.449e+004	0.5817	21.62
	0.6519				
Methanol	134.8	0.1710	4319	0.1734	5.427
	0.1637				
H2O	338.7	0.4298	6102	0.2450	6.115
	0.1844				
Total	788.1	1.0000	2.491e+004	1.0000	33.16
	1.0000				

K VALUE

COMPONENTS	MIXED	LIGHT
HEAVY		
diM-Ether	0.0000	0.0000
Methanol	0.0000	0.0000
H2O	0.0000	0.0000

UNIT OPERATIONS

FEED TO	PRODUCT FROM	LOGICAL CONNECTION
Tower: Main Tower @COL1	Material Stream: turn down	
UTILITIES		

(No utilities reference this stream)
 PROCESS UTILITY

Main Tower @COL1 (Tower): Design, Rating,
 Performance

Tower: Main Tower @COL1

Vapour Draws Summary

Name:	Name:	Name:
Tray Number		
Temperature (C)		
Pressure (kPa)		
Mass Flow (kg/h)		
Molar Flow (kgmole/h)		
Ideal Liquid Volume Flow (m ³ /h)		
Molar Enthalpy (kJ/kgmole)		
Mass Enthalpy (kJ/kg)		
Heat Flow (kJ/h)		
Molecular Weight		
Molar Entropy (kJ/kgmole-C)		
Mass Entropy (kJ/kg-C)		
Molar Density (kgmole/m ³)		

Mass Density (kg/m ³)		
Std Liq Mass Den (kg/m ³)		
Molar Heat Cap (kJ/kgmole-C)		
Mass Heat Cap (kJ/kg-C)		
Thermal Cond (W/m-K)		
Viscosity (cP)		
Surface Tension (dyne/cm)	---	---
Z Factor		
Liquid Draws Summary		

Name:	Name:	Name:
Tray Number		
Temperature (C)		
Pressure (kPa)		
Mass Flow (kg/h)		
Molar Flow (kgmole/h)		
Ideal Liquid Volume Flow (m ³ /h)		
Molar Enthalpy (kJ/kgmole)		
Mass Enthalpy (kJ/kg)		
Heat Flow (kJ/h)		
Molecular Weight		
Molar Entropy (kJ/kgmole-C)		
Mass Entropy (kJ/kg-C)		
Molar Density (kgmole/m ³)		
Mass Density (kg/m ³)		
Std Liq Mass Den (kg/m ³)		
Molar Heat Cap (kJ/kgmole-C)		
Mass Heat Cap (kJ/kg-C)		
Thermal Cond (W/m-K)		
Viscosity (cP)		
Surface Tension (dyne/cm)		
Z Factor		
Water Draws Summary		

Name:	Name:	Name:
Tray Number		
Temperature (C)		
Pressure (kPa)		
Mass Flow (kg/h)		
Molar Flow (kgmole/h)		
Water Volume Flow (m ³ /h)		
Molar Enthalpy (kJ/kgmole)		
Mass Enthalpy (kJ/kg)		
Heat Flow (kJ/h)		
Molecular Weight		
Molar Entropy (kJ/kgmole-C)		
Mass Entropy (kJ/kg-C)		
Molar Density (kgmole/m ³)		
Mass Density (kg/m ³)		
Std Liq Mass Den (kg/m ³)		
Molar Heat Cap (kJ/kgmole-C)		
Mass Heat Cap (kJ/kg-C)		
Thermal Cond (W/m-K)		
Viscosity (cP)		
Surface Tension (dyne/cm)		
Z Factor		
User Variables		

RATING

Sizing

Weir Height (m)	5.000e-002	9_Main Tower	1.000			
Weir Length (m)	1.200	10_Main Tower	1.000			
Tray Space (m)	0.5000	Component Efficiency				
Tray Volume (m3)	0.8836	Tray	diM-Ether	Methanol	H2O	
DC Volume (m3)	8.836e-002	1_Main Tower	1.000	1.000	1.000	
Diameter (m)	1.500	2_Main Tower	1.000	1.000	1.000	
Active Area (m2)	1.264	3_Main Tower	1.000	1.000	1.000	
Flow Paths	1	4_Main Tower	1.000	1.000	1.000	
Internal Type: Sieve		5_Main Tower	1.000	1.000	1.000	
Nozzles		6_Main Tower	1.000	1.000	1.000	
Tray Section Elevation Relative to Ground Level 0.0000 m		7_Main Tower	1.000	1.000	1.000	
HoldupRG VtoAbove (m) Diameter (m) L		8_Main Tower	1.000	1.000	1.000	
toBelow (m) Diameter (m)		9_Main Tower	1.000	1.000	1.000	
1_Main Tower 4.500 m	---	10_Main Tower	1.000	1.000	1.000	
3.000e-003 m		Pressure Drop				
2_Main Tower 4.000 m	0.5000 m	3.000e-003 m	Pressure (kPa)	Pressure Drop (kPa)		
0.0000 m	3.000e-003 m	1_Main Tower	820.0 kPa	2.222 kPa		
3_Main Tower 3.500 m	0.5000 m	3.000e-003 m	2_Main Tower	822.2 kPa	2.222 kPa	
0.0000 m	3.000e-003 m	3_Main Tower	824.4 kPa	2.222 kPa		
4_Main Tower 3.000 m	0.5000 m	3.000e-003 m	4_Main Tower	826.7 kPa	2.222 kPa	
0.0000 m	3.000e-003 m	5_Main Tower	828.9 kPa	2.222 kPa		
5_Main Tower 2.500 m	0.5000 m	3.000e-003 m	6_Main Tower	831.1 kPa	2.222 kPa	
0.0000 m	3.000e-003 m	7_Main Tower	833.3 kPa	2.222 kPa		
6_Main Tower 2.000 m	0.5000 m	3.000e-003 m	8_Main Tower	835.6 kPa	2.222 kPa	
0.0000 m	3.000e-003 m	9_Main Tower	837.8 kPa	2.222 kPa		
7_Main Tower 1.500 m	0.5000 m	3.000e-003 m	10_Main Tower	840.0 kPa	---	
0.0000 m	3.000e-003 m	Rating Enabled: No	Top Tray Fixed For Update Tray			
8_Main Tower 1.000 m	0.5000 m	3.000e-003 m	Section Pressure Drop 20.00 kPa			
0.0000 m	3.000e-003 m	Vapour Mole Fractions				
9_Main Tower 0.5000 m	0.5000 m	3.000e-003 m	Tray Number	diM-Ether	Methanol	H2O
0.0000 m	3.000e-003 m	1_Main Tower	0.9993	0.0007	0.0000	
10_Main Tower 0.0000 m	0.5000 m	3.000e-003 m	2_Main Tower	0.9905	0.0093	0.0002
---		3_Main Tower	0.9224	0.0709	0.0066	
Feed Tray	Elevation RH (m)	Diameter (m)	4_Main Tower	0.8073	0.1476	0.0451
DME reflux	1_Main Tower	0.3750 m	5_Main Tower	0.6443	0.2738	0.0819
002 m		6_Main Tower	0.5394	0.3545	0.1061	
normal op	4_Main Tower	0.3750 m	7_Main Tower	0.4941	0.3883	0.1176
002 m		8_Main Tower	0.4778	0.3969	0.1253	
turn down	9_Main Tower	0.3750 m	9_Main Tower	0.4735	0.3862	0.1403
002 m		10_Main Tower	0.1979	0.5647	0.2374	
Boilup	10_Main Tower	0.0000 m	Liquid Mole Fractions			
002 m		Tray Number	diM-Ether	Methanol	H2O	
Prod Tray	Elevation RH (m)	Diameter (m)	1_Main Tower	0.9814	0.0182	0.0004
DME outlet	1_Main Tower	0.5000 m	2_Main Tower	0.8151	0.1690	0.0159
002 m		3_Main Tower	0.4351	0.4325	0.1324	
To Reboiler	10_Main Tower	0.0000 m	4_Main Tower	0.2534	0.3576	0.3890
003 m		5_Main Tower	0.1586	0.4268	0.4146	
Heat Loss		6_Main Tower	0.1191	0.4554	0.4254	
		7_Main Tower	0.1048	0.4627	0.4325	
Efficiency		8_Main Tower	0.0996	0.4541	0.4463	
Overall Efficiency	Overall	9_Main Tower	0.0967	0.4134	0.4899	
Tray		10_Main Tower	0.0328	0.4094	0.5578	
1_Main Tower	1.000	Vapour Mass Fractions				
2_Main Tower	1.000	Tray Number	diM-Ether	Methanol	H2O	
3_Main Tower	1.000	1_Main Tower	0.9995	0.0005	0.0000	
4_Main Tower	1.000	2_Main Tower	0.9935	0.0065	0.0001	
5_Main Tower	1.000	3_Main Tower	0.9467	0.0506	0.0027	
6_Main Tower	1.000	4_Main Tower	0.8703	0.1107	0.0190	
7_Main Tower	1.000					
8_Main Tower	1.000					

5_Main Tower	0.7433	0.2197	0.0370
6_Main Tower	0.6518	0.2980	0.0501
7_Main Tower	0.6099	0.3334	0.0567
8_Main Tower	0.5952	0.3438	0.0610
9_Main Tower	0.5941	0.3371	0.0688
10_Main Tower	0.2896	0.5746	0.1358

Liquid Mass Fractions

Tray Number diM-Ether	Methanol	H2O	
1_Main Tower	0.9871	0.0127	0.0002
2_Main Tower	0.8682	0.1252	0.0066
3_Main Tower	0.5523	0.3819	0.0657
4_Main Tower	0.3873	0.3801	0.2325
5_Main Tower	0.2569	0.4806	0.2625
6_Main Tower	0.1978	0.5260	0.2762
7_Main Tower	0.1759	0.5402	0.2839
8_Main Tower	0.1688	0.5353	0.2958
9_Main Tower	0.1679	0.4994	0.3327
10_Main Tower	0.0613	0.5315	0.4072

Vapour LiqVolume Fractions

Tray Number diM-Ether	Methanol	H2O	
1_Main Tower	0.9996	0.0004	0.0000
2_Main Tower	0.9945	0.0055	0.0001
3_Main Tower	0.9552	0.0430	0.0018
4_Main Tower	0.8914	0.0955	0.0131
5_Main Tower	0.7798	0.1942	0.0260
6_Main Tower	0.6960	0.2680	0.0360
7_Main Tower	0.6566	0.3023	0.0410
8_Main Tower	0.6429	0.3128	0.0443
9_Main Tower	0.6428	0.3072	0.0500
10_Main Tower	0.3348	0.5597	0.1055

Liquid LiqVolume Fractions

Tray Number diM-Ether	Methanol	H2O	
1_Main Tower	0.9891	0.0108	0.0001
2_Main Tower	0.8876	0.1078	0.0045
3_Main Tower	0.6015	0.3504	0.0481
4_Main Tower	0.4484	0.3707	0.1808
5_Main Tower	0.3065	0.4831	0.2104
6_Main Tower	0.2394	0.5361	0.2245
7_Main Tower	0.2141	0.5539	0.2320
8_Main Tower	0.2063	0.5510	0.2428
9_Main Tower	0.2068	0.5180	0.2752
10_Main Tower	0.0783	0.5722	0.3495

Reboiler @COL1 (Reboiler): Design, Rating, Performance

Reboiler: Reboiler @COL1

CONNECTIONS

Inlet Name	From Oper	
To Reboiler @COL1	Tower: Main Tower	
@COL1		
Outlet Name	To Oper	
Boilup @COL1	Tower: Main Tower @COL1	
Meth H2O @COL1	Material Stream: Meth	
H2O		
Energy Name	To Oper	

reboiler 1 @COL1 Reboiler: Reboiler @COL1
PARAMETERS

Vessel Volume: 2.000 m3 Pressure Drop: 0.0000 kPa Duty:
2.7071e+07 kJ/h
Level SP: 50.00 % Liquid Volume: 1.000 m3
RATING

Sizing

Cylinder Horizontal This reboiler has a
Boot: No
Volume 2.000 m3 Diameter 1.193 m Length
1.789
Nozzles

Base Elevation Relative to Ground Level 0.0000 m
Diameter 1.193 m Length 1.789

To Reboiler @COL1 Boilup @COL1

Meth H2O @COL1
Diameter (m) 5.965e-002 5.965e-002 5.965e-002
Elevation (Base) (m) 1.193 1.193 0.0000
Elevation (Ground) (m) 1.193 1.193 0.0000
Elevation (% of Height) (%) 100.00 100.00 0.00
Options

PV Work Term Contribution (%) 100.00

PERFORMANCE TABLE

Overall Phase

Temperature (C)	Pressure (kPa)	Heat Flow (kJ/h)	Enthalpy (kJ/kgmole)
135.21	840.00	0.00	-252922.57
145.35	840.00	27071392.97	-237479.59
Vapour Fraction	Vap Phase Mass Frac	Heat of Vap (kJ/kgmole)	
0.0000	0.0000	---	
0.4553	0.5098	---	
Vapour Phase			

Mass Flow (kg/h)	Molecular Wt	Density (kg/m3)	Mass Sp Density (kg/kg-C)	Heat of (cP)	Thermal (W/m-K)
0.00	31.49	7.79	1.75	0.01	0.02
22053.58	27.63	6.67	1.84	0.01	0.03
Std Gas Flow Z Factor	Pseudo Zc	Pseudo Pc	Pseudo Tc	Pseudo Omega	
(STD_m3/h)	(kgPa)	(C)			
0.00	1.00	10469.21	249.14	0.26	0.44
18872.39	1.00	12797.33	283.18	0.25	0.45
Light Liquid Phase					

Mass Flow (kg/h)	Density (kg/m3)	Mass Sp Heat (W/m-K)	Viscosity (dyne/cm)	Thermal Cond (W/m-K)
43260.85	744.75	4.14	0.16	0.36
---	---	---	---	34.10
Molecular Wt	Sp Gravity	Pseudo Pc	Pseudo Tc	Pseudo Omega
Zc	Pseudo Omega			

24.68	0.74	(kPa) 15532.75	(C) 310.89	0.26	0.43	
---	---	---	---	---	---	
Heavy Liquid Phase						
Mass Flow	Density	Mass Sp	Heat	Viscosity	Thermal	
Cond	Surface	Tens				
(kg/h)	(kg/m ³)	(kJ/kg-C)	(cP)	(W/m-K)		
(dyne/cm)						
---	---	---	---	---	---	
21207.27	786.30	4.31	0.15	0.46	38.43	
Molecular Wt	Sp Gravity	Pseudo	Pc	Pseudo	Tc	Pseudo
Zc	Pseudo Omega					
(kPa)	(C)					
---	---	---	---	---	---	
22.21	0.79	17819.42	334.05	0.26	0.40	
Mixed Liquid Phase						
Mass Flow	Density	Mass Sp	Heat	Viscosity	Thermal	
Cond	Surface	Tens				
(kg/h)	(kg/m ³)	(kJ/kg-C)	(cP)	(W/m-K)		
(dyne/cm)						
43260.85	744.75	4.14	0.16	0.36	34.10	
21207.27	786.30	4.31	0.15	0.46	38.43	
Molecular Wt	Sp Gravity	Pseudo	Pc	Pseudo	Tc	Pseudo
Zc	Pseudo Omega					
(kPa)	(C)					
24.68	0.74	15532.75	310.89	0.26	0.43	
22.21	0.79	17819.42	334.05	0.26	0.40	

Meth Recycle @COL2 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Meth Recycle @COL2 Fluid Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL VAPOUR PH.

Vapour / Phase Fraction	1.0000	1.0000	
Temperature: (C)	136.3	136.3	
Pressure: (kPa)	870.0	870.0	
Molar Flow (kgmole/h)	650.0	650.0	
Mass Flow (kg/h)	1.965e+004	1.965e+004	
Std Ideal Liq VolFlow (m3/h)	24.41	24.41	
Molar Enthalpy (kJ/kgmole)	-2.018e+05	-2.018e+05	
Molar Entropy (kJ/kgmole-C)	1.712e+02	1.712e+02	
Heat Flow (kJ/h)	-1.312e+08	-1.312e+08	
Liq VolFlow @Std Cond (m3/h)	24.36	24.36	
COMPOSITION			

Overall Phase	Vapour Fraction
1.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC (kgmole/h) (kg/h) (m3/h)

diM-Ether	16.83	0.0259	775.3	0.0395	1.157
0.0474					

Methanol	532.2	0.8187	1.705e+004	0.8679	21.43
0.8779					
H2O	101.0	0.1554	1820	0.0926	1.823
0.0747					
Total	650.0	1.0000	1.965e+004	1.0000	24.41
1.0000					
Vapour Phase				Phase Fraction	
1.000					

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC (kgmole/h) (kg/h) (m3/h)					
diM-Ether	16.83	0.0259	775.3	0.0395	1.157
0.0474					
Methanol	532.2	0.8187	1.705e+004	0.8679	21.43
0.8779					
H2O	101.0	0.1554	1820	0.0926	1.823
0.0747					
Total	650.0	1.0000	1.965e+004	1.0000	24.41
1.0000					
K VALUE					

COMPONENTS	MIXED	LIGHT
HEAVY		
diM-Ether	---	---
Methanol	---	---
H2O	---	---
UNIT OPERATIONS		

FEED TO PRODUCT FROM LOGICAL CONNECTION
Material Stream: Meth Recycle Tower: Main Tower @COL2 UTILITIES
(No utilities reference this stream)
PROCESS UTILITY

To Reboiler @COL2 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: To Reboiler @COL2 Fluid Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL VAPOUR PH. LIQUID PH.

Vapour / Phase Fraction	0.0000	0.0000	1.0000	
Temperature: (C)	172.7	172.7	172.7	
Pressure: (kPa)	890.0	890.0	890.0	
Molar Flow (kgmole/h)	1268	0.0000	1268	
Mass Flow (kg/h)	2.307e+004	0.0000	2.307e+004	
Std Ideal Liq VolFlow (m3/h)	23.26	0.0000	23.26	
Molar Enthalpy (kJ/kgmole)	-2.729e+05	-2.341e+05	-2.729e+05	
Molar Entropy (kJ/kgmole-C)	3.936e+01	1.254e+02	3.936e+01	
Heat Flow (kJ/h)	-3.460e+08	0.000e-01	-3.460e+08	

Liq VolFlow @Std Cond (m3/h) 22.87 0.0000 22.87
COMPOSITION

Overall Phase	Vapour Fraction
0.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 3.233e-003 0.0000 0.1489 0.0000 2.222e-004 0.0000
Methanol 16.68 0.0132 534.4 0.0232 0.6716 0.0289
H2O 1251 0.9868 2.254e+004 0.9768 22.59 0.9711
Total 1268 1.0000 2.307e+004 1.0000 23.26 1.0000
Vapour Phase Phase Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 0.0000 0.0000 0.0000 0.0001 0.0000 0.0001
Methanol 0.0000 0.0635 0.0000 0.1076 0.0000 0.1313
H2O 0.0000 0.9365 0.0000 0.8923 0.0000 0.8686
Total 0.0000 1.0000 0.0000 1.0000 0.0000 1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 3.233e-003 0.0000 0.1489 0.0000 2.222e-004 0.0000
Methanol 16.68 0.0132 534.4 0.0232 0.6716 0.0289
H2O 1251 0.9868 2.254e+004 0.9768 22.59 0.9711
Total 1268 1.0000 2.307e+004 1.0000 23.26 1.0000
K VALUE

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	11.42	11.42	---
Methanol	4.826	4.826	---
H2O	0.9490	0.9490	---

UNIT OPERATIONS

FEED TO	PRODUCT FROM	LOGICAL CONNECTION
Reboiler: Reboiler @COL2 Tower: Main Tower @COL2 UTILITIES		

(No utilities reference this stream)
PROCESS UTILITY

Boilup @COL2 (Material Stream): Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Boilup @COL2 Fluid
Package: Basis-1

Property Package: NRTL -
Ideal CONDITIONS

OVERALL VAPOUR PH.
Vapour / Phase Fraction 1.0000 1.0000
Temperature: (C) 174.1 174.1
Pressure: (kPa) 890.0 890.0
Molar Flow (kgmole/h) 638.0 638.0
Mass Flow (kg/h) 1.169e+004 1.169e+004
Std Ideal Liq VolFlow (m3/h) 11.83 11.83
Molar Enthalpy (kJ/kgmole) -2.359e+05 -2.359e+05
Molar Entropy (kJ/kgmole-C) 1.216e+02 1.216e+02
Heat Flow (kJ/h) -1.505e+08 -1.505e+08
Liq VolFlow @Std Cond (m3/h) 11.63 11.63
COMPOSITION

Overall Phase	Vapour Fraction
1.0000	

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 2.982e-003 0.0000 0.1374 0.0000 2.049e-004 0.0000
Methanol 13.94 0.0219 446.8 0.0382 0.5615 0.0475
H2O 624.1 0.9781 1.124e+004 0.9618 11.27 0.9525
Total 638.0 1.0000 1.169e+004 1.0000 11.83 1.0000
Vapour Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 2.982e-003 0.0000 0.1374 0.0000 2.049e-004 0.0000
Methanol 13.94 0.0219 446.8 0.0382 0.5615 0.0475
H2O 624.1 0.9781 1.124e+004 0.9618 11.27 0.9525
Total 638.0 1.0000 1.169e+004 1.0000 11.83 1.0000
K VALUE

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	---	---	---
Methanol	---	---	---
H2O	---	---	---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Tower: Main Tower @COL2 Reboiler: Reboiler @COL2
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

Waste Water @COL2 (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: Waste Water @COL2 Fluid
Package: Basis-1

Property Package: NRTL -

Ideal
CONDITIONS

OVERALL VAPOUR PH. LIQUID

PH.
Vapour / Phase Fraction 0.0000 0.0000 1.0000
Temperature: (C) 174.1 174.1 174.1
Pressure: (kPa) 890.0 890.0 890.0
Molar Flow (kgmole/h) 629.8 0.0000 629.8
Mass Flow (kg/h) 1.139e+004 0.0000 1.139e+004
Std Ideal Liq VolFlow (m3/h) 11.43 0.0000 11.43
Molar Enthalpy (kJ/kgmole) -2.733e+05 -2.359e+05 -
2.733e+05
Molar Entropy (kJ/kgmole-C) 3.825e+01 1.216e+02
3.825e+01
Heat Flow (kJ/h) -1.721e+08 0.000e-01 -1.721e+08
Liq VolFlow @Std Cond (m3/h) 11.24 0.0000 11.24
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 2.510e-004 0.0000 1.156e-002 0.0000
1.725e-005 0.0000
Methanol 2.733 0.0043 87.56 0.0077 0.1100
0.0096
H2O 627.1 0.9957 1.130e+004 0.9923 11.32
0.9904
Total 629.8 1.0000 1.139e+004 1.0000 11.43
1.0000
Vapour Phase Phase Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000
Methanol 0.0000 0.0219 0.0000 0.0382 0.0000
0.0475
H2O 0.0000 0.9781 0.0000 0.9618 0.0000
0.9525

Total 0.0000 1.0000 0.0000 1.0000 0.0000
1.0000
Liquid Phase Phase Fraction
1.000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC
(kgmole/h) (kg/h) (m3/h)
diM-Ether 2.510e-004 0.0000 1.156e-002 0.0000
1.725e-005 0.0000
Methanol 2.733 0.0043 87.56 0.0077 0.1100
0.0096
H2O 627.1 0.9957 1.130e+004 0.9923 11.32
0.9904
Total 629.8 1.0000 1.139e+004 1.0000 11.43
1.0000
K VALUE

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	11.73	11.73	---
Methanol	5.037	5.037	---
H2O	0.9824	0.9824	---

UNIT OPERATIONS

FEED TO PRODUCT FROM LOGICAL
CONNECTION
Material Stream: Waste Water Reboiler: Reboiler @COL2
UTILITIES

(No utilities reference this stream)
PROCESS UTILITY

METH reflux @COL2 (Material Stream): Conditions,
Composition, K Value, Package Properties, Attachments

Material Stream: METH reflux @COL2 Fluid
Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL LIQUID PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 76.29 76.29
Pressure: (kPa) 910.0 910.0
Molar Flow (kgmole/h) 325.0 325.0
Mass Flow (kg/h) 9825 9825
Std Ideal Liq VolFlow (m3/h) 12.21 12.21
Molar Enthalpy (kJ/kgmole) -2.398e+05 -2.398e+05
Molar Entropy (kJ/kgmole-C) 9.524e+01 9.524e+01
Heat Flow (kJ/h) -7.795e+07 -7.795e+07
Liq VolFlow @Std Cond (m3/h) 12.18 12.18
COMPOSITION

Overall Phase Vapour Fraction
0.0000

COMPONENTS MOLE FLOW MOLE FRAC MASS
FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC

	(kgmole/h)	(kg/h)	(m3/h)		
diM-Ether	8.583	0.0264	395.4	0.0402	0.5899
0.0483					
Methanol	265.8	0.8177	8517	0.8669	10.70
0.8768					
H2O	50.66	0.1558	912.6	0.0929	0.9144
0.0749					
Total	325.0	1.0000	9825	1.0000	12.21
1.0000					
Liquid Phase				Phase Fraction	
1.000					

	(kgmole/h)	(kg/h)	(m3/h)		
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	8.583	0.0264	395.4	0.0402	0.5899
0.0483					
Methanol	265.8	0.8177	8517	0.8669	10.70
0.8768					
H2O	50.66	0.1558	912.6	0.0929	0.9144
0.0749					
Total	325.0	1.0000	9825	1.0000	12.21
1.0000					

K VALUE

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	0.0000	0.0000	---
Methanol	0.0000	0.0000	---
H2O	0.0000	0.0000	---
UNIT OPERATIONS			
FEED TO	PRODUCT FROM	LOGICAL CONNECTION	
Tower: Main Tower @COL2	Material Stream: METH reflux		
UTILITIES			
(No utilities reference this stream)			
PROCESS UTILITY			

Meth H2O Pumped @COL2 (Material Stream):
Conditions, Composition, K Value, Package Properties, Attachments

Material Stream: Meth H2O Pumped @COL2 Fluid
Package: Basis-1

Property Package: NRTL -
Ideal
CONDITIONS

OVERALL AQUEOUS PH.
Vapour / Phase Fraction 0.0000 1.0000
Temperature: (C) 145.4 145.4
Pressure: (kPa) 880.0 880.0
Molar Flow (kgmole/h) 954.8 954.8
Mass Flow (kg/h) 2.121e+004 2.121e+004
Std Ideal Liq VolFlow (m3/h) 23.63 23.63
Molar Enthalpy (kJ/kgmole) -2.605e+05 -2.605e+05
Molar Entropy (kJ/kgmole-C) 6.944e+01 6.944e+01

Heat Flow (kJ/h)	-2.487e+08	-2.487e+08			
Liq VolFlow @Std Cond (m3/h)	23.31	23.31			
COMPOSITION					
Overall Phase		Vapour Fraction			
0.0000					
COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	8.247	0.0086	379.9	0.0179	0.5668
0.0240					
Methanol	269.1	0.2819	8623	0.4066	10.84
0.4585					
H2O	677.5	0.7095	1.220e+004	0.5755	12.23
0.5175					
Total	954.8	1.0000	2.121e+004	1.0000	23.63
1.0000					
Aqueous Phase		Phase Fraction			
1.000					

COMPONENTS MOLE FLOW MOLE FRAC MASS FLOW MASS FRAC LIQVOL FLOW LIQVOL FRAC					
(kgmole/h)	(kg/h)	(m3/h)			
diM-Ether	8.247	0.0086	379.9	0.0179	0.5668
0.0240					
Methanol	269.1	0.2819	8623	0.4066	10.84
0.4585					
H2O	677.5	0.7095	1.220e+004	0.5755	12.23
0.5175					
Total	954.8	1.0000	2.121e+004	1.0000	23.63
1.0000					
K VALUE					

COMPONENTS	MIXED	LIGHT	
HEAVY			
diM-Ether	0.0000	---	0.0000
Methanol	0.0000	---	0.0000
H2O	0.0000	---	0.0000
UNIT OPERATIONS			

FEED TO	PRODUCT FROM	LOGICAL CONNECTION	
Tower: Main Tower @COL2	Material Stream: Meth H2O Pumped		
UTILITIES			
(No utilities reference this stream)			
PROCESS UTILITY			

Main Tower @COL2 (Tower): Design, Rating, Performance

Tower: Main Tower @COL2

Vapour Draws Summary

Name:	Name:	Name:
Tray Number		
Temperature (C)		

Pressure (kPa)		Mass Heat Cap (kJ/kg-C)
Mass Flow (kg/h)		Thermal Cond (W/m-K)
Molar Flow (kgmole/h)		Viscosity (cP)
Ideal Liquid Volume Flow (m ³ /h)		Surface Tension (dyne/cm)
Molar Enthalpy (kJ/kgmole)		Z Factor
Mass Enthalpy (kJ/kg)		User Variables
Heat Flow (kJ/h)		
Molecular Weight		
Molar Entropy (kJ/kgmole-C)		RATING
Mass Entropy (kJ/kg-C)		
Molar Density (kgmole/m ³)		Sizing
Mass Density (kg/m ³)		
Std Liq Mass Den (kg/m ³)		Weir Height (m) 5.000e-002
Molar Heat Cap (kJ/kgmole-C)		Weir Length (m) 1.200
Mass Heat Cap (kJ/kg-C)		Tray Space (m) 0.5000
Thermal Cond (W/m-K)		Tray Volume (m ³) 0.8836
Viscosity (cP)		DC Volume (m ³) 8.836e-002
Surface Tension (dyne/cm) ---	---	Diameter (m) 1.500
Z Factor		Active Area (m ²) 1.264
Liquid Draws Summary		Flow Paths 1
		Internal Type: Sieve
		Nozzles
Name:	Name:	Name:
Tray Number		
Temperature (C)		Tray Section Elevation Relative to Ground Level 0.0000 m
Pressure (kPa)		HoldupRG VtoAbove (m) Diameter (m) L
Mass Flow (kg/h)		toBelow (m) Diameter (m)
Molar Flow (kgmole/h)		1_Main Tower 4.500 m --- --- 0.0000 m
Ideal Liquid Volume Flow (m ³ /h)		3.000e-003 m
Molar Enthalpy (kJ/kgmole)		2_Main Tower 4.000 m 0.5000 m 3.000e-003 m
Mass Enthalpy (kJ/kg)		0.0000 m 3.000e-003 m
Heat Flow (kJ/h)		3_Main Tower 3.500 m 0.5000 m 3.000e-003 m
Molecular Weight		0.0000 m 3.000e-003 m
Molar Entropy (kJ/kgmole-C)		4_Main Tower 3.000 m 0.5000 m 3.000e-003 m
Mass Entropy (kJ/kg-C)		0.0000 m 3.000e-003 m
Molar Density (kgmole/m ³)		5_Main Tower 2.500 m 0.5000 m 3.000e-003 m
Mass Density (kg/m ³)		0.0000 m 3.000e-003 m
Std Liq Mass Den (kg/m ³)		6_Main Tower 2.000 m 0.5000 m 3.000e-003 m
Molar Heat Cap (kJ/kgmole-C)		0.0000 m 3.000e-003 m
Mass Heat Cap (kJ/kg-C)		7_Main Tower 1.500 m 0.5000 m 3.000e-003 m
Thermal Cond (W/m-K)		0.0000 m 3.000e-003 m
Viscosity (cP)		8_Main Tower 1.000 m 0.5000 m 3.000e-003 m
Surface Tension (dyne/cm)		0.0000 m 3.000e-003 m
Z Factor		9_Main Tower 0.5000 m 0.5000 m 3.000e-003 m
Water Draws Summary		0.0000 m 3.000e-003 m
		10_Main Tower 0.0000 m 0.5000 m 3.000e-003 m ---
Name:	Name:	Name:
Tray Number		Feed Tray Elevation RH (m) Diameter (m)
Temperature (C)		METH reflux 1_Main Tower 0.3750 m
Pressure (kPa)		5.000e-002 m
Mass Flow (kg/h)		Meth H2O Pumped 6_Main Tower 0.3750 m
Molar Flow (kgmole/h)		5.000e-002 m
Water Volume Flow (m ³ /h)		Boilup 10_Main Tower 0.0000 m 5.000e-002 m
Molar Enthalpy (kJ/kgmole)		Prod Tray Elevation RH (m) Diameter (m)
Mass Enthalpy (kJ/kg)		Meth Recycle 1_Main Tower 0.5000 m
Heat Flow (kJ/h)		5.000e-002 m
Molecular Weight		To Reboiler 10_Main Tower 0.0000 m 3.000e-003 m
Molar Entropy (kJ/kgmole-C)		Heat Loss
Mass Entropy (kJ/kg-C)		
Molar Density (kgmole/m ³)		Efficiency
Mass Density (kg/m ³)		
Std Liq Mass Den (kg/m ³)		Overall Efficiency
Molar Heat Cap (kJ/kgmole-C)		

Tray	Overall						
1_Main Tower	1.000						
2_Main Tower	1.000						
3_Main Tower	1.000						
4_Main Tower	1.000						
5_Main Tower	1.000						
6_Main Tower	1.000						
7_Main Tower	1.000						
8_Main Tower	1.000						
9_Main Tower	1.000						
10_Main Tower	1.000						
Component Efficiency							
Tray	diM-Ether	Methanol	H2O				
1_Main Tower	1.000	1.000	1.000				
2_Main Tower	1.000	1.000	1.000				
3_Main Tower	1.000	1.000	1.000				
4_Main Tower	1.000	1.000	1.000				
5_Main Tower	1.000	1.000	1.000				
6_Main Tower	1.000	1.000	1.000				
7_Main Tower	1.000	1.000	1.000				
8_Main Tower	1.000	1.000	1.000				
9_Main Tower	1.000	1.000	1.000				
10_Main Tower	1.000	1.000	1.000				
Pressure Drop							
	Pressure (kPa)		Pressure Drop (kPa)				
1_Main Tower	870.0 kPa		2.222 kPa				
2_Main Tower	872.2 kPa		2.222 kPa				
3_Main Tower	874.4 kPa		2.222 kPa				
4_Main Tower	876.7 kPa		2.222 kPa				
5_Main Tower	878.9 kPa		2.222 kPa				
6_Main Tower	881.1 kPa		2.222 kPa				
7_Main Tower	883.3 kPa		2.222 kPa				
8_Main Tower	885.6 kPa		2.222 kPa				
9_Main Tower	887.8 kPa		2.222 kPa				
10_Main Tower	890.0 kPa		---				
Rating Enabled: No	Top Tray Fixed For Update	Tray					
Section Pressure Drop	20.00 kPa						
Vapour Mole Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0259	0.8187	0.1554				
2_Main Tower	0.0141	0.7477	0.2383				
3_Main Tower	0.0132	0.6653	0.3215				
4_Main Tower	0.0133	0.5947	0.3920				
5_Main Tower	0.0133	0.5488	0.4379				
6_Main Tower	0.0133	0.5252	0.4614				
7_Main Tower	0.0034	0.4278	0.5688				
8_Main Tower	0.0008	0.2849	0.7144				
9_Main Tower	0.0002	0.1495	0.8504				
10_Main Tower	0.0000	0.0635	0.9365				
Liquid Mole Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0043	0.6853	0.3105				
2_Main Tower	0.0022	0.5260	0.4718				
3_Main Tower	0.0020	0.3846	0.6134				
4_Main Tower	0.0019	0.2907	0.7074				
5_Main Tower	0.0018	0.2421	0.7561				
6_Main Tower	0.0017	0.2204	0.7779				
7_Main Tower	0.0004	0.1461	0.8535				
8_Main Tower	0.0001	0.0773	0.9226				
Vapour Mass Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0000	0.0341	0.9659				
2_Main Tower	0.0000	0.0132	0.9868				
Liquid Mass Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0395	0.8679	0.0926				
2_Main Tower	0.0224	0.8290	0.1485				
3_Main Tower	0.0220	0.7691	0.2089				
4_Main Tower	0.0229	0.7129	0.2642				
5_Main Tower	0.0235	0.6741	0.3024				
6_Main Tower	0.0239	0.6534	0.3227				
7_Main Tower	0.0065	0.5685	0.4250				
8_Main Tower	0.0016	0.4143	0.5841				
9_Main Tower	0.0004	0.2381	0.7616				
10_Main Tower	0.0001	0.1076	0.8923				
Vapour LiqVolume Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0071	0.7914	0.2016				
2_Main Tower	0.0041	0.6620	0.3339				
3_Main Tower	0.0039	0.5252	0.4710				
4_Main Tower	0.0039	0.4207	0.5755				
5_Main Tower	0.0038	0.3615	0.6347				
6_Main Tower	0.0038	0.3338	0.6624				
7_Main Tower	0.0009	0.2332	0.7659				
8_Main Tower	0.0002	0.1297	0.8701				
9_Main Tower	0.0000	0.0590	0.9409				
10_Main Tower	0.0000	0.0232	0.9768				
Liquid LiqVolume Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0474	0.8779	0.0747				
2_Main Tower	0.0273	0.8511	0.1216				
3_Main Tower	0.0271	0.7997	0.1732				
4_Main Tower	0.0286	0.7498	0.2216				
5_Main Tower	0.0296	0.7147	0.2556				
6_Main Tower	0.0302	0.6958	0.2740				
7_Main Tower	0.0084	0.6213	0.3703				
8_Main Tower	0.0022	0.4697	0.5281				
9_Main Tower	0.0005	0.2815	0.7180				
10_Main Tower	0.0001	0.1313	0.8686				
Vapour Mole Fractions							
Tray Number diM-Ether	Methanol	H2O					
1_Main Tower	0.0087	0.8239	0.1673				
2_Main Tower	0.0052	0.7095	0.2853				
3_Main Tower	0.0051	0.5801	0.4148				
4_Main Tower	0.0052	0.4758	0.5190				
5_Main Tower	0.0052	0.4145	0.5803				
6_Main Tower	0.0052	0.3852	0.6096				
7_Main Tower	0.0013	0.2760	0.7228				
8_Main Tower	0.0003	0.1574	0.8423				
9_Main Tower	0.0001	0.0729	0.9270				
10_Main Tower	0.0000	0.0289	0.9711				

Reboiler @COL2 (Reboiler): Design, Rating, Performance

Reboiler: Reboiler @COL2

CONNECTIONS

Inlet Name From Oper
 To Reboiler @COL2 Tower: Main Tower
 @COL2
 Outlet Name To Oper
 Boilup @COL2 Tower: Main Tower @COL2
 Waste Water @COL2 Material Stream: Waste
 Water

Energy Name To Oper
 Reboiler 2 @COL2 Reboiler: Reboiler @COL2
PARAMETERS

Vessel Volume: 2.000 m3 Pressure Drop: 0.0000 kPa Duty:
 2.3390e+07 kJ/h

Level SP: 50.00 % Liquid Volume: 1.000 m3

RATING

Sizing

Cylinder Horizontal This reboiler has a
 Boot: No
 Volume 2.000 m3 Diameter 1.193 m Length
 1.789
 Nozzles

Base Elevation Relative to Ground Level 0.0000 m
 Diameter 1.193 m Length 1.789

To Reboiler @COL2 Boilup @COL2
 Waste Water @COL2
 Diameter (m) 5.965e-002 5.965e-002 5.965e-
 002
 Elevation (Base) (m) 1.193 1.193 0.0000
 Elevation (Ground) (m) 1.193 1.193 0.0000
 Elevation (% of Height) (%) 100.00 100.00 0.00
 Options

PV Work Term Contribution (%) 100.00
PERFORMANCE TABLE

Overall Phase

Temperature (C)	Pressure (kPa)	Heat Flow (kJ/h)	Enthalpy (kJ/kgmole)
172.68	890.00	0.00	-272906.58
174.14	890.00	23390310.10	-254457.88
Vapour Fraction	Vap Phase Mass Frac	Heat of Vap (kJ/kgmole)	
0.0000	0.0000	---	
0.5032	0.5066	---	
Vapour Phase			

Mass Flow (kg/h)	Molecular Wt (kg/m3)	Density (kg/m3)	Mass Sp Heat (kJ/kg-C)	Viscosity (cP)	Thermal Cond (W/m-K)
0.06	18.91	4.54	2.70	0.01	0.03
11689.54	18.32	4.38	2.81	0.01	0.03
Std Gas Flow Z Factor	Pseudo	Pseudo	Pseudo	Tc	Pseudo
Zc	Pseudo Omega	(STD_m3/h)	(kPa)	(C)	
0.07	1.00	21183.60	365.59	0.26	0.36
15085.45	1.00	21797.68	371.20	0.26	0.35
Light Liquid Phase					

Mass Flow (kg/h) Density (kg/m3) Mass Sp Heat (kJ/kg-C) Viscosity (cP) Thermal Cond (W/m-K)
 Cond Surface Tens (dyne/cm)

--- --- --- --- --- --- ---
 --- --- --- --- --- --- ---
 Molecular Wt (kg/m3) Sp Gravity Pseudo Pc Pseudo Tc Pseudo
 Zc Pseudo Omega (kPa) (C)

--- --- --- --- --- --- ---
 --- --- --- --- --- --- ---

Heavy Liquid Phase

Mass Flow (kg/h) Density (kg/m3) Mass Sp Heat (kJ/kg-C) Viscosity (cP) Thermal Cond (W/m-K)
 Cond Surface Tens (dyne/cm)

23074.52 875.09 4.40 0.09 0.67 43.39
 11385.04 878.22 4.40 0.09 0.68 43.39

Molecular Wt (kg/m3) Sp Gravity Pseudo Pc Pseudo Tc Pseudo
 Zc Pseudo Omega (kPa) (C)

18.20 0.88 21926.02 372.38 0.26 0.35
 18.08 0.88 22056.02 373.56 0.26 0.34

Mixed Liquid Phase

Mass Flow (kg/h) Density (kg/m3) Mass Sp Heat (kJ/kg-C) Viscosity (cP) Thermal Cond (W/m-K)
 Cond Surface Tens (dyne/cm)

23074.52 875.09 4.40 0.09 0.67 43.39
 11385.04 878.22 4.40 0.09 0.68 43.39

Molecular Wt (kg/m3) Sp Gravity Pseudo Pc Pseudo Tc Pseudo
 Zc Pseudo Omega (kPa) (C)

18.20 0.88 21926.02 372.38 0.26 0.35
 18.08 0.88 22056.02 373.56 0.26 0.34

Aspen Technology Inc. Aspen HYSYS Version 9