

A WATER QUALITY MANAGEMENT SIMULATION GAME

By

SHIN AN CHIANG

//

Bachelor of Science in Engineering  
National Cheng Kung University  
Tainan, Taiwan  
1973

Master of Science  
University of Wisconsin  
Madison, Wisconsin  
1980

Submitted to the Faculty of the Graduate College  
of the Oklahoma State University  
in partial fulfillment of the requirements  
for the Degree of  
DOCTOR OF PHILOSOPHY  
December, 1986

Thesis  
1986D  
C532w  
cup. 2



A WATER QUALITY MANAGEMENT SIMULATION GAME

Thesis Approved:

*Richard N. DeWine*

Thesis Adviser

*Keith D. Wright*

*Erno L. Stover*

*Vernon A. Mast*

*Norman N. Dunham*

Dean of the Graduate College

## PREFACE

This paper is a description of a simulation game applied to Transferable Discharge Permits (TDP's). It uses a participant program to input data, a proctor program to simulate seasonal conditions, a cost program to evaluate the economic effectiveness of the TDP's, and the QL2SMG package to measure the impact on water quality.

I would like to express sincere gratitude to my major advisor Dr. Richard N. Devries, for his guidance and motivation. I am also thankful to Dr. Keith D. Willett and Dr. Ramesh Sharda for their insightful suggestions and invaluable help during the course of this work. An extra thank you must go to Dr. Vernon A. Mast and Dr. Enos L. Stover for agreeing to serve on my committee.

My deepest gratitude to my parents for their encouragement and for their love.

## TABLE OF CONTENTS

Chapter	Page
I. INTRODUCTION . . . . .	1
II. BACKGROUND AND LITERATURE REVIEW . . . . .	3
An Overview of TDP's. . . . .	3
Economic Rationale for TDP's . . . . .	4
Benefits of TDP's . . . . .	9
Regulation. . . . .	9
Treatment Cost Saving . . . . .	9
Incentive and Flexibility . . . . .	9
Growth and Change . . . . .	10
Water Quality Consideration. . . . .	11
An Overview of Simulation Game . . . . .	12
The Benefits of Simulation Game. . . . .	15
Research Tool . . . . .	15
Teaching Tool . . . . .	15
Disadvantages of Simulation Game . . . . .	16
III. METHODOLOGY . . . . .	19
Description of the Game . . . . .	19
Basic Game Structure . . . . .	19
Participant Characteristics. . . . .	21
Decisions and Alternatives . . . . .	24
The Conceptual Model of Game Program. . . . .	27
Participant Input Program . . . . .	27
Alternatives . . . . .	28
Alternative 1 . . . . .	28
Alternative 2 . . . . .	29
Alternative 3 . . . . .	30
Alternative 4 . . . . .	30
Alternative 5 . . . . .	30
Alternative 6 . . . . .	31
Alternative 7 . . . . .	31
Alternative 8 . . . . .	31
Proctor Input Program . . . . .	33
Cost Program . . . . .	34
Fixed Cost and Variable Cost . . . . .	35
User Charge . . . . .	35
Permit Price . . . . .	36
Enforcement . . . . .	36
Water Quality Related Cost. . . . .	37
QL2SMG Water Quality Model Description . . . . .	37

Chapter	Page
Introduction . . . . .	37
Theoretical Considerations . . . . .	38
Advection-Dispersion Equation . . . . .	39
Hydraulics. . . . .	40
Carbonaceous BOD . . . . .	41
Dissolved Oxygen . . . . .	41
The Program. . . . .	42
Input Option . . . . .	43
Input Requirements. . . . .	43
Output Information. . . . .	44
Result Analysis . . . . .	45
IV. APPLICATION . . . . .	47
Game Operation . . . . .	47
Computer Support of the Game . . . . .	47
Interactive Environment . . . . .	47
Input by Participants . . . . .	49
Input by Game Proctor . . . . .	49
Game Program Calculation . . . . .	50
Game Administration . . . . .	51
Implementation of TDP's Market . . . . .	52
Permit Durations . . . . .	54
The Market Mechanism . . . . .	54
V. RESULTS AND DISCUSSIONS . . . . .	57
Water Quality Analysis . . . . .	57
Water Cost Analysis . . . . .	63
Team 1 . . . . .	67
Team 2 . . . . .	69
Team 3 . . . . .	71
Team 4 . . . . .	72
Team 5 . . . . .	73
Team 6 . . . . .	75
Team 7 . . . . .	77
Sag Point . . . . .	79
Water Quality Impact for the Whole Region . . . . .	79
Cost Efficiency for the Whole Region. . . . .	80
VI. CONCLUSIONS AND RECOMMENDATIONS . . . . .	81
Conclusions . . . . .	81
Recommendations . . . . .	84
LITERATURE CITED. . . . .	85
APPENDICES . . . . .	90
APPENDIX A - CASE STUDY INDUSTRIAL DISCHARGE NO. 1 . . . . .	91

Chapter	Page
APPENDIX B - EXAMPLE OF WASTE DISPOSAL DECISIONS FOR CASE STUDIES . . . . .	104
APPENDIX C - COMMAND PROCEDURE TO SPECIFY DATASETS AND SUBMIT THE COST PROGRAM AND THE QL2SMG PACKAGE . . . . .	114
APPENDIX D - COMMAND PROCEDURES TO BE USED BY PARTICIPANTS FOR ENTERING DECISIONS. . . . .	116
APPENDIX E - FORTRAN PROGRAM FOR COST CALCULATIONS . . . . .	118
APPENDIX F - INTERACTIVE FORTRAN PROGRAM FOR PARTICIPANT INPUT . . . . .	123
APPENDIX G - INTERACTIVE FORTRAN PROGRAM FOR PROCTOR INPUT . . . . .	135
APPENDIX H - ALPHABETICAL LIST OF VARIABLES AND THEIR DEFINITIONS IN WATER QUALITY SIMULATION GAME . . . . .	139
APPENDIX I - TRANSACTION RECORDS OF PERMITS. . . . .	142

## LIST OF TABLES

Table	Page
I. Initial Water Parameters for the Participants . . . . .	24
II. Input Parameters for QL2SMG . . . . .	39
III. Sample Financial Report . . . . .	50
IV. Initial Distribution of TDP's . . . . .	53
V. General Wastewater Quantity and Quality Parameters Production Wastewater . . . . .	58
VI. Wilcoxon Ranks Test Result in DO Concentrations (mg/l) and Probability of Significance . . . . .	59
VII. Wilcoxon Ranks Test Result in BOD Concentrations (mg/l) and Probability of Significance . . . . .	60
VIII. Stream Quality Parameters for Period 2 . . . . .	61
IX. Stream Quality Parameters for Period 6 . . . . .	62
X. Water Quality Related Costs (\$) . . . . .	64
XI. Difference in Water Quality Related Costs for Paired Comparisons (\$) . . . . .	64
XII. Wilcoxon Ranks Test Result in Water Quality Costs (\$) and Probability of Significance . . . . .	65
XIII. Variable Costs (\$) . . . . .	65
XIV. User Charges (\$) . . . . .	66
XV. Permit Transaction Record . . . . .	66
XVI. Treated Wastewater Quantity and Quality for Team 1 . . . . .	67
XVII. Treated Wastewater Quantity and Quality for Team 2 . . . . .	70
XVIII. Treated Wastewater Quantity and Quality for Team 3 . . . . .	71
XIX. Treated Wastewater Quantity and Quality for Team 4 . . . . .	73



Table	Page
XX. Treated Wastewater Quantity and Quality for Team 5 . . .	74
XXI. Treated Wastewater Quantity and Quality for Team 6 . . .	76
XXII. Influent Flowrate (MGD) for Municipal Plants. . . . .	76
XXIII. Treated Wastewater Quantity and Quality for Team 7 . . .	77
XXIV. Water Quality Related Cost Saving (\$) . . . . .	80
A-1. Production and Effluent Forecast. . . . .	96
A-2. Variable Costs (\$) . . . . .	101
A-3. Municipal User Charges (\$) . . . . .	102
A-4. Capital Costs (\$) . . . . .	103
B-1. Variable Costs (\$) . . . . .	107
B-2. Municipal User Charges (\$) . . . . .	109
B-3. Capital Costs (\$) . . . . .	110

## LIST OF FIGURES

Figure	Page
1. Command and Control Regulatory Approach . . . . .	5
2. Transferable Discharge Permit Market. . . . .	7
3. Water Quality Management Game Flowchart . . . . .	20
4. Typical River Region Consisting of Industries and Cities . . . . .	22
5. Participant Input Program Flowchart . . . . .	28
6. Proctor Input Program Flowchart . . . . .	33
7. Cost Program Flowchart . . . . .	34
8. Computer Support and Datasets for the Game Program . .	48

## CHAPTER I

### INTRODUCTION

In recent years, environmental policy has become an increasingly important part of government regulatory activities. This, in turn, has motivated questions addressing the effectiveness of these activities. In particular, these questions are concerned with the cost effectiveness of regulatory activities as well as the ability to bring waste dischargers into compliance with environmental quality standards. An important concern is to evaluate the use of Transferable Discharge Permits (TDP's) in the attainment of water quality objectives.

A number of methods are available that could be used to evaluate the effectiveness of TDP's. David et al. [1] and Eheart et al. [2], for example, have used mathematical programming methods to evaluate the effectiveness of TDP's. In assessing the use of mathematical programming models, perhaps it could be argued that behavior cannot be predicted in a deterministic way. That is, optimization models presuppose some form of rational behavior on the part of managers such as profit maximization or cost minimization.

A viable alternative to mathematical programming models for addressing the effectiveness of TDP's is simulation gaming. The simulation game can be helpful for examining theories involving simplified situations and for abstracting phenomena from the real world. Simulation gaming has been employed as a tool for researching

and for training in various fields. However, it is a new issue to Water Quality Management (WQM) decisions. Simulation gaming is valuable not only for teaching aspects of water quality decisions, but it can also be used as a research tool in understanding economic issues of water quality management.

The objective of this dissertation is to develop a water quality management simulation game to be used in exploring the effectiveness of achieving water quality standards with a system of transferable discharge permits. The potential for substantial cost savings from trading TDP's is demonstrated using data on a hypothetical river. The game will be tested initially without offering a TDP as an alternative. After four periods the game will include TDP's as an option for water quality decisions. A simulation model of water quality (QL2SMG) is used to study the impact of waste loads (magnitude, quality and location) on in-stream water quality. QL2SMG permits simulation of oxygen dynamics in a one-dimensional system with steady state hydraulics. Details of QL2SMG are given in Chapter III.

## CHAPTER II

### BACKGROUND AND LITERATURE REVIEW

#### An Overview of TDP's

Transferable Discharge Permits (TDP's) have been examined over the past 20 years as a policy to achieve any desired level of air or water pollution abatement [3, 4, 5, 6]. Under this policy, the agency considers the assimilative capacity of the environment and issues the permit. Once distributed, the permits are tradable among polluters, their price being set by market forces and the cost of alternatives to pollution. Of course, no polluter may discharge the pollutant in excess of permit holdings, and enforcement is effected by the provision of fines which exceed the market value of the effluent permits.

The TDP system is called an "incentive type" system. The trading of permits allows more efficient waste processors to operate at a high removal efficiency and hold relatively few shares of effluent permits, while allowing less efficient waste processors to hold a relatively large number of permits, and perform little or no waste removal.

TDP's offer dischargers the alternative of purchasing a substitute for abatement. Entering the market is not coercive and will only be done when it appears profitable. In the short run, permits can be purchased to cover the excess discharges associated with plant failure or production overruns. On a seasonal basis, TDP's can be purchased to cover deficient capacity during a period of exceptionally limited

assimilative capacity in the river. On a long-term basis, TDP's may be used to provide for a substantial part of abatement during periods where one firm is deficient in abatement capacity while another has excess capacity [7, 8, 9, 10].

### Economic Rationale for TDP's

The rationale for using TDP's as a policy approach for achieving water quality objectives can be examined by using a command and control approach to allocate the responsibility for meeting a specified water quality level standard [11].

An example for two wastewater discharges is shown in Figure 1. The amount of wastewater discharged for A and B is shown on the horizontal axis and is read from left to right. The amount of pollution abatement undertaken is essentially the same as reducing the total level of discharge and is represented by reading from right to left. The cost of undertaking pollution abatement is represented by marginal control cost curves  $MC_A$  and  $MC_B$ . Marginal control costs are assumed to increase with an increase in the amount of pollution abatement. Prior to any regulatory action by the environmental authority, A will discharge  $OE_A$  and B will discharge  $OE_B$ .

Now suppose that the environmental authority sets a discharge standard of  $E_{T1}$  so that the total discharge from both dischargers cannot exceed  $E_{T1}$  (i.e.,  $OE_A + OE_B \leq OE_{T1}$ ). It is also decided that each discharger will be required to reduce discharge by an equal amount when allocating the responsibility for complying with the standard. Thus discharger A will be required to reduce its discharge by  $E_{A1}\bar{E}_A$  and discharger B will be required to reduce its discharge by  $E_{B1}\bar{E}_B$ . The




Figure 1. Command and Control Regulatory Approach

total control cost for discharger A is equal to the geometric area  $E_{A1}M\bar{E}_A$  and the total control cost for discharger B is equal to the geometric area  $E_{B1}Y\bar{E}_B$  on Figure 1. Total costs for complying with the standard are the control costs for the two dischargers.

It can be noted from Figure 1 that the marginal cost of reducing discharge by  $E_{A1}\bar{E}_A$  for discharger A is  $C_{A1}$  while the marginal cost of

reducing discharge by  $E_{B1}\bar{E}_B$  for discharger B is  $C_{B1}$ . This implies that total control costs can be reduced if discharger A is able to reduce the amount of its pollution abatement (i.e., increase its level of discharge) while discharger B is to increase its amount of pollution abatement (i.e., decrease its level of discharge). This is true because the reduction in total control cost for A to increase its emissions discharge, represented by the various points on its marginal cost curve as  $MC_A$ , is greater than the marginal cost or increased total control cost incurred by B for a higher level of pollution abatement. It is no longer possible for total costs to be reduced once marginal control costs for all dischargers are equal. In terms of Figure 1, this occurs when discharger A undertakes abatement equal to  $E_{A2}\bar{E}_A$  units of discharge and discharger B undertakes abatement equal to  $E_{B2}\bar{E}_B$  units of discharge. Of course, marginal control costs are equal at this point (i.e.,  $C_{A2} = C_{B2}$ ). Thus, the cost of achieving a given water quality standard will be minimized if and only if the marginal costs of control are equalized for all dischargers.

The rationale underlying the preference for TDP's as a regulatory mechanism for achieving a cost-minimizing solution for complying with a given water quality standard can be demonstrated with the aid of Figure 2. Assume that the environmental authority sets a standard for discharge of  $OE_{T1}$  and creates the same number of TDP's. The supply of TDP's is predetermined since the total amount is controlled by the environmental authority. Thus, the supply of TDP's is given by  $\bar{S}$ . Assume also that the individual marginal control cost curves  $MC_A$  and  $MC_B$  can be horizontally aggregated into a total marginal cost curve  $MC_{T1}$  as shown in Figure 2.






Figure 2. Transferable Discharge Permit Market

Assume that the environmental authority makes an initial distribution of TDP's to the two dischargers as follows: discharger A receives  $OE_{A1}$  permits and discharger B receives  $OE_{B1}$  permits (Note that  $OE_{A1} + OE_{B1} = OE_{T1}$ ). Dischargers are then allowed to buy and sell permits in a single clearing price TDP market. The decision to buy or sell permits will depend on the price of permits relative to the marginal cost of pollution abatement. Thus  $MC_A$  and  $MC_B$  are the individual dischargers demand curves for TDP's and  $MC_{T1}$  is the total market demand curve for TDP's.

The market-clearing price in Figure 2 is given by  $P_1$ . Discharger A will then demand  $OE_{A2}$  permits and discharger B  $OE_{B2}$  permits (where  $OE_{A2} + OE_{B2} = OE_{T1}$ ). In terms of their initial allocations, discharger B will sell discharger A a number of permits equal to  $E_{A1}E_{A2} = E_{B1}E_{B2}$  at a price of  $P_1$  per permit. Discharger A will now incur an abatement cost of  $E_{A2} \bar{N}_A$  for abating emissions equal to  $E_{A2} \bar{E}_A$ , and will spend an amount equal to  $E_{A1} R N E_{A2}$  for a number of TDP's equal to  $E_{A1} E_{A2}$ . Discharger B, on the other hand, will increase its level of emissions abatement by  $E_{B2} E_{B1}$ . B will also realize an increase in its abatement cost equal to  $E_{B2} X Y E_{B1}$ , but receives TDP revenue equal to  $E_{B2} X F E_{B1}$ . Discharger A is then subsidizing part of B's treatment cost plus providing B with a net profit equal to  $X F Y$ .

This has two desirable effects. The first is that each discharger has a continuing incentive to seek further ways to reduce discharges. The second is that the market assumes that the marginal costs of the waste control are the same for different dischargers. If the costs to each discharger for eliminating the last unit of wastes are the same,

then there are no opportunities to achieve the same total discharge reductions at a lower total cost.

### Benefits of TDP's

The TDP system has four desirable attributes. These are simplified regulation, saving in treatment costs, incentive and flexibility, and the ability to deal with the growth and entry of dischargers.

Regulation. Regulation is reduced. For example, effluent charge control for a river basin can be made simple and inexpensive with the TDP system. In addition, when permits expire, the regulatory authority can reduce the total amount of permits by issuing fewer. More important, the regulatory authority has the opportunity to buy permits on the open market and to retire them. Neither of these procedures is excessively complicated administratively and can be accomplished without devising different rules and procedures for different polluters.

Treatment Cost Saving. The reduction in treatment costs under TDP's occurs because under a TDP system the most technically efficient treatment plants will remove more of the pollution load. Braasch and Joeres [12] estimated that TDP's would result in a cost saving for the Lake Michigan basin of Wisconsin of three quarters of a million dollars annually. This cost reduction will occur without violating the wastewater level standard.

Incentive and Flexibility. For the dischargers, the important incentive is that TDP's allow flexibility in operation. Industries can

then more readily vary production and operate closer to the margin without always having to consider long-range capital investment planning. While it is hard to value flexibility in dollars, flexibility can be stressed as an advantage.

Municipalities can gain from improved timing of construction of wastewater treatment plants. Delays in construction can be handled with the purchase of permits, rather than requests for variances. And any delays in construction may allow refinement of population service demand projections. This creates potential for improved plant designs.

Incentive for the regulator derives from the fact that TDP's support the environmental mission of the agency. TDP's enhance the likelihood of meeting environmental goals. Requiring dischargers to fully explore TDP's prior to requesting variances will reduce the number of such requests to the agency, thus reducing the need for difficult social welfare decisions.

Growth and Change. The growth and entry of polluters are handled naturally and efficiently in the TDP system. Increasing waste discharges, through either entry or growth, is allowed only upon the acquisition of effluent permits. Thus, new entrants will increase the price of TDP's. This is an advantage to holders of rights who elect to sell. The increased demand for a fixed supply is a disadvantage for dischargers wanting to increase their discharge. The TDP system is preferable for all dischargers. Because although the unit cost of treatment rises as increasing amounts of pollutants must be eliminated, the average unit cost in a TDP system will still be the least cost. In a regulatory system without TDP's, the sum of the individual treatment costs is higher since each expanding facility must bear its own costs

of increased treatment, some of which will be higher than the lowest cost achievable with TDP's.

### Water Quality Consideration

One of the most important decisions the authority must make in designing any water quality management program for a particular water body is the form and stringency of the water quality goal. This goal is assumed here to be expressed as follows: A set of receiving water body conditions is chosen which represents a low extreme of assimilative capacity. These conditions, as usually represented for a stream by a low streamflow and high temperature, are referred to as the critical conditions. For example, the "sag point" in the levels of dissolved oxygen concentration. All of the authority's decisions regarding numbers of permits to issue, are assumed here to be undertaken on the basis of these conditions. Once the critical conditions have been determined, a mathematical model is assumed to be available for use by the authority to relate the water quality at all points in the receiving body to the waste discharge rates of each discharger.

Another policy decision is the basis of definition of the permits. Two definition bases are considered here. The first, called a BOD permit, entitles the holder to discharge a certain weight of BOD per day. The second type of permit entitles a discharger to deplete the dissolved oxygen at a specific location in the watercourse by a certain amount, as predicted by the water quality model for the critical conditions chosen. It is termed a Dissolved Oxygen Deficit Contribution permit (DODC). A DODC permit corresponds to a BOD permit

of a certain size when held by a given discharger. However, unlike the BOD permit, it is revalued when transferred to another location [13, 14].

Water quality problems depend in part on local physical features with the type of trading restrictions chosen by the authority varying from one water body to another. However, the efficiency achieved by the TDP system comes about by letting the most efficient plant perform most of the waste removal without regard to where it is located, except when its location affects its cost of treatment. Thus, to maintain a specified water quality profile, the authority must recognize that the effects of discharges on water quality are different for different discharge locations and must formulate the effluent permits accordingly.

This research assumed seven participants located within a given zone to allow one-to-one trades of permits. The definition base for the permits is pounds of BOD per day (Lbs-BOD/day). A simulation model of water quality (QL2SMG) is used to estimate the relations between dischargers and DO levels at various locations along the stream.

#### An Overview of Simulation Gaming

Simulation gaming is described by Wood [15] as follows: "As a form of simulation model, gaming is similar to other simulations where the major purpose is to understand dynamic process. While the approach emphasizes process, it attempts to comprehend human activities as the products of indeterministic forces which can lead to any one of a possible range of outcomes, and is in essence a probabilistic approach. Where gaming simulation differs from other methods is that it attempts

to provide experience of a 'real world' decision making situation, where goals have to be formulated, problems evaluated and judgment exercised".

Because of the complexity of human nature, it is difficult to describe the social and political system in terms of ordinary equations. Simulation gaming is designed to overcome this difficulty. As its name implies simulation gaming comprises two basic components: gaming, involving interaction between human "players", and simulation, involving interactive computer facilities [16].

Simulation gaming can be traced back to the mid-1950s when Rand Corporation developed "crisis game". This game provided foreign policy makers with a set of useable alternatives in the event that similar crises actually occurred [17]. Since that time, the number of simulation games has increased at a rapid rate. Currently, simulation gaming is widely used for amusement, education, and research.

Although still somewhat of a novel concept, simulation gaming is becoming accepted as a tool in the analysis of water resource systems, especially when decisions are likely to involve conflict and compromise. Wright and Howell [18] described a simulation gaming analysis of a water resource development issue in New South Wales. Johnson and Whitehead [19] elaborate on the value of simulation gaming in increasing the awareness of planners involved in water resource issues. Diamond et al. [20] discuss the design of simulation games for teaching and researching drought management.

One of the most recent and successful applications of water resource gaming occurred in 1982, when a one-day exercise was conducted in Washington D.C. The focus of the exercise was on reservoir

operating policy in the Potomac River Basin. The water supply situation in and around the Washington D.C. area has been the source of considerable controversy for many years. Three agencies are responsible for supplying water, primarily from the Potomac River, to the 2.5 million residents of the region. Complicated relationships have evolved between these agencies as to how water should be allocated during periods of low flow in the Potomac River. Traditionally, there have been many disputes and little cooperation between the agencies. As a result, what should have been an adequate supply of water to the region during dry periods has been allocated inefficiently, and the reliability of the regional water distribution scheme has been questioned.

A group of researchers at Johns Hopkins University developed an interactive simulation model of the Potomac River Basin water system. This model, the Potomac River Interactive Simulation Model (PRISM), was to be used as a research and learning tool for those groups involved in the water supply planning in the region. Though PRISM was valuable as an aid in identifying alternative management strategies, it was even more effective when incorporated into a simulation gaming exercise. The exercise brought together many of the key decision makers from each agency and from other groups involved with water supply management. Interacting with PRISM and among each other, these groups gained insight into many of the conflicts involved in the water supply issue. As a result of the research at Johns Hopkins, many of the obstacles which previously prevented efficient regional water management were removed. The investigation approach was so successful that the project was considered for the 1983 Outstanding Engineering Achievement Award [21].



A literature search has unveiled no game designed for water quality management. Timely and efficient disposal of the waste generated by the manufacturing plant requires engineering as well as economic analysis. This is because most companies have to operate under a permit issued by some state regulatory body. Typically these permits allow companies to release a specified maximum amount of waste with certain biochemical characteristics. The companies may also have the choice of releasing the waste into the city sewer system and paying the municipality a user charge. Obviously the decision on proper disposition of the waste can involve evaluation of several alternatives based on economic analysis. A decision to expand waste treatment also has to consider production forecasts. Thus, this game would be valuable not only for teaching aspects of water quality decisions, but it could also be used as a research tool for understanding economic issues of water quality management.

#### The Benefits of Simulation Gaming

Research Tool. Simulation gaming may provide one or more advantages as research tools including: 1) Ease of observation and data collection; 2) Reproducibility; 3) Lower cost; and, 4) Ability to study phenomenon where direct research is not politically acceptable [22]. As a result of these advantages, simulation gaming has been used for research in psychology [23], sociology, the military, economics [24] and various other fields.

Teaching Tool. Simulation gaming may also provide one or more advantages as a teaching tool including: 1) Students exhibiting a high degree of interest and participation; 2) Students experiencing

making managerial decisions; 3) The opportunity to integrate concepts from diverse areas of courses; 4) The experience of living with past decisions; and, 5) The decision-making experience is condensed into a relatively short period of time [25].

#### Disadvantages of Simulation Gaming

Aronson and Carlsmith [26] delineated two types of realism: mundane and experimental. Mundane realism relates to how likely it is that the events occurring in a laboratory are likely to occur in the real world. Experimental realism relates to how seriously the subject takes the experiment. Some users have the tendency to treat simulation as a "game" rather than to treat problems with experimental realism. This results in lack of incentive to perform the game well. Nees [27] noted that the participants in her simulation "did not bear the consequences of their decision. Neither were they penalized for failure, nor did they have to live with their undertakings after the simulation was over".

The "lack of incentive" issue is intertwined with another issue, regarding the nature of the subject group, whether they are college students or managers. On one hand, the grade environment which exists in the classroom places an incentive on student subjects to do well. Slusher, Sims and Thiel [28] found that semester-long involvement in a competitive learning environment provides a high and consistent incentive. On the other hand, when Bass [29] discussed the high motivation level usually found among manager-subjects, he observed that "real managers try to do their best when confronted with simulated management

problems". Incentive for play was attributed to competitive desires and to a sense of loyalty to one's team.

The best answer to the question of whether the game has experimental realism involves a comparison of the subjects' game behavior with their actual behavior. Obviously, this can present serious problems in the case of student subjects as they cannot be expected to be making actual decisions for most topics under investigation. However, there have been studies which compared the performance of manager-subjects in simulation games to their performance in the workplace. Babb and Bohl [30] found 70% of farmers' initial pricing decisions in a farm management game to be consistent with their real life decisions. Jones and Babb [31] found that retail managers' pricing decisions agreed with their real world behavior only about half the time. However, they did find that their non-price behavior was nearly identical to that used in the simulation games.

Babb, Leslie, and Van Slyke [32] noted that there are striking differences in game behavior and in results between students and experienced managers. Students are affected much more by information provided them, whereas managers apparently rely on experience. Managers follow more conservative policies than students, while students are more erratic in their decisions. Apparently students feel the need to learn something about the industry by experimenting with the game. Student performance was usually much lower than experienced managers in early decisions but quickly came to an equal level. The general conclusion is that experimentation on the subjects' part does take place and that this experimentation is not likely to be done in a real world environment. However, even when student subjects are used,

game behavior moves toward real life after a few decisions.

The field of simulation games is still growing at a prodigious rate, as measured by their commercial availability. Yet many reports indicate that simulation games are not entering the classroom as fast as they are proliferating on publisher's lists. The major reason is that simulation games are often viewed as highly complex, strange, slightly upsetting phenomena by teachers who have never used them. Some professors who initially undertake the usage of simulation exercise because they think it represents an escape from their teaching duties soon find that it requires a great deal more of their time than they had expected. In most cases, more time than they normally would have spent using their traditional methods. The net result being that certain professors drop the use of simulation games and return to the traditional methods with which they feel more comfortable [33].

## CHAPTER III

### METHODOLOGY

#### Description of the Game

##### Basic Game Structure

The flow chart (Figure 3) illustrates the basic structure of the game. The game begins with a detailed description (illustrated in Appendix A) of the firm or of the municipality that the participants are to represent. This includes data on production plans, costs of production, and the relationships between the output and effluent of various pollutants. The municipal managers are given data related to city waste treatment and to the requirements from the firms in the area for waste treatment. The water quality standards that the firm or the municipal plant must meet are also given to the participants. They also receive information on legal consequences of releasing effluent without treatment. This includes the estimated penalties and probability of getting fined.

Besides the production data, the manager is also given a complete list of alternatives (described later in detail). Each alternative comes with its cost effectiveness figures. Costs are given for various stages of treatment for each plant capacity [34].

After considering all the information, the participant evaluates the alternatives and makes a decision in terms of production volumes,




Figure 3. Water Quality Management Game Flowchart

pollutant disposal alternatives, and size-cost data. Also included in the decision is the choice of expanding current treatment capacity which could be available two periods later.

The decision-making is followed by the entry of the data into the computer. Then the simulation game is started, and the gaming program prepares two reports. From all the decisions, the production-pollution relationships determine the generated pollutants. The individual cost and quality of effluents are derived from the abatement options of the teams. The game also uses the QL2SMG model to calculate the water quality for the whole region. The QL2SMG model considers pollution from several sources at several points and calculates water quality in terms of BOD and dissolved oxygen concentration.

Each participant obtains a summary of results of his or her decisions, including the actual cost incurred, fines for violating water quality standards, pollution clean-up alternatives, etc. The information also includes the overall water quality at different locations in the area. The game is then repeated for the next period, i.e., the next quarter, details of which will be given later.

#### Participant Characteristics

Five industrial firms and two municipalities constitute the region simulated by the game in its current version. A team represents either a firm or a municipality. Using teams of two or more for each industry or municipality, the game can include more participants in each region. Figure 4 gives a schematic of the region. It also indicates that industries and cities are situated along a river and its tributaries. The numbered elements in the figure represent "mile-marks". Thus, for




Figure 4. Typical River Region Consisting of Industries and Cities



example, team one is four miles upstream from team two. The first three industrial firms are assumed to be in Paladine City and the others are in Eddyville. The five industries selected in this game are industries which generate significant amount of industrial wastes.

The plants represented by the industrial firms are processors of cotton, poultry, and meat, and factories making things such as potato chips and pulp-and-paper. These plants could be either small- or medium-sized. Each participant gets a description of the production function of the firm. The data involve the production forecast for four quarters, associated expected wastewater flow rates in million gallons per day (MGD), and influent BOD in milligrams per liter (mg/l). The data also include the permitted discharge to the river in terms of maximum flow rate (MGD) with limits on BOD concentration in the effluent and with the capacity of the available wastewater treatment plant. The estimated fixed as well as variable costs of operating wastewater treatments at various levels are also provided. In case a firm decides to use the municipal plant for disposal of wastewater, the participant is given the estimated user charge at different flow rates and pretreatment levels. Finally, a table containing costs of larger plant sizes accompanies the information package to help in making decisions on upgrading the plant.

The five industrial firms and the two municipal plants have a wide range of plant sizes, permits, and production forecasts. Table I contains a summary of starting values of permitted discharges, and plant sizes. The information is realistically based on interviews with representatives of many of the regulatory agencies in the State of Oklahoma.

TABLE I  
INITIAL WATER PARAMETERS FOR THE PARTICIPANTS

Team	Max. Permitted Discharge		Plant Capacity	
	Flow (MGD)	BOD (mg/l)	Flow (MGD)	BOD (mg/l)
1	1.7	30	1.5	20
2	0.38	24	0.45	24
3	0.03	40	0.05	70
4	0.04	20	0.05	20
5	2.00	20	2.00	40
6	15.00	45	16.00	40
7	3.00	10	5.5	10

### Decisions and Alternatives

By learning the key concepts and performing skills used in a decision-making process, the participants gain the ability to frame a problem, identify useful data, predict and bargain permit prices, and render judgments about the appropriate actions.

The simulation game plays eight periods, each period representing one season. The first four periods don't involve the TDP case, while the later four periods cover the TDP case, in order to make a fair comparison, the production volume of the first four periods should equal that of the following four counterpart periods: i.e., the first period production volume is the same as that of the fifth period production volume. Three types of decisions are made during the first four periods. The participants determine the production volumes and choose any of the first six alternatives in disposing of the expected waste

in the current period. The next step is to decide whether to upgrade the treatment plant. During the final four periods, participants have to make four kinds of decisions. First they negotiate the transfer of discharge permits with the other participants at a mutually agreeable price. Those who want to buy permits can only choose alternative 1, 4, 7 or 8, but if they want to sell permits, they can choose any of alternatives 1 to 7 to treat their wastewaters and finally, decide whether to upgrade their existing plants or not. If they want to upgrade their plants, the upgrades take two periods of time.

The basic production-pollution relationships and production costs are a built-in feature of the program. The eight alternatives are:

1. Treat everything in the company plant and release to the river.
2. Pretreat everything in the company plant and send to the municipal plant.
3. Send all waste to the municipal plant without treatment.
4. Treat part in the company plant and release; send the other part of the wastewater, without treatment, to the municipal plant.
5. Pretreat part in the company plant and send to the municipal plant; send the other part, without treatment, to the municipal plant.
6. Discharge without permit and without treatment.
7. Treat part in the company plant and release; send the other part, without treatment, to the river.
8. Discharge wastewater after buying permit.

The first alternative requires treating the waste entirely in the

company plant. The company then incurs capital and operating costs of a treatment plant. The next four alternatives use the municipal plant to some extent, involving the expense of a user charge. The sixth alternative is unacceptable. The last two alternatives are used for the TDP case only. If a company is caught discharging without permit and treatment, a heavy fine is imposed which simulates a penalty and bad publicity.

It is not easy to decide among these alternatives. The participants must calculate the total cost of each alternative. The alternatives involving partial treatment require consideration of the extent of treatment and of its effect on total cost. Some of the alternatives may not be practical due to the capacity of the treatment plant and/or the permitted discharge. For instance, if a firm has a wastewater treatment plant with a design capacity of 0.08 MGD flow and expects 0.09 MGD flow during a certain quarter, it cannot choose alternative 1, treating everything in the company plant and releasing to the river. Thus, the participant has to select the practical set of alternatives first, analyze their implications, and make a decision. The continuity from quarter to quarter is also an important issue to consider. The long term effect of a strategy cannot be ignored.

The decision to upgrade the plant may affect future decisions as well. The benefits of a larger plant, such as "pretreat the waste and release to the city sewer", or "treat part of the waste and release to the city sewer", have to be considered against the costs of these benefits as well as costs of alternatives. These two decisions require a thorough analysis of marginal costs of each alternative.

## The Conceptual Model of Game Program

There are five programs involved in this simulation game: (a) the participant input program, which lets the participants input their decision; (b) the proctor input program, which generates the QL2SMG input format for executing the QL2SMG program; (c) the cost program, which generates a financial report for each team; (d) the QL2SMG package, which calculates the water quality report for the whole region; and (e) the SAS package, which assesses the impacts of water quality and cost between the TDP system and the non-TDP system.

### Participant Input Program

After participants use computer command language to enter the program, the program will read plant design capacity, TDP price and permit numbers from different data files automatically. Afterwards, participants should input their team numbers (teams 1 to 5 represent industrial firms; teams 6 and 7 indicate municipal plants), period number and production volumes. The program will generate wastewater flow rates and BOD concentrations by built in production-pollution relationships. The flowchart of this program is found in Figure 5. The participant input program is given in Appendix F.

If the participants want to buy permits, they can choose alternative 1, 4, 7 or 8, but if they decide to sell permits, they can choose any alternative from 1 to 7 to treat their wastewater. Finally they are asked wheather to expand the existing plant or not. The optimal size of the plant should be the size that minimizes construction costs and penalty costs associated with inadequate capacity.




Figure 5. Participant Input Program Flowchart

### Alternatives

There are eight alternatives involved in the treatment options.

Alternative 1: Alternative 1 states "Treat all wastewater in the company plant and release to the river". This alternative will be restricted by five factors: (a) Treated wastewater flow rate should not exceed the plant's design capacity, (b) Treated wastewater flow rate should not exceed the maximum limitation of wastewater flow rate to the river, (c) Treated wastewater BOD effluent concentration should

not exceed the design BOD effluent concentration, (d) Treated wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the river, and (e) The design BOD effluent concentration should not be larger than the allowed BOD effluent concentration to the river. For the TDP case, this restriction will be released. In periods 5, 6, 7 and 8, the BOD effluent concentration is calculated by the formula:

$$\text{BODE} = (\text{SBOD} \times \text{SQ})/\text{Q1} + \text{TDP} \quad (\text{Eq. 1})$$

Where BODE is the treated BOD effluent concentration (mg/l)

SBOD is the allowed BOD effluent concentration to the river (mg/l)

SQ is the maximum limitation of wastewater flow rate to the river (MGD)

Q1 is treated wastewater flow rate (MGD)

TDP is the number of trading permits

Example: The allowed BOD effluent concentration to the river from plant 1 is 30 mg/l and the expected wastewater flow rate is 1.36 MGD in period 3 and period 7. Under the non-TDP case, team 1's discharged BOD effluent concentration should not exceed 30 mg/l. But during period 7, if this team does not trade permits, the BOD effluent concentration is 37.6 mg/l.

Alternative 2: The second alternative states "Pretreat all wastewater in the company plant and send to the municipal treatment plant". This alternative will be restricted by three factors: (a) Pretreated wastewater flow rate should not exceed the design capacity, (b) Pretreated wastewater BOD effluent concentration should not exceed the design BOD effluent concentration, and (c) Pretreated wastewater

BOD effluent concentration should not exceed the allowed BOD effluent concentration to the municipal treatment plant.

Alternative 3: The third alternative states "Send all wastewater to the municipal treatment plant without treatment". This alternative will be restricted by BOD effluent concentration of discharged wastewater, which should not exceed the allowed BOD effluent concentration to the municipal treatment plant.

Alternative 4: The fourth alternative states "Treat part of the wastewater in the company plant and release; send the other part of the wastewater, without treatment, to the municipal plant". This alternative will be restricted by seven factors: (a) Treated wastewater flow rate should not exceed the production wastewater flow rate, (b) Treated wastewater flow rate should not exceed the plant's design capacity, (c) Treated wastewater flow rate should not exceed the maximum limitation of wastewater flow rate to the river, (d) Treated wastewater BOD effluent concentration should not exceed the design BOD effluent concentration, (e) Treated wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the river, (f) Discharged wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the municipal treatment plant, and (g) The design BOD effluent concentration should not be larger than the allowed BOD effluent concentration to the river (for the TDP case, this restriction is cancelled).

Alternative 5: The fifth alternative states "Pretreat part of the wastewater in the company plant and send to the municipal plant; send the other part of the wastewater, without treatment, to the municipal plant". This alternative will be restricted by four factors: (a)



Pretreated wastewater flow rate should not exceed the production wastewater flow rate, (b) Pretreated wastewater quantity should not exceed the design capacity, (c) Pretreated wastewater BOD effluent concentration should not exceed the design capacity for BOD effluent concentration, and (d) Pretreated and discharged wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the municipal treatment plant.

Alternative 6: The sixth alternative says "Discharge all wastewater without permit and without treatment". This alternative does not have any restrictions.

Alternative 7: The seventh alternative states "Treat part of the wastewater in the company plant and release; send the other part, without treatment, to the river". This alternative will be restricted by three factors: (a) Treated wastewater flow rate should not exceed the production wastewater flow rate, (b) Treated wastewater flow rate should not exceed the plant's design capacity, and (c) The discharge permitted is equal to the initial permit holdings plus traded permits. The teams must be careful because this situation can only exist in the TDP case.

Alternative 8: The eighth alternative says "Discharge wastewater after buying permit". This alternative will be restricted by the fact that the discharge permit needed is equal to the initial permit holding plus purchased permit numbers (for the TDP case only).

The upgrade plan is restricted by: (a) Future design capacity is not less than the current design capacity, and (b) Future design BOD effluent concentration is not larger than the current design BOD effluent concentration.

In the TDP system, each permit authorizes a specific rate of discharges, say one Lb-BOD/day. After initial distribution of permits among participants, if the participants still want to purchase permits, they can slacken wastewater discharge, i.e., the current maximum of limitation of BOD effluent concentration will be increased. For example, the current design BOD effluent concentration for team 3 is 70 mg/l, the maximum limitation of BOD effluent concentration is 40 mg/l and expected wastewater flow rate is 0.030 MGD. Owing to the restriction alternative 1 (e), "The design BOD effluent concentration should not exceed the allowed BOD effluent concentration to the river", under the non-TDP system, they can never choose alternative 1 for disposal of their wastewater, but under the TDP system if they purchase permits for 7.51 Lb-BOD/day, their discharged BOD effluent concentration can be 70 mg/l. In other words, the maximum limitation BOD effluent concentration is increased to 70 mg/l. Therefore, team 3 can choose alternative 1.

In certain cases, participants decide to expand the existing treatment facilities. This decision will invoke additional capital costs. These costs will vary with the wastewater design flow and BOD design effluent concentration. Once the wastewater treatment facilities are defined in terms of wastewater design flow and BOD design effluent concentration, the capital costs become fixed costs until further decisions are made to augment the treatment plant again. The additional capacity for the plant will not become available until two periods after the decision to upgrade the plant has been made.

### Proctor Input Program

The stream flow rate and water temperature are the most important physical parameters that affect the capacity of a stream to assimilate BOD effect. In this program, it is assumed that flow and water temperature vary in a predictable sequence over the course of an annual cycle. For control purposes, the year is divided into four periods, each exhibiting constant stream conditions. After the proctor chooses a season index (1 for spring, 2 for summer, 3 for fall and 4 for winter), the program will set the suitable flow rates and temperatures for each computational element automatically. The discharge loading at various points is read from participant decision datasets and used to define the point source conditions. Finally, this program will generate an input format for the QL2SMG program (See Figure 6). The proctor input program is given in Appendix G.




Figure 6. Proctor Input Program Flowchart

Cost Program

The purpose of the cost program is to calculate the capital costs (See Figure 7), operation costs, and total net income for each participant. Considerable effort was made to ensure the accuracy of the relationship included in the cost program. The Fortran program for cost calculations is given in Appendix E.




Figure 7. Cost Program Flowchart

Fixed Cost and Variable Cost. Wastewater treatment costs consist of both the capital cost incurred to construct the facility and operation and maintenance costs (O&M) associated with treating the waste stream. Capital cost would be expected to be related to design flow and performance, while O&M cost would be related to actual flow and performance. Design flow is used in the equation for capital cost and actual flow is used in the equation for O&M cost. Frass and Munley [35], based on statistical analysis, proposed the equations (2) and (3). C1 and C2 are used here to represent the cost adjustment factors for small-sized plants.

Fixed cost

$$= 78239 \times DQ^{0.89} \times BBOD^{0.24} \times DBOD^{-0.16} \times 0.25 + C1 \quad (\text{Eq. 2})$$

Variable cost

$$= 39244 \times AQ^{0.79} \times BBOD^{0.24} \times ABOD^{-0.07} \times 0.25 + C2 \quad (\text{Eq. 3})$$

Where AQ is actual flow (MGD)

DQ is design flow (MGD)

ABOD is actual effluent concentration (mg/l)

BBOD is actual influent concentration (mg/l)

DBOD is design BOD effluent concentration (mg/l)

C1 = \$16,714 (for plant 3), \$17,552 (for plant 4)

C2 = \$6,416 (for plant 3), \$1,445 (for plant 4).

User Charge. User charges are defined as those charges assessed against contributors to the treatment works for their proportional share of operation and maintenance costs. Considering constrained capacity and willingness to buy permits, dischargers decide whether to discharge pollutants to the municipal plant or not. If the discharged

BOD concentration exceeds 250 mg/l, the discharger must pay an additional charge for high-strength wastewater. Based on a statistical analysis Dyer et al. [36], proposed a formula to calculate user fees. For the purpose of this dissertation, this formula was modified because the formula establishes user charges on the basis of BOD, suspended solids, and phosphorous contents of the wastewater. BOD is assumed here to be the only criterion for measurement of water quality.

$$\text{User Charge} = (Q1 \times 0.106) + (Q2 \times 0.443 \times (\text{BOD} - 250)) \quad (\text{Eq. 4})$$

Where Q1 is the average annual discharge rate expressed in  
thousand liters/year

Q2 is the average annual discharge rate expressed in  
million liters/year.

Permit Price. The total permit cost is equal to the unit permit price multiplied by total permit numbers. Dischargers with an excess of TDP's would offer them for sale. If the team decides to sell permits, the total permit price will be deducted from the water quality related cost. Those with a deficiency would seek to purchase them. If the team decides to buy permits, the total permit price will be added to the water quality related cost.

Enforcement. The idea of computing uncertainty of penalty is based on probability. The cost program uses the pseudo-random number uniform distribution (RANF) to generate a random number between 0 and 1. If a team decides to release untreated wastewater without appropriate permits, the game program attempts to simulate reality by randomly deciding whether the team is caught by the inspector, assuming that there is a 60% probability of getting caught. Therefore, if the

outcome is less than 0.6, the team will be forced to pay a large amount in fines.

The fine for exceeding the allowable discharge or pollutant concentration should be greater than the price of an effluent permit in order to encourage the use of the effluent permit market to allocate discharges throughout a river basin. As the prices of permits rise, the incentive to discharge illegally grows; consequently, the penalty for non-compliance should increase.

Water Quality Related Cost. The water quality related cost is broken into five areas: (1) fixed cost, (2) variable cost, (3) user charge, (4) permit expense, and (5) penalty fine. Fixed cost reflects all construction cost for the treatment plant. The variable cost is all labor, material and supply costs necessary to operate the process after construction. All these costs must be estimated separately and added together to reflect total system costs.

## QL2SMG Water Quality Model Description

### Introduction

The model selected for this simulation game is an updated version of the stream quality model QUAL-II which was originally developed in 1973 by Water Resources Engineers, Inc. for the systems development branch of the U.S. Environmental Protection Agency. QUAL-II has been widely used and accepted across the country for the purposes of wasteload allocation and water quality management planning.

The updated version of QUAL-II that is used for this study is appropriately named QL2SMG, developed by the Southeast Michigan Council

of Governments (SEMCOG). Although several modifications and capabilities were added to the original program, the model package still retains the basic QUAL-II structure. The QL2SMG model will predict both the temporal and spatial quantities of the following water quality variables; temperature, conservative mineral, carbonaceous BOD, algae, phosphorus, nitrogen, dissolved oxygen, and coliform [37, 38].

QL2SMG can simulate either the steady-state or the psuedo dynamic response of a river system to a set of specified input conditions. Steady state is applied in this dissertation. QL2SMG is a finite difference solution of the one-dimensional advection-dispersion equation. In addition, the program has the capability of determining the stream flow required to maintain a preselected target dissolved oxygen level [39, 40].

### Theoretical Consideration

BOD, DO, and hydraulic conditions are major concern parameters in this dissertation. Each of these variables are discussed in the following section. Table II lists the usual range of numerical values for these variables. The rest of the parameters can be found in reference [41].



TABLE II  
INPUT PARAMETERS FOR QL2SMG

Name	Range of Values
D	3.0 - 100.0
K1	0.1 - 2.0
K2	-0.36 - 0.36
K3	0.0 - 10.0
K4	0.0 - 5.0
w1	1.4 - 1.8
w2	1.6 - 2.3
w3	3.0 - 4.0
w4	1.0 - 1.14
u	1.0 - 3.0
p	0.05 - 0.5
u1	0.1 - 0.5
u2	0.5 - 2.0
a	0.22 - 0.30
b	0.30 - 0.37
c	0.43 - 0.51
d	0.38 - 0.61

Advection-Dispersion Equation. The QL2SMG model numerically solves the advection-dispersion mass transport equation for each water quality constituent being modeled. This equation represents a

differential mass balance on the volume of each computational element in the system.

$$\begin{aligned} \frac{\partial C}{\partial t} &= \frac{\partial (D \frac{\partial C}{\partial X})}{\partial X} - \frac{\partial (UC)}{\partial X} + Z \end{aligned} \quad (\text{Eq. 5})$$

(1)            (2)            (3)    (4)

where: C = concentration (mg/l)

X = distance (L)

t = time (T)

U = average stream velocity (L/T)

Z = source or sink (mg/l/T)

D = dispersion coefficient (L x L/T)

The first term (1) represents the time rate of change of concentration, the second term (2) represents transport of mass by longitudinal dispersion, the third term (3) represents the advective component of mass transport, and the last term (4) is the sum of all sources and sinks of material. In a steady state simulation, the first term is omitted from the mass balance.

Hydraulics. QL2SMG assumes steady, gradually varied hydraulics. Steady hydraulics implies that the flow, velocity, width and depth at a given point in the stream are constant with time. Gradually varied flow allows these four factors to vary in the longitudinal direction, from element to element and from reach to reach. The flow in each computational element is calculated from a mass balance on the forcing functions applied to the element and inputs from upstream elements. Velocity can be found by  $V = aQ^b$ , and depth is calculated as  $D = cQ^d$ .

where: a = velocity coefficient

b = velocity exponent

c = depth coefficient

d = depth exponent.

Carbonaceous BOD. Carbonaceous BOD may be expressed as a three term equation. The general equation for BOD is:

$$L(T) = F - K_1 L - K_2 L \quad (\text{Eq. 6})$$

where: L(T) = ultimate BOD concentration at time t (mg/l)

F = input forcing function for carbonaceous BOD (mg/l)

K<sub>1</sub> = bio-oxidation coefficient for CBOD (1/day)

K<sub>2</sub> = coefficient for settling and scour effects

L = ultimate CBOD concentration in the computational element (mg/l).

Dissolved Oxygen. The reactive component of the source-sink term for dissolved oxygen is written for bio-oxidation of CBOD, reaeration, sediment oxygen demand, net oxygen production by algae, and oxidation of ammonia and nitrite. All of these factors are modeled as first order kinetics, except the SOD effect which is zero order.

$$dO/dt = F + K_3 (c^* - c) + (w_1 u - w_2 p) A - K_1 L - K_4/Ax - w_3 u_1 N_1 - w_4 u_2 N_2 \quad (\text{Eq. 7})$$

where: F = input forcing function for dissolved oxygen (mg/l)

c\* = saturation dissolved oxygen concentration (mg/l)  
(temperature dependent)

c = dissolved oxygen concentration (mg/l)

w<sub>1</sub> = ratio of oxygen production per unit of algae growth

w<sub>2</sub> = ratio of oxygen uptake per unit of algae respired

w<sub>3</sub> = ratio of oxygen uptake per unit of ammonia  
nitrogen oxidation

w4 = ratio of oxygen uptake per unit of nitrite  
nitrogen oxidation

k3 = reaeration rate (1/day) (temperature dependent)

k4 = rate coefficient for sediment oxygen demand

u = local specific growth rate of algae

p = local settling rate for algae

A = algae biomass concentration in the computational  
element

Ax = average cross sectional area of the computational  
element

u1 = rate of conversion of NH<sub>3</sub>-N to NO<sub>2</sub>-N (1/day)  
(temperature dependent)

u2 = rate of conversion of nitrite to nitrate (1/day)  
(temperature dependent)

N1 = ammonia nitrogen as N (mg/l)

N2 = nitrite nitrogen as N (mg/l).

### The Program

The computer program for the water quality model QL2SMG consists of a MAIN program and 23 subroutines. The MAIN program calls subroutine INDATA which reads and echo prints the input data. The main program then controls the sequence of subroutine calls for routing the desired water variables. It calls subroutines HYDRAU and TRIMAT to set up the hydrodynamic components of the mass balance. It then completes the balance by calling the constituent subroutine for the water quality variable being modeled. The resulting set of simultaneous equations is then solved in subroutine SOVMAT. If more than one water quality

variable is being simulated, the mass balance is re-established in the appropriate subroutine and solved. When all the water quality variables have been solved for each computational element, the program time counters are advanced to the next time step. In the steady state mode, the final solution is obtained on the first time step although a number of iterations may be required to balance the algae, nitrite, phosphorus, and temperature computations [42].

Input Option. In order to save time and effort, the input program can formulate QL2SMG package input data from an external file. One can specify the expected ambient temperature, flow conditions in the region and so on. All such environmental conditions can automatically be generated through this program if one specifies a season index for the quarter under consideration. The four sets of environmental conditions are built in, one for each season.

Input Requirements. Input information is provided to QL2SMG in groups called "data types". As a general rule, the different data types are input by reach, starting with the headwaters and proceeding downstream. All input data are read in by subroutine INDATA, with the exception of local climatology.

The descriptive titles of the data types are listed here, the detailed summary can be found in reference [43].

1. Program Titles.
2. Data Type 1; Program Control Data.
3. Data Type 1A; Algae Production and Nitrogen Oxidation Constants.
4. Data Type 2; Reach Identification and River Mile Data.

5. Data Type 3; Flow Augmentation Data.
6. Data Type 4; Computational Element Flag Field.
7. Data Type 5; Hydraulic Data for Determining Velocity and Depth.
8. Data Type 6; Reaction Coefficients for Deoxygenation and Reaeration.
9. Data Type 6A; Algae, Nitrogen, and Phosphorus Coefficients.
10. Data Type 6B; Other Coefficients (SOD, etc).
11. Data Type 7; Initial conditions.
12. Data Type 7A; Initial conditions (Algae and Coliform, etc.).
13. Data Type 8; Incremental Inflow.
14. Data Type 8A; Incremental Inflow (Algae and Coliform, etc).
15. Data Type 9; Stream Junction Data.
16. Data Type 10; Headwater Characteristics.
17. Data Type 10A; Headwater Characteristics (Algae and Coliform, etc.).
18. Data Type 11; Waste Inputs and Withdrawals.
19. Data Type 11A; Waste Inputs and Withdrawals (Algae and Coliform, etc.).
20. Local Climatological Data.

Output Information. The output from QL2SMG consists of three parts: an echo-printing of the input data (optional), intermediate summary (optional), and a final summary.

1. INPUT DATA - All input data (except local climatology) are echo printed by QL2SMG.
2. INTERMEDIATE SUMMARY - The intermediate summary is a brief

listing of computed values of the simulated water quality variables for each computational element in the basin. In the steady state mode it is printed after the steady state solution has converged.

3. FINAL SUMMARY - The final summary is a detailed listing of the results of the simulation and is printed in two parts. The first part contains location, flow and forcing function data as well as the final values of the simulated water quality variables for each computational element in the system. The second part contains river mile location, velocity, and depth data as well as the values of the reaction coefficients for each computational element in the system.

### Result Analysis

The reason for testing the TDP system is to see if it reduces water quality related cost without any adverse effects on the water quality. The measure of the true gain is when:  $X(po) > X(pe)$ . (Where  $X$  = mean value of a performance variable,  $X(po)$  are data taken at the post-test [TDP system] period, and  $X(pe)$  are data taken at the pre-test [non-TDP system] period.) If  $X(po)$  is greater than  $X(pe)$ , then statistical significance must be tested.

The successful statistical test requires rejecting a null hypothesis which states that the true mean of both populations are equal and accepting an alternative hypothesis which says that the true mean of these two populations is significantly different. To test the null hypothesis, some degree of desired significance is established and this factor determines the critical region between acceptance and rejection of the sampling distribution. For the paired comparison, there is a test presented by Wilcoxon to test whether a particular

sample came from a particular population. If the probability of significance is greater than 0.05, the null hypothesis is accepted but if it is less, then the null hypothesis is rejected. Rejecting the null hypothesis means accepting the alternative hypothesis.

The usual parametric counterpart to the Wilcoxon nonparametric test is the "paired t-test". If the sample size is less than 15, it is appropriate to use a Wilcoxon signed ranks test instead of the Student's t-test. The analyses in Chapter V are based on the Wilcoxon Ranks Test [44].



## CHAPTER IV

### APPLICATION

#### Game Operation

##### Computer Support of the Game

The players interface with the simulation when they input their data, after making their decisions based on engineering considerations and economic principles. The computer program is used to record these decisions and to analyze their effects. The overall game program consists of a number of computer programs, command procedures and datasets. Figure 8 presents a schematic of these programs and datasets.

Interactive Environment. The first of these two command procedures for interaction in the game is used by participants to enter their decisions. This command procedure (illustrated in Appendix D) arranges appropriate datasets, calls the participants input program, prompts the participants for decisions, allows corrections to be made, and records the decisions in two datasets. One dataset records the details of the decision for the current period's wastewater disposal, and the other dataset records the plant size available for two periods later, based on the upgrade decisions. Two periods are required to upgrade a plant.




Figure 8. Computer Support and Datasets for the Game Program

The second command procedure (Appendix C) is used by the proctor to enter his or her decision. This command procedure arranges participant decision datasets, calls the proctor input program, prompts the proctor for the season index, and records the output in a dataset. This dataset is prepared as input for the QL2SMG program. The command procedure then submits two batch jobs, one for the execution of the cost program and the other for the QL2SMG program. The program also writes all relevant information onto the current history file and appends it to the archival dataset for further Statistical Analysis

System (SAS) analysis. The whole process is, therefore, automated. The proctor just needs to log on the computer once a week and input the seasonal index.

The game is programmed in FORTRAN for the interactive mode and delivered to the user in load module form. Participants need not have any prior knowledge of computer programming. The QL2SMG program, developed by the EPA, is also written in standard FORTRAN.

Input by Participants. Participants access the program through a password protected identification using remote terminals. They submit their decisions for the period of play in response to the questions from the interactive program. This program is "user friendly", which means that during the input mode, the participants can correct input errors easily. Through job control language manipulation, the decision dataset is created under a specified name and stored in a partitioned dataset form. During each decision period, the dataset reads decision data from the appropriate participant. If participants want to substitute new datasets, each decision dataset can be updated easily without interrupting the sequencing for input to the main program.

Input by Game Proctor. After all the decisions have been made and the data entered into a computer dataset, the proctor can specify the expected ambient temperatures and flow conditions of the region. Such environmental conditions can automatically be generated through a computer program if the proctor indicates a season for the specified quarter. Thus, four sets of environmental conditions are built into the program, one for each season.

Game Program Calculation. When the game participants and the proctor have entered their information, a cost program simulates economic effects of the decisions. Each team gets a financial report that includes the result of their decisions, upgraded plant capacity and cost analysis of their decisions. In addition, reports for industrial firms include simplified income statements based on their production decisions and on fixed relationships between production, price, and cost variables. Table III illustrates a sample financial report.

TABLE III  
SAMPLE FINANCIAL REPORT

---

WATER QUALITY SIMULATION GAME

REGION : A  
GAME PERIOD : 6  
REPORT FOR TEAM : 3

DECISIONS FOR WATER QUALITY MANAGEMENT

CURRENT DESIGN CAPACITY : 0.050 MGD  
CURRENT DESIGN BOD EFFLUENT CONCENTRATION: 70.0 MG/L  
CURRENT MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE RIVER: 40.0 MG/L  
THIS IS INDUSTRIAL FIRM

PRODUCTION FORCAST : 1.250 MILLION POUNDS OF PRODUCT  
EXPECTED WASTEWATER FLOW RATE : 0.047 MGD  
EXPECTED BOD INFLUENT CONCENTRATION : 400.0 MG/L

THIS IS YOUR ALTERNATIVE

DISCHARGE WITH PERMIT  
DISCHARGED WASTEWATER FLOW RATE : 0.047 MGD  
DISCHARGED BOD EFFLUENT CONCENTRATION : 400.0 MG/L

WATER QUALITY-RELATED COSTS

QUARTERLY INVESTMENT AND FIXED OPERATING COSTS OF PLANT : 7081. DOLLARS  
OPERATION COSTS : 1604. DOLLARS  
INDUSTRIAL USER CHARGES : 0. DOLLARS  
NUMBER OF PERMITS BOUGHT : 147.00 FROM TEAM 6 TO TEAM 3  
UNIT PERMIT BUYING PRICE : 18. DOLLARS  
COST OF PERMITS : 2617. DOLLARS  
TOTAL CURRENT COSTS : 11301. DOLLARS

PROFIT & LOSS STATEMENT

TOTAL SALES REVENUE : 2250000. DOLLARS  
LABOR AND MATERIAL COSTS : 1350000. DOLLARS  
OTHER EXPENSES : 225000. DOLLARS  
TOTAL EXPENSES : 1586301. DOLLARS  
TOTAL TAXABLE INCOME : 663699. DOLLARS  
TAX ON CURRENT INCOME : 305302. DOLLARS  
NET EARNING : 358397. DOLLARS

---

A second component of the game program simulates the water quality of the whole region based on discharges at various points and on environmental conditions. The QL2SMG package serves this purpose [45].

#### Game Administration

A region represented by seven teams is simulated by the game. Two of these teams represent municipalities; the others are industrial firms. In this game, two participants represent one team and the entire section simulates one region.

The game was designed to be played in a Natural Resource Economics class, an elective taken by Economics, Business and Civil Engineering majors. The class normally meets on Mondays, Wednesdays, and Fridays for fifty minutes. After the proctor covers the topics relevant to water quality management, the game is introduced and the participants are handed descriptions of the firms they represent. By Friday of each week, their decisions must be entered into the computer. After all the decisions are entered, the proctor calls the appropriate command procedure to submit the jobs. The output containing cost reports and river water quality is then distributed back to participants, normally on Monday. After the participants receive the feedback regarding the accuracy of their predictions about the game consequences of their decisions, they keep these reports so that they can analyze their future strategies. Game participants understand that their decisions lead to predictable results, and they will try to follow a systematic process that will enable them to achieve optimal outcomes. When those outcomes are used in discussions between the participants and the proctor, to analyze the adequacy of past performance and to gain clues

for improving future performance, Fletcher [46] found that this improved participants' decision-making effectiveness in the game context.

The game session extended over a six-week period in the fall of 1985. The Natural Resource Economics class students only played the first four-period game which involved non-TDP cases. The remaining four periods were played by two professors and three graduate students. Each professor represented one industrial firm and one municipal plant, and each graduate student represented one industrial firm. The final result is based on these two different stages of decision-making.

#### Implementation of the TDP Market

A transferable Discharge Permit is not an effluent charge. Unlike the effluent charge, it does not purport to solve the problems of how much waste should be assimilated in water resources [47]. Rather, it assumes that some maximum loading has been selected and that the problem at hand is to find an efficient means for allocating that load among dischargers. Two major considerations in the allocating system are equity and efficiency. Some aspects of fairness are that each discharger should be allocated some share of the assimilative capacity of the stream, but that no discharger should have to bear an undue financial burden, and that dischargers do not make a sufficient effort to abate their pollution should not be entitled to a relatively larger share of TDP's than dischargers who do the cleanup. For the system to encourage efficiency, dischargers who can abate pollution relatively cheaply should do most of the required cleanup. TDP's provide a

mechanism for the exchange of pollution discharge units such that each discharger pays an equitable share of the costs of abatement, but only those dischargers who can abate pollution relatively cheaply are required to do the physical treatment.

The first step in establishing a TDP market is to allocate shares to the dischargers. The second step is to allow these permits to be transferred among dischargers. The quantity which can be bought and sold is fixed partly by the total loading and partly by the wastewater treatment requirements [48].

The foregoing suggest the following administrative framework for TDP's:

1. All point sources of wastewater would be required to hold TDP's equal to their permitted discharge. Table IV shows the initial holdings of permitted discharges for each discharger.

TABLE IV  
INITIAL DISTRIBUTION OF TDP'S

Team	Maximum Permitted Discharge		
	Flow (MGD)	BOD (mg/l)	Permit (Lbs-BOD/day)
1	1.70	30	424.0
2	0.38	24	76.0
3	0.03	40	10.0
4	0.04	20	6.66
5	2.00	20	333.6
6	15.0	45	5629.5
7	3.0	10	250.2

2. Dischargers with an excess of TDP's would offer them for sale. Those with a deficiency would seek to purchase them. Exchange of TDP's would reallocate waste load so as to minimize the cost of attaining the desired water quality.

3. The penalty for exceeding the permitted discharge would be a fine sufficiently large to make the payment for TDP's preferable to the payment of fines.

### Permit Durations

Permits can be issued with finite durations or in perpetuity. If permits are of short duration, the authority will presumably have more flexibility in altering the supply to adjust waster quality. Long-term permits, on the other hand, would allow dischargers to plan capital investment with less uncertainty and would allow improved cost efficiency in waste management.

### The Market Mechanism

TDP market solutions are simulated by using engineering estimates of waste treatment costs. Other costs, such as transaction costs or administrative costs, are not taken into account. It is assumed that waste production levels and waste reduction costs will remain constant and that dischargers will trade permits as long as cost savings are possible. Their bids will reflect their marginal abatement costs since the dischargers will minimize the sum of the cost of the permits and of their treatment costs.

The combined usage of the "zero revenue auction" and the "incentive-compatible auction" were utilized to build a TDP market. At



the beginning of each period, each participant would receive an initial allocation of free permits; an incentive-compatible auction would then be held. Incentive compatibility is defined as the property whereby the mechanism encourages truthful revelation of information by each participant. As long as bidder collusion may be ruled out, an individual discharger's dominant strategy in such an auction is to reveal (bid) the true value of his TDP's. This would result in an efficient allocation of aggregate discharge. (In contrast, procedures that are not incentive-compatible may not always be efficient because bids may reflect discharger's strategies rather than the true value of TDP's.) The incentive-compatible auction is a part of the general class of preference revelation mechanisms investigated by Vickrey [49] and Clarke [50]. When homogenous (i.e., identical) TDP's are being allocated, the mechanism operates as follows: Bidders submit binding bid schedules to the authority, which then allocates permits to the highest bidders, as in the single-price auction. Instead of paying a uniform price for permits, however, a discharger winning  $k$  permits would pay the  $k$  highest rejected bids of all dischargers except himself. So, for example, if a discharger wins two permits, he would pay the two highest rejected bids for permits submitted by other dischargers. This procedure encourages bidders to always pay different prices for rights, instead of the uniform price as in the single-price auction [51, 52].

The incentive-compatible approach has the advantage, however, that it does not encourage strategic behavior by individual participants even where there are small numbers of them. Thus, the procedure is always efficient, even when the bidders have dissimilar beliefs. Such

dissimilarities may be important in real-world applications. Different dischargers, for example, may be expected to have different demands for TDP's based on their observable size or output characteristics. This is the reason why the incentive-compatible auction was used rather than the single-price auction because the TDP demand curve is non-continuous.

The zero revenue auction has several attractive features. It is designed so that net revenue collection by the authority is zero. All the revenues from the auction are completely redistributed to the participants. Firms who reduce emissions relative to their initial allocations receive payments from firms who increase their emissions relative to their initial allocations. Thus, there is a net monetary transfer from polluters to abaters.

## CHAPTER V

### RESULTS AND DISCUSSIONS

#### Water Quality Analysis

One of the most important decisions the authority must make in designing any water quality management problem for a particular water body is to maintain the water quality standards. A water quality standard is assumed here to be expressed as the DO concentration and the BOD concentration. This research compares the water quality in a system with and without TDP's. A general hypothesis - water quality will deteriorate in the TDP system - was tested by using the Wilcoxon Ranks Test to consider performances of each team. For this evaluation the null hypothesis is defined as: there is no difference in water quality between the non-TDP system and TDP systems. Rank values can be calculated using the following relationship:

$$D = WQ(pe) - WQ(po)$$

Where D is difference

pe is pre-test (non-TDP case)

po is post-test (TDP case)

WQ is the water quality parameter

The results are analyzed at the location of all discharge points and at the sag point. Figure 4 indicates Teams 1 through 7 correspond to region elements 4, 8, 39, 18, 22, 14, and 30 respectively. The sag point is downstream element 45.

Table V presents general wastewater quality and quantity information for each team for the eight periods of play. Table VI and

TABLE V  
GENERAL WASTEWATER QUANTITY AND QUALITY  
PARAMETERS PRODUCTION WASTEWATER

Team	PERIOD							
	1	2	3	4	5	6	7	8
1 FLOW*	1.2	1.2	1.36	1.45	1.2	1.26	1.36	1.45
BOD**	200	200	200	200	200	200	200	200
2 FLOW	0.5	0.56	0.61	0.68	0.5	0.56	0.61	0.68
BOD	300	300	300	300	300	300	300	300
3 FLOW	0.04	0.05	0.06	0.06	0.04	0.05	0.06	0.06
BOD	400	400	400	400	400	400	400	400
4 FLOW	0.04	0.05	0.05	0.06	0.04	0.05	0.05	0.06
BOD	100	100	100	100	100	100	100	100
5 FLOW	2.00	2.04	2.08	2.12	2.00	2.04	2.08	2.12
BOD	400	400	400	400	400	400	400	400
6 FLOW	15.54	15.61	15.66	15.09	15.11	15.16	15.23	15.04
BOD	202.6	204.2	202.9	202.8	200.9	200.7	201.0	201.5
7 FLOW	5.04	5.08	5.13	5.18	3.0	3.04	3.08	3.12
BOD	171.3	220.2	139.7	141.7	200.0	202.4	205.1	207.6

\*Flow is measured in MGD

\*\*BOD is measured in mg/l

VII list the probabilities of significance and mean differences of DO concentrations and BOD concentrations for the eight system elements. Table VIII and IX list the stream quality parameters for periods 2 and 6 respectively.

TABLE VI  
WILCOXON RANKS TEST RESULT IN  
DO CONCENTRATIONS (mg/l) AND  
PROBABILITY OF SIGNIFICANCE

System# Element	*Mean of Non-TDP System	**Mean of TDP System	Difference	Probability of Significance
4 (Team 1)	8.00	7.98	0.02	0.77
8 (Team 2)	7.97	7.78	0.19	0.56
14 (Team 6)	6.61	6.60	0.01	1.00
18 (Team 4)	8.75	8.72	0.03	0.56
22 (Team 5)	8.67	7.64	1.03	0.24
30 (Team 7)	7.93	7.81	0.12	0.66
39 (Team 3)	6.76	6.77	-0.01	0.88
45 (Sag Point)	6.68	6.67	0.01	0.77

\*Non-TDP system, periods 1, 2, 3, and 4.

\*\*TDP system, periods 5, 6, 7, and 8.

#See Figure 4

TABLE VII

WILCOXON RANKS TEST RESULT IN  
BOD CONCENTRATIONS (mg/l) AND  
PROBABILITY OF SIGNIFICANCE

System# Element	*Mean of Non-TDP System	**Mean of TDP System	Difference	Probability of Significance
4 (Team 1)	18.82	19.69	-0.87	0.04
8 (Team 2)	16.96	17.84	-0.88	0.14
14 (Team 6)	26.69	24.81	1.88	0.08
18 (Team 4)	18.25	18.60	-0.35	0.24
22 (Team 5)	18.64	21.60	-2.96	0.02
30 (Team 7)	13.94	15.71	-1.77	0.04
39 (Team 3)	17.46	17.48	-0.02	1.00
45 (Sag Point)	15.20	15.22	-0.02	1.00

\*Non-TDP system, periods 1, 2, 3, and 4.

\*\*TDP system, periods 5, 6, 7, and 8.

#See Figure 4

TABLE VIII  
 STREAM QUALITY PARAMETERS FOR PERIOD 2

System# Element	Point Source		Stream Condition		
	Flow (MGD)	BOD (mg/l)	Flow (MGD)	DO (mg/l)	BOD (mg/l)
4 (Team 1)	1.26	30	17.86	6.64	18.13
8 (Team 2)	0.	0.	18.32	6.22	15.52
12	0.	0.	19.20	6.07	13.24
13	0.	0.	19.20	6.06	12.72
14 (Team 6)	15.61	45	34.81	5.32	26.51
18 (Team 4)	0.	0.	8.70	7.77	17.97
22 (Team 5)	0.	0.	10.31	7.63	18.20
30 (Team 7)	5.09	10	26.80	6.41	12.77
39 (Team 3)	0.	0.	64.12	4.77	15.72
45 (Sag Point)	0.	0.	65.49	4.70	12.83

#See Figure 4

TABLE IX  
 STREAM QUALITY PARAMETERS FOR PERIOD 6

System# Element	Point Source		Stream Condition		
	Flow (MGD)	BOD (mg/l)	Flow (MGD)	DO (mg/l)	BOD (mg/l)
4 (Team 1)	1.26	*46	17.86	6.61	19.24
8 (Team 2)	0.45	24	18.78	6.01	16.62
12	0.	0.	19.70	5.91	14.17
13	0.	0.	19.70	5.91	13.61
14 (Team 6)	15.11	40	34.81	5.30	24.43
18 (Team 4)	0.05	100	8.93	7.73	18.38
22 (Team 5)	2.0	40	12.37	6.61	21.61
30 (Team 7)	3.04	10	26.80	6.19	14.62
39 (Team 3)	0.05	400	64.12	4.77	15.70
45 (Sag Point)	0.	0.	65.49	4.70	12.81

\*Treated wastewater flow rate is 1.08 MGD, BOD concentration is 20 mg/l.

Discharged waste flow rate is 0.18 MGD, BOD concentration is 200 mg/l.

Total wastewater flow is 1.26 MGD, Average BOD concentration is 46 mg/l.

#See Figure 4



## Water Cost Analysis

The relationship between effluent treatment cost and level of treatment achieved represents an essential element in evaluation of water quality pollution control policies. The objective of the wastewater treatment plant manager is to determine the minimum cost combination of treatment levels that meets a certain stream quality standard. Therefore, a purpose of this game is to see if it is possible to lower the financial burden on industrial firms and municipal plants without an adverse impact on the water quality standards.

This game uses the SAS package NPAR1WAY procedure to analyze TDP's impact on water quality related costs. The differences of the water quality related costs form a symmetric distribution. Therefore, Wilcoxon Ranks Test for significance can be utilized to measure and evaluate the differences between the water quality related costs under the TDP and non-TDP systems. The analysis is then performed on the average difference as a single sample observation. The samples are divided into groupings that represent each team and all teams (the whole region).

Table X indicates the water quality related cost for each team, Table XI presents the difference in water quality related costs for the paired comparisons, Table XII presents the Wilcoxon Ranks Test results, Table XIII presents the variable costs, Table XIV lists user charges for each team, and Table XV lists the transaction record for permits.

Based on the results shown in the tables, the following discussions are made:

TABLE X  
WATER QUALITY RELATED COSTS (\$)

Team	PERIOD							
	1	2	3	4	5	6	7	8
1	93818	95070	97067	99067	92307	93149	96517	98306
2	53606	47417	57493	62574	41632	44185	46310	49541
3	11067	11484	12080	12437	10887	11301	11889	12248
4	8756	9013	9086	9342	8333	8579	8626	8879
5	209876	208586	217673	220115	154419	156689	159131	161573
6	669018	664570	664473	662579	661786	662302	660634	658498
7	243885	253037	239783	238163	290995	289690	288955	287498

TABLE XI  
DIFFERENCE IN WATER QUALITY RELATED  
COSTS FOR PAIRED COMPARISONS (\$)

Team	Pairs				AVERAGE
	WC (1)- WC (5)	WC (2)- WC (6)	WC (3)- WC (7)	WC (4)- WC (8)	
1	1511	1921	550	739	1178
2	11974	3232	11183	13033	9855
3	180	183	191	189	186
4	423	434	460	463	445
5	55457	51897	58542	58542	56109
6	7232	2268	3839	4081	4355
7	-47110	-36653	-49172	-49335	-45567

TABLE XII  
 WILCOXON RANKS TEST RESULT IN WATER QUALITY  
 COSTS (\$) AND PROBABILITY OF SIGNIFICANCE

System Team	*Mean of Non-TDP System	**Mean of TDP System	Difference	Probability of Significance
1	96247	95069	1178	0.38
2	55272	45417	9855	0.04
3	11767	11581	186	0.56
4	9049	8604	445	0.04
5	214062	157953	56109	0.02
6	665160	660805	4355	0.02
7	243717	289284	-45567	0.02

\*Non-TDP System for periods 1, 2, 3, and 4.

\*\*TDP System for periods 5, 6, 7, and 8.

TABLE XIII  
 VARIABLE COSTS (\$)

Team	Period							
	1	2	3	4	5	6	7	8
1	31850	33102	35099	37067	25647	30040	34549	37033
2	11434	0	10247	12862	16430	16430	16430	16430
3	1604	1604	1604	1604	1604	1604	1604	1604
4	361	361	361	361	361	361	361	361
5	47629	48547	55192	55192	55127	55192	55192	55192
6	234872	236085	236414	237342	230902	231079	231746	232759
7	102926	110126	99387	100466	70939	71838	72828	73813

TABLE XIV  
USER CHARGES (\$)

Team	Period							
	1	2	3	4	5	6	7	8
1	0	0	0	0	0	0	0	0
2	19453	24697	24527	26993	2213	4780	6905	10136
3	2382	2799	3395	3752	2382	0	0	0
4	1464	1721	1794	2050	0	0	0	0
5	77632	75425	77867	80309	0	2204	4646	7088
6	(21835)	(27497)	(27992)	(30745)	(4595)	(4780)	(6705)	(10136)
7	(79097)	(77145)	(79660)	(82359)	0	(2204)	(4646)	(7088)

\*The numbers in parentheses indicate the revenue from user charges

TABLE XV  
PERMIT TRANSACTION RECORD

Period Team	Number of Permits				Permit Costs (\$)			
	5	6	7	8	5	6	7	8
1	260.7	64.2	0	*(39.1)	4693	1141	0	** (695)
2	14.2	14.2	14.2	14.2	270	256	256	256
3	*(10.0)	147.0	180.0	200.2	** (180)	2617	3204	3564
4	26.7	33	34.2	40.7	1041	1287	1334	1587
5	333.6	333.6	333.6	333.6	14678	14678	14678	14678
6	(625.5)	(592.0)	(570.34)	(558)	(20502)	(19979)	(20189)	(20107)
7	0	0	8.34	8.34	0	0	717	717

\*Parentheses indicate selling of permits.

\*\*Parentheses indicate revenue from selling permits.

## Team 1

The bidding permit price is lower for Team 1 than for other teams (details are given in Appendix I). Therefore, during periods 5 and 6, Team 1 can only buy the remaining available permits from the TDP market and can only discharge a portion of their wastewater to the river. Team 1's design BOD capacity is 20 mg/l and permitted BOD discharge concentration is 30 mg/l (Table I). Even though this team improves its treatment level of BOD to 20 mg/l in periods 5 and 6, the discharged waste flow to the river is increased with a BOD concentration of 200 mg/l (Table XVI). Therefore, the BOD loading to the river for periods

TABLE XVI  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 1

Period	Alt.	Treated Waste		Discharged Waste	
		Flow (MGD)	BOD (mg/l)	Flow (MGD)	BOD (mg/l)
1	1	1.2	30	0	0
2	1	1.26	30	0	0
3	1	1.36	30	0	0
4	1	1.45	30	0	0
5	7	0.88	20	0.32	200
6	7	1.08	20	0.18	200
7	1	1.36	37.6	0	0
8	1	1.45	30.4	0	0

5 and 6 is larger than that of the counterpart periods 1 and 2. In periods 7 and 8, as illustrated by the characteristics of the TDP system, the discharged BOD concentration can be slightly reduced. Therefore, the average BOD concentration under the TDP system is larger than that under the non-TDP system by 0.87 mg/l (Table VII), and the increased BOD loading results in decreasing DO concentration by 0.02 mg/l (Table VI).

The variable cost is a reflection of the treatment level, during periods 5 and 6, even though Team 1 uses its extra treatment capacity of 10 mg/l to lower its BOD effluent concentration to 20 mg/l, but since the treated wastewater flow is reduced (Table XVI), the variable cost for periods 5 and 6 is still less than that of the corresponding periods 1 and 2 (Table XIII), and the permit expense can not offset the variable cost saving. Therefore, the water quality related cost is reduced at periods 5 and 6 (Table XI). In period 7, since there are only a few remaining permits available in the TDP market, this team does not want to trade any permits. In period 7, the BOD effluent concentration is required to be 37.6 mg/l (calculation is given on page 29) to meet the discharge regulation. However, in period 3, in order to meet the water quality standard, the BOD effluent concentration has to be treated to 30 mg/l (Table XVI). The water quality related cost savings for paired period 7 is \$550, which means the free initial permit value is worth \$550 (Table XI). In period 8, since the unit treatment cost is lower than the permit market-clearing price for this team, it is a profitable option to sell permits. The policy for deciding the best strategy under the TDP system is given in Appendix B.

## Team 2

Discharge point 2 is not far from discharge point 1, and the ratio of discharge flow is approximately 2% of the river flow near this point. Therefore, the stream water quality is slightly affected by this point source.

During periods 1, 2, 3, and 4, Team 2 allocates its pollution loading to municipal plant 6 by paying the user charge. During periods 5, 6, 7, and 8, the permit bid price for this team is higher than most teams in the TDP market (Appendix I), which means that this team can buy permits from the market and adjust to full capacity to obtain lower unit treatment costs. For this team, the trade-off is between difference of the variable cost, the user charge, and the permit expense. For instance, in period 7, the generated wastewater flowrate is 0.61 MGD (Table XVII). The initial permit holding is 76 (Table IV). If this team wants to send all its wastewater to the municipal plant, it needs to pay a \$26,822 user charge. But, if this team wants to choose alternative 4, it needs to buy 14.2 permits to adjust its permit discharge capacity from 0.38 MGD to its full plant capacity 0.45 MGD (Table I) and pay \$6,905 (Table XIV) in user charges and \$16,430 (Table XIII) in variable costs. From these data, the permit price is \$38.67 and can be calculated using the following relationship:

$$\text{Permit price} = (\text{difference in user charge} + \text{difference in variable cost}) / \text{number of permits}$$

During periods 2, Team 2 chooses alternative 3 without paying the variable cost (Table XIII). During periods 1, 3, and 4, this team chooses alternative 5 by paying both the variable costs and user

TABLE XVII  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 2

Period	Alt.	Treated Waste		Send Waste to Municipal Plant	
		Flow (MGD)	BOD (mg/l)	Flow (MGD)	BOD (mg/l)
1	5	0	0	0.35	250
				0.15	300
2	3	0	0	0.56	300
3	5	0	0	0.3	210
				0.31	300
4	5	0	0	0.40	210
				0.28	300
5	4	0.45	24	0.05	300
6	4	0.45	24	0.11	300
7	4	0.45	24	0.16	300
8	4	0.45	24	0.23	300

charges (Table XIII, Table XIV). However, the difference in variable cost is much larger than that of the user charges. Therefore, this team does not choose the less expensive treatment alternatives during periods 1, 3, and 4. This can be illustrated by the significant reduction in the water quality related costs (Table XI) for the paired periods 2 and 6, compared to the remainder of paired periods. The average difference of water quality related cost savings for this team



is \$9,855, and the probability of significance is less than 0.05 (Table XII). Obviously, this team is benefiting from the TDP system.

### Team 3

The discharge at this point is less than 1% of the local river flow. Therefore, the stream water quality is slightly affected by this point source. Treated wastewater quantity and quality for Team 3 is shown in Table XVIII.

TABLE XVIII  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 3

Period	Alt.	Send Waste to Municipal Plant		Discharge Waste to the River	
		Flow (MGD)	BOD (mg/l)	Flow (MGD)	BOD (mg/l)
1	3	0.04	400	0	0
2	3	0.05	400	0	0
3	3	0.06	400	0	0
4	3	0.06	400	0	0
5	3	0.04	400	0	0
6	8	0	0	0.05	400
7	8	0	0	0.06	400
8	8	0	0	0.06	400

Team 3 represents a small plant, and generally a small plant is less efficient in treating wastewater. Therefore, under the non-TDP system, Team 3 always chooses alternative 3, "send all wastewater to the municipal plant" under the non-TDP system. In period 5, the bidding permit price for this team is the second lowest in the TDP market (Appendix I). So this team sells 10 free initial permits (Table XV) to Team 1 and chooses alternative 3. The revenue for selling the permits is \$180 (Table XI). Again, this means that the free initial permits are worth \$180. The trade-off for this team is between the permit expense and the user charge. For periods 6, 7, and 8, the permit expense (Table XV) is less than the user charge of corresponding periods 2, 3 and 4 (Table XIV). Therefore, this team always chooses alternative 8, "discharge wastewater after buying permits".

#### Team 4

Team 4 is a small plant, and the unit treatment cost is higher than the user charge and the permit expense. Therefore, under the non-TDP system, this team always chooses alternative 3, "send all wastewater to the municipal plant 7" (Table XIX). Under the TDP system, this team always buys permits and chooses alternative 8, "discharge wastewater after buying permits".

The result of these alternatives is that under the TDP system, the BOD loading to the river increases at this point, however, the discharge from this point is very small, and the amount of impact on the water quality is not significant. The water quality related cost savings for this team comes from the difference between the user charge and the permit expense. The average cost savings is \$445, and the

TABLE XIX  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 4

Period	Alt.	Send Waste to Municipal Plant		Discharge Waste to the River	
		Flow (MGD)	BOD (mg/l)	Flow (MGD)	BOD (mg/l)
1	3	0.04	100	0	0
2	3	0.05	100	0	0
3	3	0.05	100	0	0
4	3	0.06	100	0	0
5	8	0	0	0.04	100
6	8	0	0	0.05	100
7	8	0	0	0.05	100
8	8	0	0	0.06	100

probability of significance is 0.04 (Table XII), which means that the null hypothesis of two systems being equal is rejected.

#### Team 5

Team 5 is a large plant, and the unit treatment cost is lower compared to that of other plants. The design BOD effluent concentration is 40 mg/l and the maximum permitted discharge BOD concentration is 20 mg/l, which means that this team can not choose alternative 1 "treat wastewater in the company plant and release to the river", unless they upgrade the plant. Therefore, under the non-TDP system,

this team allocates its wasteload to municipal plant 7. Under the TDP system, Team 5 buys 333.6 additional permits (Table XV), adjusts the permitted BOD effluent concentration to 20 mg/l, and chooses inexpensive treatment option 1 or 4 to treat its wastewater in its own plant (Table XX). Therefore, the BOD loading from this point discharge to the river is increased. According to the Wilcoxon Ranks Test, the probability of significance is approximately 0.02 (Table VII), which means the increased BOD loading is significant. The lower DO profile

TABLE XX  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 5

Period	Alt.	Treated Waste		Send Waste to Municipal Plant	
		Flow (MGD)	BOD (mg/l)	Flow (MGD)	BOD (mg/l)
1	5	0	0	1.8	100
				0.2	400
2	5	0	0	2.0	250
				0.04	400
3	5	0	0	2.0	40
				0.08	400
4	5	0	0	2.0	40
				0.12	400
5	1	2.0	40	0	0
6	4	2.0	40	0.04	400
7	4	2.0	40	0.08	400
8	4	2.0	40	0.12	400

downstream of this point is a consequence of a higher BOD loading under the TDP system. The mean differences for the DO concentration is 1.03 mg/l (Table VI) and for the BOD concentration is -2.96 mg/l (Table VII). Table XI indicates the average water quality related cost saving is \$56,109 for this team. Certainly this team benefits from using the TDP system.

#### Team 6

The structure of this game is to let the industrial firms discharge the wastewater to the municipal plant by paying the user charge. The major concern of the municipal plant managers is to bring the influent wastewater to the quality standard of the river authority. Under the non-TDP system, for the municipal plant, even though this plant has extra treatment capacity (the BOD permitted discharge concentration is 45 mg/l, and the design BOD effluent concentration is 40 mg/l), there is no strong incentive for reducing the BOD effluent concentration to 40 mg/l (Table XXI). Industrial firms under the non-TDP system are not allowed to buy permits and the only remaining feasible option is to send excess wastewater to the municipal plant, as illustrated in Table XXII, Team 2 and Team 3 allocate their wasteloads to this plant under the non-TDP system, this creates uncertainty about influent wastewater and the possibility of degrading water quality.

The purpose of TDP's is to facilitate exchange among treatment plants by compensating those who undertake a higher level of treatment in favor of those who don't. Under the TDP system, plant 6, by engaging in such treatment, receives revenue from selling permits and reduces the BOD effluent concentration to 40 mg/l (Table XXI).

TABLE XXI  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 6

Period	Treated Waste	
	Flow (MGD)	BOD (mg/l)
1	15.54	45
2	15.61	45
3	15.67	45
4	15.74	45
5	15.09	40
6	15.11	40
7	15.16	40
8	15.23	40

TABLE XXII  
INFLUENT FLOWRATE (MGD) FOR  
MUNICIPAL PLANTS

Team	Period							
	1	2	3	4	5	6	7	8
2	0.50	0.56	0.61	0.68	0.05	0.11	0.16	0.23
3	0.04	0.05	0.06	0.06	0.04	0.04	0.	0.
6	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0
Total for 6	15.54	15.61	15.67	15.74	15.09	15.11	15.16	15.23
4	0.04	0.05	0.05	0.06	0.	0.	0.	0.
5	2.00	2.04	2.08	2.12	0.	0.04	0.08	0.12
7	3	3	3	3	3	3	3	3
Total for 7	5.04	5.09	5.13	5.18	3	3.04	3.08	3.12

These phenomena reflect in the cost analysis: Under the non-TDP system, the major income is user fees (Table XIV). Under the TDP system, the major revenue is from selling permits (Table XV). For Team 6, the average water quality related cost savings is \$4,355 which is approximately 0.7% of the total water quality related cost (Table XXIV).

#### Team 7

Under the TDP system, plant 7 receives a relatively small amount of wastewater from plants 4 and 5 (Table XXIII). Under the non-TDP system, plant 7 receives a relatively large amount of wastewater from plants 4 and 5, causing the increased discharge from this point to the river (Table XXIII). However, the BOD effluent concentration from this point source is 10 mg/l, which is lower than that of the point source

TABLE XXIII  
TREATED WASTEWATER QUANTITY AND  
QUALITY FOR TEAM 7

Period	Treated Waste	
	Flow (MGD)	BOD (mg/l)
1	5.04	10
2	5.09	10
3	5.13	10
4	5.18	10
5	3.00	10
6	3.04	10
7	3.08	10
8	3.12	10

of Team 4 (Table XIX) and Team 5 (Table XX). Plant 7 is located downstream from the discharge points of plant 4 and plant 5. The aggregated discharge from plant 4, plant 5, and plant 7 are equal at this point. Therefore, the increased discharge from this point results in a decreased BOD concentration in the river under the non-TDP system. The general rule is that the lower the BOD concentration, the higher the DO concentration. Considering these two systems, under the non-TDP system, the larger discharge from this point results in a lower BOD concentration and a higher DO concentration. These phenomena reflect in the water quality analysis: In period 2 (non-TDP system) the stream DO concentration is 6.41 mg/l and BOD concentration is 12.77 mg/l (Table VIII). In period 6 (TDP system), the stream DO concentration is 6.19 mg/l and BOD concentration is 14.62 mg/l (Table IX). The mean differences for the DO concentration and BOD concentration of these two systems are 0.12 mg/l (Table VI) and -1.77 mg/l (Table VII) respectively.

During periods 1, 2, 3, and 4, the influent wastewater from plants 4 and 5 is approximately 40% of the influent residential wastewater to plant 7. During periods 5, 6, 7, and 8, the influent wastewater from plants 4 and 5 is approximately 2% of the influent residential wastewater to this plant (Table XXII). These effects reflect in the cost analysis report: Under the non-TDP system, the average user charge is \$79,000, but in the TDP system the average user charge drops to \$4,000 (Table XIV), which means the uncertainty of influent wastewater quality and quantity can be minimized.

Team 7 does not have extra treatment capacity for incoming industrial wastewater. (The permitted discharge BOD concentration is 10 mg/l, and design BOD effluent concentration is 10 mg/l). In order



to meet the water quality, this team needs to buy additional permits for an external wasteload (Table XV). Under the non-TDP system, the water quality related cost is subsidized by the user fees. But under the TDP system, this team only receives a small amount from the user fees and the drop in the user fees is greater than the drop in the variable costs (Table XIII). Even though this team has extra flow capacity (the permitted discharge capacity is 3.0 MGD, and design flow capacity is 5.5 MGD), it can not use its extra flow capacity, since the TDP's are distributed on the basis of permitted standards. Therefore, Team 7 is the only team losing under the TDP system (Table XI).

#### Sag Point

In this simulation game, the critical DO point occurs at element 45 (Figure 4). For the DO concentration, the average concentration is 6.68 mg/l before the TDP scheme. After implementing the TDP system, the average concentration is 6.67 mg/l. the probability of significance in this case is approximately 0.77 (Table VI); the null hypothesis can be accepted, and there is no significant difference between these two systems.

#### Water Quality Impact for the Whole Region

When the Wilcoxon Ranks Test is analyzed in terms of the BOD concentration, only seven elements (elements 22, 23, 24, 25, 26, 27, and 30) show less than 0.05 significant probabilities. In terms of DO concentration, there is no significant effect on these elements. The conclusion is that the null hypothesis is accepted and the environmental impact of discharge is identical before and after the TDP system.

### Cost Efficiency for the Whole Region

The cost efficiency of a particular program is measured by the aggregate economic cost of achieving the water quality standard. Only the costs of real resources are considered in calculating the aggregate cost. The payments for discharge should not be included because these payments are transferred between parties.

Table XXIV lists the water quality related cost savings for each team. The total cost savings for all the teams is \$26,561 per quarter and approximately \$106,000 per year. Table XII, the Wilcoxon Ranks Test results, shows the probability of significance for Teams 2, 4, 5, and 6 is less than 0.05, i.e., four out of seven teams benefit from the TDP system.

TABLE XXIV  
WATER QUALITY RELATED COST SAVING (\$)

System Team	*Mean of Non-TDP System	**Mean of TDP System	Difference	Ratio
1	96,247	95,069	1,178	1.2%
2	55,272	45,417	9,855	17.8%
3	11,767	11,581	186	1.5%
4	9,049	8,604	445	4.9%
5	214,062	157,953	56,109	26.2%
6	665,160	660,805	4,355	0.7%
7	243,717	289,284	-45,567	-18.7%
Total Cost Saving			26,561	

\*Non-TDP system, periods 1, 2, 3, and 4.

\*\*TDP system, periods 5, 6, 7, and 8.

## CHAPTER VI

### CONCLUSIONS AND RECOMMENDATIONS

#### Conclusions

The analyzed results indicate that the TDP system is cost efficient. Using the TDP system would result in a total annual savings of approximately \$106,000. The average DO concentration at the sag point however, is decreased slightly. Transferable permits are important because the total costs of attaining water quality standards are lower with transfers.

After implementing the TDP system, the whole region will have water quality related cost savings without an adverse effect on water quality. Also, four teams benefit from the TDP system, and the reasons can be attributed to: (1) Incentive-compatible auctions, (2) Plants have different alternatives for controlling effluent, and (3) Free initial distribution of permits.

Team 7 is the only team that bears an undue financial burden under the TDP system. For this team, the design capacity is 5.5 MGD, but the permitted discharge capacity is 3.0 MGD (Table I). Since the TDP's are distributed on the basis of permitted standards, this team can not use its extra capacity in terms of flow. A reasonable approach to the permit distribution should be considered in terms of both the permitted standards and design capacity.

Transferable discharge permits would result in higher actual (in contrasted to permitted) wasteloads. Dischargers who, for example, expand their production and find their waste treatment capacity inadequate can acquire permission to discharge from those with excess treatment capacity. With such offsets, water quality standards continue to be met, but the level of actual discharge to the watercourse is closer to the water quality limits.

BOD is an important representative of the category of water pollutants that degrade once discharged. In such cases the location of discharges affects water quality (dissolved oxygen in the BOD case) at a given location. Also, because physical parameters typically vary throughout a watercourse, a change in the location of a discharge usually not only shifts the location of impact, but it also affects the degree of impact. But in this dissertation, the transfer coefficient for each permit is the same for allowing one-to-one trades of permits, however the effect of discharges on water quality is different for different discharge locations. Therefore, it is better to formulate the effluent permits by impact coefficients. If the goal is to achieve a given level of dissolved oxygen concentration, the impact coefficients can be generated by simulating a series of DO levels associated with increased individual effluent loadings and calculating the changes in the DO at the sag points. Sensitivity analysis may confirm the accuracy of using linear approximations to define the effluent/water quality relationship at different combinations of stream flow and stream temperature. In this way, the number of permits issued by an authority would depend on the desired water quality. To account for the differential impact of different pollutants on the water quality,

permits will be worth different amounts to different polluters.

Time variability in the assimilative capabilities of the environment and in demands for the waste disposal services of the environment have long posed problems for pollution control systems. Streamflows vary and atmospheric conditions change over both long and short periods, requiring variations in TDP's if water quality standards are not to be violated. This research does not deal with this problem and assumes the river flow is constant for the entire period. To avoid violating real-world facts, a "priority rights" system for allocating available assimilative capacity should be established. In the case of surface water, the functioning of a priority system depends on the probability distribution of streamflows: More senior rights have a higher probability of getting their streamflow to assimilate waste than do more junior rights.

To help ensure the continued maintenance of water quality, market restrictions may be added to prevent or discourage transfers of permits that would cause violations. Since water quality problems depend in part on local physical features, the type of trading restrictions chosen by policymakers would be expected to vary from one water body to another. One way to restrict transfers is to define permits so that they can be exercised in only a certain zone in a waterway. This mechanism can allow equal opportunities for dischargers within a given zone to purchase BOD permits (This research assumes seven teams are located within one zone). Between-zone inequities could still be perceived, however, depending on the characteristics of the dischargers and of the physical river system under study.

## Recommendations

Future research work should be continued in the TDP system in several areas:

1. Transferable discharge permits should be formulated by impact coefficients. The nature of the impact is modified by - temperature and flow - which affect the assimilative capacity of the stream.

2. Transferable discharge permit distribution should be considered in terms of both the permitted standards and discharge capacity.

3. Priority rights can increase the adaptability of the TDP system to short-term fluctuations in the assimilative capacity of the environment. They should be combined with the TDP system.

4. The definition base of permits should not be restricted by only BOD and DO. Nitrogen, phosphate, and heavy metals seem to be candidates for the basis of definition of permits.

5. Unrestricted transfers of BOD permits could cause violations of the water quality standard. Restricting transfers of permits to geographical zones could be used to reduce or possibly prevent violations of a standard.

#### LITERATURE CITED

1. David, M. H., Eheart, J. W., Joeres, E. F., and David, E. L., "Market Permits for the Control of Phosphorous Effluent into Lake Michigan." Water Resources Research 16, (1980), pp. 263-370.
2. Eheart, J. W., Joeres, E. F., and David, M. H. "Distribution Methods for Transferable Discharge Permits." Water Resources Research 16, (1980), pp. 833-843.
3. Atkinson, S. E., and Tietenberg, T. H. "The Empirical Properties of Two Classes of Designs for Transferable Discharge Permit Markets." Journal of Environmental Economics and Management, 9, (1982), pp. 101-121.
4. Noll, R. G. "Implementing Marketable Emissions Permit." American Economic Review, 72, 2 (1982), pp. 120-124.
5. Tietenberg, T. H. "Transferable Discharge Permits and the Control of Stationary-Source Air Pollution: A Survey and Synthesis." Land Economics, 6, (1980), pp. 313-317.
6. United States Environmental Protection Agency Emission Reduction Banking and Trading Project: Annotated Bibliography, 5th edition. USEPA Office of Planning and Evaluation, Washington, D.C., 1980.
7. Brill, E. D., Eheart, J. W., Kshirsagar, S. R., and Lence, B. J. "Water Quality Impacts of Biochemical Oxygen Demand Under Transferable Discharge Permit Programs." Water Resources Research, 20, (1984), pp. 445-455.
8. David, M. H., and David, E. L. "Cost-Effective Regulatory Options for Water Quality Limited Stream." Water Resources Research, 19, (1983), pp. 421-428.
9. Eheart, J. W. "Cost Efficiency of Transferable Discharge Permits for the Control of BOD Discharge." Water Resources Research, 16, (1980), pp. 980-986.
10. Brill, E. D., Revelle, C. S., and Liebman, J. C. "Alternative Effluent Charge Functions: Costs, Financial Burden and Punitive Effects." Water Resources Research, 15, (1979), pp. 993-1000.

11. Tietenberg, T. H. Environmental and Natural Resource Economics, Glenview, Illinois, Scott, Foresman and Company, 1984.
12. Braasch, D. E., and Joeres, E. F. Analysis of the Lake Michigan Phosphorous Removal Policy in Wisconsin, Sea Grant Technical Report WISSQ-75 224, University of Wisconsin, Madison 1975.
13. deLucia, R. J. An Evaluation of Marketable Effluent Permit Systems, USEPA (600/5-74-030), Socioeconomic Environmental Studies Series, U.S. Govt. Printing Office, Washington, D.C., 1974.
14. Joeres, E. F., and David, M. H. Buying a Better Environment, U.S. Land Economics, Monograph No. 6. Madison, Wisconsin, 1982.
15. Wood, C. J. Handbook of Geographical Games, Western Geographical Series, 7, University of Victoria, B.C., 1973.
16. Gentry, J. W., Tice, T. F., Robertson, C. W., and Gentry, M. J. "Simulation Gaming as a Means of Researching Substantive Issues: Another Look." Working paper No. 83-9, College of Business Administration, Oklahoma State University, 1983.
17. Maidment, Robert, and Bronstein, R. H. Simulation Games Design and Implementation, Columbus, Ohio: Bell & Howell Company, 1973, pp. 9-15.
18. Wright, G. L., and Howell, D. T. "Application of Gaming Simulation to Water Resources Planning." Hydrology Symposium, Papers, 1975, pp. 211-214, Armidale Australia, 1975.
19. Johnson, J. M., Whitehead, M. H., and Johnson, G. P. "Enhancing Water Resource Planning Effectiveness: A Simulation Gaming Approach." Proceedings of the World Congress on Water Resources, Chicago, Illinois, (1973) pp. 238-248.
20. Diamond, J. T., Wright, J. R., Houck, M. H., and Randall, D. "Design of a Drought Management Exercise: Simulation Gaming Applied to the Indianapolis Water Supply System." Water Resource Research Center, Purdue University, August 1984.
21. Palmer, R. N., Wright, J. R., Smith, J. A., Cohon, J. L., and Reville, C. S. Policy Analysis of Reservoir Operation in the Potomac River Basin. Technical Report No. 59, University of Maryland Water Resources Research Center, College Park, Maryland, 1979.
22. Raser, John. Simulation and Society, Boston: Allyn and Bacon, 1969, pp. 15-19.
23. Breznitz, Shlomo and Liebllich, Amia. "How to Simulate if You Must: Simulating the Dream-Work" Simulation and Gaming in Social Science, New York: The Free Press, 1972, pp. 69-91.



24. Mcinish, Thomas. "Game Simulations as Economic Research Tools." Journal of Experiential Learning and Simulation, 2 (1981), pp. 183-191.
25. Nulsen, R. O., and Faria, A. J. "New Horizons in Simulated Research." New Horizons in Simulation Games and Experiential Learning, Wichita, Kansas, (1977), pp. 217-222.
26. Aronson, Elliot and Carlsmith, J. W. "Experimentation in Social Psychology." in Handbook of Social Psychology ed. Lindzey, G. and Aronson, E. PA: Addison-Wesley, 1968, pp. 1-79.
27. Nees, Danielle B. "Simulation: A complementary Method for Research on Strategic-Making Processes." Strategic Management Journal, 4 (1983), pp. 175-185.
28. Slusher, E. Allen, Sims, Henry, and Thiel, John. "Bargaining Behavior in a Business Simulation Game." Decision Science, 9, (1978), pp. 310-321.
29. Bass, E. M. "Business Gaming for Organization Research". Management Science, 10 (1964), pp. 545-556.
30. Babb, E. M., and Bohl, L.P. "Experimental Gaming-Application to Input Marketing." in Farm/Ranch Input Research ed. Nelson, P. E., East Lansing, MI: Michigan State Agricultural Experiment Station, (1973), pp. 173-191.
31. Jones, L. D. and Babb, E. M. "An Analysis of Behavior and Performance in the Food Retailing Industry Using Experimental Business Gaming." Decision Science, 6, (1975), pp. 541-555.
32. Babb, E. M., Leslie, M. A., and Van Slyke, M. D. "The Potential of Business-Gaming Methods in Research." Journal of Business, 39, (1966), pp. 465-472.
33. Horn, R. E., and Zuckerman, D. W. The Guide to Simulation/Games for Education and Training, Lexington, Mass.: Information Resources, Inc., 1973.
34. Ramesh, Sharda, Willet, Keith, and Chiang, Shin An. "A Water Quality Management Simulation Game." Development in Business Simulation and Experiential Exercise, 13 (1986), pp. 146-151.
35. Frass, Arthur G. and Munley, Vincent G. "Municipal Wastewater Treatment Cost." Journal of Environmental Economics and Management, 11, (1984), pp. 28-38.
36. Dyer, John C., Vernick, Arnold S., and Feiler, Howard D. Handbook of Industrial Wastes Pretreatment, New York: Garland STPM Press, 1981.

37. Texas Water Development Board. DOSAG-1, Simulation of Water Quality in Streams and Canals: Program Documentation and User's Manual, Springfield, Virginia, 1970.
38. Roesner, L. A., Monser, J. R., and Evenson, D. E. Computer Program Documentation for the Stream Water Quality Model, QUAL-II, Walnut Creek, California: Water Resources Engineers, Inc., 1973.
39. Roesner, L. A., Monser, J. R., and Evenson, D. E. Computer Program Documentation for the Stream Quality Model QUAL-II, Walnut Creek, California: Water Resources Engineers, Inc., 1977.
40. Roesner, L. A., Monser, J. R., and Evenson, D. E. User's Manual for the Stream Quality Model QUAL-II, Walnut Creek, California: Water Resources Engineers, Inc., 1977.
41. Blosser, O. Russel. The Mathematical Water Quality Model QUAL-II and Guidance for Its Use - Revised Version, New York: NCASI Inc., 1982.
42. Grenney, W. J., Teusher, M. C., and Dixon, L. S. "Characteristics of the Solution Algorithms for the QUAL-II River Model." Journal, WPCF, 50, 1 (Jan., 1978), pp. 151-157.
43. Roesner, L. A., Monser, J. R., and Evenson, D. E. Computer Program Documentation for the Stream Quality Model QUAL-II, EPA Report No. 600/9-81-014, U.S. Environmental Protection Agency, Athens, Georgia, 1981.
44. Box, G. E. P., Hunter, W. G., and Hunter, J. S. Statistics for Experimenters, 1978 edition, New York: John Wiley & Sons, Inc., 1978.
45. Tietenberg, T. H. Emissions Trading, 1985 edition, Washington, D.C.: Resources for the Future, Inc., 1985.
46. Fletcher, J. "Evaluation of Learning in Two Social Studies Simulation Games." Simulation and Games, 2, (1971), pp.259-286.
47. Rose-Ackerman, S. "Market Models for Water Pollution Controls: Their Strengths and Weaknesses." Public Policy, 25 (1977), pp. 383-406.
48. Hahn, R. W., and Noll, R. G. "Designing a Market for Tradable Emission Permits." Reform of Environmental Regulation, Cambridge, Mass.: Ballinger 1982.
49. Vickrey, W. "Counterspeculation, Auction and Competitive Sealed Teners." Journal of Finance, 16, (1961), pp. 8-37.

50. Clarke, E. H. "Multipart Pricing of Public Goods." Public Choice, 11, (1971), pp. 17-33.
51. Lyon, Randolph M. "Auctions and Alternative Procedures for Allocation." Land Economics, 58, (1982), pp. 16-32.
52. Lyon, Randolph M. "Equilibrium Properties of Auctions and Alternative Procedures for Allocating Transferable Permits." Journal of Environmental Economics and Management, 13, (1986), pp. 129-152.

## APPENDICES

APPENDIX A

CASE STUDY INDUSTRIAL DISCHARGE NO. 1

## COTTON PROCESSING PLANT

Synopsis

You are the water quality manager for the Sunbelt Cotton Company. This company is a major producer of cotton fiber products and is located along the Paladine River. The area has experienced a lot of growth in the last 50 years, with a resultant decrease in stream water quality. The State Water Resources Board, as mandated by the Environmental Protection Agency, has established standards or waste load allocations for each discharger along the river. You have a number of alternatives for complying with the waste load allocations. These alternatives are: (I) Treat all wastewater in the company plant and release to the river; (II) Pretreat all wastewater in the company plant and send to the municipal treatment plant; (III) Send all wastewater to the municipal treatment plant without treatment; (IV) Treat part of the wastewater in the company plant and release, send the other part of the wastewater, without treatment, to the municipal plant; (V) Pretreat part of the wastewater in the company plant and send to the municipal plant, send the other part of the wastewater, without treatment, to the municipal treatment plant; (VI) Discharge all wastewater without permit and without treatment; (VII) Treat part of the waste in the company and release it to the river, send the other part, without treatment, to the river; (VIII) Discharge wastewater after buying permit. If the cost of treatment outweigh the marginal profits, you might recommend reducing the production levels. You might also decide to upgrade the plant. Your task is to determine the best

alternative for disposing of the current period's waste and decide if any upgrades of the plant should be made.

#### Description of the Company

The Sunbelt Cotton Company is a large producer of cotton fiber products. Sunbelt's products are sold in a national market with the company having a 9% share of the market. However, the market is very competitive. The company cannot increase prices without a reduction in demand. Also, price promotions are usually copied by competitors as well.

The company was founded by the Simpson family. This family was among the first families to settle in Paladine City and thus chose to locate the plant close to the local river, the Paladine River, so that most of the effluent of the plant could simply be released into the river. This was an effective and inexpensive way to dispose of the waste of the plant. The flow of the river was sufficient to carry all the waste that was generated. The city had a treatment plant which was able to treat the biological waste efficiently. The river water quality was acceptable for body contact recreation and for aquatic life.

As the years went by, other companies located in the area. The city also experienced a lot of growth. Since the founding family, the Simpsons, was very conscientious about the river water quality, they installed a treatment plant in the company to treat the waste. The plant was installed in 1976, the same year the Simpsons sold the company to a national concern. The plant has not been upgraded since then even though the company has continued to experience a rapid

growth. The parent company viewed the treatment plant as an unnecessary overhead.

As the quality of discharge from Sunbelt deteriorated and the city and other companies grew in size, there was a noticeable decline in the water quality of the Paladine River. One other factor in this decline was a new major reservoir upstream which resulted in frequent low flow conditions.

A number of letters to the editor in the local papers was followed by protests to the Water Resources Board from the citizens of Jonesville, a city located 15 miles downstream. The first task of the board was to establish the effect of existing effluent loads on the water quality. An acceptable total waste load was then deduced from the desired water quality target. This total waste load was then allocated among the different dischargers along the river. This was accomplished by allocating to each discharger a claim on the receiving stream's capacity to assimilate waste, which is called a "waste load allocation". These waste load allocations are developed in terms of Biochemical Oxygen Demand (BOD) and its corresponding water quality parameter, Dissolved Oxygen (DO). The waste load allocation is used as the basis for permit limits for each discharger. (Water quality is measured only in terms of BOD levels. While this is a narrow view of the quality of water, this simplification permits us to concentrate on other economic issues.)

You have been hired by Sunbelt to manage its effluent treatment program and are thus responsible for making decisions for treating the company's wastewater. You report directly to the vice president of operations. While you are not directly involved in the production



decisions, the V.P. has assured you that your inputs will be given high consideration in making final decisions on production levels.

### Production Function

The conversion of cotton fiber into a finished product involves a number of different operations. The cotton is received in bales which are opened and cleaned by machines which blend the cotton while removing a great deal of loose dirt. The cotton is then rolled into sheets ready for the carding and spinning operations. The carding operation combs the cotton, aligning the fibers in parallel prior to spinning them into yarn. Before the yarn can be woven into fabric, it must be strengthened. This is done in an operation known as slashing. The purpose of slashing is to stiffen the fiber by loading it with starch and with other substances called sizing. The sized yarn is then woven into the fabric, brushed, singed and inspected. Finally, the fabric is put through dyeing and finishing operations.

The marketing, finance, and operations departments have developed the final forecasts of production over the next year. The total fabric processed (in millions of pounds) is expected to be as shown in Table A-1.

Even though production fluctuates from quarter to quarter the company tries to maintain the same payroll. The company has been reasonably profitable to date. A simplified earnings statement indicates that the company can sell its output at \$1,200,000 per million pounds of fabric produced. Cost of goods sold is about 60% of sales revenue, exclusive of waste treatment costs. Other expenses are about 10% of sales revenue. The company has a healthy balance sheet. It has very little debt and a \$15 million line of credit which is mostly used

TABLE A-1  
 PRODUCTION AND EFFLUENT FORECAST

	First Quarter	Second Quarter	Third Quarter	Fourth Quarter
Millions Of Pounds Of Fabric	2.475	2.600	2.800	3.000
Discharge (MGD)	1.200	1.260	1.360	1.460
BOD (mg/l)	200	200	200	200

to finance the purchase of cotton. Last year, the company earned about \$1.8 million on sales of about \$12 million.

#### Effluents

The cotton processing plant in the company has state-of-the-art equipment. However, a large amount of biological waste is generated. The waste is a function of the production volume. The wastewater flow rate is 32,000 gallons of water per 1,000 pounds of output produced and the BOD concentration is 200 mg/l. Based on historical analysis, you have determined that the wastewater discharges and BOD levels in Table A-1 would result if planned production was realized. (Other BOD discharge for any other production levels can be determined by using the participant input program.)

### Effluent Removal Strategies

At the present time, Sunbelt's water quality standard has been set at a BOD concentration of 30 mg/l and wastewater flow of 1.7 MGD. The company's wastewater treatment plant has a wastewater design flow rate of 1.5 MGD and a BOD concentration design level of 20 mg/l.

The options available for complying with the waste load allocations established by Water Resources are:

Alternative 1: Alternative 1 involves "Treat all wastewater in the company plant and release to the river". This alternative is subjected to a number of restrictions; (a) Treated wastewater flow rate should not exceed the plant's design capacity, (b) The treated wastewater flow rate should not exceed the maximum limitation of wastewater flow rate established by the Water Resources Board, (c) The treated wastewater BOD effluent concentration should not exceed the plant's design BOD effluent concentration, (d) The treated wastewater BOD effluent concentration should not exceed the allowed BOD effluent concentration to the river set by the Water Resources Board, (e) The plant's design BOD effluent concentration should not be larger than the allowed BOD effluent concentration to the river. For the TDP case, this restriction will be released.

Alternative 2: The second alternative states "Pretreat all wastewater in the company plant and send to the municipal treatment plant." This alternative will be subjected to the following restrictions: (a) Pretreated wastewater flow rate should not exceed the design capacity, (b) Pretreated wastewater BOD effluent concentration should not exceed the design BOD effluent concentration,

and (c) Pretreated wastewater BOD effluent concentration should not exceed the allowed BOD effluent concentration to the municipal treatment plant.

Alternative 3: The third alternative states "Send all wastewater to the municipal treatment plant without treatment". This alternative will be restricted by BOD effluent concentration of discharged wastewater, which should not exceed the allowed BOD effluent concentration to the municipal treatment plant.

Alternative 4: The fourth alternative states "Treat part of the wastewater in the company plant and release; send the other part of the wastewater, without treatment, to the municipal plant". This alternative will be restricted by seven factors: (a) Treated wastewater flow rate should not exceed the production wastewater flow rate, (b) Treated wastewater flow rate should not exceed the plant's design capacity, (c) Treated wastewater should not exceed the maximum limitation of wastewater flow rate to the river, (d) Treated wastewater BOD effluent concentration should not exceed the design BOD effluent concentration, (e) Treated wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the river, (f) Discharged wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the municipal treatment plant, and (g) The design BOD effluent concentration should not be larger than the allowed BOD effluent concentration to the river (for TDP case, this restriction is cancelled).

Alternative 5: The fifth alternative states "Pretreat part of the wastewater in the company plant and send to the municipal treatment; send the other part of the wastewater, without treatment, to the

municipal treatment plant". This alternative will be restricted by four factors: (a) Pretreated wastewater flow rate should not exceed the production wastewater flow rate, (b) Pretreated wastewater quantity should not exceed the design capacity, (c) Pretreated wastewater BOD effluent concentration should not exceed the design capacity for BOD effluent concentration, and (d) Pretreated and discharged wastewater BOD effluent concentration should not exceed allowed BOD effluent concentration to the municipal treatment plant.

Alternative 6: The sixth alternative says "Discharge all wastewater without permit and without treatment". This alternative does not have any restrictions.

Alternative 7: The seventh alternative states "Treat part of the wastewater in the company plant and release; send the other part, without treatment, to the river". This alternative will be restricted by three factors: (a) Treated wastewater flow rate should not exceed the production wastewater flow rate, (b) Treated wastewater flow rate should not exceed the plant's design capacity, (c) The discharge permitted is equal to the initial permit holdings plus traded permits.

Alternative 8: The eighth alternative says "Discharge wastewater after buying permit". This alternative will be restricted by the fact that the discharge permit needed is equal to the initial permit holding plus buying permit numbers (for TDP case only).

Upgrade Plan: Should your production forecasts indicate that you will not have enough capacity in your company's treatment plant and you decide to treat the waste in your plant, you might decide to upgrade your plant capacity. The upgrade plant is restricted by the following: (a) The future design capacity is not less than the current design

capacity, and (b) The future design BOD effluent concentration is not more than the current design BOD effluent concentration (i.e., quality of treated waste should not be worse than the current quality of the effluent).

If the costs of treatment outweigh the marginal profits, you might recommend reducing the production levels. It is assumed in the statement of these alternatives that it is not feasible for Sunbelt to install new cotton processing technology.

The selection of any one of the options listed above will involve several types of costs. These include capital or fixed costs, variable costs, and municipal user charges. (Fixed costs will always be greater than zero regardless of your decision for handling the company's waste.) These costs vary with the wastewater design flow rate and the BOD design effluent concentration. As stated above, the wastewater design flow rate for Sunbelt's treatment plant is 1.5 MGD and the design BOD effluent concentration is 20 mg/l. For this plant, the annual fixed costs are \$61,968.00.

The variable costs are shown in Table A-2. For a given BOD capacity design removal rate, variable costs vary with the actual BOD treatment level and the actual waste flow rate.

The transfer of any amount of waste to the municipal treatment plant involves the payment of a user charge to the municipal treatment plant. The size of this charge will vary with the volume of wastewater flow and the concentration of BOD if it is greater than 250 mg/l. A schedule of user charges for Sunbelt is shown in Table A-3.

TABLE A-2  
VARIABLE COSTS (\$)

Wastewater (MGD)	BOD Effluent Concentration (mg/l)			
	160	140	40	20
1.1	\$26,447	\$26,695	\$29,142	\$30,591
1.2	28,329	28,595	31,215	32,767
1.3	30,178	30,461	33,253	34,906
1.4	31,997	32,298	35,258	37,011
1.5	33,790	34,107	37,233	39,084
1.6	35,557	35,891	39,181	41,129
1.7	37,302	37,652	41,103	43,146
1.8	39,024	39,391	43,001	45,139
1.9	40,727	41,110	44,878	47,109
2.0	42,412	42,810	46,734	49,057

In certain cases you may decide to expand and/or upgrade the existing treatment facilities. This decision involves additional capital costs. The annual fixed capital costs for a number of upgraded plants are shown in Table A-4. These costs will vary with the wastewater design flow and with the BOD design removal rate. Once the waste treatment facility capacity is defined in terms of the wastewater design flow and the BOD capacity design removal rate, the capital costs become fixed costs until further decisions are made to again augment the treatment plant. The operation of the plant in this case will

TABLE A-3  
MUNICIPAL USER CHARGES (\$)

Wastewater (MGD)	BOD Effluent Concentration (mg/l)			
	200	140	120	100
1.0	\$36,610	\$36,610	\$36,610	\$36,610
1.1	40,271	40,271	40,271	40,271
1.2	43,932	43,932	43,932	43,932
1.3	47,593	47,593	47,593	47,593
1.4	51,255	51,255	51,255	51,255
1.5	54,915	54,915	54,915	54,915
1.6	58,577	58,577	58,577	58,577
1.7	62,238	62,238	62,238	62,238
1.8	65,899	65,899	65,899	65,899
1.9	69,560	69,560	69,560	69,560
2.0	73,221	73,221	73,221	73,221



TABLE A-4  
CAPITAL COSTS (\$)

Design Wastewater (MGD)	Design BOD Effluent Concentration (mg/l)	
	20	10
1.5	\$61,968	\$69,235
1.7	69,269	77,394
1.8	72,884	81,433
2.0	80,050	89,438
2.1	83,603	93,408
2.2	87,137	97,387
2.3	90,653	101,280

involve variable costs which will increase nonlinearly with changes in the actual BOD effluent concentration level and the actual wastewater flow rate. The additions to the plant will not become available for actual use until two periods after the decision to upgrade and/or add to the plant has been made.

APPENDIX B

EXAMPLE OF WASTE DISPOSAL DECISIONS  
FOR CASE STUDIES

Decisions Without TDP

Team 1: Cotton Processing Plant

Production Forecast = 2.475 million pounds of product

Discharge = 1.200 MGD

BOD Concentration = 200 mg/l

Water Quality Standard

Discharge = 1.70 MGD

BOD Concentration = 30 mg/l

Treatment Plant Design Capacity

Discharge = 1.50 MGD

BOD Concentration = 20 mg/l

Viable Alternatives for Disposing of Waste

Could use one of the following alternatives:

- A) Alternative 1
- B) Alternative 2
- C) Alternative 3
- D) Alternative 4
- E) Alternative 5

Costs of the Different Alternatives

**Note:** All of the different alternatives have the same capital or fixed cost which is \$61,968 (illustrated in Table B-3).

- A) Cost of alternative 1: Treat all wastewater in the company

plant and release to the river. This alternative would require payment of variable cost for operation of the treatment plant. The amount of waste to be treated in the company plant and released cannot exceed the standard of a BOD concentration equal to 30 mg/l and wastewater flow equal to 1.70 MGD.

The variable cost for a treatment plant treating 1.2 MGD wastewater with a BOD effluent concentration of 30 mg/l can be calculated from Table B-1 by extrapolation.

Using Table B-1, look at the row of wastewater flow for 1.2 MGD and the columns of BOD effluent concentration of 40 mg/l and 20 mg/l.

If the BOD concentration is 40 mg/l and the treated wastewater flow is 1.2 MGD, the variable cost is \$31,497.

If the BOD concentration is 20 mg/l and the treated wastewater flow is 1.2 MGD, the variable cost is \$32,767. Find the approximate charge for a BOD effluent concentration by extrapolating as follows:

1) Let  $X_1$  = lower BOD effluent concentration.

Let  $X_2$  = upper BOD effluent concentration.

Let  $X_a$  = actual BOD effluent concentration.

$P$  = proportionality factor

Calculate  $P$  as follows:

$$P = (x_a - x_1)/(x_2 - x_1)$$

For this example,  $X_1 = 20$ ,  $X_2 = 40$ ,  $X_a = 30$ .

$$P = (30 - 20)/(40 - 20) = 0.50.$$

2) Let  $C_1$  = Variable cost associated with  $X_1$ .

TABLE B-1  
VARIABLE COSTS (\$)

Wastewater (MGD)	BOD Effluent Concentration (mg/l)			
	160	140	40	20
1.1	\$26,447	\$26,695	\$29,142	\$30,591
1.2	28,329	28,595	31,497	32,767
1.3	30,178	30,461	32,253	34,906
1.4	31,997	32,298	35,258	37,011
1.5	33,790	34,107	37,233	39,084
1.6	35,557	35,891	39,181	41,129
1.7	37,302	37,652	41,103	43,146

Let  $C_2$  = Variable cost associated with X2.

Let  $D$  = Difference in variable cost.

$$D = C_2 - C_1$$

For this example,  $C_1 = \$31,497$  and  $C_2 = \$32,767$ .

From Table B-1:

$$D = 32,767 - 31,497 = \$1,270$$

3) Let  $I$  = Proportionality cost.

For this example,  $I = (0.50) (1,270) = \$635$

4) Let  $C_e$  = estimated variable cost

$$C_e = C_1 + I$$

$C_e$  for this example:

$$C_e = 31,497 + 635 = 32,132$$

The total cost of alternative 3 is as follows:

Fixed Cost = \$61,968

Variable Cost = \$32,132

Total Cost = \$94,100.

- B) Cost of alternative 2: Pretreat all wastewater in the company plant and send to the municipal plant. This alternative would require payment of a municipal user charge as well as incurring variable cost for operating the treatment plant.

Since the generated BOD concentration is 200 mg/l, the municipal user charge will be the same as that of alternative 3.

Therefore, total cost of alternative 2 will always be more expensive than that of alternative 3.

- C) Cost of alternative 3: Send all waste to the municipal plant without treatment.

This alternative would require payment of a municipal user charge.

Waste flow parameters are as follows:

BOD concentration = 200 mg/l

Discharge flow = 1.2 MGD.

The municipal user charge can be found from Table B-2. Using Table B-2, and the column for 100 mg/l and the row of wastewater flow for 1.2 MGD; the user charge is \$43,932.

Fixed Cost = \$61,968

Municipal User Charge = \$43,932

Total Cost = \$105,900.

TABLE B-2  
MUNICIPAL USER CHARGES (\$)

Wastewater (MGD)	BOD Effluent Concentration (mg/l)			
	200	140	120	100
1.0	\$36,610	\$36,610	\$36,610	\$36,610
1.1	40,271	40,271	40,271	40,271
1.2	43,932	43,932	43,932	43,932
1.3	47,593	47,593	47,593	47,593
1.4	51,255	51,255	51,255	51,255
1.5	54,915	54,915	54,915	54,915

- D) Cost of alternative 4: Treat part of the wastewater in the company plant and release; send the other part of the wastewater, without treatment, to the municipal plant.
- E) Cost of alternative 5: Pretreat part of the wastewater in the company plant and send to the municipal plant; send the other part of the wastewater, without treatment, to the municipal plant.

These alternatives would require payment of a municipal user charge as well as incurring a variable cost for operating the treatment plant.

Since the municipal user charge is more expensive than the variable cost, no matter what proportion of wastewater is

treated in the company plant, the total cost will always be greater than alternative 1.

Based on these calculations, the best alternative for Team 1 is alternative 1.

TABLE B-3  
CAPITAL COSTS (\$)

Design Wastewater (MGD)	Design BOD Effluent Concentration (mg/l)	
	20	10
1.5	\$61,968	\$69,235
1.7	69,269	77,394
1.8	72,884	81,433
2.0	80,050	89,438
2.1	83,603	93,408

Example of Waste Disposal Decisions with TDP's

Determination of Bid/Ask Price for a TDP

Again, consider Team 1. One permit entitles the holder to discharge one Lb. of BOD per day for one quarter.

$$\text{Lbs-BOD/day} = (\text{mg/l}) \times (\text{MGD}) \times 8.34 \text{ lbs}/[(\text{mg/l}) \times (\text{MG})]$$

Each discharger is given an initial number of permits to coincide with its stated wasteload allocation.



In this example, BOD Lbs/day is as follows:

$$\text{Lbs-BOD/day} = (30 \text{ mg/l}) \times (1.70 \text{ MGD}) \times (8.34 \text{ Lbs}/[(\text{mg/l}) \times (\text{MG})])$$

For this example, the discharger is allowed to emit 424 Lbs of BOD per day for one quarter.

Discharger now has 424 permits.

### The Decision to Buy or Sell Permits

When break-even analysis is used to determine the bidding permit price, the logical boundaries for when to buy and sell permits must be considered.

The decision to buy or sell TDP's entails a comparison of the internal estimated cost of removal of waste at the local plant and the cost of TDP's. If TDP's are less costly than local treatment, TDP's will be purchased and local treatment will not be undertaken.

If alternative 8, "Discharge wastewater after buying permits" is chosen, 1577 permits are needed, and the cost of this option would be the permit buying cost.

The revenues from buying the permits could be used to offset the variable cost.

Additional permits needed are equal to

$$(1.2 \times 200 \times 8.34) - 424 = 1577.$$

If alternative 1, "Treat wastewater in the company plant and release it to the river" is selected, 1.2 MGD wastewater is treated to BOD effluent concentration 20 mg/l.

The number of permits to be sold in alternative 1 is based on the difference between the treatment plant capacity and the permitted discharge standard.

Fixed Cost = \$61,968

Variable Cost = \$32,767

Surplus Permit Sold =  $424 - (1.2 \times 20 \times 8.34) = 224$

Using break-even analysis:

$32767 - 224 \times \text{unit permit price} = 1577 \times \text{unit permit price}.$

Unit Permit Price = \$18.19.

This means that if the TDP market price is less than 18.19, and if Team 1 decides to choose alternative 8, Team 1 will buy 1577 permits, at most. On the contrary, if the TDP market price is more expensive than 18.19, and if Team 1 decides to select alternative 1, Team 1 will sell 224 permits, at most.

#### How to Decide Market Price for Permit

The market model is based on the multiple-price auction, negotiation between bidders, and rational bidder behavior. The following table is obtained from Appendix I.

Team	# of permit bought	buying Price	# of permit sold	selling price
1	<-1577	<-18.19	<-224	18.19->
2	<-14.2	<-38.67	<-76	38.67->
3	<-123	<-17.8	<-10	17.8->
4	<-26.66	<-43.88	<-6.66	43.88->
5	<-333.6	<-95.8	<-333.6	95.8->
6	---	---	<-625.5	5.0->
7	---	---	---	---

Based on the above information, the administration decides to make the following trading transactions:

Team 1 will buy 10.0 permits at \$18 from Team 3  
 Team 1 will buy 250.7 permits at \$18 from Team 6  
 Team 2 will buy 14.2 permits at \$19 from Team 6  
 Team 3 will sell 10.0 permits at \$18 to Team 1  
 Team 4 will buy 26.7 permits at \$39 from Team 6  
 Team 5 will buy 333.6 permits at \$44 from Team 6  
 Team 6 will sell 250.7 permits at \$18 to Team 1  
 Team 6 will sell 14.2 permits at \$19 to Team 2  
 Team 6 will sell 26.7 permits at \$39 to Team 4  
 Team 6 will sell 333.6 permits at \$44 to Team 5.

Best Strategy With TDP Case

Current permit holding =  $424 + 260.7 = 684.7$

Design flow rate = 1.5 MGD

Actual flow rate = 1.2 MGD

Design BOD effluent concentration = 20 mg/l

Expected BOD influent concentration = 200 mg/l

Apparently, alternative 7, "Treat part of the wastewater in the company plant and release; send the other part, without treatment, to the river", will be a less expensive alternative.

Assumption: Y is the discharged flow rate

$(200 \times Y \times 8.34) + (1.2 - Y) \times 20 \times 8.34 = 684.7$

$Y = 0.32$  MGD

Therefore, the best alternative for Team 1 is to treat 0.88 MGD wastewater from BOD 200 mg/l influent concentration to 20 mg/l effluent concentration, and discharge 0.32 MGD to the river.

APPENDIX C

COMMAND PROCEDURE TO SPECIFY DATASETS AND SUBMIT  
THE COST PROGRAM AND THE QL2SMG PACKAGE

\*\*\*\* TSO FOREGROUND HARDCOPY \*\*\*\*  
DSNAME=U11502C.TEACHERA.CLIST

```
00000100CONTROL MSG
00000200FREEALL
00000300WRITE THIS PROGRAM WILL TAKE YOUR INPUT FOR THE WATER QUALITY
00000400WRITE SIMULATION GAME AND GENERATE THE OUTPUT FILE
00000500WRITE
00000600WRITE ENTER PERIOD NUMBER (E.G. 1)
00000700READ &PERIOD
00000800WRITE ENTER PASSWORD
00000900READ &PASSWORD
00001000ATTRIB TEMP BLKSIZE(6160) LRECL(80) RECFM(F B)
00001100ALLOC F(FT15F001) DS(DECISION.DATA(A1&PERIOD)) SHR
00001200ALLOC F(FT16F001) DS(DECISION.DATA(A2&PERIOD)) SHR
00001300ALLOC F(FT17F001) DS(DECISION.DATA(A3&PERIOD)) SHR
00001400ALLOC F(FT18F001) DS(DECISION.DATA(A4&PERIOD)) SHR
00001500ALLOC F(FT19F001) DS(DECISION.DATA(A5&PERIOD)) SHR
00001600ALLOC F(FT20F001) DS(DECISION.DATA(A6&PERIOD)) SHR
00001700ALLOC F(FT21F001) DS(DECISION.DATA(A7&PERIOD)) SHR
00001800ALLOC F(FT11F001) DS(QUALITY.DATA(A&PERIOD)) OLD CATALOG +
00001810 UNIT(STORAGE) TRACKS SPACE(1,1) DIR(10) USING(TEMP)
00001900WRITE DATA SETS ARE ALLOCATED
00002000CALL 'U11502C.QUI.LOAD(INQUI)'
00002100EDIT COST.CNTL(A)
00002200C 700 /ZZ/&PERIOD./
00002300C 800 1500 /ZZ)/&PERIOD.) / ALL
00002400C 1600 /ZZ./&PERIOD../
00002500C 2200 2300 /ZZ/&PERIOD./ ALL
00002600C 300 /????/&PASSWORD./
00002700SUBMIT
00002800C 700 /&PERIOD../ZZ./
00002900C 800 1500 /&PERIOD.) /ZZ) / ALL
00003000C 1600 /&PERIOD../ZZ./
00003100C 2200 2300 /A&PERIOD./AZZ/ ALL
00003200C 300 /&PASSWORD./????/
00003300END S
00003400FREEALL
```

APPENDIX D

COMMAND PROCEDURES TO BE USED BY PARTICIPANTS  
FOR ENTERING DECISIONS

\*\*\*\* TSO FOREGROUND HARDCOPY \*\*\*\*

DSNAME=U11502C.INPUTA.CLIST

```
00000100CONTROL MSG
00000200FREEALL
00000400WRITE THIS PROGRAM WILL TAKE YOUR INPUT FOR THE WATER QUALITY
00000500WRITE SIMULATION GAME AND PREPARE THE DATA FILE
00000600WRITE
00000700WRITE ENTER YOUR TEAM NUMBER (E.G. 1)
00000800READ &TEAM
00000900WRITE ENTER YOUR PERIOD NUMBER (E.G. 1)
00001000READ &PERIOD
00001100SET &P=&PERIOD + 2
00001200ATTRIB TEMP BLKSIZE(6160) LRECL(80) RECFM(F B)
00001300ALLOC F(FT20F001) DS(PLANTA&P..CNTL) MOD USING(TEMP)
00001400ALLOC F(FT10F001) DS(PLANTA&PERIOD..CNTL) SHR
00001410ALLOC F(FT09F001) DS(TDPSA&PERIOD..CNTL) SHR
00001500ALLOC F(FT11F001) DS(DECISION.DATA(A&TEAM&PERIOD)) OLD
00001600WRITE DATA SETS ARE ALLOCATED
00001700CALL 'U11502C.SIMT.LOAD(TEMPNAME)'
00001800FREE F(FT11F001) ATTRLIST(TEMP)
00001900FREE F(FT20F001) ATTRLIST(TEMP)
```

APPENDIX E

FORTRAN PROGRAM FOR COST CALCULATIONS



\*\*\* TSO FOREGROUND HARDCOPY \*\*\*\*  
 SNAME=U11502C.MSIMU.CNTL

THIS IS THE MAIN PROGRAM WHICH CONTAINS COST FUNCTION TO CALCULATE THE COST OF EACH TEAM, THE PROGRAM WILL READ STUDENT DECISION FILES, PLANT FILE, AND TDP FILE. THIS PROGRAM WILL GENERATE A FINANCIAL REPORT FOR EACH TEAM.

CH -> CONVERSION FACTOR LMGD IS EQUAL TO 157.7 CUBIC METERS/HOUR  
 CML -> CONVERSION FACTOR LMGD IS EQUAL TO 1381.525 MILLION LITERS/  
 YEAR  
 CTL -> CONVERSION FACTOR LMGD IS EQUAL TO 1381525 THOUSAND LITERS/  
 YEAR  
 PLA(1) -> PRICE OF LABOR AND MATERIAL COSTS PER UNIT PRODUCT, FIRM  
 POE(1) -> PRICE OF OTHER EXPENSES PER UNIT PRODUCT, FIRM I  
 PRI(1) -> PRICE PER UNIT PRODUCT, FIRM I

DIMENSION PR(7),PQ(7),PBOD(7),DQ(7),DBOD(7),FQ(7),FBOD(7),Q1(7),  
 \*BOD1(7),Q2(7),BOD2(7),Q3(7),BOD3(7),Q4(7),BOD4(7),UBOD(7),  
 \*IT(7),IJ(7),IP(7),IS(7),BQ(7),BBOD(7),ABOD(7),RAT(7),C1(7),UC(7),  
 \*VC(7),PC(7),WC(7),TC(7),SR(7),ALM(7),OE(7),TTI(7),TCI(7),TNE(7),  
 \*PRI(5),PLA(5),POE(5),PP(7,7),TDPN(7,7),PTDP(7,7),SBOD(7),CBOD(7),  
 \*TPP(7)

CHARACTER\*1 AR  
 DATA CH,CML,CTL/157.7,1381.525,1381525./  
 DATA PRI/1200000.,1850000.,1800000.,1200000.,370000./  
 DATA BQ,SBOD,C1,UC,TPP/7\*0.,7\*0.,7\*0.,7\*0.,7\*0./

CALCULATE LABOR & MATERIAL COSTS AND OTHER EXPENSES  
 DO 27 I=1,5  
 PLA(I)=PRI(I)\*0.6  
 POE(I)=PRI(I)\*0.1

27 CONTINUE  
 READ DATA FROM STUDENT DECISION FILES  
 DO 29 I=1,7  
 READ(14+I,105) AR,IT(I),IJ(I),IS(I),IP(I),PR(I),PQ(I),PBOD(I),Q1(I)  
 \*),BOD1(I),Q2(I),BOD2(I),Q3(I),BOD3(I),Q4(I),BOD4(I),UBOD(I),  
 \*FQ(I),FBOD(I),SBOD(I),CBOD(I)

105 SEED OF THE UNIFORMLY DISTRIBUTED PSEUDO-RANDOM NUMBERS  
 NRG=NRG+PR(I)  
 105 FORMAT(A1,4I1,F6.3,6(F6.3,F5.1)/F6.3,3F5.1)

29 CONTINUE  
 INITIALIZE PERMIT PRICE, PERMIT NUMBER, AND TOTAL PERMIT PRICE  
 DO 240 I=1,7  
 DO 240 J=1,7  
 PP(I,J)=0.  
 TDPN(I,J)=0.  
 PTDP(I,J)=0.

240 CONTINUE  
 READ PLANT DESIGN CAPACITY AND DESIGN BOD EFFLUENT CONCENTRATION  
 28 READ(11,106,END=30) I,DQ(I),DBOD(I)  
 106 FORMAT(I2,I,X,F6.3,F5.1)

GO TO 28  
 READ TDP PRICE AND NUMBER OF PERMITS OF EACH TEAM  
 30 READ(22,107) (PTDP(I,J),J=1,7),I=1,7)  
 107 FORMAT(7F10.0)

READ(24,108) (TDPN(I,J),J=1,7),I=1,7)  
 108 FORMAT(7F10.2)

C FIND FLOW RATES, BOD CONCENTRATIONS AND DESIGN BOD REMOVAL RATE  
 FOR EACH INDIVIDUAL WASTEWATER TREATMENT PLANT OF INDUSTRIAL FIRMS  
 DO 32 I=1,5  
 GO TO (121,122,123,121,122,123,121,123),IS(I)

121 BQ(I)=Q1(I)  
 BBOD(I)=PBOD(I)  
 ABOD(I)=BOD1(I)  
 RAT(I)=(BBOD(I)-DBOD(I))/BBOD(I)  
 GO TO 32

122 BQ(I)=Q2(I)  
 BBOD(I)=PBOD(I)  
 ABOD(I)=BOD2(I)  
 RAT(I)=(BBOD(I)-DBOD(I))/BBOD(I)  
 GO TO 32

123 IF (IS(I).NE.6) GO TO 125  
 DISCHARGE WITHOUT PERMIT -> USE UNIFORMLY DISTRIBUTED PSEUDO -  
 RANDOM NUMBER U TO CATCH INFRACTIONS IF U IS LESS THAN 60 PERCENT  
 U=RANF(2\*ABS(NRG)+1)  
 IF (U.LE.0.6) GO TO 124  
 GO TO 125

124 PC(I)=200000.  
 125 BBOD(I)=PBOD(I)  
 ABOD(I)=0.  
 RAT(I)=0.

32 CONTINUE

C CALCULATE FLOW RATES, BOD CONCENTRATIONS AND DESIGN BOD REMOVAL  
 RATES FOR MUNICIPAL WASTEWATER TREATMENT PLANTS  
 DO 33 I=1,3  
 BQ(6)=BQ(6)+Q2(I)+Q3(I)  
 BBOD(6)=BBOD(6)+Q2(I)\*BOD2(I)+Q3(I)\*BOD3(I)

33 CONTINUE  
 DO 34 I=4,5  
 BQ(7)=BQ(7)+Q2(I)+Q3(I)  
 BBOD(7)=BBOD(7)+Q2(I)\*BOD2(I)+Q3(I)\*BOD3(I)

34 CONTINUE  
 DO 35 I=6,7  
 BQ(I)=BQ(I)+UQ(I)  
 BBOD(I)=(BBOD(I)+UQ(I)\*UBOD(I))/BQ(I)  
 ABOD(I)=CBOD(I)  
 RAT(I)=(BBOD(I)-DBOD(I))/BBOD(I)

35 CONTINUE

C CALCULATE INVESTMENT COSTS AND OPERATION COSTS  
 DO 36 I=1,7  
 C1(I)=78239\*DQ(I)\*\*0.89\*BBOD(I)\*\*0.24\*DBOD(I)\*\*(-0.16)\*0.25  
 IF (RAT(I).NE.0.) GO TO 128

C DURING MAINTENANCE PERIOD, QUARTERLY INVESTMENT AND FIXED  
 C OPERATION COSTS OF THE DISCHARGER IS EQUAL TO HALF OF THE NORMAL  
 C COST  
 C1(I)=0.5\*C1(I)  
 VC(I)=39244\*BQ(I)\*\*0.79\*BBOD(I)\*\*0.24\*ABOD(I)\*\*(-0.07)\*0.25

C CALCULATE TOTAL PERMIT PRICE, BUYING PERMIT IS PLUS, SELLING  
 C PERMIT IS MINUS AND PRICE IS ALWAYS PLUS  
 DO 36 J=1,7  
 PP(I,J)=PTDP(I,J)\*TDPN(I,J)

36 CONTINUE  
 C1(6)=78239\*DQ(6)\*\*0.89\*200\*\*0.24\*DBOD(6)\*\*(-0.16)\*0.25  
 C1(7)=78239\*DQ(7)\*\*0.89\*200\*\*0.24\*DBOD(7)\*\*(-0.16)\*0.25

DO 250 I=1,7  
 DO 250 J=1,7  
 250 TPP(I)=TPP(I)+PP(I,J)  
 C1(3)=C1(3)+(1671+0.25)  
 C1(4)=C1(4)+(17552\*0.25)  
 VC(3)=VC(3)+(6416\*0.25)

```

VC(4)=VC(4)+(1445*0.25) 00012600
00012700
CALCULATE WATER QUALITY-RELATED COSTS AND PROFIT
DO 37 I=1,5 00012800
UC(I)=(Q2(I)*CTL*0.106+Q3(I)*CTL*0.106)/4 00013000
IF BOD EFFLUENT CONCENTRATION EXCEEDS 250 MG/L THE FIRM HAS TO PAY 00013100
SURCHARGE FEE 00013200
IF (BOD2(I).LE.250) GO TO 51 00013300
UC(I)=UC(I)+(Q2(I)*CML*0.443*(BOD2(I)-250))/4 00013400
51 IF (BOD3(I).LE.250) GO TO 52 00013500
UC(I)=UC(I)+(Q3(I)*CML*0.443*(BOD3(I)-250))/4 00013600
52 WC(I)=C1(I)+VC(I)+UC(I)+PC(I)+TPP(I) 00013700
SR(I)=PR(I)*PRI(I) 00013800
ALM(I)=PR(I)*PLA(I) 00013900
OE(I)=PR(I)*POE(I) 00014000
TC(I)=WC(I)+ALM(I)+OE(I) 00014100
TTI(I)=SR(I)-TC(I) 00014200
TAX IS 46 PERCENT 00014300
TCI(I)=0.46*TTI(I) 00014400
TNE(I)=(1-0.46)*TTI(I) 00014500
37 CONTINUE 00014600
DO 38 I=1,3 00014700
UC(6)=UC(6)+UC(I) 00014800
38 CONTINUE 00014900
DO 39 I=4,5 00015000
UC(7)=UC(7)+UC(I) 00015100
39 CONTINUE 00015200
DO 40 I=6,7 00015300
WC(I)=C1(I)+VC(I)+UC(I)+TPP(I) 00015400
40 CONTINUE 00015500
PRINT OUTPUT FOR INDUSTRIAL FIRMS 00015600
DO 61 I=1,5 00015700
CALL INFO(AR,I,IJ(I),IP(I),PR(I),DQ(I),DBOD(I),PQ(I),PBOD(I),UQ(I) 00015800
*,UBOD(I),SBOD(I),CBOD(I)) 00015900
CALL SALT(IS(I),Q1(I),BOD1(I),Q2(I),BOD2(I),Q3(I),BOD3(I),Q4(I),BO 00016000
*d4(I)) 00016100
IF (RAT(I).EQ.0.) GO TO 153 00016200
WRITE(6,158) RAT(I) 00016300
158 FORMAT(/HD,'DESIGN BOD REMOVAL RATE',F7.2) 00016400
153 IF (FQ(I).LE.0.) GO TO 151 00016500
CALL SHUPGR(FQ(I),FBOD(I)) 00016600
151 WRITE(6,159) 00016700
159 FORMAT(/HD,' WATER QUALITY-RELATED COSTS') 00016800
WRITE(6,160) C1(I) 00016900
160 FORMAT(' QUARTERLY INVESTMENT AND FIXED OPERATING COSTS OF PLANT 00017000
*',F9.0,' DOLLARS') 00017100
WRITE(6,161) VC(I) 00017200
161 FORMAT(' OPERATION COSTS',F9.0,' DOLLAR00017300
*') 00017400
WRITE(6,162) UC(I) 00017500
162 FORMAT(' INDUSTRIAL USER CHARGES',F9.0,' DOLLAR00017600
*') 00017700
IF (PC(I).EQ.0.) GO TO 155 00017800
WRITE(6,163) PC(I) 00017900
163 FORMAT(' DISCHARGE WITHOUT PERMIT -> PENALTY COST',F9.0,' DOLLAR00018000
*') 00018100
DO 300 J=1,7 00018200
IF (TDPN(I,J)) 301,300,302 00018300
301 WRITE(6,310) ABS(TDPN(I,J)),J 00018400
310 FORMAT(' NUMBER OF PERMITS SOLD',F9.2,' FROM TEAM',I2,' TO TE00018500
*AM',I2) 00018600
WRITE(6,311) PTD(I,J) 00018700
311 FORMAT(' UNIT PERMIT SELLING PRICE',F9.0,' DOLLAR00018800
*') 00018900
WRITE(6,312) ABS(PP(I,J)) 00019000
00019100

```

```

312 FORMAT(' REVENUE FROM PERMITS',F9.0,' DOLLAR00019200
*') 00019300
IF (I.NE.7 .AND. J.NE.7) GO TO 300 00019400
IF (I.EQ.7 .AND. J.EQ.7) GO TO 221 00019500
302 WRITE(6,315) TDPN(I,J),J,I 00019600
315 FORMAT(' NUMBER OF PERMITS BOUGHT',F9.2,' FROM TEAM',I2,' TO TE00019700
*AM',I2) 00019800
WRITE(6,316) PTD(I,J) 00019900
316 FORMAT(' UNIT PERMIT BUYING PRICE',F9.0,' DOLLAR00020000
*') 00020100
WRITE(6,317) PP(I,J) 00020200
317 FORMAT(' COST OF PERMITS',F9.0,' DOLLAR00020300
*') 00020400
300 CONTINUE 00020500
221 WRITE(6,169) WC(I) 00020600
169 FORMAT(' TOTAL CURRENT COSTS',F9.0,' DOLLAR00020700
*') 00020800
WRITE(6,170) 00020900
170 FORMAT(/HD,' PROFIT & LOSS STATEMENT') 00021000
WRITE(6,171) SR(I) 00021100
171 FORMAT(' TOTAL SALES REVENUE',F9.0,' DOLLAR00021200
*') 00021300
WRITE(6,172) ALM(I) 00021400
172 FORMAT(' LABOR AND MATERIAL COSTS',F9.0,' DOLLAR00021500
*') 00021600
WRITE(6,173) OE(I) 00021700
173 FORMAT(' OTHER EXPENSES',F9.0,' DOLLAR00021800
*') 00021900
WRITE(6,174) TC(I) 00022000
174 FORMAT(' TOTAL EXPENSES',F9.0,' DOLLAR00022100
*') 00022200
WRITE(6,175) TTI(I) 00022300
175 FORMAT(' TOTAL TAXABLE INCOME',F9.0,' DOLLAR00022400
*') 00022500
WRITE(6,176) TCI(I) 00022600
176 FORMAT(' TAX ON CURRENT INCOME',F9.0,' DOLLAR00022700
*') 00022800
WRITE(6,177) TNE(I) 00022900
177 FORMAT(' NET EARNING',F9.0,' DOLLAR00023000
*') 00023100
WRITE(23,230) AR,I,IJ(I),IS(I),IP(I),PR(I),PQ(I),PBOD(I),Q1(I),BOD00023200
*1(I),Q2(I),BOD2(I),Q3(I),BOD3(I),Q4(I),BOD4(I),UQ(I),UBOD(I),FQ(I)00023300
*,FBOD(I),SBOD(I),CBOD(I),RAT(I),C1(I),VC(I),UC(I),PC(I),WC(I),SR(I)00023400
*,ALM(I),OE(I),TC(I),TTI(I),TCI(I),TNE(I),TPP(I)) 00023500
230 FORMAT(A1,4I1,F6.3,6(F6.3,F5.1)/F6.3,3F5.1,F5.3,6F9.0/6F9.0,F10.0)00023600
61 CONTINUE 00023700
00023800
C PRINT OUTPUT FOR MUNICIPAL TREATMENT PLANTS 00023900
DO 62 I=6,7 00024000
CALL INFO(AR,I,IJ(I),IP(I),PR(I),DQ(I),DBOD(I),PQ(I),PBOD(I),UQ(I)00024100
*,UBOD(I),SBOD(I),CBOD(I)) 00024200
IF (I.EQ.6) GO TO 140 00024300
IF (I.EQ.7) GO TO 141 00024400
140 DO 142 J=1,3 00024500
IF (Q2(J).LE.0.) GO TO 143 00024600
WRITE(6,180) J,Q2(J) 00024700
180 FORMAT(' ACTUAL PRETREATED WASTEWATER FLOW RATE FROM INDUSTRIAL F00024800
*RM',I2,' :',F7.3,' MGD') 00024900
WRITE(6,181) J,BOD2(J) 00025000
181 FORMAT(' ACTUAL PRETREATED WASTEWATER BOD INFLUENT CONCENTRATION P00025100
*ROM INDUSTRIAL FIRM',I2,' :',F5.1,' MG/L') 00025200
143 IF (Q3(J).LE.0.) GO TO 142 00025300
WRITE(6,182) J,Q3(J) 00025400
182 FORMAT(' ACTUAL RAW WASTEWATER FLOW RATE FROM INDUSTRIAL FIRM',I2,00025500
* :',F7.3,' MGD') 00025600
WRITE(6,183) J,BOD3(J) 00025700

```

```

183 FORMAT(' ACTUAL RAW WASTEWATER BOD INFLUENT CONCENTRATION FROM INDO0025800
*USTRIAL FIRM',I2,' :',F5.1,' MG/L') 0025900
142 CONTINUE 0026000
GO TO 154 0026100
141 DO 144 J=4,5 0026200
IF (Q2(J).LE.0.) GO TO 145 0026300
WRITE(6,184) J,Q2(J) 0026400
184 FORMAT(' ACTUAL PRETREATED WASTEWATER FLOW RATE FROM INDUSTRIAL FLOW0026500
*RM',I2,' :',F7.3,' MGD') 0026600
WRITE(6,185) J,BOD2(J) 0026700
185 FORMAT(' ACTUAL PRETREATED WASTEWATER BOD INFLUENT CONCENTRATION FLOW0026800
*ROM INDUSTRIAL FIRM',I2,' :',F5.1,' MG/L') 0026900
145 IF (Q3(J).LE.0.) GO TO 144 0027000
WRITE(6,186) J,Q3(J) 0027100
186 FORMAT(' ACTUAL RAW WASTEWATER FLOW RATE FROM INDUSTRIAL FIRM',I2,0027200
* :',F7.3,' MGD') 0027300
WRITE(6,187) J,BOD3(J) 0027400
187 FORMAT(' ACTUAL RAW WASTEWATER BOD INFLUENT CONCENTRATION FROM INDO0027500
*USTRIAL FIRM',I2,' :',F5.1,' MG/L') 0027600
144 CONTINUE 0027700
154 WRITE(6,188) BQ(I) 0027800
188 FORMAT(' ACTUAL TOTAL WASTEWATER FLOW RATE 0027900
* :',F7.3,' MGD') 0028000
WRITE(6,189) BBOD(I) 0028100
189 FORMAT(' ACTUAL AVERAGE BOD INFLUENT CONCENTRATION 0028200
* :',F5.1,' MG/L') 0028300
WRITE(6,191) CBOD(I) 0028400
191 FORMAT(' ACTUAL MUNICIPAL PLANT WASTEWATER BOD EFFLUENT CONCENTRAT0028500
*ION :',F5.1,' MG/L') 0028600
190 FORMAT(/1H0,' DESIGN BOD REMOVAL RATE :',F7.2) 0028800
IF (FQ(I).LE.0.) GO TO 152 0028900
CALL SHUPGR(FQ(I),FBOD(I)) 0029000
152 WRITE(6,201) 0029100
201 FORMAT(/1H0,' WATER QUALITY-RELATED COSTS') 0029200
WRITE(6,202) CI(I) 0029300
202 FORMAT(' ANNUAL INVESTMENT AND FIXED OPERATING COSTS OF PLANT :',F00029400
*9.0,' DOLLARS') 0029500
WRITE(6,203) VC(I) 0029600
203 FORMAT(' OPERATION COSTS :',F00029700
*9.0,' DOLLARS') 0029800
IF (I.EQ.6) GO TO 146 0029900
IF (I.EQ.7) GO TO 147 0030000
DO 148 J=1,3 0030100
IF (UC(J).LE.0.) GO TO 148 0030200
WRITE(6,204) J,UC(J) 0030300
204 FORMAT(' MUNICIPAL USER CHARGE FROM INDUSTRIAL FIRM',I2,'
*:',F9.0,' DOLLARS') 0030500
148 CONTINUE 0030600
GO TO 150 0030700
147 DO 149 J=4,5 0030800
IF (UC(J).LE.0.) GO TO 149 0030900
WRITE(6,205) J,UC(J) 0031000
205 FORMAT(' MUNICIPAL USER CHARGE FROM INDUSTRIAL FIRM',I2,'
*:',F9.0,' DOLLARS') 0031200
149 CONTINUE 0031300
150 WRITE(6,206) UC(I) 0031400
206 FORMAT(' TOTAL MUNICIPAL USER CHARGES :',F00031500
*9.0,' DOLLARS') 0031600
DO 400 J=1,7 0031700
IF (TDPN(I,J)) 401,400,402 0031800
401 WRITE(6,410) ABS(TDPN(I,J)),I,J 0031900
110 FORMAT(' NUMBER OF PERMITS SOLD :',F9.2,' FROM TEAM ',I2,' TO TE00032000
*AM ',I2) 0032100
WRITE(6,411) PTDP(I,J) 0032200
111 FORMAT(' UNIT PERMIT SELLING PRICE :',F9.0,' DOLLAR00032300
*S') 00032400
WRITE(6,412) ABS(PP(I,J)) 00032500
412 FORMAT(' REVENUE FROM PERMITS :',F9.0,' DOLLAR00032600
*S') 00032700
IF (I.NE.7 .AND. J.NE.7) GO TO 400 00032800
IF (I.EQ.6 .AND. J.EQ.7) GO TO 400 00032900
IF (I.EQ.7 .AND. J.EQ.7) GO TO 222 00033000
402 WRITE(6,415) TDPN(I,J),J,I 00033100
415 FORMAT(' NUMBER OF PERMITS BOUGHT :',F9.2,' FROM TEAM ',I2,' TO TE00033200
*AM ',I2) 00033300
WRITE(6,416) PTDP(I,J) 00033400
416 FORMAT(' UNIT PERMIT BUYING PRICE :',F9.0,' DOLLAR00033500
*S') 00033600
WRITE(6,417) PP(I,J) 00033700
417 FORMAT(' COST OF PERMITS :',F9.0,' DOLLAR00033800
*S') 00033900
400 CONTINUE 00034000
222 WRITE(6,210) WC(I) 00034100
210 FORMAT(' TOTAL CURRENT COSTS :',F00034200
*9.0,' DOLLARS') 00034300
WRITE(23,230) AR,I,IJ(I),IS(I),IP(I),PR(I),BQ(I),BBOD(I),Q1(I),BOD00034400
*1(I),Q2(I),BOD2(I),Q3(I),BOD3(I),Q4(I),BOD4(I),UQ(I),UBOD(I),FQ(I)00034500
*,FBOD(I),SBOD(I),CBOD(I),RAT(I),CI(I),VC(I),UC(I),PC(I),WC(I),SR(I)00034600
*),ALM(I),OE(I),TC(I),TTI(I),TCI(I),TNE(I),TPP(I) 00034700
62 CONTINUE 00034800
STOP 00034900
END 00035000
C THIS SUBROUTINE IS USED FOR PRINTING BASIC INFORMATION 00035200
SUBROUTINE INFO(AR,IA,IJ,IP,PRIT,DQIT,DBODIT,PQIT,PBODIT,UQ1IT, 00035300
*UBODIT,SBODIT,CBODIT) 00035400
CHARACTER*1 AR 00035500
WRITE(6,112) 00035600
112 FORMAT(1H1,/1H0,' WATER QUALITY SIMULATION GAME') 00035700
WRITE(6,114) AR 00025800
114 FORMAT(1H0,' REGION :',1X,A1) 00035900
WRITE(6,105) IP 00036000
105 FORMAT(' GAME PERIOD :',I2) 00036100
WRITE(6,115) IA 00036200
115 FORMAT(' REPORT FOR TEAM :',I2) 00036300
WRITE(6,125) 00036400
125 FORMAT(/1H0,' DECISIONS FOR WATER QUALITY MANAGEMENT') 00036500
WRITE(6,135) DQIT 00036600
135 FORMAT(' CURRENT DESIGN CAPACITY :',F7.3,' MGD') 00036700
WRITE(6,145) DBODIT 00036800
145 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION:',F5.1,' MG/L00036900
*') 00037000
WRITE(6,146) SBODIT 00037100
146 FORMAT(' CURRENT MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION 00037200
*TO THE RIVER:',F6.1,' MG/L') 00037300
IF (IJ.GT.1) GO TO 101 00037400
WRITE(6,155) 00037500
155 FORMAT(' THIS IS INDUSTRIAL FIRM') 00037600
GO TO 102 00037700
101 WRITE(6,165) 00027800
165 FORMAT(' THIS IS MUNICIPAL TREATMENT PLANT') 00037900
WRITE(6,175) UQ1IT 00038000
175 FORMAT(' ACTUAL RESIDENTIAL WASTEWATER FLOW RATE 00038100
* :',F7.3,' MGD') 00038200
WRITE(6,185) UBODIT 00038300
185 FORMAT(' ACTUAL RESIDENTIAL WASTEWATER BOD INFLUENT CONCENTRATION 00038400
* :',F5.1,' MG/L') 00038500
GO TO 103 00038600
102 IF (IA.EQ.2) GO TO 104 00038700
WRITE(6,195) PRIT 00038800
195 FORMAT(' PRODUCTION FORECAST :',F7.3,' MILLIO00038900

```

```

*N POUNDS OF PRODUCT')          00039000
GO TO 106                        00039100
104 WRITE(6,196) PRIT             00039200
196 FORMAT(' PRODUCTION FORECAST :',F7.3,' MILLION00039300
*NS OF BIRDS')                   00039400
106 WRITE(6,205) FQIT             00039500
205 FORMAT(' EXPECTED WASTEWATER FLOW RATE :',F7.3,' MGD') 00039600
WRITE(6,215) FBODIT              00039700
215 FORMAT(' EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,' MG/L00039800
*')                               00039900
103 RETURN                        00040000
END                               00040100
                                00040200
C THIS SUBROUTINE IS USED FOR PRINTING ALTERNATIVE 00040300
SUBROUTINE SALT(IS,Q1IT,BOD1IT,Q2IT,BOD2IT,Q3IT,BOD3IT,Q4IT,BOD4IT00040400
*)                                00040500
WRITE(6,201)                     00040600
201 FORMAT(/1H0,' THIS IS YOUR ALTERNATIVE') 00040700
GO TO (101,102,103,104,106,107,108,109),IS 00040800
101 WRITE(6,105)                  00040900
105 FORMAT(' TREAT EVERYTHING IN THE COMPANY PLANT & RELEASE.') 00041000
WRITE(6,115) Q1IT                00041100
115 FORMAT(' TREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00041200
WRITE(6,125) BOD1IT             00041300
125 FORMAT(' EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00041400
*')                               00041500
GO TO 325                        00041600
102 WRITE(6,135)                 00041700
135 FORMAT(' PRETREAT EVERYTHING IN THE COMPANY PLANT & SEND TO THE MU00041800
*NICIPAL PLANT.')              00041900
WRITE(6,145) Q2IT               00042000
145 FORMAT(' PRETREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00042100
WRITE(6,155) BOD2IT            00042200
155 FORMAT(' EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00042300
*')                               00042400
GO TO 325                        00042500
103 WRITE(6,165)                 00042600
165 FORMAT(' SEND ALL WASTEWATER TO THE MUNICIPAL PLANT WITHOUT TREATM00042700
*ENT.')                          00042800
WRITE(6,175) Q3IT              00042900
175 FORMAT(' SEND WASTEWATER FLOW RATE :',F7.3,' MGD') 00043000
WRITE(6,185) BOD3IT            00043100
185 FORMAT(' SEND WASTEWATER BOD CONCENTRATION :',F5.1,' MG/L00043200
*')                               00043300
GO TO 325                        00043400
104 WRITE(6,195)                 00043500
195 FORMAT(' TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OTHER00043600
* PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT.') 00043700
WRITE(6,205) Q1IT              00043800
205 FORMAT(' TREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00043900
WRITE(6,215) BOD1IT            00044000
215 FORMAT(' TREATED WASTEWATER BOD EFFLUENT CONCENTRATION :00044100
*,F5.1,' MG/L')                00044200
WRITE(6,225) Q3IT              00044300
225 FORMAT(' WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,' MGD') 00044400
WRITE(6,235) BOD3IT            00044500
235 FORMAT(' WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION :00044600
*,F5.1,' MG/L')                00044700
GO TO 325                        00044800
106 WRITE(6,245)                 00044900
245 FORMAT(' PRETREAT PART IN THE COMPANY PLANT & SEND TO MUNICIPAL 00045000
*PLANT, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT00045100
*')                               00045200
WRITE(6,255) Q2IT              00045300
255 FORMAT(' PRETREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00045400
WRITE(6,265) BOD2IT            00045500
265 FORMAT(' PRETREATED WASTEWATER BOD EFFLUENT CONCENTRATION :00045600
*,F5.1,' MG/L')                00045700
WRITE(6,275) Q3IT              00045800
275 FORMAT(' WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,' MGD') 00045900
WRITE(6,285) BOD3IT            00046000
285 FORMAT(' WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION :00046100
*,F5.1,' MG/L')                00046200
GO TO 325                        00046300
107 WRITE(6,295)                 00046400
295 FORMAT(' DISCHARGE WITHOUT PERMIT') 00046500
WRITE(6,305) Q4IT              00046600
305 FORMAT(' DISCHARGED WASTEWATER FLOW RATE :',F7.3,' MGD') 00046700
WRITE(6,315) BOD4IT            00046800
315 FORMAT(' DISCHARGED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00046900
*')                               00047000
GO TO 325                        00047100
108 WRITE(6,335)                 00047200
335 FORMAT(' TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OTHER00047300
* PART WITHOUT TREATMENT TO THE RIVER.') 00047400
WRITE(6,345) Q1IT              00047500
345 FORMAT(' TREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00047600
WRITE(6,355) BOD1IT            00047700
355 FORMAT(' TREATED WASTEWATER BOD EFFLUENT CONCENTRATION :00047800
*,F5.1,' MG/L')                00047900
WRITE(6,225) Q4IT              00048000
365 FORMAT(' DISCHARGED WASTEWATER FLOW RATE :',F7.3,' MGD') 00048100
WRITE(6,375) BOD4IT            00048200
375 FORMAT(' DISCHARGED WASTEWATER BOD EFFLUENT CONCENTRATION :00048300
*,F5.1,' MG/L')                00048400
GO TO 325                        00048500
109 WRITE(6,385)                 00048600
385 FORMAT(' DISCHARGE WITH PERMIT') 00048700
WRITE(6,395) Q4IT              00048800
395 FORMAT(' DISCHARGED WASTEWATER FLOW RATE :',F7.3,' MGD') 00048900
WRITE(6,405) BOD4IT            00049000
405 FORMAT(' DISCHARGED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00049100
*')                               00049200
325 RETURN                        00049300
END                               00049400
                                00049500
C THIS SUBROUTINE IS USED FOR PRINTING UPGRADE PLAN 00049600
SUBROUTINE SHUPGR(FQIT,FBODIT) 00049700
WRITE(6,105)                     00049800
105 FORMAT(/1H0,' THIS IS YOUR UPGRADE PLAN') 00049900
WRITE(6,115) FQIT               00050000
115 FORMAT(' FUTURE DESIGN CAPACITY :',F7.3,' MGD') 00050100
WRITE(6,125) FBODIT            00050200
125 FORMAT(' FUTURE DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00050300
*')                               00050400
RETURN                            00050500
END                               00050600

```

APPENDIX F

INTERACTIVE FORTRAN PROGRAM FOR  
PARTICIPANT INPUT

\*\*\* TSO FOREGROUND HARDCOPY \*\*\*\*  
 \$NAME=U11502C.SIMT.CNTL

THIS IS AN INTERACTIVE INPUT PROGRAM FOR STUDENTS. THE STUDENT HAS TO PROVIDE TEAM NUMBER (TEAM 1 TO 5 ARE INDUSTRIAL FIRMS, TEAM 6 AND 7 ARE MUNICIPAL TREATMENT PLANTS), PERIOD NUMBERS, BASIC INFORMATION OF PRODUCTION VOLUME PRODUCED, WASTEWATER FLOW RATE AND BOD CONCENTRATION. IF THE STUDENT WANTS TO BUY PERMITS, HE CAN ONLY CHOOSE ALTERNATIVE 1, 4, 7 OR ALTERNATIVE 8, IF HE WANTS TO SELL PERMITS, HE CAN CHOOSE ANY ONE OF THESE EIGHT ALTERNATIVE TO TREAT ITS WASTEWATER AND DECIDE WHETHER TO UPGRADE EXISTING PLANT OR NOT. IF THE STUDENT WANTS TO UPGRADE THE PLANT, THE UPGRADE TAKES 2 PERIODS OF TIME.  
 THIS PROGRAM WILL READ PLANT FILE AND TDP FILE. THE PROGRAM WILL BE CREATED AS A LOAD MODULE AND EXECUTED BY TSO COMMAND LANGUAGE (INPUTA.CLIST).  
 THE PROGRAM WILL GENERATE STUDENT DECISION FILE AND PLANT FILE. THE STUDENT DECISION FILE WILL BE FED INTO MAIN PROGRAM AND INSTRUCTOR INPUT PROGRAM. THE PLANT FILE WILL BE FED INTO MAIN PROGRAM AND STUDENT INPUT PROGRAM LATER.

SQ(I) -> THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE TO THE RIVER (MGD), TEAM I  
 SBOD(I) -> THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE RIVER (MG/L), TEAM I  
 PBOD(I) -> WASTEWATER BOD CONCENTRATION PRODUCED (MG/L), FIRM I  
 PF(I) -> PRODUCTION FUNCTION OF INDUSTRIAL PRODUCT, FIRM I  
 RMBOD -> THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE MUNICIPAL TREATMENT PLANT (MG/L)

DIMENSION PR(7),PQ(7),PROD(7),DQ(7),DBOD(7),FQ(7),FBOD(7),Q1(7),BOD1(7),Q2(7),BOD2(7),Q3(7),BOD3(7),Q4(7),BOD4(7),UQ1(7),UBOD1(7),F(7),SQ(7),SBOD(7),PF(7),TDP(7),CBOD(7)

CHARACTER\*1 AR  
 DATA SQ/1.7,0.38,0.03,0.04,2.,26.7,5.6/  
 DATA SBOD/30.,24.,40.,20.,45.,10./  
 DATA PBOD/200.,300.,400.,100.,400.,0.,0./  
 DATA PF/0.4848,0.1212,0.0379,0.1569,0.0379,0.,0./  
 DATA RMBOD/400./

READ TRADING NUMBER PERMITS OF EACH TEAM  
 READ(9,107) (IF(I),TDP(IF(I)),I=1,7)  
 .07 FORMAT(I2,1X,F10.2)  
 READ CURRENT DESIGN CAPACITY AND DESIGN BOD EFFLUENT CONCENTRATION  
 .14 READ(10,115,END=101) I,DQ(I),DBOD(I)  
 .15 FORMAT(I2,1X,F6.3,F5.1)  
 GO TO 114  
 .101 DO 116 I=1,7  
 PQ(I)=0.  
 .16 CONTINUE  
 SBOD(1)=30.  
 SBOD(2)=24.  
 SBOD(3)=40.  
 SBOD(4)=20.  
 SBOD(5)=20.  
 SBOD(6)=45.  
 SBOD(7)=10.  
 MFLG AND INFLG ARE FLAGS TO CONTROL SWITCH  
 MFLG=-1

INFLG=-1 00006000  
 IS=0 00006100  
 00006200  
 00006300  
 C INPUT BASIC INFORMATION FOR THE SIMULATION GAME 00006400  
 123 FORMAT(1X,'PLEASE ENTER YOUR REGION (E.G. A, B OR C)') 00006500  
 READ(5,124) AR 00006600  
 124 FORMAT(A1) 00006700  
 PRINT 125 00006800  
 125 FORMAT(1X,'PLEASE ENTER YOUR TEAM NUMBER AGAIN (E.G. 1)') 00006900  
 READ\*,IT 00007000  
 PRINT 135 00007100  
 135 FORMAT(1X,'PLEASE ENTER YOUR PERIOD NUMBER AGAIN (E.G. 1)') 00007200  
 READ\*,IP 00007300  
 CALL INTALT(IFLAG,Q1(IT),BOD1(IT),Q2(IT),BOD2(IT),Q3(IT),BOD3(IT),Q4(IT),BOD4(IT),UQ1(IT),UBOD1(IT),FQ(IT),FBOD(IT)) 00007400  
 IF (IT.LE.5) GO TO 201 00007500  
 IF (IT.GT.5) GO TO 202 00007600  
 201 IJ=1 00007700  
 PRINT 145 00007800  
 145 FORMAT(1X,'INDUSTRIAL FIRM') 00007900  
 91 PRINT 155 00008000  
 155 FORMAT(1X,'ENTER YOUR PRODUCTION FORCAST') 00008100  
 READ\*,PR(IT) 00008200  
 PQ(IT)=PR(IT)\*PF(IT) 00008300  
 PRINT 165,PQ(IT) 00008400  
 165 FORMAT(1X,'EXPECTED WASTEWATER FLOW RATE :',F7.3,'MGD') 00008500  
 PRINT 175,PBOD(IT) 00008600  
 175 FORMAT(1X,'EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,' MG/L') 00008700  
 PRINT 185 00008800  
 185 FORMAT(1X,'DO YOU WANT TO TRY ANOTHER PRODUCTION LEVEL') 00008900  
 CALL YESNO(IA) 00009000  
 IF (IA.EQ.1) GO TO 91 00009100  
 IF (IA.EQ.2) GO TO 210 00009200  
 IA.EQ.1 --> YES, IA.EQ.2 --> NO 00009300  
 C 00009400  
 202 IJ=2 00009500  
 PRINT 140 00009600  
 140 FORMAT(1X,'MUNICIPAL TREATMENT PLANT') 00009700  
 PRINT 150 00009800  
 150 FORMAT(1X,'ENTER YOUR RESIDENTIAL WASTEWATER FLOW RATE (MGD)') 00009900  
 READ\*,UQ1(IT) 00010000  
 PRINT 160 00010100  
 160 FORMAT(1X,'ENTER YOUR RESIDENTIAL WASTEWATER BOD INFLUENT CONCENTRATION (MG/L)') 00010200  
 \*ATON (MG/L)') 00010300  
 READ\*,UBOD1(IT) 00010400  
 CALL MPEBOD(DBOD(IT),CBOD(IT),SBOD(IT)) 00010500  
 210 CALL INFO(AR,IT,:J,IP,PR(IT),DQ(IT),DBOD(IT),PQ(IT),PBOD(IT),UQ1(IT),UBOD1(IT),TDP(IT),SBOD(IT),CBOD(IT)) 00010600  
 \*T),UBOD1(IT),TDP(IT),SBOD(IT),CBOD(IT)) 00010700  
 102 PRINT 195 00010800  
 195 FORMAT(1X,'DO YOU WANT TO SELECT AN ALTERNATIVE FOR DISPOSING OF CURRENT PERIOD WASTEWATER OR UPGRADE EXISTING PLANT') 00010900  
 PRINT 196 00011000  
 196 FORMAT('OR CORRECT SOME INFORMATION') 00011100  
 CALL YESNO(IA) 00011200  
 IF ((IA.EQ.2).AND.(IJ.EQ.2)) GO TO 765 00011300  
 IF (IA.EQ.2) GO TO 501 00011400  
 C FLAG FOR MUNICIPAL TREATMENT PLANT EFFECTIVE FOR 190 FORMAT 00011500  
 IF (MFLG.EQ.0) GO TO 180 00011600  
 C FLAG FOR INDUSTRIAL FIRM EFFECTIVE FOR 265 FORMAT 00011700  
 IF (INFLG.EQ.0) GO TO 255 00011800  
 PRINT 215 00011900  
 C ASK FOR ANY CORRECTION ? 00012000  
 215 FORMAT(1X,'IS THE INFORMATION SHOWN ABOVE CORRECT?') 00012100  
 CALL CORT(IC) 00012200  
 IF (IJ.EQ.1) GO TO 103 00012300  
 IF (IC.EQ.1) GO TO 735 00012400  
 00012500

	IF (IC.EQ.2) GO TO 180	00012600	IF (IB.EQ.2) GO TO 255	00019200
		00012700		00019300
	MAKE CORRECTION FOR THE MUNICIPAL TREATMENT PLANT	00012800	C SELECT ALTERNATIVE FOR DISPOSING WASTEWATER	00019400
180	PRINT 190	00012900	495 PRINT 505	00019500
190	FORMAT(' TYPE VARIABLE NUMBER TO BE CHANGED OR -1 TO LIST THE INFORMATION YOU HAVE')	00013000	505 FORMAT(/1X,'SELECT ALTERNATIVE FOR DISPOSING OF CURRENT PERIOD WAS00019600	
	PRINT 200	00013100	*WATER - ENTER NUMBER')	00019700
200	FORMAT(' FOR EXAMPLE: TYPE 2 FOR PERIOD NUMBER')	00013200	162 CALL INTACT(IFLAG,Q1(IT),BOD1(IT),Q2(IT),BOD2(IT),Q3(IT),BOD3(IT),00019800	
	READ*,MFLG	00013300	*Q4(IT),BOD4(IT),DQ1(IT),UBOD1(IT),FQ(IT),FBOD(IT))	00019900
	IF (MFLG.GE.0) GO TO 205	00013400	C PRINT LIST OF ALTERNATIVES	00020000
	MFLG=0	00013500	PRINT 515	00020100
	GO TO 210	00013600	515 FORMAT(1X,'1 TREAT EVERYTHING IN THE COMPANY PLANT & RELEASE.')	00020200
	IN=MFLG	00013700	PRINT 525	00020300
205	GO TO (285,295,225,235,245),IN	00013800	525 FORMAT(1X,'2 PRETREAT EVERYTHING IN THE COMPANY PLANT & SEND TO TH00020400	
	PRINT 260,IN	00013900	*E MUNICIPAL PLANT.')	00020500
260	FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00014000	00014000	PRINT 535	00020600
	* REASONABLE VALUE')	00014100	535 FORMAT(1X,'3 SEND ALL WASTE TO THE MUNICIPAL PLANT WITHOUT TREATME00020700	
	GO TO 180	00014200	*NT.')	00020800
225	PRINT 150	00014300	PRINT 555	00020900
	READ*,DQ(IT)	00014400	555 FORMAT(1X,'4 TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE 00021000	
	CALL CORT(IB)	00014500	*THER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT.')	00021100
	IF (IB.EQ.1) GO TO 210	00014600	PRINT 565	00021200
	IF (IB.EQ.2) GO TO 180	00014700	565 FORMAT(1X,'5 PRETREAT PART IN THE COMPANY PLANT & SEND TO MUNICIPAL00021300	
235	PRINT 160	00014800	* PLANT, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLA00021400	
	READ*,UBOD1(IT)	00014900	*NT.')	00021500
	CALL CORT(IB)	00015000	PRINT 574	00021600
	IF (IB.EQ.1) GO TO 210	00015100	574 FORMAT(1X,'6 DISCHARGE WITHOUT PERMIT.')	00021700
	IF (IB.EQ.2) GO TO 180	00015200	PRINT 575	00021800
245	CALL MPEBOD(DBOD(IT),CBOD(IT),SBOD(IT))	00015300	575 FORMAT(1X,'7 TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE 00021900	
	CALL CORT(IB)	00015400	*THER PART WITHOUT TREATMENT TO THE RIVER.')	00022000
	IF (IB.EQ.1) GO TO 210	00015500	PRINT 576	00022100
	IF (IB.EQ.2) GO TO 180	00015600	576 FORMAT(1X,'8 DISCHARGE WITH PERMIT.')	00022200
103	IF (IC.EQ.1) GO TO 495	00015700	PRINT 577	00022300
	IF (IC.EQ.2) GO TO 255	00015800	577 FORMAT(1X,'IF YOU BUY PERMITS, YOU CAN ONLY CHOOSE ALTERNATIVE 1, 40022400	
		00015900	* 7 OR ALTERNATIVE 8')	00022500
		00016000	PRINT 578	00022600
	MAKE CORRECTION FOR THE INDUSTRIAL FIRM	00016100	578 FORMAT(1X,'IF YOU SELL PERMITS, YOU CAN CHOOSE ANY ONE OF THESE S100022700	
255	PRINT 265	00016200	*X ALTERNATIVES')	00022800
265	FORMAT(' TYPE VARIABLE NUMBER TO BE CHANGED OR -1 TO LIST THE INFORMATION YOU HAVE')	00016300	READ*,IS	00022900
	PRINT 275	00016400	GO TO (585,595,605,615,625,635,665,666),IS	00023000
275	FORMAT(' FOR EXAMPLE: TYPE 3 FOR PRODUCTION FORCAST')	00016500	PRINT 645,IS	00023100
	READ*,INFLG	00016600	645 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE CORRECT00023200	
	IF (INFLG.GE.0) GO TO 266	00016700	* YOUR ALTERNATIVE')	00023300
	INFLG=0	00016800	GO TO 495	00023400
	GO TO 210	00016900	585 CALL TECP(IFLAG,DQ(IT),DBOD(IT),PQ(IT),PBOD(IT),SQ(IT),SBOD(IT),Q100023500	
266	IN=MFLG	00017000	* (IT),BOD1(IT),TDP(IT))	00023600
	GO TO (285,295,305),IN	00017100	IF (IFLAG.EQ.1) GO TO 495	00023700
	PRINT 260,IN	00017200	GO TO 555	00023800
	GO TO 255	00017300	595 CALL PESH(IFLAG,DQ(IT),DBOD(IT),PQ(IT),PBOD(IT),RMBOD,Q2(IT),BOD2(00023900	
285	PRINT 125	00017400	*IT),TDP(IT))	00024000
	READ*,IT	00017500	IF (IFLAG.EQ.1) GO TO 495	00024100
	CALL CORT(IB)	00017600	GO TO 655	00024200
	IF (IB.EQ.1) GO TO 210	00017700	605 CALL SEMP(IFLAG,PQ(IT),PBOD(IT),Q3(IT),BOD3(IT),TDP(IT),RMBOD) 00024300	
	IF ((IB.EQ.2).AND.(IJ.EQ.1)) GO TO 255	00017800	IF (IFLAG.EQ.1),GO TO 495	00024400
	IF ((IB.EQ.2).AND.(IJ.EQ.2)) GO TO 180	00017900	GO TO 655	00024500
295	PRINT 135	00018000	615 CALL TPCWM(IFLAG,DQ(IT),DBOD(IT),PQ(IT),PBOD(IT),SQ(IT),SBOD(IT),20024600	
	READ*,IP	00018100	*1(IT),BOD1(IT),Q3(IT),BOD3(IT),TDP(IT))	00024700
	CALL CORT(IB)	00018200	IF (IFLAG.EQ.1) GO TO 495	00024800
	IF (IB.EQ.1) GO TO 210	00018300	GO TO 655	00024900
	IF ((IB.EQ.2).AND.(IJ.EQ.1)) GO TO 255	00018400	625 CALL PFCWM(IFLAG,DQ(IT),DBOD(IT),PQ(IT),PBOD(IT),RMBOD,Q2(IT),BOD200025000	
	IF ((IB.EQ.2).AND.(IJ.EQ.2)) GO TO 180	00018500	* (IT),Q3(IT),BOD3(IT),TDP(IT))	00025100
305	PRINT 155	00018600	IF (IFLAG.EQ.1) GO TO 495	00025200
	READ*,PR(IT)	00018700	GO TO 655	00025300
	PQ(IT)=PR(IT)*PF(IT)	00018800	635 CALL WDUMP(IFLAG,PQ(IT),PBOD(IT),Q4(IT),BOD4(IT),TDP(IT)) 00025400	
	CALL CORT(IB)	00018900	IF (IFLAG.EQ.1) GO TO 495	00025500
	IF (IB.EQ.1) GO TO 210	00019000	GO TO 655	00025600
		00019100	665 CALL TFSR (IFLAG,DQ(IT),DBOD(IT),PQ(IT),PBOD(IT),SQ(IT),SBOD(IT),Q00025700	

```

*1(IT),BOD1(IT),Q4(IT),BOD4(IT),TDP(IT))          00025800
IF (IFLAG.EQ.1) GO TO 495                          00025900
GO TO 655                                          00026000
666 CALL WPDUMP(IFLAG,PQ(IT),PBOD(IT),Q4(IT),BOD4(IT),TDP(IT)) 00026100
IF (IFLAG.EQ.1) GO TO 495                          00026200
855 CALL SALT(1S,Q1(IT),BOD1(IT),Q2(IT),BOD2(IT),Q3(IT),BOD3(IT),Q4(IT),BOD4(IT)) 00026300
*) ,BOD4(IT))                                     00026400
PRINT 675                                          00026500
675 FORMAT(1X,'IS THIS CORRECT')                  00026600
681 PRINT 685                                      00026700
685 FORMAT(1X,'ENTER 1 IF CORRECT')               00026800
PRINT 695                                          00026900
695 FORMAT(1X,'ENTER 2 IF WANT TO DELETE CHOSEN ALTERNATIVE AND SELECT ANOTHER ALTERNATIVE') 00027000
* ANOTHER ALTERNATIVE')                          00027100
READ*,IC                                           00027200
IF (IC.EQ.1) GO TO 735                             00027300
IF (IC.EQ.2) GO TO 715                             00027400
PRINT 705,IC                                       00027500
705 FORMAT(' WARNING: ',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 00027600
* REASONABLE VALUE')
GO TO 161                                          00027700
715 PRINT 725                                      00027800
725 FORMAT(1X,'ENTER ALTERNATIVE NUMBER TO BE SELECTED') 00027900
GO TO 162                                          00028000
DECIDE TO UPGRADE EXISTING PLANT                  00028100
735 PRINT 745                                      00028200
745 FORMAT(1X,'DO YOU WANT TO UPGRADE EXISTING PLANT') 00028300
CALL YESNO(1A)                                    00028400
IF (1A.EQ.2) GO TO 765                             00028500
CALL UPGRAD(IFLAG,DQ(IT),DBOD(IT),FQ(IT),FBOD(IT),SQ(IT),SBOD(IT)) 00028600
765 CALL INFO(AR,IT,IJ,IP,PR(IT),DQ(IT),DBOD(IT),FQ(IT),PBOD(IT),UQ1(IT),UBOD1(IT),TDP(IT),SBOD(IT),CBOD(IT)) 00028700
*) ,BOD1(IT),TDP(IT),SBOD(IT),CBOD(IT))          00028800
IF (IJ.EQ.2) GO TO 104                             00028900
CALL SALT(1S,Q1(IT),BOD1(IT),Q2(IT),BOD2(IT),Q3(IT),BOD3(IT),Q4(IT),BOD4(IT)) 00029000
*) ,BOD4(IT))                                     00029100
104 IF (1A.EQ.2) GO TO 775                          00029200
IF (IFLAG.EQ.1) GO TO 775                          00029300
CALL SHUPGR(FQ(IT),FBOD(IT))                      00029400
775 PRINT 785                                      00029500
785 FORMAT(' THIS WILL BE STORED AS YOUR DECISION FOR THIS PERIOD IN A DATA FILE.') 00029600
* DATA FILE.')
PRINT 795                                          00029700
795 FORMAT(' IF YOU WANT TO INPUT ALL THE DATA AGAIN, PLEASE TYPE -1 OTHERWISE TYPE 0') 00029800
READ*,IFLG                                        00029900
IF (IFLG.GE.0) GO TO 805                           00030000
GO TO 101                                          00030100
PRINT OUTPUT FOR STUDENT DECISION FILE            00030200
805 WRITE(11,50) AR,IT,IJ,IS,IP,PR(IT),PQ(IT),PROD(IT),Q1(IT),BOD1(IT),Q2(IT),BOD2(IT),Q3(IT),BOD3(IT),Q4(IT),BOD4(IT),UQ1(IT),UBOD1(IT)) 00030300
*) ,FQ(IT),FBOD(IT),SBOD(IT),CBOD(IT))          00030400
50 FORMAT(A1,I1,F6.3,F6.3,F5.1)/F6.3,3F5.1) 00030500
IF(FQ(IT).LE.D) GO TO 815                          00030600
PRINT OUTPUT FOR PLANT FILE                      00030700
WRITE(20,806) IT,FQ(IT),FBOD(IT)                  00030800
806 FORMAT(I2,1X,F6.3,F5.1)                        00030900
GO TO 501                                          00031000
815 WRITE(20,806) IT,DQ(IT),DBOD(IT)              00031100
501 STOP                                          00031200
END                                                00031300
THIS SUBROUTINE IS USED FOR INITIALIZATION        00031400
SUBROUTINE INTALT(LFLAG,Q1IT,BOD1IT,Q2IT,BOD2IT,Q3IT,BOD3IT,Q4IT,UBOD1IT,SBODIT,CBODIT) 00031500
*OD4IT,UQ1IT,UBODIT,FQIT,FBODIT)                00031600
IFLAG=0                                           00031700
Q1IT=0.                                           00031800
BOD1IT=0.                                         00031900
Q2IT=0.                                           00032000
BOD2IT=0.                                         00032100
Q3IT=0.                                           00032200
BOD3IT=0.                                         00032300
Q4IT=0.                                           00032400
BOD4IT=0.                                         00032500
UQ1IT=0.                                          00032600
UBODIT=0.                                         00032700
FQIT=0.                                           00032800
FBODIT=0.                                         00032900
RETURN                                             00033000
END                                                00033100
C THIS SUBROUTINE IS USED FOR SELECTING MUNICIPAL PLANT WASTEWATER OD EFFLUENT CONCENTRATION 00033200
C SUBROUTINE MPEBOD(DBODIT,CBODIT,SBODIT)         00033300
PRINT 105,DBODIT                                  00033400
105 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION ',F5.1,' MG/L') 00033500
* ',F5.1,' MG/L')
PRINT 115,SBODIT                                  00033600
115 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO HE RIVER ',F5.1,' MG/L') 00033700
*HE RIVER ',F5.1,' MG/L')
155 PRINT 125                                      00033800
125 FORMAT(1X,'ENTER EXPECTED BOD EFFLUENT CONCENTRATION (MG/L)') 00033900
READ*,CBODIT                                      00034000
C SHOW RESTRICTION ITEMS                          00034100
IF (CBODIT.GE.DBODIT) GC TO 135                    00034200
PRINT 145,CBODIT,DBODIT                           00034300
145 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L L00034400
*EXCEEDS THE DESIGN BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00034500
GO TO 155                                          00034600
135 IF (CBODIT.LE.SBODIT) GO TO 165               00034700
PRINT 175,CBODIT,SBODIT                           00034800
175 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L E00034900
*EXCEED THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00035000
165 RETURN                                         00035100
END                                                00035200
C THIS SUBROUTINE IS USED FOR PRINTING BASIC INFORMATION 00035300
SUBROUTINE INFO(AR,IT,IJ,IP,PRIT,DQIT,DBODIT,PQIT,PRODIT,UQ1IT,UBOD1IT,SBODIT,CBODIT) 00035400
*DIT,TDPIT,SBODIT,CBODIT)                        00035500
PRINT 105                                          00035600
105 FORMAT(1X,' THIS IS THE INFORMATION YOU HAVE') 00035700
PRINT 114,AR                                       00035800
114 FORMAT(1X,' REGION ',I1,X,A1) .                00035900
PRINT 115,IT                                       00036000
115 FORMAT(1X,' 1.TEAM NUMBER ',I2)                00036100
PRINT 125,IP                                       00036200
125 FORMAT(1X,' 2.PERIOD NUMBER ',I2)              00036300
PRINT 135,DQIT                                     00036400
135 FORMAT(1X,' CURRENT DESIGN CAPACITY ',F7.3,'MGD') 00036500
PRINT 145,DBODIT                                   00036600
145 FORMAT(1X,' CURRENT DESIGN BOD EFFLUENT CONCENTRATION : ',F5.1,'MG/L00036700
*) ' )
PRINT 146,SBODIT                                   00036800
146 FORMAT(1X,' CURRENT MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE RIVER ',F6.1,' MG/L') 00036900
* N TO THE RIVER ',F6.1,' MG/L')
IF (TDPIT) 104,106,107                             00037000
104 PRINT 147, ABS(TDPIT)                           00037100
147 FORMAT(1X,' NUMBER OF PERMITS SOLD ',F6.2)    00037200
GO TO 106                                          00037300
107 PRINT 148,TDPIT                                 00037400
148 FORMAT(1X,' NUMBER OF PERMITS BOUGHT ',F6.2)  00037500

```



```

.06 IF (I,J.GT.1) GO TO 101                                00039000
    PRINT 155                                              00039100
.155 FORMAT(1X,' THIS IS INDUSTRIAL FIRM')                00039200
    GO TO 102                                              00039300
.01 PRINT 165                                              00039400
.165 FORMAT(1X,' THIS IS MUNICIPAL TREATMENT PLANT')     00039500
    PRINT 175,QIIT                                         00039600
.75 FORMAT(1X,'3.EXPECTED RESIDENTIAL WASTEWATER FLOW RATE  00039700
    :',F7.3,'MGD')                                        00039800
    PRINT 185,UBODIT                                       00039900
.85 FORMAT(1X,'4.EXPECTED RESIDENTIAL WASTEWATER BOD INFLUENT CONCENTR00040000
    *ATION :',F5.1,'MG/L')                                00040100
    PRINT 186,CBODIT                                       00040200
.186 FORMAT(1X,'5.EXPECTED MUNICIPAL PLANT WASTEWATER BOD EFFLUENT CONC00040300
    *ENTRATION :',F5.1,'MG/L')                           00040400
    GO TO 103                                              00040500
.102 PRINT 195,PRIT                                        00040600
.95 FORMAT(1X,'3.PRODUCTION FORECAST :',F7.3)            00040700
    PRINT 205,QIIT                                         00040800
.205 FORMAT(1X,' EXPECTED WASTEWATER FLOW RATE :',F7.3,'MGD') 00040900
    PRINT 215,PBODIT                                       00041000
.215 FORMAT(1X,' EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,'MG/00041100
    *L')                                                  00041200
.103 RETURN                                              00041300
    END                                                    00041400
    THIS SUBROUTINE IS USED FOR ALTERNATIVE "TREAT EVERYTHING IN THE 00041500
    COMPANY PLANT AND RELEASE"                               00041600
    SUBROUTINE TECP(IFLAG,DQIT,DBODIT,QIIT,PBODIT,SQIT,SBODIT,QIIT,BOD00041700
    *IIT,TDPIT)                                             00041800
    IFLAG=0                                                00041900
    SHOW BASIC INFORMATION                                00042000
    PRINT 205                                             00042100
.105 FORMAT(' TREAT EVERYTHING IN THE COMPANY PLANT & RELEASE.') 00042200
    PRINT 115,DQIT                                         00042300
.15 FORMAT(' CURRENT DESIGN CAPACITY :',F7.3,'MGD')      00042400
    PRINT 125,DBODIT                                       00042500
.25 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,'  00042600
    *')                                                    00042700
    IF (TDPIT) 126,127,128                                00042800
.126 PRINT 129, ABS(TDPIT)                                00042900
.129 FORMAT(' NUMBER OF PERMITS SOLD :',F6.2)             00043000
    GO TO 127                                              00043100
.128 PRINT 130,TDPIT                                       00043200
.130 FORMAT(' NUMBER OF PERMITS BOUGHT :',F6.2)           00043300
.27 PRINT 135,POIT                                         00043400
.35 FORMAT(' EXPECTED WASTEWATER FLOW RATE :',F7.3,'MGD') 00043500
    PRINT 145,PBODIT                                       00043600
.45 FORMAT(' EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,' MG/L00043700
    *')                                                    00043800
    PRINT 146,SQIT                                         00043900
.146 FORMAT(' THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE TO THE RIV00044000
    *ER :',F7.3,'MGD')                                    00044100
    PRINT 147,SBODIT                                       00044200
.147 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO T00044300
    *HE RIVER :',F5.1,' MG/L')                            00044400
    SHOW RESTRICTION ITEMS                                00044500
    IF (QIIT.LE.DQIT) GO TO 160                            00044600
.155 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE',F9.5,'MGD EXCEEDS 00044700
    *THE DESIGN CAPACITY',F9.5,'MGD')                     00044800
    PRINT 156                                              00044900
.156 FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION, PLEASE CONSID00045000
    *ER ALTERNATIVE 3,4,5,6')                             00045100
    GO TO 102                                              00045200
.160 IF (QIIT.LE.SQIT) GO TO 164                          00045300
    PRINT 157,POIT,SQIT                                    00045400
.157 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE',F9.5,'MGD EXCEEDS 00045500
    *THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE TO THE RIVER',F9.5,00045600
    *'MGD')                                                00045700
    PRINT 156                                              00045800
    GO TO 102                                              00045900
.164 CALL YESNO(IA)                                       00046000
    IF (IA.EQ.2) GO TO 102                                00046100
.175 QIIT=POIT                                           00046200
    PERMIT SOLD IS NEGATIVE SIGN IN THE INPUT FILE       00046300
.101 BODIIT=(SBODIT*SQIT)/QIIT+TDPIT/8.34                00046400
    GET INPUT DATA                                       00046500
    PRINT 185                                              00046600
.185 FORMAT(1X,'ENTER DESIRED BOD EFFLUENT CONCENTRATION (MG/L') 00046700
    READ*,BODIIT                                          00046800
    PRINT 100                                              00046900
.100 FORMAT(1X,'THIS IS YOUR ALTERNATIVE')                00047000
    PRINT 195,QIIT                                         00047100
.195 FORMAT(1X,'TREATED WASTEWATER FLOW RATE :',F7.3,'MGD') 00047200
    PRINT 205,BODIIT                                       00047300
.205 FORMAT(1X,'EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L') 00047400
    MAKE CORRECTION                                       00047500
.107 PRINT 215                                             00047600
.215 FORMAT(' IS THIS CORRECT')                           00047700
.103 PRINT 225                                             00047800
.225 FORMAT(' ENTER 1 IF CORRECT')                        00047900
    PRINT 235                                              00048000
.235 FORMAT(' ENTER 2 IF WANT TO CHANGE BOD EFFLUENT CONCENTRATION') 00048100
    PRINT 245                                              00048200
.245 FORMAT(' ENTER 3 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 00048300
    READ*,IC                                              00048400
    GO TO (265,175,102),IC                                00048500
.255 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00048600
    * REASONABLE VALUE')                                  00048700
    GO TO 103                                              00048800
.102 IFLAG=1                                             00048900
    QIIT=0.                                                00049000
    BODIIT=0.                                              00049100
    GO TO 335                                              00049200
.305 QIIT=FLG                                             00049300
    GO TO 101                                              00049400
.265 IF (QIIT.LE.DQIT) GO TO 335                          00049500
    PRINT 325,QIIT,DQIT                                    00049600
.325 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE ',F7.3,'MGD EXCEEDS00049700
    *THE DESIGN WASTEWATER CAPACITY ',F7.3,'MGD')         00049800
    PRINT 326                                              00049900
.326 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DI00050000
    *FFERENT ALTERNATIVE')                               00050100
    READ*,FLG                                             00050200
    IF (FLG.GE.0.) GO TO 305                              00050300
    GO TO 102                                              00050400
.335 RETURN                                              00050500
    END                                                    00050600
    THIS SUBROUTINE IS USED FOR ALTERNATIVE "PRETREAT EVERYTHING IN 00050700
    THE COMPANY PLANT & SEND TO THE MUNICIPAL TREATMENT" 00050800
    SUBROUTINE PESM(IFLAG,DQIT,DBODIT,QIIT,PBODIT,RMBOD,Q2IT,BOD2IT,TD00050900
    *PIT)                                                  00051000
    IFLAG=0                                                00051100
    PRINT 105                                              00051200
.105 FORMAT(' PRETREAT EVERYTHING IN THE COMPANY PLANT & SEND TO THE MU00051300
    *NICIPAL PLANT.')                                     00051400
    IF (TDPIT.LE.0.) GO TO 104                            00051500
    PRINT 114,TDPIT                                       00051600
.114 FORMAT(' NUMBER OF PERMITS BOUGHT IS',F5.0,'SORRY THIS IS INFEASIB00051700

```

```

*LE SOLUTION, PLEASE CONSIDER ALTERNATIVE 1,4') 00052200
GO TO 102 00052300
SHOW BASIC INFORMATION 00052400
104 PRINT 115,DQIT 00052500
FORMAT(' CURRENT DESIGN CAPACITY :',F7.3,'MGD') 00052600
PRINT 125,DBODIT 00052700
125 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00052800
*') 00052900
PRINT 135,PQIT 00053000
FORMAT(' EXPECTED WASTEWATER FLOW RATE :',F7.3,'MGD') 00053100
135 PRINT 145,PSODIT 00053200
FORMAT(' EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,' MG/L00053300
*') 00053400
PRINT 146,RMBOD 00053500
146 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO T00053600
*HE MUNICIPAL TREATMENT PLANT :',F5.1,' MG/L') 00053700
SHOW RESTRICTION ITEMS 00053800
IF (PQIT.LE.DQIT) GO TO 161 00053900
PRINT 155,PQIT,DQIT 00054000
155 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE',F9.5,'MGD EXCEED T00054100
*HE DESIGN CAPACITY',F9.5,'MGD') 00054200
PRINT 156 00054300
FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION, PLEASE CONSIDER00054400
*ER ALTERNATIVE 3,4,5,6') 00054500
GO TO 102 00054600
161 IF (DBODIT.LE.RMBOD) GO TO 164 00054700
PRINT 162,RMBOD,DBODIT 00054800
162 FORMAT(' WARNING: THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG00054900
*/L LOWERS THE DESIGN BOD EFFLUENT CONCENTRATION LIMITS',F5.1,'MG/L00055000
*') 00055100
PRINT 163 00055200
FORMAT(' SORRY THIS INFEASIBLE SOLUTION, PLEASE CONSIDER00055300
* ALTERNATIVE 3,6') 00055400
GO TO 102 00055500
164 CALL YESNO(IA) 00055600
IF (IA.EQ.2) GO TO 102 00055700
Q2IT=PQIT 00055800
GET INPUT DATA 00055900
175 PRINT 185 00056000
185 FORMAT(IX,'ENTER DESIRED BOD EFFLUENT CONCENTRATION (MG/L') 00056100
READ*,BOD2IT 00056200
101 PRINT 100 00056300
100 FORMAT(IX,'THIS IS YOUR ALTERNATIVE') 00056400
PRINT 195,Q2IT 00056500
195 FORMAT(IX,'PRETREATED WASTEWATER FLOW RATE :',F7.3,'MGD') 00056600
PRINT 205,BOD2IT 00056700
205 FORMAT(IX,'EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L') 00056800
MAKE CORRECTION 00056900
PRINT 215 00057000
215 FORMAT(' IS THIS CORRECT') 00057100
103 PRINT 225 00057200
225 FORMAT(' ENTER 1 IF CORRECT') 00057300
PRINT 235 00057400
235 FORMAT(' ENTER 2 IF WANT TO CHANGE BOD EFFLUENT CONCENTRATION') 00057500
PRINT 245 00057600
245 FORMAT(' ENTER 3 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 00057700
READ*,IC 00057800
GO TO (265,175,102),IC 00057900
PRINT 255,IC 00058000
255 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00058100
* REASONABLE VALUE') 00058200
GO TO 103 00058300
265 IF (BOD2IT.LE.RMBOD) GO TO 285 00058400
PRINT 275,BOD2IT,RMBOD 00058500
275 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L 00058600
*OWERS THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L PLEASE IN00058700

* PUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATI00058800
*VE') 00058900
READ*,FLG 00059000
IF (FLG.GE.0.) GO TO 305 00059100
102 IFLAG=1 00059200
BOD2IT=0. 00059300
GO TO 335 00059400
305 BOD2IT=FLG 00059500
GO TO 101 00059600
285 IF (BOD2IT.GE.DBODIT) GO TO 335 00059700
PRINT 325,BOD2IT,DBODIT 00059800
325 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L 00059900
*OWERS THE DESIGN BOD EFFLUENT CONCENTRATION LIMITATION',F5.1,'MG/L00060000
*') 00060100
PRINT 326 00060200
FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DI00060300
*FFERENT ALTERNATIVE') 00060400
READ*,FLG 00060500
IF (FLG.GE.0.) GO TO 305 00060600
GO TO 102 00060700
335 RETURN 00060800
END 00060900
00061000
C THIS SUBROUTINE IS USED FOR ALTERNATIVE "SEND ALL WASTE TO THE 00061100
MUNICIPAL TREATMENT WITHOUT TREATMENT" 00061200
C SUBROUTINE SEMP(IFLAG,PQIT,PSODIT,Q3IT,BOD3IT,TDPT,RMBOD) 00061300
IFLAG=0 00061400
PRINT 105 00061500
105 FORMAT(IX,'SEND ALL WASTE TO THE MUNICIPAL PLANT WITHOUT TREATMENT00061600
*') 00061700
BOD3IT=PSODIT 00061800
IF (TDPT.LE.0.) GO TO 103 00061900
PRINT 115,TDPT 00062000
115 FORMAT(' NUMBER OF PERMITS BOUGHT IS',F5.0,'SORRY THIS IS INFEASIB00062100
*LE SOLUTION, PLEASE CONSIDER ALTERNATIVE 1,4') 00062200
GO TO 102 00062300
103 IF (BOD3IT.LE.RMBOD) GO TO 104 00062400
PRINT 125,BOD3IT,RMBOD 00062500
125 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L 00062600
*OWERS THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00062700
PRINT 135 00062800
135 FORMAT(' SORRY THIS INFEASIBLE SOLUTION, PLEASE CONSIDER00062900
* ALTERNATIVE 1,2,6') 00063000
GO TO 102 00063100
104 CALL YESNO(IA) 00063200
IF (IA.EQ.2) GO TO 102 00063300
Q3IT=PQIT 00063400
PRINT 100 00063500
100 FORMAT(IX,'THIS IS YOUR ALTERNATIVE') 00063600
PRINT 145,Q3IT 00063700
145 FORMAT(IX,'SEND WASTEWATER FLOW RATE TO THE MUNICIPAL PLANT 00063800
* :',F6.2,'MGD') 00063900
PRINT 155,BOD3IT 00064000
155 FORMAT(IX,'EXPECTED BOD EFFLUENT CONCENTRATION TO THE MUNICIPAL P00064100
*LANT :',F6.2,'MG/L') 00064200
MAKE CORRECTION 00064300
PRINT 165 00064400
165 FORMAT(' IS THIS CORRECT') 00064500
101 PRINT 175 00064600
175 FORMAT(' ENTER 1 IF CORRECT') 00064700
PRINT 185 00064800
185 FORMAT(' ENTER 2 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 00064900
READ*,IC 00065000
GO TO (205,102),IC 00065100
PRINT 195,IC 00065200
195 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00065300

```

```

* REASONABLE VALUE')
GO TO 101
102 IFLAG=1
Q3IT=0.
BOD3IT=0.
205 RETURN
END

THIS SUBROUTINE IS USED FOR ALTERNATIVE "TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT"
SUBROUTINE TPCWM(IFLAG,DQIT,DBODIT,PQIT,PBODIT,SQIT,SBODIT,Q1IT,BOD1IT,BOD3IT,TDPIIT)
*DLIT,Q3IT,BOD3IT,TDPIIT)
IFLAG=0
SHOW BASIC INFORMATION
PRINT 105
105 FORMAT(' TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT')
PRINT 115,DQIT
:15 FORMAT(' CURRENT DESIGN CAPACITY :',F7.3,'MGD')
PRINT 125,DBODIT
:25 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L)
*1)
IF (TDPIIT) 126,127,128
:26 PRINT 129, ABS(TDPIIT)
:29 FORMAT(' NUMBER OF PERMITS SOLD :',F6.2)
GO TO 127
:28 PRINT 130,TDPIIT
:30 FORMAT(' NUMBER OF PERMITS BOUGHT :',F6.2)
:27 PRINT 135,PQIT
:35 FORMAT(' EXPECTED WASTEWATER FLOW RATE :',F7.3,'MGD')
PRINT 145,PRODIT
:45 FORMAT(' EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,' MG/L)
*1)
PRINT 154,SQIT
:54 FORMAT(' THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE TO THE RIVER :',F7.3,'MGD')
*ER :',F7.3,'MGD')
PRINT 155,SBODIT
:55 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE RIVER :',F7.3,'MG/L')
*HE RIVER :',F7.3,'MG/L')
SHOW RESTRICTION ITEMS
101 CALL YESNO(IA)
IF (IA.EQ.2) GO TO 102
GET INPUT DATA
IN=0
385 PRINT 185
:85 FORMAT(IX,'ENTER TREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT',F7.3,'MGD')
READ*,Q1IT
104 IF (Q1IT.LE.PQIT) GO TO 201
PRINT 195,Q1IT,PQIT
:95 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT EXCEEDS THE PRODUCTION WASTEWATER FLOW RATE',F7.3,'MGD')
*T',F7.3,'MGD EXCEEDS THE PRODUCTION WASTEWATER FLOW RATE',F7.3,'MGD')
*D')
PRINT 196
:96 FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION PLEASE INPUT A REASONABLE VALUE')
GO TO 385
201 IF (Q1IT.LE.DQIT) GO TO 205
PRINT 197,Q1IT,DQIT
:97 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT EXCEEDS THE DESIGN CAPACITY',F7.3,'MGD')
*T',F7.3,'MGD EXCEEDS THE DESIGN CAPACITY',F7.3,'MGD')
PRINT 198
:98 FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE')
*A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE')
GO TO 103
READ*,FLG
00065400
00065500
00065600
00065700
00065800
00065900
00066000
00066100
00066200
00066300
00066400
00066500
00066600
00066700
00066800
00066900
00067000
00067100
00067200
00067300
00067400
00067500
00067600
00067700
00067800
00067900
00068000
00068100
00068200
00068300
00068400
00068500
00068600
00068700
00068800
00068900
00069000
00069100
00069200
00069300
00069400
00069500
00069600
00069700
00069800
00069900
00070000
00070100
00070200
00070300
00070400
00070500
00070600
00070700
00070800
00070900
00071000
00071100
00071200
00071300
00071400
00071500
00071600
00071700
00071800
00071900
IF (FLG.GE.0.) GO TO 325
102 IFLAG=1
Q1IT=0.
BOD1IT=0.
GO TO 475
325 Q1IT=FLG
GO TO 104
C202 IF (Q1IT.LE.SQIT) GO TO 205
C PRINT 199,Q1IT,SQIT
C199 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT EXCEEDS THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE',F7.3,'MGD')
*E',F7.3,'MGD')
C PRINT 198
C READ*,FLG
C IF (FLG.GE.0.) GO TO 325
C GO TO 102
205 Q3IT=PQIT-Q1IT
IF (IN.EQ.1) GO TO 108
PRINT 175
175 FORMAT(IX,'ENTER DESIRED BOD EFFLUENT CONCENTRATION FROM THE COMPANY PLANT & RELEASE TO THE RIVER (MG/L)')
*NY PLANT & RELEASE TO THE RIVER (MG/L)')
READ*,BOD1IT
C MEASURE THE TDP'S EFFECT ON ALLOWED BOD EFFLUENT CONCENTRATION
Q1IT*BOD1IT-SBODIT*SQIT+TDPIIT
C BOD3IT=PRODIT
107 PRINT 215
215 FORMAT(IX,'THIS IS YOUR ALTERNATIVE')
PRINT 225,Q1IT
225 FORMAT(IX,'1.TREATED WASTEWATER FLOW RATE :',F7.3,'MGD')
PRINT 235,BOD1IT
235 FORMAT(IX,'2.TREATED WASTEWATER BOD EFFLUENT CONCENTRATION :',F5.1,'MG/L')
*1,'MG/L')
PRINT 245,Q3IT
245 FORMAT(IX,'WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,'MGD')
PRINT 255,BOD3IT
255 FORMAT(IX,'WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION :',F5.1,'MG/L')
*:',F5.1,'MG/L')
IF (DTBOD) 110,111,112
C 110 PRINT 256, ABS(DTBOD)
C 256 FORMAT(IX,'THE ALLOWED BOD EFFLUENT CONCENTRATION WILL BE DECREASED BY',F6.1,'MG/L BY SELLING PERMITS')
D BY',F6.1,'MG/L BY BUYING PERMITS')
C GO TO 113
C 112 PRINT 257,DTBOD
C 257 FORMAT(IX,'THE ALLOWED BOD EFFLUENT CONCENTRATION WILL BE INCREASED BY',F6.1,'MG/L BY BUYING PERMITS')
D BY',F6.1,'MG/L BY BUYING PERMITS')
C PRINT 258,SBODIT
C 113 PRINT 258,SBODIT
C 258 FORMAT(IX,'THE CURRENT MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE RIVER IS',F6.1,'MG/L BY TRADING PERMITS')
MAKE CORRECTION
PRINT 265
265 FORMAT(' IS THIS CORRECT')
103 PRINT 275
275 FORMAT(' ENTER 1 IF CORRECT')
PRINT 285
285 FORMAT(' ENTER 2 IF NEED TO MAKE A CHANGE')
PRINT 295
295 FORMAT(' ENTER 3 IF WANT TO INPUT DATA AGAIN')
PRINT 305
305 FORMAT(' ENTER 4 IF WANT TO SELECT DIFFERENT ALTERNATIVE')
READ*,IC
GO TO (475,345,106,102),IC
PRINT 315,IC
315 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE')
*A REASONABLE VALUE')
GO TO 103
345 PRINT 355
00072000
00072100
00072200
00072300
00072400
00072500
00072600
00072700
00072800
00072900
00073000
00073100
00073200
00073300
00073400
00073500
00073600
00073700
00073800
00073900
00074000
00074100
00074200
00074300
00074400
00074500
00074600
00074700
00074800
00074900
00075000
00075100
00075200
00075300
00075400
00075500
00075600
00075700
00075800
00075900
00076000
00076100
00076200
00076300
00076400
00076500
00076600
00076700
00076800
00076900
00077000
00077100
00077200
00077300
00077400
00077500
00077600
00077700
00077800
00077900
00078000
00078100
00078200
00078300
00078400
00078500

```

```

55 FORMAT(' TYPE VARIABLE NUMBER TO BE CHANGED')          00078600
   PRINT 365                                              00078700
.65 FORMAT(' FOR EXAMPLE: TYPE 2 FOR TREATED BOD EFFLUENT CONCENTRATION TO THE RIVER') 00078800
   READ* IN                                              00078900
   GO TO (385,109),IN                                    00079000
   PRINT 375,IN                                          00079200
75 FORMAT(' WARNING: ',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 00079300
   GO TO 345                                             00079400
.09 PRINT 175                                             00079500
   READ*,BODLIT                                         00079600
.108 PRINT 395                                           00079700
.395 FORMAT(' ENTER 1 IF CORRECT')                       00079800
   PRINT 405                                             00079900
.105 FORMAT(' ENTER 2 IF NEED TO MAKE MORE CORRECTION') 00080000
   READ*,IB                                              00080100
   IF (IB.EQ.1) GO TO 107                                00080200
   IF (IB.EQ.2) GO TO 345                                00080300
   PRINT 415,IB                                          00080400
.115 FORMAT(' WARNING: ',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 00080500
   GO TO 425,BODLIT,SBODIT                              00080600
.125 IF (BODLIT.LE.SBODIT) GO TO 455                    00080700
   PRINT 425,BODLIT,SBODIT                              00080800
.125 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L LOWERS THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00080900
   PRINT 426                                             00081000
.126 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE') 00081100
   READ*,FLG                                             00081200
   IF (FLG.GE.0.) GO TO 435                              00081300
   GO TO 102                                             00081400
.135 BODLIT=FLG                                          00081500
   GO TO 107                                             00081600
.155 IF (BODLIT.GE.DBODIT) GO TO 475                     00081700
   PRINT 465,BODLIT,DBODIT                              00081800
.165 FORMAT(' WARNING: TREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L EXCEEDS THE DESIGN BOD EFFLUENT CONCENTRATION LIMITATION',F5.1,'MG/L') 00081900
   PRINT 466                                             00082000
.166 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE') 00082100
   READ*,FLG                                             00082200
   IF (FLG.GE.0.) GO TO 305                              00082300
.175 RETURN                                             00082400
   END                                                  00082500
   THIS SUBROUTINE IS USED FOR SUBROUTINE "PRETREAT PART IN THE COMPANY PLANT & SEND TO THE MUNICIPAL PLANT, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT"
   SUBROUTINE PPCWM(IFLAG,DQIT,DBODIT,PQIT,PBODIT,RMBOD,Q2IT,BOD2IT,Q3IT,BOD3IT,TDPT)
   IFLAG=0
   SHOW BASIC INFORMATION
   PRINT 105
.105 FORMAT(' PRETREAT PART IN THE COMPANY PLANT & SEND TO THE MUNICIPAL PLANT, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT')
   IF (TDPT.LE.0.) GO TO 110
   PRINT 114,TDPT
.114 FORMAT(' NUMBER OF PERMITS BOUGHT IS',F5.0,'SORRY THIS IS INFEASIBLE SOLUTION, PLEASE CONSIDER ALTERNATIVE 1,4')
   GO TO 102
.110 PRINT 115,DQIT
.115 FORMAT(' CURRENT DESIGN CAPACITY',F7.3,'MGD')
125 PRINT 125,DBODIT
125 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION',F5.1,' MG/L')
*')
   PRINT 135,PQIT
135 FORMAT(' EXPECTED WASTEWATER FLOW RATE',F7.3,'MGD')
   PRINT 145,PBODIT
145 FORMAT(' EXPECTED BOD INFLUENT CONCENTRATION',F5.1,' MG/L')
*')
   PRINT 146,RMBOD
146 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO THE MUNICIPAL TREATMENT PLANT',F5.1,'MG/L')
C SHOW RESTRICTION ITEMS
   IF (DBODIT.LE.RMBOD) GO TO 101
   PRINT 147,RMBOD,DBODIT
147 FORMAT(' WARNING: THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L LOWERS THE DESIGN BOD EFFLUENT CONCENTRATION LIMITATION',F5.1,'MG/L')
*MG/L')
   PRINT 148
148 FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION, PLEASE CONSIDER ALTERNATIVE 3,6')
   GO TO 102
101 CALL YESNO(1A)
   IF (1A.EQ.2) GO TO 102
C GET INPUT DATA
106 IN=0
385 PRINT 185
185 FORMAT(1X,'ENTER TREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT (MGD)')
   READ*,Q2IT
104 IF (Q2IT.LE.PQIT) GO TO 201
   PRINT 195,Q2IT,PQIT
195 FORMAT(' WARNING: PRETREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT EXCEEDS THE PRODUCTION WASTEWATER FLOW RATE',F7.3,'MGD')
*')
   PRINT 196
196 FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION PLEASE INPUT A REASONABLE VALUE')
   GO TO 385
201 IF (Q2IT.LE.DQIT) GO TO 205
   PRINT 197,Q2IT,DQIT
197 FORMAT(' WARNING: PRETREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT EXCEEDS THE DESIGN CAPACITY',F7.3,'MGD')
   PRINT 198
198 FORMAT(' SORRY THIS IS INFEASIBLE SOLUTION PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE')
   READ*,FLG
   IF (FLG.GE.0.) GO TO 325
102 IFLAG=1
   Q2IT=0
   BOD2IT=0
   GO TO 475
325 Q2IT=FLG
   GO TO 104
205 Q3IT=PQIT-Q2IT
   IF (IN.EQ.1) GO TO 108
   PRINT 175
175 FORMAT(1X,'ENTER DESIRED BOD EFFLUENT CONCENTRATION FROM THE COMPANY PLANT & RELEASE TO THE RIVER (MG/L)')
   READ*,BOD2IT
   BOD3IT=PBODIT
107 PRINT 215
215 FORMAT(1X,'THIS IS YOUR ALTERNATIVE')
   PRINT 225,Q2IT
225 FORMAT(1X,'1.PRETREATED WASTEWATER FLOW RATE',F7.3,'MGD')
   PRINT 235,BOD2IT
235 FORMAT(1X,'2.PRETREATED WASTEWATER BOD EFFLUENT CONCENTRATION',F5.0)

```

```

*5.1,'MG/L') 00091800
PRINT 245,Q3IT 00091900
245 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,'MGD') 00092000
PRINT 255,BOD3IT 00092100
255 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00092200
* :',F5.1,'MG/L') 00092300
MAKE CORRECTION 00092400
PRINT 265 00092500
265 FORMAT(' IS THIS CORRECT') 00092600
103 PRINT 275 00092700
275 FORMAT(' ENTER 1 IF CORRECT') 00092800
PRINT 285 00092900
285 FORMAT(' ENTER 2 IF NEED TO MAKE A CHANGE') 00093000
PRINT 295 00093100
295 FORMAT(' ENTER 3 IF WANT TO INPUT DATA AGAIN') 00093200
PRINT 305 00093300
305 FORMAT(' ENTER 4 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 00093400
READ*,IC 00093500
GO TO (335,345,106,102),IC 00093600
PRINT 315,IC 00093700
315 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 00093800
* REASONABLE VALUE') 00093900
GO TO 103 00094000
345 PRINT 355 00094100
355 FORMAT(' TYPE VARIABLE NUMBER TO BE CHANGED') 00094200
PRINT 365 00094300
365 FORMAT(' FOR EXAMPLE: TYPE 1 FOR PRETREATED WASTEWATER FLOW RATE') 00094400
READ*,IN 00094500
GO TO (385,109),IN 00094600
PRINT 375,IN 00094700
375 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 00094800
* REASONABLE VALUE') 00094900
GO TO 345 00095000
109 PRINT 175 00095100
READ*,BOD2IT 00095200
108 PRINT 395 00095300
395 FORMAT(' ENTER 1 IF CORRECT') 00095400
PRINT 405 00095500
405 FORMAT(' ENTER 2 IF NEED TO MAKE MORE CORRECTION') 00095600
READ*,IB 00095700
IF (IB.EQ.1) GO TO 107 00095800
IF (IB.EQ.2) GO TO 345 00095900
PRINT 415,IB 00096000
415 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 00096100
* REASONABLE VALUE') 00096200
GO TO 108 00096300
335 IF (BOD2IT.LE.RMBOD) GO TO 455 00096400
PRINT 425,BOD2IT,RMBOD 00096500
425 FORMAT(' WARNING: PRETREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00096600
*L LOWERS THE ALLOWED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00096700
PRINT 426 00096800
426 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE') 00096900
*ELECT DIFFERENT ALTERNATIVE') 00097000
READ*,FLG 00097100
IF (FLG.GE.0.) GO TO 435 00097200
GO TO 102 00097300
135 BOD2IT=FLG 00097400
GO TO 107 00097500
455 IF (BOD2IT.GE.DBODIT) GO TO 475 00097600
PRINT 465,BOD2IT,DBODIT 00097700
465 FORMAT(' WARNING: PRETREATED BOD EFFLUENT CONCENTRATION',F5.1,'MG/L') 00097800
*L LOWERS THE DESIGN BOD EFFLUENT CONCENTRATION LIMITS',F5.1,'MG/L') 00097900
*) 00098000
PRINT 466 00098100
466 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE') 00098200
*ELECT DIFFERENT ALTERNATIVE') 00098300

READ*,FLG 00098400
IF (FLG.GE.0.) GO TO 435 00098500
GO TO 102 00098600
475 RETURN 00098700
END 00098800
00098900
C THIS SUBROUTINE IS USED FOR SUBROUTINE "DISCHARGE WITHOUT PERMIT" 00099000
SUBROUTINE WDMPT(IFLAG,PQIT,PBODIT,Q4IT,BOD4IT,TDPIT) 00099100
IFLAG=0 00099200
C SHOW BASIC INFORMATION 00099300
PRINT 105 00099400
105 FORMAT(1X,'DISCHARGE WITHOUT PERMIT') 00099500
IF (TDPIT.LE.0.) GO TO 103 00099600
PRINT 115,TDPIT 00099700
115 FORMAT(' NUMBER OF PERMITS BOUGHT IS',F5.0,'SORRY THIS IS INFEASIBLE SOLUTION, PLEASE CONSIDER ALTERNATIVE 1, 4, 7 OR 8') 00099800
*LE SOLUTION, PLEASE CONSIDER ALTERNATIVE 1, 4, 7 OR 8') 00099900
GO TO 102 01000000
103 CALL YESNO(IA) 01000100
IF (IA.EQ.2) GO TO 102 01000200
Q4IT=PQIT 01000300
BOD4IT=PBODIT 01000400
PRINT 100 01000500
100 FORMAT(1X,'THIS IS YOUR ALTERNATIVE') 01000600
145 FORMAT(1X,'DISCHARGE WASTEWATER FLOW RATE :',F7.3,'MGD') 01000700
PRINT 155,BOD4IT 01000800
155 FORMAT(1X,'EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L') 01000900
C MAKE CORRECTION 01001000
PRINT 165 01001100
165 FORMAT(' IS THIS CORRECT') 01001200
101 PRINT 175 01001300
175 FORMAT(' ENTER 1 IF CORRECT') 01001400
PRINT 185 01001500
185 FORMAT(' ENTER 2 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 01001600
READ*,IC 01001700
GO TO (205,102),IC 01001800
PRINT 195,IC 01001900
195 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A REASONABLE VALUE') 01002000
* REASONABLE VALUE') 01002100
GO TO 101 01002200
102 IFLAG=1 01002300
Q4IT=0. 01002400
BOD4IT=0. 01002500
205 RETURN 01002600
END 01002700
01002800
01002900
C THIS SUBROUTINE IS USED FOR ALTERNATIVE "TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OTHER PART WITHOUT TREATMENT TO THE RIVER" 01003000
SUBROUTINE TPSR (IFLAG,DQIT,DBODIT,PQIT,PBODIT,SQIT,SBODIT,QLIT,BOO103300
*DLIT,Q4IT,BOD4IT,TDPIT) 01003100
IFLAG=0 01003200
C SHOW BASIC INFORMATION 01003300
PRINT 105 01003400
105 FORMAT(' TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT') 01003500
* PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT') 01003600
PRINT 115,DQIT 01003700
115 FORMAT(' CURRENT DESIGN CAPACITY :',F7.3,'MGD') 01003800
PRINT 125,DBODIT 01003900
125 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L') 01004000
*) 01004100
IF (TDPIT) 126,127,128 01004200
126 PRINT 129, ABS(TDPIT) 01004300
129 FORMAT(' NUMBER OF PERMITS SOLD :',F6.2) 01004400
GO TO 127 01004500
128 PRINT 130,TDPIT 01004600
01004700
01004800
01004900

```

```

30 FORMAT(' NUMBER OF PERMITS BOUGHT          :',F6.2)          00105000
27 PRINT 135,PQIT                                          00105100
35 FORMAT(' EXPECTED WASTEWATER FLOW RATE      :',F7.3,'MGD')  00105200
   PRINT 145,PBODIT                                       00105300
45 FORMAT(' EXPECTED BOD INFLUENT CONCENTRATION :',F5.1,' MG/L00105400
   *)
   PRINT 154,SQIT                                          00105500
54 FORMAT(' THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE TO THE RIV00105600
   ER :',F7.3,'MGD')                                     00105700
   PRINT 155,SBODIT                                       00105800
55 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO T00106000
   HE RIVER :',F7.3,'MG/L')                               00106100
   SHOW RESTRICTION ITEMS                                00106200
.01 CALL YESNO(1A)                                         00106300
   IF (1A.EQ.2) GO TO 102                                 00106400
   GET INPUT DATA                                       00106500
06 IN=0                                                    00106600
85 PRINT 185                                              00106700
85 FORMAT(1X,'ENTER TREATED WASTEWATER FLOW RATE IN THE COMPANY PLANT00106800
   (MGD)')                                                00106900
04 READ*,Q1IT                                             00107000
   IF (Q1IT.LE.PQIT) GO TO 201                            00107100
   PRINT 195,Q1IT,PQIT                                    00107200
95 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE IN THE COMPANY PLAN00107300
   *T',F7.3,'MGD EXCEEDS THE PRODUCTION WASTEWATER FLOW RATE',F7.3,'MG00107400
   *D')                                                    00107500
   PRINT 196                                              00107600
96 FORMAT('          SORRY THIS IS INFEASIBLE SOLUTION PLEASE INPUT 00107700
   *A REASONABLE VALUE')                                  00107800
   GO TO 385                                              00107900
.01 IF (Q1IT.LE.DQIT) GO TO 205                            00108000
   PRINT 197,Q1IT,DQIT                                    00108100
.97 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE IN THE COMPANY PLAN00108200
   *T',F7.3,'MGD EXCEEDS THE DESIGN CAPACITY',F7.3,'MGD') 00108300
   PRINT 198                                              00108400
98 FORMAT('          SORRY THIS IS INFEASIBLE SOLUTION PLEASE INPUT A00108500
   * REASONABLE VALUE OR ENTER -1 TO SELECT DIFFERENT ALTERNATIVE') 00108600
   READ*,FLG                                             00108700
   IF (FLG.GE.0.) GO TO 325                               00108800
.02 IFLAG=1                                               00108900
   Q1IT=0.                                                00109000
   BODLIT=0.                                              00109100
   GO TO 475                                              00109200
.25 Q1IT=FLG                                              00109300
   GO TO 104                                              00109400
.02 IF (Q1IT.LE.SQIT) GO TO 205                            00109500
   PRINT 199,Q1IT,SQIT                                    00109600
99 FORMAT(' WARNING: TREATED WASTEWATER FLOW RATE IN THE COMPANY PLAN00109700
   *T',F7.3,'MGD EXCEEDS THE MAXIMUM LIMITATION OF WASTEWATER FLOW RAT00109800
   *E',F7.3,'MGD')                                       00109900
   PRINT 198                                              00110000
   READ*,FLG                                             00110100
   IF (FLG.GE.0.) GO TO 325                               00110200
   GO TO 102                                              00110300
35 Q1IT=PQIT-Q1IT                                         00110400
   IF (1N.EQ.1) GO TO 108                                 00110500
   PRINT 175                                              00110600
.75 FORMAT(1X,'ENTER DESIRED BOD EFFLUENT CONCENTRATION FROM THE COMP00110700
   *NY PLANT & RELEASE TO THE RIVER (MG/L)')             00110800
   READ*,BODLIT                                          00110900
   MEASURE THE TDP'S EFFECT ON ALLOWED BOD EFFLUENT CONCENTRATION 00111000
   BOD4IT=PBODIT                                         00111100
.07 PRINT 215                                              00111200
.15 FORMAT(1X,'THIS IS YOUR ALTERNATIVE')                00111300
   PRINT 225,Q1IT                                         00111400
.25 FORMAT(1X,'1.TREATED WASTEWATER FLOW RATE          :',F7.3,'MGD') 00111500

PRINT 235,BOD1IT                                          00111600
235 FORMAT(1X,'2.TREATED WASTEWATERE BOD EFFLUENT CONCENTRATION :',F5.00111700
   *1,'MG/L')                                             00111800
   PRINT 245,Q4IT                                         00111900
245 FORMAT(1X,'DISCHARGED WASTEWATER FLOW RATE TO THE RIVER:',F7.3,'M00112000
   *GD')                                                  00112100
   PRINT 255,BOD4IT                                       00112200
255 FORMAT(1X,'DISCHARGED WASTEWATER BOD EFFLUENT CONCENTRATION:',F5.00112300
   *1,'MG/L')                                             00112400
C MAKE CORRECTION                                         00112500
   PRINT 265                                              00112600
265 FORMAT(' IS THIS CORRECT')                            00112700
103 PRINT 275                                             00112800
275 FORMAT(' ENTER 1 IF CORRECT')                          00112900
   PRINT 285                                              00113000
285 FORMAT(' ENTER 2 IF NEED TO MAKE A CHANGE')           00113100
   PRINT 295                                              00113200
295 FORMAT(' ENTER 3 IF WANT TO INPUT DATA AGAIN')       00113300
   PRINT 305                                              00113400
305 FORMAT(' ENTER 4 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 00113500
   READ*,IC                                              00113600
   GO TO (475,345,106,102),IC                             00113700
   PRINT 315,IC                                           00113800
315 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00113900
   * REASONABLE VALUE')                                  00114000
   GO TO 103                                              00114100
345 PRINT 355                                             00114200
355 FORMAT(' TYPE VARIABLE NUMBER TO BE CHANGED')        00114300
   PRINT 365                                              00114400
365 FORMAT(' FOR EXAMPLE: TYPE 2 FOR TREATED BOD EFFLUENT CONCENTRATIO00114500
   *N TO THE RIVER')                                    00114600
   READ*,IN                                              00114700
   GO TO (385,109),IN                                     00114800
   PRINT 375,IN                                           00114900
375 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00115000
   * REASONABLE VALUE')                                  00115100
   GO TO 345                                              00115200
109 PRINT 175                                             00115300
   READ*,BODLIT                                          00115400
108 PRINT 395                                             00115500
395 FORMAT(' ENTER 1 IF CORRECT')                          00115600
   PRINT 405                                              00115700
405 FORMAT(' ENTER 2 IF NEED TO MAKE MORE CORRECTION')   00115800
   READ*,IB                                              00115900
   IF (IB.EQ.1) GO TO 107                                 00116000
   IF (IB.EQ.2) GO TO 345                                 00116100
   PRINT 415,IB                                           00116200
415 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00116300
   * REASONABLE VALUE')                                  00116400
   GO TO 108                                              00116500
475 RETURN                                               00116600
   END                                                    00116700
   END                                                    00116800
C THIS SUBROUTINE IS USED FOR SUBROUTINE "DISCHARGE WITH PERMIT" 00116900
   SUBROUTINE WPDUMP(:FLAG,PQIT,PBODIT,Q4IT,BOD4IT,TDPIT) 00117000
   IFLAG=0                                                00117100
C SHOW BASIC INFORMATION                                  00117200
   PRINT 105                                              00117300
105 FORMAT(1X,'DISCHARGE WITH PERMIT')                   00117400
   IF (TDPIT.GT.0.) GO TO 114                             00117500
111 PRINT 112, ABS(TDPIT)                                  00117600
112 FORMAT(' NUMBER OF PERMITS SOLD IS',F5.0,' SORRY THIS IS INFEASIBL00117700
   * SOLUTION, PLEASE CONDIDER OTHER ALTERNATIVE')      00117800
   GO TO 102                                              00117900
114 PRINT 115,TDPIT                                       00118000
115 FORMAT(' NUMBER OF PERMITS BOUGHT IS',F5.0)          00118100

```

```

CALL YESNO(1A)                                00118200
IF (1A.EQ.2) GO TO 102                        00118300
Q4IT=PQIT                                     00118400
BOD4IT=PBODIT                                 00118500
PRINT 100                                     00118600
100 FORMAT(1X,'THIS IS YOUR ALTERNATIVE')     00118700
PRINT 145,Q4IT                                 00118800
145 FORMAT(1X,'DISCHARGED WASTEWATER FLOW RATE :',F7.3,'MGD') 00118900
PRINT 155,BOD4IT                               00119000
155 FORMAT(1X,'DISCHARGED BOD CONCENTRATION :',F5.1,' MG/L') 00119100
MAKE CORRECTION                               00119200
PRINT 165                                       00119300
165 FORMAT(' IS THIS CORRECT')                00119400
101 PRINT 175                                  00119500
175 FORMAT(' ENTER 1 IF CORRECT')             00119600
PRINT 185                                       00119700
185 FORMAT(' ENTER 2 IF WANT TO SELECT DIFFERENT ALTERNATIVE') 00119800
READ*,IC                                       00119900
GO TO (205,102),IC                             00200000
PRINT 195,IC                                   00201000
195 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A0020200
* REASONABLE VALUE')                          00203000
GO TO 101                                       00204000
102 IFLAG=1                                    00205000
Q4IT=0                                         00206000
BOD4IT=0.                                     00207000
205 RETURN                                     00208000
END                                             00209000
THIS SUBROUTINE IS USED FOR PRINTING ALTERNATIVE 00211000
SUBROUTINE SALT(IS,Q1IT,BOD1IT,Q2IT,BOD2IT,Q3IT,BOD3IT,Q4IT,BOD4IT)00212000
*)
PRINT 201                                     00211400
201 FORMAT(1X,'THIS IS YOUR ALTERNATIVE')     00211500
GO TO (101,102,103,104,106,107,108,109),IS    00211600
101 PRINT 105                                  00211700
105 FORMAT(' 1.TREAT EVERYTHING IN THE COMPANY PLANT & RELEASE.') 00211800
PRINT 115,Q1IT                                 00211900
115 FORMAT(' TREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00220000
PRINT 125,BOD1IT                              00221000
125 FORMAT(' EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L') 00222000
GO TO 325                                     00223000
102 PRINT 135                                  00224000
135 FORMAT(' 2.PRETREAT EVERYTHING IN THE COMPANY PLANT & SEND TO THE 00225000
*MUNICIPAL PLANT.')                          00226000
PRINT 145,Q2IT                                 00227000
145 FORMAT(' PRETREATED WASTEWATER FLOW RATE :',F7.3,' MGD') 00228000
PRINT 155,BOD2IT                              00229000
155 FORMAT(' EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L') 00230000
GO TO 325                                     00231000
103 PRINT 165                                  00232000
165 FORMAT(' 3.SEND ALL WASTEWATER TO THE MUNICIPAL PLANT WITHOUT TREA00233000
*MENT.')                                      00234000
PRINT 175,Q3IT                                 00235000
175 FORMAT(1X,'SEND WASTEWATER FLOW RATE :',F7.3,' MGD') 00236000
PRINT 185,BOD3IT                              00237000
185 FORMAT(1X,'SEND WASTEWATER BOD CONCENTRATION :',F5.1,' MG/L') 00238000
GO TO 325                                     00239000
104 PRINT 195                                  00240000
195 FORMAT(' 4. TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OT00241000
*HER PART WITHOUT TREATMENT TO THE MUNICIPAL PLANT.') 00242000
PRINT 205,Q1IT                                 00243000
205 FORMAT(1X,'TREATED WASTEWATER FLOW RATE :',F7.3,'MGD') 00244000
PRINT 215,BOD1IT                              00245000
215 FORMAT(1X,'TREATED WASTEWATER BOD EFFLUENT CONCENTRATION :',F5.1,' 00246000
*MG/L')                                       00247000
PRINT 225,Q3IT                                00248000
225 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,'MGD') 00249000
PRINT 235,BOD3IT                              00250000
235 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION00251000
* :',F5.1,'MG/L')                             00252000
GO TO 325                                     00253000
106 PRINT 245                                  00254000
245 FORMAT(' 5. PRETREAT PART IN THE COMPANY PLANT & SEND TO MUNICIPAL00255000
* PLANT, SEND THE OTHER PART WITHOUT TREATMENT TO THE MUNICIPAL PLA00256000
*NT')                                         00257000
PRINT 255,Q2IT                                 00258000
255 FORMAT(1X,'PRETREATED WASTEWATER FLOW RATE :',F7.3,'MGD') 00259000
PRINT 265,BOD2IT                              00260000
265 FORMAT(1X,'PRETREATED WASTEWATER BOD EFFLUENT CONCENTRATION :',F500261000
*.1,'MG/L')                                   00262000
PRINT 275,Q3IT                                 00263000
275 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,'MGD') 00264000
PRINT 285,BOD3IT                              00265000
285 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION00266000
* :',F5.1,'MG/L')                             00267000
GO TO 325                                     00268000
107 PRINT 295                                  00269000
295 FORMAT(' 6. DISCHARGE WITHOUT PERMIT')     00270000
PRINT 305,Q4IT                                 00271000
305 FORMAT(1X,'DISCHARGE WASTEWATER FLOW RATE :',F7.3,'MGD') 00272000
PRINT 315,BOD4IT                              00273000
315 FORMAT(1X,'EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L')00274000
GO TO 325                                     00275000
108 PRINT 335                                  00276000
335 FORMAT(' 7. TREAT PART IN THE COMPANY PLANT & RELEASE, SEND THE OT00277000
*HER PART WITHOUT TREATMENT TO RIVER.')      00278000
PRINT 345,Q1IT                                 00279000
345 FORMAT(1X,'TREATED WASTEWATER FLOW RATE :',F7.3,'MGD') 00280000
PRINT 355,BOD1IT                              00281000
355 FORMAT(1X,'TREATED WASTEWATER BOD EFFLUENT CONCENTRATION :',F5.1,' 00282000
*MG/L')                                       00283000
PRINT 365,Q4IT                                 00284000
365 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER FLOW RATE :',F7.3,'MGD') 00285000
PRINT 375,BOD4IT                              00286000
375 FORMAT(1X,'WITHOUT TREATMENT WASTEWATER BOD EFFLUENT CONCENTRATION00287000
* :',F5.1,'MG/L')                             00288000
GO TO 325                                     00289000
109 PRINT 385                                  00290000
385 FORMAT(' 8. DISCHARGE WITH PERMIT')       00291000
PRINT 395,Q4IT                                 00292000
395 FORMAT(1X,'DISCHARGE WASTEWATER FLOW RATE :',F7.3,'MGD') 00293000
PRINT 405,BOD4IT                              00294000
405 FORMAT(1X,'EXPECTED BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L')00295000
325 RETURN                                     00296000
END                                             00297000
C THIS SUBROUTINE IS USED FOR UPGRADING EXISTING PLANT 00298000
SUBROUTINE UPGRAD(IFLAG,DQIT,DBODIT,FQIT,FBODIT) 00299000
IFLAG=0                                       00301000
IN=0                                          00302000
C SHOW BASIC INFORMATION                      00303000
PRINT 105                                     00304000
105 FORMAT(' UPGRADE EXISTING PLANT')         00305000
PRINT 115,DQIT                                00306000
115 FORMAT(' CURRENT DESIGN CAPACITY :',F7.3,'MGD') 00307000
PRINT 125,DBODIT                              00308000
125 FORMAT(' CURRENT DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L00309000
*')                                           00310000
PRINT 135,SQIT                                00311000
135 FORMAT(' THE MAXIMUM LIMITATION OF WASTEWATER FLOW RATE TO THE RIV00312000
*ER :',F7.3,'MGD')                          00313000

```

```

PRINT 136,SBODIT                                00131400
.36 FORMAT(' THE MAXIMUM LIMITATION OF BOD EFFLUENT CONCENTRATION TO T00131500
*HE RIVER :',F5.1,' MG/L')                      00131600
CALL YESNO(IA)                                  00131700
IF (IA.EQ.2) GO TO 102                          00131800
GET INPUT DATA                                00131900
.04 PRINT 145                                    00132000
.45 FORMAT(IX,'ENTER FUTURE DESIGN CAPACITY (MGD)') 00132100
READ*,FQIT                                     00132200
IF (IN.EQ.1) GO TO 109                          00132300
.07 PRINT 155                                    00132400
.55 FORMAT(IX,'ENTER FUTURE DESIGN BOD EFFLUENT CONCENTRATION (MG/L)')00132500
READ*,FBODIT                                   00132600
IF (IN.EQ.2) GO TO 109                          00132700
.01 PRINT 160                                    00132800
.00 FORMAT(' THIS IS YOUR UPGRADE PLAN')         00132900
PRINT 165,FQIT                                  00133000
.65 FORMAT(' 1.FUTURE DESIGN CAPACITY           :',F7.3,'MGD')00133100
PRINT 175,FBODIT                                00133200
.75 FORMAT(' 2.FUTURE DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/00133300
*L')                                             00133400
MAKE CORRECTION                                00133500
.08 PRINT 185                                    00133600
.85 FORMAT(' IS THIS CORRECT')                  00133700
.03 PRINT 195                                    00133800
.95 FORMAT(' ENTER 1 IF CORRECT')               00133900
PRINT 205                                       00134000
.105 FORMAT(' ENTER 2 IF NEED TO MAKE A CHANGE') 00134100
PRINT 215                                       00134200
.115 FORMAT(' ENTER 3 IF WANT TO GIVE UP UPGRADE PLAN') 00134300
READ*,IC                                        00134400
GO TO (265,106,102),IC                        00134500
PRINT 225,IC                                    00134600
.125 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00134700
* REASONABLE VALUE')                          00134800
GO TO 103                                       00134900
.06 PRINT 235                                    00135000
.135 FORMAT(IX,'TYPE VARIABLE NUMBLE TO BE CHANGED') 00135100
PRINT 245                                       00135200
.245 FORMAT(IX,'FOR EXAMPLE: TYPE 1 FOR FUTURE DESIGN CAPACITY') 00135300
READ*,IN                                       00135400
IF (IN.EQ.1) GO TO 104                          00135500
IF (IN.EQ.2) GO TO 107                          00135600
PRINT 255,IN                                    00135700
.255 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00135800
* REASONABLE VALUE')                          00135900
GO TO 106                                       00136000
.09 PRINT 335                                    00136100
.335 FORMAT(' ENTER 1 IF CORRECT')              00136200
PRINT 345                                       00136300
.345 FORMAT(' ENTER 2 IF NEED TO MAKE MORE CORRECTION') 00136400
READ*,IB                                       00136500
IF (IB.EQ.1) GO TO 101                          00136600
IF (IB.EQ.2) GO TO 106                          00136700
PRINT 355,IB                                    00136800
.355 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00136900
* REASONABLE VALUE')                          00137000
GO TO 109                                       00137100
.265 IF (FQIT.GE.DQIT) GO TO 285                00137200
PRINT 275,FQIT,DQIT                            00137300
.275 FORMAT(' WARNING: FUTURE DESIGN CAPACITY',F7.3,'MGD LESS THAN THE 00137400
*CURRENT DESIGN CAPACITY',F7.3,'MGD')         00137500
PRINT 276                                       00137600
.276 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO Q00137700
*UIT UPGRADE PLAN')                          00137800
READ*,FLG                                       00137900

IF (FLG.GE.0.) GO TO 295                        00138000
102 IFLAG=1                                     00138100
FQIT=0                                          00138200
FBODIT=0                                       00138300
GO TO 325                                       00138400
.295 FQIT=FLG                                    00138500
GO TO 101                                       00138600
.285 IF (FBODIT.LE.DBODIT) GO TO 325           00138700
PRINT 305,FBODIT,DBODIT                       00138800
.305 FORMAT(' WARNING: FUTURE DESIGN BOD EFFLUENT CONCENTRATION',F5.1,'00138900
*MG/L LARGER THAN CURRENT DESIGN BOD EFFLUENT CONCENTRATION',F5.1,'00139000
*MG/L')                                         00139100
PRINT 306                                       00139200
.306 FORMAT(' PLEASE INPUT A REASONABLE VALUE OR ENTER -1 TO Q00139300
*UIT UPGRADE PLAN')                          00139400
READ*,FLG                                       00139500
IF (FLG.GE.0.) GO TO 315                       00139600
GO TO 102                                       00139700
.315 FBODIT=FLG                                 00139800
GO TO 101                                       00139900
.325 RETURN                                     00140000
END                                             00140100
C THIS SUBROUTINE IS USED FOR PRINTING UPGRADE PLAN 00140200
SUBROUTINE SHUPGR(FQIT,FBODIT)                00140300
PRINT 105                                       00140400
.105 FORMAT(' THIS IS YOUR UPGRADE PLAN')       00140500
PRINT 115,FQIT                                 00140600
.115 FORMAT(' FUTURE DESIGN CAPACITY           :',F7.3,'MGD') 00140700
PRINT 125,FBODIT                              00140800
.125 FORMAT(' FUTURE DESIGN BOD EFFLUENT CONCENTRATION :',F5.1,' MG/L'00140900
*)                                              00141000
RETURN                                         00141100
END                                             00141200
C THIS SUBROUTINE IS USED FOR CORRECTING INPUT 00141300
SUBROUTINE CORT(IB)                           00141400
.155 PRINT 105                                  00141500
.105 FORMAT(IX,'ENTER 1 IF CORRECT')           00141600
PRINT 115                                       00141700
.115 FORMAT(IX,'ENTER 2 IF NEED TO MAKE A CHANGE') 00141800
READ*,IB                                       00141900
IF (IB.EQ.1) GO TO 135                          00142000
IF (IB.EQ.2) GO TO 135                          00142100
PRINT 145,IB                                    00142200
.145 FORMAT(' WARNING:',I2,' EXCEEDS THE BOUNDARY VALUE PLEASE INPUT A00142300
* REASONABLE VALUE')                          00142400
GO TO 155                                       00142500
.135 RETURN                                     00142600
END                                             00142700
C THIS SUBROUTINE IS USED FOR OPTION " YES OR NO " 00142800
SUBROUTINE YESNO(IX)                           00142900
CHARACTER*3 AD                                 00143000
PRINT 105                                       00143100
.105 FORMAT(IX,'ENTER "YES" OR "NO" TO CONFIRM YOUR CHOICE') 00143200
.101 READ(5,31) AD                              00143300
.31 FORMAT(A3)                                  00143400
IF (AD.EQ.'YES') GO TO 102                     00143500
IF (AD.EQ.'NO ') GO TO 103                    00143600
PRINT 115                                       00143700
.115 FORMAT(IX,'PLEASE TYPE "YES" OR "NO"')    00143800
GO TO 101                                       00143900
IX=1                                           00144000
.102 GO TO 104                                  00144100
GO TO 104                                       00144200
END                                             00144300
END                                             00144400
END                                             00144500

```



APPENDIX G

INTERACTIVE FORTRAN PROGRAM FOR PROCTOR INPUT

\* TSO FOREGROUND HARDCOPY \*\*\*\*  
 AME=U11502C,QUAL.CNTL

THIS IS AN INTERACTIVE INPUT PROGRAM FOR INSTRUCTORS. THE INSTRUCTOR HAS ONLY TO CHOOSE A SEASON INDEX ( 1 FOR SPRING 2 FOR SUMMER 3 FOR FALL AND 4 FOR WINTER ) AND THE PROGRAM WILL CHOOSE THE SUITABLE TEMPERATURE, BOD CONCENTRATION AND FLOW RATE AUTOMATICALLY. THIS PROGRAM WILL READ POINT SOURCE FLOW RATE AND BOD CONCENTRATION FROM STUDENT DECISION FILES. THE PROGRAM WILL BE CREATED AS A LOAD MODULE AND EXECUTED BY TSO COMMAND LANGUAGE ( SQWAL.LLIST ). THE PROGRAM WILL GENERATE A WATER QUALITY FILE. THIS DATA FILE WILL BE FED INTO QUAL-11 PACKAGE TO PRODUCE WATER QUALITY OF THE WHOLE REACH.

INITIAL CONDITIONS :  
 TMP1(I,J) -> TEMPERATURE (\*C) REACH I, SEASON J.  
 BODIN(I) -> BOD CONCENTRATION (MG/L) REACH I.  
 DOIN(I) -> DO CONCENTRATION (MG/L) REACH I.  
 INCREMENTAL CONDITIONS :  
 TMP(J) -> TEMPERATURE (\*C) SEASON J.  
 FLI(I,J) -> FLOW RATE (CMS) REACH I, SEASON J.  
 BODIC(I) -> BOD CONCENTRATION (MG/L) REACH I.  
 DOIC(I) -> DO CONCENTRATION (MG/L) REACH I.  
 HEADWATER CONDITIONS :  
 TMPH(I,J) -> TEMPERATURE (\*C) HEADWATER I, SEASON J.  
 FLH(I,J) -> FLOW RATE (CMS) HEADWATER I, SEASON J.  
 BODH(I) -> BOD CONCENTRATION (MG/L) HEADWATER I.  
 DOH(I) -> DO CONCENTRATION (MG/L) HEADWATER I.  
 POINT SOURCE CONDITIONS :  
 TMPP(I,J) -> TEMPERATURE (\*C) POINT SOURCE I, SEASON J.  
 DTP(J) -> DRY BULB TEMPERATURE (\*C) SEASON J.  
 WTP(J) -> WET BULB TEMPERATURE (\*C) SEASON J.  
 CH -> CONVERSION FACTOR 1 MGD IS EQUAL TO 1.55 CFS.  
 CVH -> CONVERSION FACTOR 1 CFS IS EQUAL TO 0.0283 CMS.

DIMENSION IS(7),Q1(7),BOD1(7),Q2(7),BOD2(7),Q3(7),BOD3(7),Q4(7),  
 \*BOD4(7),UQ(7),UBOD(7),FPL(7),PRD(7),FO(7),FBOD(7),TMPI(5,4),  
 \*BODIN(5),TMP(4),FLI(5,4),BODIC(5),TMPH(3,4),FLH(3,4),BODH(3),  
 \*TMPP(7,4),DTP(4),WTP(4),SBOD(7),CBOD(7),DOIN(5),DOIC(5),DOH(3),  
 \*PDO(7)

CHARACTER\*1 AR,AP  
 DATA TMPI/5\*22.,5\*26.,5\*9.,5\*6./  
 DATA BODIN/20.,43.,46.,37.,27./  
 DATA DOIN/20.,43.,46.,47.,27./  
 DATA TMP/20.,24.,7.,4./  
 DATA FLI/0.16,0.08,0.03,0.02,0.02,0.09,0.05,0.019,0.12,0.12,  
 \*0.13,0.07,0.024,0.016,0.016,0.11,0.06,0.021,0.014,0.014/  
 DATA BODIC/5\*60./  
 DATA TMPH/3\*22.,3\*26.,3\*9.,3\*6./  
 DATA FLH/1.3,0.11,0.23,0.78,0.07,0.14,0.14,0.09,0.18,0.9,0.08,0.16,0.005100,  
 \*/  
 DATA BODH/3\*20./  
 DATA TMPP/23.,22.,23.,22.,23.,22.,27.,26.,27.,26.,27.,26.,26.,  
 \*10.,9.,10.,9.,10.,9.,9.,7.,6.,7.,6.,7.,6.,6./  
 DATA WTP/22.,26.,9.,6./  
 DATA DTP/26.,30.,13.,10./  
 CH=1.55

CONVERT FROM METRIC UNIT TO ENGLISH UNIT

```

DO 15 I=1,4
TMP(I)=TMP(I)*1.8+32
DTP(I)=DTP(I)*1.8+32
WTP(I)=WTP(I)*1.8+32
DO 16 J=1,3
TMPH(J,I)=TMPH(J,I)*1.8+32
FLH(J,I)=FLH(J,I)*0.03
16 CONTINUE
DO 17 J=1,5
TMPI(J,I)=TMPI(J,I)*1.8+32
FLI(J,I)=FLI(J,I)*35.3
17 CONTINUE
DO 18 J=1,7
TMPP(J,I)=TMPP(J,I)*1.8+32
18 CONTINUE
15 CONTINUE
C GET SEASON INDEX
PRINT 49
49 FORMAT(' ENTER SEASON INDEX --> 1 FOR SPRING 2 FOR SUMMER 3 FOR FALL AND 4 FOR WINTER')
READ*,J
C READ STUDENT DECISION FILES
DO 23 I=1,7
READ(I4+I,45) AR,IT,IJ,I5(I),AP,PR,PC,PRBOD,Q1(I),BOD1(I),Q2(I),
* BOD2(I),Q3(I),BOD3(I),Q4(I),BOD4(I),UQ(I),UBOD(I),FO(I),FBOD(I),
*SBOD(I),CBOD(I)
45 FORMAT(A1,3I1,A1,F6.3,6(F6.5,FE.1)/F6.3,3FE.1)
23 CONTINUE
WRITE (11,50)
50 FORMAT('TITLE01',14X,'WATER QUALITY SIMULATION GAME')
WRITE(11,51) AR,AP
51 FORMAT('TITLE02',14X,'REGION',1X,A1,3X,'PERIOD',1X,A1)
WRITE(11,52)
52 FORMAT('TITLE03',3X,'NO',9X,'CONSERVATIVE MINERAL I')
WRITE(11,53)
53 FORMAT('TITLE04',3X,'NO',9X,'CONSERVATIVE MINERAL II')
WRITE(11,54)
54 FORMAT('TITLE05',3X,'NO',9X,'CONSERVATIVE MINERAL III')
WRITE(11,55)
55 FORMAT('TITLE06',2X,'YES',9X,'TEMPERATURE')
WRITE(11,56)
56 FORMAT('TITLE07',2X,'YES',9X,'BIOCHEMICAL OXYGEN DEMAND IN MG/L')
WRITE(11,57)
57 FORMAT('TITLE08',3X,'NO',9X,'ALGAE AS CHL A IN UG/L')
WRITE(11,58)
58 FORMAT('TITLE09',3X,'NO',9X,'PHOSPHORUS AS P IN MG/L')
WRITE(11,59)
59 FORMAT('TITLE10',3X,'NO',9X,'AMMONIA AS N IN MG/L')
WRITE(11,60)
60 FORMAT('TITLE11',3X,'NO',9X,'NITRITE AS N IN MG/L')
WRITE(11,61)
61 FORMAT('TITLE12',3X,'NO',9X,'NITRATE AS N IN MG/L')
WRITE(11,62)
62 FORMAT('TITLE13',2X,'YES',9X,'DISSOLVED OXYGEN IN MG/L')
WRITE(11,63)
63 FORMAT('TITLE14',3X,'NO',9X,'COLIFORMS IN NO/100 ML')
WRITE(11,64)
64 FORMAT('TITLE15',3X,'NO',9X,'ARBITRARY NON-CONSERVATIVE')
WRITE(11,65)
65 FORMAT('ENDTITLE')
WRITE(11,66)
66 FORMAT('LIST DATA INPUT')
WRITE(11,67)
67 FORMAT('WRITE OPTIONAL SUMMARY')
WRITE(11,68)

```

```

68 FORMAT('NO FLOW AUGMENTATION')          00012900
WRITE(11,69)                                00013000
69 FORMAT('STEADY STATE')                    00013100
WRITE(11,70)                                00013200
70 FORMAT('NO TRAPEZOIDAL X-SECTION')        00013300
WRITE(11,71)                                00013400
71 FORMAT('INPUT METRIC (YES=1)',4X,'=',9X,'0',10X,'OUTPUT METRIC (YES=1)',4X,'=',9X,'0')
*5=1',3X,'=',9X,'0')                      00013500
WRITE(11,72)                                00013600
72 FORMAT('NUMBER OF REACHES',7X,'=',9X,'5',10X,'NUMBER OF JUNCTIONS',7X,'=',9X,'2')
*5X,'=',9X,'2')                          00013700
WRITE(11,73)                                00013800
73 FORMAT('NUM OF HEADWATERS',7X,'=',9X,'3',10X,'NUMBER OF POINT LOADS',7X,'=',9X,'7')
*3X,'=',9X,'7')                          00013900
WRITE(11,74)                                00014000
74 FORMAT('TIME STEP (HOURS)',7X,'=',20X,'LNTH COMP ELEMENT (MI)',7X,'=',9X,'1')
*9X,'1')                                  00014100
WRITE(11,75)                                00014200
75 FORMAT('MAXIMUM ROUTE TIME (HRS)',8X,'30',10X,'TIME INC. FOR RPT',8X,'30',10X,'TIME INC. FOR RPT')
*(HRS)=')                                00014300
WRITE(11,120)                               00014400
20 FORMAT('LATITUDE OF BASIN (DEG) =',6X,'42.5',10X,'LONGITUDE OF BASIN (DEG) =',6X,'83.3')
*IN (DEG) =',6X,'83.3')                  00014500
WRITE(11,121)                               00014600
21 FORMAT('STANDARD MERIDIAN (DEG) =',6X,'75.0',10X,'DAY OF YEAR STAR',8X,'30',10X,'DAY OF YEAR STAR')
*T TIME =',5X,'180.0')                   00014700
WRITE(11,122)                               00014800
22 FORMAT('EVAP. COEF. (AE)',8X,'=',2X,'.0000062',10X,'EVAP. COEF. (BO)',8X,'=',2X,'.0000055')
*E',8X,'=',2X,'.0000055')               00014900
WRITE(11,123)                               00015000
23 FORMAT('ELEV. OF BASIN (METERS)',1X,'=',6X,'250.',10X,'DUST ATTENUATION COEF.',2X,'=',6X,'0.13')
*ATON COEF.',2X,'=',6X,'0.13')          00015100
WRITE(11,124)                               00015200
76 FORMAT('ENDATA1')                        00015300
WRITE(11,125)                               00015400
77 FORMAT('ENDATA1A')                      00015500
WRITE(11,126)                               00015600
78 FORMAT('STREAM REACH',5X,'1.0RCH=',19X,'FROM',9X,'46.0',4X,'TO',10X,'1000016600')
*X,'30.')                                00015700
WRITE(11,127)                               00015800
79 FORMAT('STREAM REACH',5X,'2.0RCH=',19X,'FROM',9X,'14.0',4X,'TO',10X,'1000016900')
*X,'10.')                                00015900
WRITE(11,128)                               00016000
80 FORMAT('STREAM REACH',5X,'3.0RCH=',19X,'FROM',10X,'3.0',4X,'TO',10X,'1100017200')
*X,'0.')                                  00016100
WRITE(11,129)                               00016200
81 FORMAT('STREAM REACH',5X,'4.0RCH=',19X,'FROM',9X,'10.0',4X,'TO',10X,'1100017500')
*X,'0.')                                  00016300
WRITE(11,130)                               00016400
82 FORMAT('STREAM REACH',5X,'5.0RCH=',19X,'FROM',9X,'30.0',4X,'TO',10X,'1000017800')
*X,'18.')                                00016500
WRITE(11,131)                               00016600
83 FORMAT('ENDATA2')                        00016700
WRITE(11,132)                               00016800
84 FORMAT('ENDATA3')                        00016900
WRITE(11,133)                               00017000
85 FORMAT('FLAG FIELD RCH=',2X,'1.0',6X,'16.0',10X,'1.2.2.6.2.2.2.6.2.00018500')
*2.2.2.2.6.2.3.')                      00017100
WRITE(11,134)                               00017200
86 FORMAT('FLAG FIELD RCH=',2X,'2.0',7X,'4.0',10X,'1.6.2.3.')
*2.3.')                                  00017300
WRITE(11,135)                               00017400
87 FORMAT('FLAG FIELD RCH=',2X,'3.0',7X,'3.0',10X,'1.6.2.')
*2.2.')                                  00017500
WRITE(11,136)                               00017600
88 FORMAT('FLAG FIELD RCH=',2X,'4.0',6X,'10.0',10X,'4.2.2.2.2.6.2.2.00019200')
*2.')                                    00017700
WRITE(11,137)                               00017800
89 FORMAT('FLAG FIELD RCH=',2X,'5.0',6X,'12.0',10X,'4.2.2.2.2.6.2.2.00019500')
*2.2.5.')                                00017900
WRITE(11,138)                               00018000
90 FORMAT('ENDATA4')                        00018100
WRITE(11,139)                               00018200
91 FORMAT('HYDRAULICS RCH=',2X,'1.0',15X,'.2500',5X,'0.300',5X,'0.44',10X,'.00020000')
*'.6X,'0.55',5X,'0.040')               00020100
WRITE(11,140)                               00020200
92 FORMAT('HYDRAULICS RCH=',2X,'2.0',15X,'.3800',5X,'0.370',5X,'0.510',10X,'.00020300')
*'.6X,'0.61',5X,'0.040')               00020400
WRITE(11,141)                               00020500
93 FORMAT('HYDRAULICS RCH=',2X,'3.0',15X,'.2800',5X,'0.350',5X,'0.480',10X,'.00020600')
*'.6X,'0.58',5X,'0.040')               00020700
WRITE(11,142)                               00020800
94 FORMAT('HYDRAULICS RCH=',2X,'4.0',15X,'.3800',5X,'0.370',5X,'0.510',10X,'.00020900')
*'.6X,'0.61',5X,'0.040')               00021000
WRITE(11,143)                               00021100
95 FORMAT('HYDRAULICS RCH=',2X,'5.0',15X,'.2200',5X,'0.330',5X,'0.430',10X,'.00021200')
*'.6X,'0.38',5X,'0.040')               00021300
WRITE(11,144)                               00021400
96 FORMAT('ENDATA5')                        00021500
WRITE(11,145)                               00021600
97 FORMAT('REACT COEF RCH=',2X,'1.0',6X,'0.60',7X,'0.0',7X,'2.0')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00021700
WRITE(11,146)                               00021800
98 FORMAT('REACT COEF RCH=',2X,'2.0',6X,'0.60',7X,'0.0',7X,'2.0')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00021900
WRITE(11,147)                               00022000
99 FORMAT('REACT COEF RCH=',2X,'3.0',6X,'0.60',7X,'0.0',7X,'2.0')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00022100
WRITE(11,148)                               00022200
100 FORMAT('REACT COEF RCH=',2X,'4.0',6X,'0.60',7X,'0.0',7X,'2.0')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00022300
WRITE(11,149)                               00022400
101 FORMAT('REACT COEF RCH=',2X,'5.0',6X,'0.60',7X,'0.0',7X,'2.0')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00022500
WRITE(11,150)                               00022600
102 FORMAT('ENDATA6')                      00022700
WRITE(11,151)                               00022800
103 FORMAT('ENDATA6A')                     00022900
WRITE(11,152)                               00023000
104 FORMAT('ENDATA6B')                     00023100
INITIAL CONDITIONS                         00023200
DO 21 I=1,5                                00023300
21 CONTINUE                                00023400
105 FORMAT('INITIAL CONDITIONS',3X,'RCH=',4X,I1,F10.3,F5.1,F5.1)
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00023500
WRITE(11,153)                               00023600
106 FORMAT('ENDATA7')                      00023700
WRITE(11,154)                               00023800
107 FORMAT('ENDATA7A')                     00023900
INCREMENTAL INFLOW                         00024000
DO 29 I=1,5                                00024100
29 CONTINUE                                00024200
150 FORMAT('INCREMENTAL INFLOW',3X,'RCH=',4X,I1,F5.3,F5.1,F5.1,F5.1)
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00024300
WRITE(11,155)                               00024400
108 FORMAT('ENDATA8')                      00024500
WRITE(11,156)                               00024600
109 FORMAT('ENDATA8A')                     00024700
WRITE(11,157)                               00024800
110 FORMAT('STREAM JUNCTION',7X,'1.0',5X,'JNC=',23X,'20.',7X,'24.',7X,'23.',10X,'.00025000')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00025100
WRITE(11,158)                               00025200
111 FORMAT('STREAM JUNCTION',7X,'2.0',5X,'JNC=',23X,'16.',7X,'34.',7X,'23.',10X,'.00025400')
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00025500
WRITE(11,159)                               00025600
112 FORMAT('ENDATA9')                      00025700
DO 22 I=1,3                                00025800
22 CONTINUE                                00025900
113 FORMAT('HEADWATER',10X,I1,'HDW=',16X,F10.3,F5.1,F5.1,F5.1)
*'.6X,'0.60',7X,'0.0',7X,'2.0')        00026000

```

```

22 CONTINUE                                00026100
   WRITE(11,114)                          00026200
114 FORMAT('ENDATA10')                    00026300
   WRITE(11,115)                          00026400
115 FORMAT('ENDATA10A')                   00026500
   POINT SOURCE LOADING                    00026600
   DO 24 I=1,5                             00026700
   GO TO (131,132,132,131,132,133,134,133),IS(I) 00026800
131 PFL(I)=Q1(I)                          00026900
   PBOD(I)=BOD1(I)                        00027000
   GO TO 24                                00027100
132 PFL(I)=0.                              00027200
   PBOD(I)=0.                             00027300
   GO TO 24                                00027400
133 PFL(I)=Q4(I)                          00027500
   PBOD(I)=BOD4(I)                        00027600
   GO TO 24                                00027700
134 PFL(I)=Q1(I)+Q4(I)                    00027800
   PBOD(I)=(Q1(I)*BOD1(I)+Q4(I)*BOD4(I))/(Q1(I)+Q4(I)) 00027900
24 CONTINUE                                00028000
   CALCULATE FLOW RATES AND BOD CONCENTRATION FOR MUNICIPAL TREATMENT PLANTS 00028100
   DO 25 I=1,3                             00028200
   PFL(6)=Q2(I)+Q3(I)+PFL(6)              00028300
125 CONTINUE                               00028400
   DO 26 I=4,5                             00028500
   PFL(7)=Q2(I)+Q3(I)+PFL(7)              00028600
26 CONTINUE                               00028700
   DO 27 I=6,7                             00028800
   PFL(I)=PFL(I)+UQ(I)                    00028900
   PBOD(I)=CBOD(I)                        00029000
127 CONTINUE                               00029100
   DO 28 I=1,7                             00029200
   PFL(I)=PFL(I)*CH                       00029300
28 CONTINUE                               00029400
   CONVERT TEAM SEQUENCE TO POINT LOAD SEQUENCE 00029500
   P=PFL(3)                                00029600
   PFL(3)=PFL(6)                          00029700
   PFL(6)=PFL(7)                          00029800
   PFL(7)=P                                00029900
   P=PBOD(3)                              00030000
   PBOD(3)=PBOD(6)                        00030100
   PBOD(6)=PBOD(7)                        00030200
   PBOD(7)=P                              00030300
   T=TMPP(3,J)                            00030400
   TMPP(3,J)=TMPP(6,J)                    00030500
   TMPP(6,J)=TMPP(7,J)                    00030600
   TMPP(7,J)=T                            00030700
   CONVERT LCFS TO 1 CMS                    00030800
   DO 201 I=1,7                            00030900
   PFL(I)=PFL(I)*0.0283                    00031000
201 CONTINUE                               00031100
   DO 30 I=1,7                             00031200
   WRITE(11,116) I,PFL(I),TMPP(I,J),PDO(I),PBOD(I) 00031300
116 FORMAT('POINT LOAD',4X,I1,'PTL=',18X,'0.0',F10.3,F5.1,F5.1,F5.1) 00031400
30 CONTINUE                               00031500
   WRITE(11,117)                          00031600
117 FORMAT('ENDATA11')                    00031700
   WRITE(11,118)                          00031800
118 FORMAT('ENDATA11A')                   00031900
   WRITE(11,119) DTP(J),WTP(J)            00032000
119 FORMAT('LOCAL CLIMATOLOGY',28X,'0.2',3X,F5.1,3X,F5.1,2X,'1000.0',500032500
   *X,'3.0')                               00032100

```

APPENDIX H

ALPHABETICAL LIST OF VARIABLES AND THEIR  
DEFINITIONS IN WATER QUALITY  
SIMULATION GAME

AR	Region index
ALM (I)	Labor and Material cost, Firm I
ABOD (I)	BOD Effluent concentration to the treatment plant, Team I
BOD1 (I)	BOD effluent concentration treated from the industrial treatment plant to the river, Firm I
BOD2 (I)	BOD effluent concentration treated from the industrial treatment plant to the municipal treatment plant, Firm I
BOD3 (I)	BOD concentration sent without treatment from the industrial firm to the municipal treatment plant, Firm I
BOD4 (I)	BOD concentration discharged without treatment from the industrial firm to the river, Firm I
BQ (I)	Wastewater flow rate to the treatment plant, Team I
C1 (I)	Quarterly investment and fixed operation costs, Firm I
CBOD (I)	Municipal plant wastewater BOD effluent concentration, Team I
DBOD (I)	Current design BOD effluent concentration, Team I
DQ (I)	Current design capacity, Team I
FBOD (I)	Future design BOD effluent concentration, Team I
FQ (I)	Future design capacity, Team I
I	Dummy team number index
IJ	Industrial firm or municipal treatment plant index
IP	Period number index
IS	Alternative index
NRG	Seed of the uniformly distributed pseudo-random numbers
OE (I)	Other expenses of the industrial firm, Firm I
PBOD (I)	Wastewater BOD concentration produced, Firm I
PC (I)	Discharge without permit -> penalty costs, Firm I
POE (I)	Price of other expenses per unit products, Firm I
PLA (I)	Price of labor and material costs per unit product, Firm I

PQ (I)	Wastewater flow rate produced, Firm I
Q1 (I)	Wastewater flow rate pretreated from the industrial treatment plant to the river, Firm I
Q2 (I)	Wastewater flow rate pretreated from the industrial treatment plant to the municipal treatment plant, Firm I
Q3 (I)	Wastewater flow rate sent without treatment from the industrial firm to the municipal treatment plant, Firm I
Q4 (I)	Wastewater flow rate discharged from the industrial firm to the river, Firm I
RANF	Uniform distributed pseudo-random number function
RAT (I)	Design BOD removal rate, Team I
SR (I)	Total sales revenue, Firm I
TC (I)	Total expenses, Firm I
TCI (I)	Tax on current income, Firm I
TNE (I)	Total net earning, Firm I
TPP (I)	Total price of permits
TTI (I)	Total taxable income, Firm I
UBOD (I)	Residential wastewater BOD concentration, Team I
UC (I)	Industrial wastewater user charges, Team I
UQ (I)	Residential wastewater flow rate, Team I
VC (I)	Operation costs, Team I
WC (I)	Total water quality related costs, Team I.

APPENDIX I

TRANSACTION RECORDS OF PERMITS



## Period 5

The market model is based on multiple-price auction, negotiation between bidders and rationale bidder behavior.

Team	# of Permits Bought	Buying Price	# of Permits Sold	Selling Price
1	<-1577	<-18.19	<-224	18.19->
2	<-14.2	<-38.67	<-76	38.67->
3	<-123	<-17.8	<-10	17.8->
4	<-26.66	<-43.88	<-6.66	43.88->
5	<-333.6	<-95.8	<-333.6	95.8->
6	---	---	<-625.5	5.0->
7	---	---	---	---

Based on the above information, the administration decides the following trading transaction.

Team 1 will buy 10.0 permits at \$18 from Team 3  
 Team 1 will buy 250.7 permits at \$18 from Team 6  
 Team 2 will buy 14.2 permits at \$19 from Team 6  
 Team 3 will sell 10.0 permits at \$18 to Team 1  
 Team 4 will buy 26.7 permits at \$39 from Team 6  
 Team 5 will buy 333.6 permits at \$44 from Team 6  
 Team 6 will sell 250.7 permits at \$18 to Team 1  
 Team 6 will sell 14.2 permits at \$19 to Team 2  
 Team 6 will sell 26.7 permits at \$39 to Team 4  
 Team 6 will sell 333.6 permits at \$44 to Team 5

## Period 6

Team	# of Permits Bought	Buying Price	# of Permits Sold	Selling Price
1	<-1678	<-17.73	<-213.7	17.73->
2	<-14.2	<-38.67	<-76	38.67->
3	<-157	<-17.8	<-10	17.8->
4	<-33	<-43.88	<-6.66	43.88->
5	<-333.6	<-85.8	<-333.6	85.8->
6	---	---	<-592.	5.0->
7	---	---	---	---

Based on the above information, the administration decides the following trading transactions.

- Team 1 will buy 64.2 permits at \$17.78 from Team 6
- Team 2 will buy 14.2 permits at \$18 from Team 6
- Team 3 will buy 147.0 permits at \$17.78 from Team 6
- Team 4 will buy 33.0 permits at \$39 from Team 6
- Team 5 will buy 333.6 permits at \$44 from Team 6
- Team 6 will sell 64.2 permits at \$17.78 to Team 1
- Team 6 will sell 14.2 permits at \$18 to Team 2
- Team 6 will sell 147.0 permits at \$17.78 to Team 3
- Team 6 will sell 33.0 permits at \$39 to Team 4
- Team 6 will sell 333.6 permits at \$44 to Team 5

## Period 7

Team	# of Permits Bought	Buying Price	# of Permits Sold	Selling Price
1	<-1839	<-17.73	<-197.7	17.73->
2	<-14.2	<-38.67	<-76	38.67->
3	<-180	<-17.8	<-10	17.8->
4	<-34.2	<-43.88	<-6.66	43.88->
5	<-333.6	<-85.8	<-333.6	85.8->
6	---	---	<-572.	5.0->
7	<-8.34	<-470.2	---	---

Based on the above information, the administration decides the following trading transactions.

Team 2 will buy 14.2 permits at \$18 from Team 6

Team 3 will buy 180.0 permits at \$17.78 from Team 6

Team 4 will buy 34.2 permits at \$39 from Team 6

Team 5 will buy 333.6 permits at \$44 from Team 6

Team 7 will buy 8.34 permits at \$46 from Team 6

Team 6 will sell 14.2 permits at \$18 to Team 2

Team 6 will sell 180.0 permits at \$17.78 to Team 3

Team 6 will sell 34.2 permits at \$39 to Team 4

Team 6 will sell 333.6 permits at \$44 to Team 5

Team 6 will sell 8.34 permits at \$46 to Team 7

## Period 8

Team	# of Permits Bought	Buying Price	# of Permits Sold	Selling Price
1	<-1910	<-17.13	<-181.4	17.73->
2	<-14.2	<-38.67	<-76	38.67->
3	<-200.2	<-17.8	<-10	17.8->
4	<-40.7	<-43.88	<-6.66	43.88->
5	<-333.6	<-85.8	<-333.6	85.8->
6	---	---	<-558.	5.0->
7	<-8.34	<-470.2	---	---

Based on the above information, the administration decides the following trading transactions.

Team 2 will buy 14.2 permits at \$18 from Team 6

Team 3 will buy 161.16 permits at \$17.78 from Team 6

Team 3 will buy 39.04 permits at \$17.78 from Team 1

Team 4 will buy 40.7 permits at \$39 from Team 6

Team 5 will buy 333.6 permits at \$44 from Team 6

Team 7 will buy 8.34 permits at \$86 from Team 6

Team 6 will sell 14.2 permits at \$18 to Team 2

Team 6 will sell 161.16 permits at \$17.78 to Team 3

Team 1 will sell 39.04 permits at \$17.78 to Team 3

Team 6 will sell 40.7 permits at \$39 to Team 4

Team 6 will sell 333.6 permits at \$44 to Team 5

Team 6 will sell 8.34 permits at \$86 to Team 7

VITA<sup>2</sup>

Shin An Chiang

Candidate for the Degree of

Doctor of Philosophy

Thesis: A WATER QUALITY MANAGEMENT SIMULATION GAME

Major Field: Civil Engineering

Biographical:

Personal Data: Born in Taipei, Taiwan, June 5, 1950, the son of Chiang Yung Ching and Yu Wen Quey.

Education: Received Bachelor of Science Degree in Engineering from National Cheng Kung University in July, 1973; Received Master of Science Degree from University of Wisconsin, Madison, in December, 1980; Completed requirements for the Doctor of Philosophy Degree at Oklahoma State University in December, 1986.

Professional Experience: Research Assistant, Department of Civil Engineering, University of Wisconsin, July, 1978 to June, 1980; Research Assistant, Water Resource Research Center, Oklahoma State University, June, 1984 to December, 1986.